

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 10/Nov/2018 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 129.603        | 1301.773        | 1) Gujrat                      | -0.791         | -22.767         |
| 2) Hydro            | 3.781          | 63.013          | 2) Madhya Pradesh              | 9.161          | 122.812         |
| 3) Gas              | 6.703          | 61.963          | 3) Chattisgarh                 | 6.460          | 71.860          |
| <b>Total MSPGCL</b> | <b>140.087</b> | <b>1426.749</b> | 4) Maharashtra Net             | 113.709        | 1294.738        |
| B) 1) APML          | 62.866         | 640.342         | 5) Goa (Amona)                 | -0.550         | -4.554          |
| 2) JSWEL            | 23.804         | 258.813         | <b>Total</b>                   | <b>127.989</b> | <b>1462.089</b> |
| 3) VIPL             | 5.040          | 56.029          | a) Mumbai Schedule             | 19.251         | 223.513         |
| 4) RPL(AMT)         | 4.810          | 57.858          | b) Mumbai Drawl                | 27.442         | 281.405         |
| 5) WPCL             | 4.498          | 50.769          | c) MSEDCL Bilateral *          | 41.961         | 526.735         |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | 8.775          | 162.579         |
| 7) Other IPP        | 12.571         | 121.859         | d) Mumbai Bilateral *          | 19.251         | 214.959         |
| C) 1) TPCL Thermal  | 12.350         | 140.165         | Include PX                     | 3.235          | 58.404          |
| 2) TPCL Hydro       | 1.657          | 33.991          | Include Standby                | 0.000          | 8.554           |
| 3) TPCL Gas         | 4.313          | 43.216          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) R-INFRA Thermal  | 9.021          | 104.620         | 1) MSEDCL                      | 364.957        | 3916.360        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 54.784         | 603.401         |
| 1) Thermal          | 264.563        | 2732.228        | <b>TOTAL STATE</b>             | <b>419.741</b> | <b>4519.761</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 5.438          | 97.004          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.016         | 105.179         |                                |                |                 |
| (A3+B6+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 4.811          | 69.356          |                                |                |                 |
| 6) SOLAR            | 5.923          | 53.901          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>291.751</b> | <b>3057.668</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 1 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5598                      | 5453                  | 5439                      | 5227                      |
| MSPGCL Hydro             | 274                       | 160                   | 125                       | 113                       |
| MSPGCL Gas               | 275                       | 272                   | 277                       | 281                       |
| MSPGCL Total Generation  | 6147                      | 5885                  | 5841                      | 5621                      |
| Central Sector Receipt   | 6785                      | 6966                  | 5256                      | 4278                      |
| WIND                     | 245                       | 222                   | 205                       | 193                       |
| CPP / IPP Thermal        | 5112                      | 4789                  | 4785                      | 4382                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 857                       | 855                   | 0                         | 0                         |
| Exchange with Mumbai     | -1327                     | -1304                 | -1368                     | -1195                     |
| <b>MSEDCL DEMAND MET</b> | <b>17819</b>              | <b>17413</b>          | <b>14719</b>              | <b>13279</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 17819                     | 17413                 | 14719                     | 13279                     |
| TPCL GENERATION          | 818                       | 851                   | 833                       | 689                       |
| R-INFRA GENERATION       | 376                       | 377                   | 376                       | 377                       |
| <b>MUMBAI DEMAND</b>     | <b>2521</b>               | <b>2532</b>           | <b>2577</b>               | <b>2261</b>               |
| STATE DEMAND MET         | 20340                     | 19945                 | 17296                     | 15540                     |
| <b>STATE DEMAND</b>      | <b>20340</b>              | <b>19945</b>          | <b>17296</b>              | <b>15540</b>              |
| Frequency (Hz)           | 49.95                     | 49.93                 | 50.00                     | 49.97                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.15 Hz at 06.32 Hrs | 49.8 Hz at 17.54 Hrs | 49.96         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 10/Nov/2018

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.34         | 0.34          | 97       | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 8.10         | 76.22         | 351      | 300      |
| Unit 9             | 8.31         | 83.40         | 361      | 300      |
| Unit 10            | 8.28         | 81.17         | 360      | 297      |
| <b>Total</b>       | <b>25.02</b> | <b>241.13</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 7.94         | 87.96         | 355      | 300      |
| Unit 5             | 7.96         | 86.88         | 360      | 325      |
| <b>Total</b>       | <b>15.90</b> | <b>174.83</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 4.69         | 43.98         | 202      | 187      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 4.36         | 47.58         | 202      | 170      |
| <b>Total</b>       | <b>9.05</b>  | <b>91.56</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 8.97         | 93.53         | 435      | 350      |
| Unit 6             | 9.21         | 96.92         | 450      | 350      |
| Unit 7             | 8.78         | 94.70         | 390      | 328      |
| Unit 8             | 9.71         | 95.68         | 450      | 355      |
| Unit 9             | 9.75         | 99.21         | 455      | 360      |
| <b>Total</b>       | <b>46.42</b> | <b>480.05</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.71         | 49.31         | 228      | 190      |
| <b>Total</b>       | <b>4.71</b>  | <b>49.31</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 3.87         | 39.44         | 180      | 150      |
| Unit 3             | 3.92         | 41.42         | 179      | 158      |
| Unit 4             | 3.88         | 41.64         | 175      | 160      |
| Unit 5             | 9.28         | 66.04         | 420      | 379      |
| <b>Total</b>       | <b>20.95</b> | <b>188.54</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.72         | 37.22         | 159      | 151      |
| Unit 4             | 3.82         | 39.13         | 163      | 154      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>7.54</b>  | <b>76.35</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.70         | 61.96         | 294      | 269      |
| <b>Total</b>       | <b>6.70</b>  | <b>61.96</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.07         | 1.18          | 45       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.07</b>   | <b>1.18</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 1.14          | 18.60          | 165      | 40       |
| Stage 4         | 0.00          | 12.28          | 0        | 0        |
| Stage 3         | 0.23          | 6.43           | 80       | 0        |
| <b>Total</b>    | <b>1.38</b>   | <b>37.31</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.89          | 6.88           | 37       | 37       |
| VTRNA           | 0.42          | 4.40           | 60       | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.04          | 1.90           | 27       | 0        |
| RNGR+BHTSA      | 0.39          | 3.87           | 17       | 16       |
| BHANDARDRA      | 0.29          | 3.02           | 13       | 12       |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.24          | 2.31           | 19       | 8        |
| GHATGHAR        | 0.13          | 3.32           | 120      | 0        |
| <b>Total</b>    | <b>2.40</b>   | <b>25.71</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 4.81          | 69.36          | 0        | 0        |
| <b>Total</b>    | <b>4.81</b>   | <b>69.36</b>   |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 62.87         | 640.34         | 0        | 0        |
| JSWEL(Mus)      | 23.80         | 258.81         | 0        | 0        |
| VIPL(Mus)       | 5.04          | 56.03          | 0        | 0        |
| RPLAMT(Mus)     | 4.81          | 57.86          | 0        | 0        |
| WPCL(Mus)       | 4.50          | 50.77          | 0        | 0        |
| Other(Mus)      | 12.57         | 121.86         | 0        | 0        |
| <b>Total</b>    | <b>113.59</b> | <b>1185.67</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 5.92          | 53.90          | 0        | 0        |
| <b>Total</b>    | <b>5.92</b>   | <b>53.90</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 7.46          | 88.62          | 344      | 307      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.77          | 27.46          | 118      | 114      |
| Trombay 7B      | 1.54          | 15.76          | 67       | 37       |
| Trombay 8       | 4.89          | 51.55          | 213      | 201      |
| TATA Hydro      | 1.66          | 33.99          | 198      | 31       |
| <b>Total</b>    | <b>18.32</b>  | <b>217.37</b>  |          |          |
| <b>R-INFRA</b>  |               |                |          |          |
| DTPS U-1&2      | 9.02          | 104.62         | 377      | 375      |
| <b>Total</b>    | <b>9.02</b>   | <b>104.62</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 129.60      | 1301.77       | MSPGCL Total        | 140.09      | 1426.75       |
|                |             |         | MSPGCL Thml+Gas | 136.31      | 1363.74       | Koyna 1,2 & 4 Total | 1.14        | 30.88         |
|                |             |         | MSPGCL Hydro    | 3.78        | 63.01         | State Total         | 291.75      | 3057.67       |

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 10/Nov/2018**

**Annexure-2**

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5227        | 113  | 281  | 5621   | 193  | 4382      | 0    | 0     | 4518        | 4278        | -1195                | 13279                 | 0                    | 13279                     | 2261             | 15540           | 49.97         |
| 2                  | 5262        | 113  | 292  | 5667   | 168  | 4387      | 0    | 0     | 4415        | 4386        | -1043                | 13565                 | 0                    | 13565                     | 2113             | 15678           | 49.93         |
| 3                  | 5255        | 113  | 282  | 5650   | 190  | 4375      | 0    | 0     | 4741        | 4627        | -916                 | 13926                 | 0                    | 13926                     | 1985             | 15911           | 49.89         |
| 4                  | 5254        | 118  | 281  | 5653   | 179  | 4397      | 0    | 0     | 4953        | 4709        | -830                 | 14108                 | 0                    | 14108                     | 1898             | 16006           | 49.94         |
| 5                  | 5265        | 118  | 294  | 5677   | 200  | 4444      | 0    | 0     | 5215        | 5049        | -793                 | 14577                 | 0                    | 14577                     | 1857             | 16434           | 49.98         |
| 6                  | 5382        | 113  | 282  | 5777   | 294  | 4543      | 0    | 0     | 5443        | 5159        | -821                 | 14952                 | 0                    | 14952                     | 1888             | 16840           | 49.93         |
| 7                  | 5718        | 118  | 283  | 6119   | 294  | 5053      | 0    | 10    | 5790        | 5003        | -837                 | 15642                 | 0                    | 15642                     | 1902             | 17544           | 50.02         |
| 8                  | 5443        | 238  | 284  | 5965   | 199  | 4990      | 0    | 157   | 5342        | 5306        | -852                 | 15765                 | 0                    | 15765                     | 1920             | 17685           | 49.93         |
| 9                  | 5537        | 251  | 291  | 6079   | 193  | 5121      | 0    | 436   | 5527        | 5374        | -988                 | 16215                 | 0                    | 16215                     | 2055             | 18270           | 49.93         |
| 10                 | 5563        | 195  | 278  | 6036   | 218  | 5199      | 0    | 635   | 5724        | 5557        | -1138                | 16507                 | 0                    | 16507                     | 2245             | 18752           | 49.98         |
| 11                 | 5598        | 271  | 276  | 6145   | 257  | 5222      | 0    | 782   | 6497        | 6119        | -1226                | 17299                 | 0                    | 17299                     | 2431             | 19730           | 49.98         |
| 12                 | 5598        | 274  | 275  | 6147   | 245  | 5112      | 0    | 857   | 7342        | 6785        | -1327                | 17819                 | 0                    | 17819                     | 2521             | 20340           | 49.95         |
| 13                 | 5453        | 160  | 272  | 5885   | 222  | 4789      | 0    | 855   | 7217        | 6966        | -1304                | 17413                 | 0                    | 17413                     | 2532             | 19945           | 49.93         |
| 14                 | 5489        | 128  | 271  | 5888   | 205  | 4679      | 0    | 814   | 7010        | 6833        | -1213                | 17206                 | 0                    | 17206                     | 2486             | 19692           | 49.98         |
| 15                 | 5439        | 113  | 269  | 5821   | 191  | 4667      | 0    | 676   | 7094        | 6881        | -1311                | 16925                 | 0                    | 16925                     | 2516             | 19441           | 50.00         |
| 16                 | 5391        | 114  | 271  | 5776   | 181  | 4693      | 0    | 461   | 6772        | 6319        | -1317                | 16113                 | 0                    | 16113                     | 2525             | 18638           | 49.94         |
| 17                 | 5426        | 119  | 273  | 5818   | 167  | 4693      | 0    | 216   | 5981        | 5740        | -1256                | 15378                 | 0                    | 15378                     | 2488             | 17866           | 49.96         |
| 18                 | 5462        | 119  | 275  | 5856   | 176  | 4736      | 0    | 24    | 5331        | 5025        | -1297                | 14520                 | 0                    | 14520                     | 2467             | 16987           | 49.91         |
| 19                 | 5439        | 125  | 277  | 5841   | 205  | 4785      | 0    | 0     | 5311        | 5256        | -1368                | 14719                 | 0                    | 14719                     | 2577             | 17296           | 50.00         |
| 20                 | 5512        | 235  | 278  | 6025   | 149  | 4876      | 0    | 0     | 5384        | 4809        | -1314                | 14545                 | 0                    | 14545                     | 2580             | 17125           | 50.02         |
| 21                 | 5247        | 187  | 280  | 5714   | 112  | 4650      | 0    | 0     | 4995        | 4770        | -1314                | 13932                 | 0                    | 13932                     | 2504             | 16436           | 49.98         |
| 22                 | 5202        | 175  | 280  | 5657   | 148  | 4609      | 0    | 0     | 4760        | 4598        | -1322                | 13690                 | 0                    | 13690                     | 2425             | 16115           | 50.01         |
| 23                 | 5216        | 151  | 280  | 5647   | 184  | 4625      | 0    | 0     | 4584        | 4177        | -1249                | 13384                 | 0                    | 13384                     | 2321             | 15705           | 49.94         |
| 24                 | 5225        | 120  | 278  | 5623   | 241  | 4562      | 0    | 0     | 4638        | 4263        | -1211                | 13478                 | 0                    | 13478                     | 2286             | 15764           | 49.97         |
| MUs                | 129.60      | 3.78 | 6.70 | 140.09 | 4.81 | 113.59    | 0.00 | 5.92  | 134.58      | 127.99      | -27.44               | 364.96                | 0.00                 | 364.96                    | 54.78            | 419.74          | 49.96         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 10/Nov/2018**

**Position as on 6.30 Hrs of 11/Nov/2018**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                     | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                      |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                      |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                      |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                    |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                              |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                    |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                    |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                          |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 21/05/2018   | 18.46        |            | Continued. | Coal Swapping IEPL                   |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.  |               |
| MSPGCL                | Koradi Unit 7           | 210      | 03/08/2018   | 15.54        |            | Continued. | Poor Coal Receipt.                   |               |
| MSPGCL                | Khaparkhedda Unit 1     | 210      | 11/08/2018   | 23.57        |            | Continued. | Poor coal Receipt                    |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                    |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |            | Continued. | Withdrawn due to B0 & U-7            |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |            | Continued. | Stator Earth Fault                   |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |            | Continued. | Poor Coal Receipt                    |               |
| IPP                   | RPL(AMT) U-5            | 270      | 21/09/2018   | 00.05        |            | Continued. | Poor Coal Receipt                    |               |
| IPP                   | RPL(AMT) U-1            | 270      | 22/09/2018   | 00.00        |            | Continued. | Poor Coal Receipt                    |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/09/2018   | 0.00         |            | Continued. | Poor Coal Receipt                    |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 06/10/2018   | 0.45         |            | Continued. | Poor Coal Receipt                    |               |
| IPP                   | VIPL U-1                | 300      | 17/10/2018   | 12.30        |            | Continued. | Poor Coal Receipt                    |               |
| MSPGCL                | Parli Unit 7            | 250      | 19/10/2018   | 00.23        |            | Continued. | Poor Coal Receipt.                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/10/2018   | 05.48        | 10/11/2018 | 12.44      | Boiler Tube Leakage                  |               |
| MSPGCL                | Nasik Unit 5            | 210      | 26/10/2018   | 12.15        |            | Continued. | Coal Swapping with DIL.              |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 04/11/2018   | 18.45        |            | Continued. | Poor Coal Receipt                    |               |
| MSPGCL                | Koradi Unit 6           | 210      | 10/11/2018   | 16.52        | 10/11/2018 | 21.04      | Loss of fuel                         |               |
| MSPGCL                | Uran Unit 5             | 108      | 11/11/2018   | 00.00        | 11/11/2018 | 19.38      | Turbine bearing Vabration checking.  |               |
| RINFRA-G              | REL Unit 1              | 250      | 11/11/2018   | 11.54        |            | Continued. | Boiler Tube Leakage                  |               |
| MSPGCL                | Koradi Unit 6           | 210      | 11/11/2018   | 19.58        |            | Continued. | Unit Auxiliary Transformer Bus Trip. |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 10/Nov/2018**

**Statement-VII**

Position as on 6.30 Hrs of 11/Nov/2018

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                           | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                                               |
| Dhule Sar'Sarovar I                          | InterState                | 06/11/2018   | 17.04        | 11/11/2018 | 11.05      | HT          | Over Voltage                                                                                                                           |
| Dhule Sar'Sarovar II                         | InterState                | 11/11/2018   | 17.08        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Dhule- Bableshwar - I                        | IntraState                | 01/06/2018   | 16.42        |            | Continued. | T           | Distance Protection Y-PH (Tower Collapsed)                                                                                             |
| Dhule - Bableshwar - li                      | IntraState                | 01/06/2018   | 16.42        |            | Continued. | T           | Distance Protection Y-PH (Tower Collapsed)                                                                                             |
| Koradi 2-IEPL                                | IntraState                | 09/11/2018   | 06.00        | 10/11/2018 | 07.08      | T           | R-Y Phase to phase Distance Protection                                                                                                 |
| Khadka-Aurangabad (Waluj)                    | IntraState                | 09/11/2018   | 16.53        | 10/11/2018 | 11.12      | HT          | Over Voltage                                                                                                                           |
| karad -kolhapur-II                           | IntraState                | 10/11/2018   | 09.53        | 10/11/2018 | 13.23      | PO          | PID Testing Work.                                                                                                                      |
| karad -kolhapur-I                            | IntraState                | 10/11/2018   | 09.53        | 10/11/2018 | 13.23      | PO          | PID Testing Work.                                                                                                                      |
| Koradi-Bhusawal                              | IntraState                | 10/11/2018   | 13.38        |            | Continued. | T           | Due To Fire On Reactor At Bhusawal.                                                                                                    |
| Babhaleshwar - Bhusawal II                   | IntraState                | 10/11/2018   | 13.38        |            | Continued. | T           | Due To Fire On Reactor At Bhusawal.                                                                                                    |
| Akola - Bhusawal                             | IntraState                | 10/11/2018   | 13.38        |            | Continued. | T           | Due To Fire On Reactor At Bhusawal.                                                                                                    |
| Khadka-Aurangabad (Waluj)                    | IntraState                | 10/11/2018   | 13:38        |            | Continued. | T           | Bus Reactor caught Fire and Control Cable Burnt.                                                                                       |
| Lonikand I - Koyna stage-IV                  | IntraState                | 10/11/2018   | 23.24        | 11/11/2018 | 09.30      | HT          | Over Voltage                                                                                                                           |
| Akola II - RPL(Rattanindia) Ckt I            | IntraState                | 11/11/2018   | 14.10        | 11/11/2018 | 22.56      | T           | R-Phase Distance Protection.                                                                                                           |
| Lonikand I - Koyna stage-IV                  | IntraState                | 11/11/2018   | 22.46        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| <b>220 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                          | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                          | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Chandrapur GCR - Warora - I                  | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.                   |
| Chandrapur GCR - Wani                        | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                              | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To control line loading.                                                                                                               |
| Kalwa 52B Interconnector CB                  | IntraState                | 16/10/2018   | 08.28        |            | Continued. | HT          | Interconnector open.                                                                                                                   |
| ALEPHATA UTECH SUGAR                         | IntraState                | 10/11/2018   | 02.05        | 10/11/2018 | 02.26      | T           | Distance Protection, Z1, R PH, 14.37Km. 2.6KA.                                                                                         |
| Waluj- Padegaon li                           | IntraState                | 10/11/2018   | 13.05        | 10/11/2018 | 15.30      | PO          | Routine Maintenance Work & Diagnostic Testing Work.                                                                                    |
| Waluj-Padegaon I                             | IntraState                | 10/11/2018   | 15.40        | 10/11/2018 | 18.00      | PO          | Routine Maintenance Work & Diagnostic Testing Work.                                                                                    |
| Apta - Taloja                                | IntraState                | 11/11/2018   | 08.24        | 11/11/2018 | 10.44      | EO          | R & B Phase CT Hot Spot Attending Work.                                                                                                |
| Chakan I - Chakan II (tap to Volkswagen)     | IntraState                | 11/11/2018   | 08.33        | 11/11/2018 | 18.29      | PO          | Stringing Work.                                                                                                                        |
| Chakan (400kv)-Volskwagon                    | IntraState                | 11/11/2018   | 08.33        | 11/11/2018 | 18.30      | OO          | For Maintenance Work.                                                                                                                  |
| Kalwa-Salsette-IV                            | IntraState                | 11/11/2018   | 10.40        | 11/11/2018 | 14.00      | PO          | Tree Trimming Work.                                                                                                                    |
| <b>220 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                        |
| 220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded | IntraState                | 10/11/2018   | 15.40        | 10/11/2018 | 18.00      | PO          | Routine Maintenance Work & Diagnostic Testing Work.                                                                                    |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage