

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 10/Nov/2019 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 100.317        | 931.539         | 1) Gujrat                      | 2.073          | 30.800          |
| 2) Hydro            | 6.251          | 77.474          | 2) Madhya Pradesh              | 9.923          | 66.373          |
| 3) Gas              | 6.766          | 87.632          | 3) Chattisgarh                 | 7.250          | 72.350          |
| <b>Total MSPGCL</b> | <b>113.334</b> | <b>1096.645</b> | 4) Maharashtra                 | 109.415        | 1107.117        |
| B) 1) APMIL         | 71.848         | 722.943         | 5) Goa (Amona)                 | -0.242         | -4.444          |
| 2) JSWEL            | 18.971         | 201.110         | <b>Total</b>                   | <b>128.419</b> | <b>1272.196</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 21.758         | 256.081         |
| 4) RPL(AMT)         | 5.176          | 44.396          | b) Mumbai Drawl                | 24.799         | 287.264         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 26.136         | 232.667         |
| 6) Other IPP        | 8.091          | 82.939          | Include PX                     | 0.229          | -7.040          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 21.758         | 256.081         |
| C) 1) TPCL Thermal  | 12.779         | 132.031         | Include PX                     | 9.120          | 86.478          |
| 2) TPCL Hydro       | 0.877          | 38.173          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.727          | 41.065          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.616          | 96.544          | 1) MSEDCL                      | 329.528        | 3247.095        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 51.798         | 595.072         |
| 1) Thermal          | 226.798        | 2211.502        | <b>TOTAL STATE</b>             | <b>381.326</b> | <b>3842.167</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 7.128          | 115.647         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 10.493         | 128.697         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 2.625          | 61.311          |                                |                |                 |
| 6) SOLAR            | 5.863          | 52.819          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>252.907</b> | <b>2569.976</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 2 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4077                      | 4101                  | 4721                      | 4026                      |
| MSPGCL Hydro             | 151                       | 121                   | 753                       | 81                        |
| MSPGCL Gas               | 266                       | 274                   | 278                       | 286                       |
| MSPGCL Total Generation  | 4494                      | 4496                  | 5752                      | 4393                      |
| Central Sector Receipt   | 6059                      | 5785                  | 5382                      | 5113                      |
| WIND                     | 208                       | 143                   | 125                       | 36                        |
| CPP / IPP Thermal        | 4078                      | 4051                  | 4629                      | 3871                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 885                       | 834                   | 0                         | 0                         |
| Exchange with Mumbai     | -1228                     | -1219                 | -1024                     | -1042                     |
| <b>MSEDCL DEMAND MET</b> | <b>14496</b>              | <b>14090</b>          | <b>14864</b>              | <b>12371</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14496                     | 14090                 | 14864                     | 12371                     |
| TPCL GENERATION          | 693                       | 696                   | 886                       | 601                       |
| AEML GENERATION          | 374                       | 373                   | 487                       | 375                       |
| <b>MUMBAI DEMAND</b>     | <b>2295</b>               | <b>2288</b>           | <b>2397</b>               | <b>2018</b>               |
| STATE DEMAND MET         | 16791                     | 16378                 | 17261                     | 14389                     |
| <b>STATE DEMAND</b>      | <b>16791</b>              | <b>16378</b>          | <b>17261</b>              | <b>14389</b>              |
| Frequency (Hz)           | 50.02                     | 49.99                 | 50.07                     | 49.97                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.19 Hz at 18.30 Hrs | 49.85 Hz at 08:49 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 10/Nov/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 9.56         | 106.07        | 462      | 300      |
| Unit 9             | 9.88         | 111.74        | 505      | 295      |
| Unit 10            | 8.42         | 87.52         | 400      | 280      |
| <b>Total</b>       | <b>27.86</b> | <b>305.34</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.06         | 91.97         | 460      | 360      |
| Unit 5             | 8.99         | 93.34         | 445      | 350      |
| <b>Total</b>       | <b>18.06</b> | <b>185.32</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.12         | 25.72         | 190      | 163      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 8.83         | 57.67         | 385      | 347      |
| Unit 6             | 9.06         | 63.67         | 440      | 360      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 9.44         | 97.38         | 500      | 360      |
| Unit 9             | 9.20         | 87.22         | 460      | 350      |
| <b>Total</b>       | <b>40.66</b> | <b>331.66</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 9.76         | 73.27         | 500      | 370      |
| <b>Total</b>       | <b>9.76</b>  | <b>73.27</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.99         | 31.05         | 190      | 160      |
| Unit 5             | 0.00         | 4.91          | 0        | 0        |
| <b>Total</b>       | <b>3.99</b>  | <b>35.96</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.77         | 87.63         | 299      | 260      |
| <b>Total</b>       | <b>6.77</b>  | <b>87.63</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.10         | 4.16          | 36       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.10</b>   | <b>4.16</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 2.57          | 26.51          | 305      | 35       |
| Stage 4         | 1.37          | 22.43          | 386      | 0        |
| Stage 3         | 0.96          | 11.24          | 160      | 0        |
| <b>Total</b>    | <b>4.90</b>   | <b>60.18</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 0.00           | 0        | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.00          | 1.54           | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.18          | 2.99           | 80       | 0        |
| RNGR+BHTSA      | 0.00          | 2.63           | 0        | 0        |
| BHANDARDRA      | 0.00          | 0.19           | 0        | 0        |
| ELDARY          | 0.54          | 3.12           | 23       | 22       |
| SMLHY_PTN       | 0.32          | 3.59           | 14       | 13       |
| GHATGHAR        | 0.31          | 3.23           | 125      | 0        |
| <b>Total</b>    | <b>1.35</b>   | <b>17.29</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 2.62          | 61.31          | 0        | 0        |
| <b>Total</b>    | <b>2.62</b>   | <b>61.31</b>   |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 71.85         | 722.94         | 0        | 0        |
| JSWEL(Mus)      | 18.97         | 201.11         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 5.18          | 44.40          | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 8.09          | 82.94          | 0        | 0        |
| <b>Total</b>    | <b>104.09</b> | <b>1051.39</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 5.86          | 52.82          | 0        | 0        |
| <b>Total</b>    | <b>5.86</b>   | <b>52.82</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.02          | 84.50          | 474      | 285      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.30          | 25.91          | 116      | 66       |
| Trombay 7B      | 1.43          | 15.16          | 66       | 50       |
| Trombay 8       | 4.75          | 47.54          | 200      | 196      |
| TATA Hydro      | 0.88          | 38.17          | 157      | 0        |
| <b>Total</b>    | <b>17.38</b>  | <b>211.27</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.62          | 96.54          | 498      | 373      |
| <b>Total</b>    | <b>9.62</b>   | <b>96.54</b>   |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 100.32      | 931.54        | MSPGCL Total        | 113.33      | 1096.64       |
|                |             |         | MSPGCL Thml+Gas | 107.08      | 1019.17       | Koyna 1,2 & 4 Total | 3.94        | 48.94         |
|                |             |         | MSPGCL Hydro    | 6.25        | 77.47         | State Total         | 252.91      | 2569.98       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 10/Nov/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4115        | 200  | 296  | 4611   | 29   | 3885      | 0    | 0     | 5264        | 5322        | -1192                | 12655                 | 0                    | 12655                     | 2171             | 14826           | 49.98         |
| 2                  | 4026        | 81   | 286  | 4393   | 36   | 3871      | 0    | 0     | 5130        | 5113        | -1042                | 12371                 | 0                    | 12371                     | 2018             | 14389           | 49.97         |
| 3                  | 3840        | 201  | 287  | 4328   | 32   | 4015      | 0    | 0     | 5008        | 5062        | -936                 | 12501                 | 0                    | 12501                     | 1910             | 14411           | 50.00         |
| 4                  | 3834        | 126  | 297  | 4257   | 42   | 4319      | 0    | 0     | 4917        | 4951        | -855                 | 12714                 | 0                    | 12714                     | 1829             | 14543           | 50.01         |
| 5                  | 3838        | 126  | 287  | 4251   | 54   | 4405      | 0    | 0     | 4895        | 5028        | -829                 | 12909                 | 0                    | 12909                     | 1803             | 14712           | 49.97         |
| 6                  | 4237        | 185  | 288  | 4710   | 98   | 4603      | 0    | 0     | 4915        | 4994        | -822                 | 13583                 | 0                    | 13583                     | 1846             | 15429           | 50.00         |
| 7                  | 4335        | 765  | 299  | 5399   | 156  | 4718      | 0    | 13    | 4914        | 4934        | -618                 | 14602                 | 0                    | 14602                     | 1876             | 16478           | 50.01         |
| 8                  | 4358        | 625  | 288  | 5271   | 206  | 4708      | 0    | 155   | 5008        | 4969        | -586                 | 14723                 | 0                    | 14723                     | 1909             | 16632           | 49.99         |
| 9                  | 4360        | 168  | 288  | 4816   | 142  | 4641      | 0    | 428   | 5270        | 5430        | -792                 | 14665                 | 0                    | 14665                     | 1998             | 16663           | 49.98         |
| 10                 | 4032        | 160  | 292  | 4484   | 210  | 4549      | 0    | 665   | 5544        | 5400        | -1089                | 14219                 | 0                    | 14219                     | 2121             | 16340           | 50.02         |
| 11                 | 4069        | 120  | 280  | 4469   | 208  | 4263      | 0    | 828   | 5798        | 5779        | -1183                | 14364                 | 0                    | 14364                     | 2228             | 16592           | 50.03         |
| 12                 | 4077        | 151  | 266  | 4494   | 208  | 4078      | 0    | 885   | 5915        | 6059        | -1228                | 14496                 | 0                    | 14496                     | 2295             | 16791           | 50.02         |
| 13                 | 4101        | 121  | 274  | 4496   | 143  | 4051      | 0    | 834   | 5927        | 5785        | -1219                | 14090                 | 0                    | 14090                     | 2288             | 16378           | 49.99         |
| 14                 | 4113        | 71   | 272  | 4456   | 141  | 3932      | 0    | 776   | 5596        | 5713        | -1188                | 13830                 | 0                    | 13830                     | 2256             | 16086           | 50.00         |
| 15                 | 4129        | 321  | 260  | 4710   | 113  | 3968      | 0    | 625   | 5615        | 5833        | -1178                | 14071                 | 0                    | 14071                     | 2250             | 16321           | 50.02         |
| 16                 | 4139        | 265  | 271  | 4675   | 94   | 4156      | 0    | 433   | 5596        | 5765        | -1150                | 13973                 | 0                    | 13973                     | 2244             | 16217           | 50.01         |
| 17                 | 4141        | 280  | 263  | 4684   | 85   | 4451      | 0    | 191   | 5342        | 5353        | -1112                | 13652                 | 0                    | 13652                     | 2225             | 15877           | 49.99         |
| 18                 | 4411        | 150  | 277  | 4838   | 64   | 4642      | 0    | 30    | 5094        | 5144        | -1017                | 13701                 | 0                    | 13701                     | 2224             | 15925           | 50.03         |
| 19                 | 4721        | 753  | 278  | 5752   | 125  | 4629      | 0    | 0     | 5220        | 5382        | -1024                | 14864                 | 0                    | 14864                     | 2397             | 17261           | 50.07         |
| 20                 | 4658        | 674  | 280  | 5612   | 111  | 4720      | 0    | 0     | 5205        | 5074        | -989                 | 14528                 | 0                    | 14528                     | 2431             | 16959           | 50.03         |
| 21                 | 4576        | 275  | 280  | 5131   | 71   | 4638      | 0    | 0     | 5116        | 5083        | -1014                | 13909                 | 0                    | 13909                     | 2404             | 16313           | 50.02         |
| 22                 | 4197        | 173  | 282  | 4652   | 53   | 4594      | 0    | 0     | 5131        | 5177        | -1154                | 13322                 | 0                    | 13322                     | 2381             | 15703           | 50.03         |
| 23                 | 4021        | 151  | 281  | 4453   | 66   | 4300      | 0    | 0     | 5349        | 5568        | -1293                | 13094                 | 0                    | 13094                     | 2360             | 15454           | 50.01         |
| 24                 | 3989        | 109  | 294  | 4392   | 138  | 3950      | 0    | 0     | 5303        | 5501        | -1289                | 12692                 | 0                    | 12692                     | 2334             | 15026           | 50.04         |
| MUs                | 100.32      | 6.25 | 6.77 | 113.33 | 2.62 | 104.09    | 0.00 | 5.86  | 127.07      | 128.42      | -24.80               | 329.53                | 0.00                 | 329.53                    | 51.80            | 381.33          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 10/Nov/2019**

**Position as on 6.30 Hrs of 11/Nov/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                             |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |           | Continued. | Annual Overhaul                                                                             |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 27/07/2019   | 00.00        |           | Continued. | Annual Overhaul                                                                             |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 25/09/2019   | 04.20        |           | Continued. | Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.                     |               |
| MSPGCL                | Koyna Unit 7            | 80       | 31/10/2019   | 16.30        |           | Continued. | Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)    |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                             |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                     |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                           |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                           |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                      |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |           | Continued. | No Schedule.                                                                                |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                 |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                               |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                               |               |
| MSPGCL                | Paras Unit 4            | 250      | 25/08/2019   | 00.45        |           | Continued. | Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00                               |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs) |               |
| IPP                   | RPL(AMT) U-1            | 270      | 01/09/2019   | 09.11        |           | Continued. | Generator Protection operated                                                               |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL                | Nasik Unit 3            | 210      | 09/10/2019   | 23.57        |           | Continued. | Under Case 4 Bidding.                                                                       |               |
| MSPGCL                | Khaparkhedha Unit 1     | 210      | 12/10/2019   | 00.11        |           | Continued. | Zero Schedule                                                                               |               |
| MSPGCL                | Khaparkhedha Unit 2     | 210      | 12/10/2019   | 00.17        |           | Continued. | Zero Schedule                                                                               |               |
| MSPGCL                | Khaparkhedha Unit 3     | 210      | 13/10/2019   | 19.57        |           | Continued. | Zero Schedule                                                                               |               |
| MSPGCL                | Parli Unit 8            | 250      | 16/10/2019   | 01.36        |           | Continued. | Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)                          |               |
| MSPGCL                | Khaparkhedha Unit 4     | 210      | 22/10/2019   | 23.52        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL                | Paras Unit 3            | 250      | 23/10/2019   | 00.00        |           | Continued. | Zero Schedule                                                                               |               |
| MSPGCL                | Parli Unit 6            | 250      | 23/10/2019   | 03.30        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL                | Parli Unit 7            | 250      | 23/10/2019   | 17.00        |           | Continued. | Zero Schedule.                                                                              |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/10/2019   | 02.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 10/Nov/2019**

**Position as on 6.30 Hrs of 11/Nov/2019**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                            | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------|---------------|
| IPP                | RPL(AMT) U-2            | 270      | 25/10/2019   | 22.00        |            | Continued. | Zero Schedule By MSEDCL.                                                    |               |
| MSPGCL             | Chandrapur Unit 4       | 210      | 31/10/2019   | 08.16        |            | Continued. | Excessive Consumption of Hydrogen Cylinder.                                 |               |
| MSPGCL             | Nasik Unit 5            | 210      | 02/11/2019   | 10.35        |            | Continued. | Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019) |               |
| MSPGCL             | Uran Unit 7             | 108      | 05/11/2019   | 00.17        |            | Continued. | Internal Inspection                                                         |               |
| MSPGCL             | Uran Unit B0            | 120      | 06/11/2019   | 03.05        |            | Continued. | Bearing vibration high                                                      |               |
| MSPGCL             | Uran Unit 8             | 108      | 06/11/2019   | 19.23        |            | Continued. | Turbine Vibration                                                           |               |
| IPP                | RPL(AMT) U-5            | 270      | 09/11/2019   | 03.00        |            | Continued. | Zero Schedule By MSEDCL.                                                    |               |
| IPP                | JSW (J) U3              | 300      | 10/11/2019   | 18.16        |            | Continued. | Zero schedule.                                                              |               |
| MSPGCL             | Uran Unit 5             | 108      | 11/11/2019   | 02.03        | 11/11/2019 | 20.38      | Damper discrepancy                                                          |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 10/Nov/2019**

**Statement-VII**

Position as on 6.30 Hrs of 11/Nov/2019

| Name of Line                                   | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                         |
|------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                          |
| Karad Solapur (PG)                             | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403 |
| Dhule Sar'Sarovar II                           | InterState                | 07/11/2019   | 19.22        | 11/11/2019 | 08.30      | HT          | Over Voltage                                             |
| Koradi Bhilai                                  | InterState                | 11/11/2019   | 09.45        |            | Continued. | PO          | Line Maintenance work                                    |
| Chandrapur II - Dhariwal -I                    | InterState                | 11/11/2019   | 10.29        | 11/11/2019 | 23.15      | PO          | Annual Maintenance Work                                  |
| Dhule Sar'Sarovar I                            | InterState                | 11/11/2019   | 12.18        |            | Continued. | HT          | Over Voltage                                             |
| Akola II - RPL(Rattaniindia) Ckt I             | IntraState                | 27/10/2019   | 14.07        |            | Continued. | HT          | Over Voltage                                             |
| Karad-Jaigad - I                               | IntraState                | 06/11/2019   | 21.58        | 11/11/2019 | 08.55      | HT          | Over Voltage                                             |
| Bhusawal-Aurangabad                            | IntraState                | 08/11/2019   | 19.58        | 11/11/2019 | 08.39      | HT          | Over Voltage                                             |
| Lonikand I - Koyna stage-IV                    | IntraState                | 11/11/2019   | 00.04        | 11/11/2019 | 08.54      | HT          | Over Voltage                                             |
| Bhusawal-Aurangabad                            | IntraState                | 11/11/2019   | 17.17        |            | Continued. | HT          | Over Voltage                                             |
| <b>400 KV ICT Outages/Trippings</b>            |                           |              |              |            |            |             |                                                          |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe            | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2     | IntraState                | 12/04/2019   | 17.10        |            | Continued. | HT          | Due To CVT Porcelain Collars Of The ICT-1 are Damaged.   |
| 400/220 Kv 600 MVA ICT-II @Kalwa               | IntraState                | 10/11/2019   | 09.11        | 10/11/2019 | 17.38      | PO          | Testing Work                                             |
| 400/220/33 Kv 500 Mva Ict 3 @Dhule             | IntraState                | 11/11/2019   | 10.12        | 11/11/2019 | 14.22      | PO          | Routine Maintenance Work                                 |
| <b>220 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                          |
| Mudshingi Chikodi                              | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.(close at Mudshingi end only)                |
| Talandage - Chikodi                            | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                  |
| Tillari Amona                                  | InterState                | 06/11/2019   | 15.12        | 10/11/2019 | 15.40      | T           | Distance Protection, R-N, 15.5KM, 2.79KA.                |
| BOISAR BORIVALI                                | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)             |
| Ranjangaon-Lonikand                            | IntraState                | 31/10/2019   | 15.29        |            | Continued. | PO          | Tower jumps opened.                                      |
| 220kv Halkarni- Tillary                        | IntraState                | 06/11/2019   | 18.06        | 10/11/2019 | 16.10      | T           | B PH PT Burst.                                           |
| Trombay - Kalwa                                | IntraState                | 08/11/2019   | 21.01        | 11/11/2019 | 07.48      | PO          | Pilling Work At LOC.NO.19                                |
| Trombay - Mulund                               | IntraState                | 09/11/2019   | 22.59        | 10/11/2019 | 18.28      | T           | Distance Protection                                      |
| MAHAPE - RELIANCE GIS                          | IntraState                | 10/11/2019   | 09.30        | 10/11/2019 | 14.02      | PO          | Safety permit for dismantling of Idle 220KV Tower        |
| Balapur-Akola I                                | IntraState                | 10/11/2019   | 10.40        | 10/11/2019 | 17.44      | PO          | Replacement of LA                                        |
| Adlabs - Pedambe                               | IntraState                | 10/11/2019   | 15.01        | 10/11/2019 | 16.00      | T           | Distance Protection                                      |
| Tambati - Adlabs                               | IntraState                | 10/11/2019   | 15.01        | 10/11/2019 | 16.00      | T           | Distance Protection                                      |
| Phursungi-Serum                                | IntraState                | 10/11/2019   | 16.51        | 10/11/2019 | 18.08      | PO          | Insulator Replacement Work                               |
| Badnera-Akola I                                | IntraState                | 10/11/2019   | 19.13        | 10/11/2019 | 19.23      | EO          | To attend Hot Spot                                       |
| Khaparkheda-Kalmeshwar                         | IntraState                | 11/11/2019   | 08.50        | 11/11/2019 | 10.04      | PO          | Conversion of SSN TO DSN                                 |
| Talandage(400kv) - Five Star Midc              | IntraState                | 11/11/2019   | 09.30        | 11/11/2019 | 15.52      | PO          | Quarterly Maintainance Work                              |
| Nadgaonpeth-Amravati                           | IntraState                | 11/11/2019   | 10.04        | 11/11/2019 | 16.28      | PO          | Quarterly Maintainance Work                              |
| Karad(400kv) -Nigade                           | IntraState                | 11/11/2019   | 10.07        | 11/11/2019 | 15.21      | PO          | Overhauling of SF6 CB                                    |
| Chandrapur GCR - Wani                          | IntraState                | 11/11/2019   | 10.20        | 11/11/2019 | 14.54      | PO          | Trimming work                                            |
| Trombay - Mulund                               | IntraState                | 11/11/2019   | 20.21        |            | Continued. | PO          | Construction work                                        |
| <b>220 KV ICT Outages/Trippings</b>            |                           |              |              |            |            |             |                                                          |
| 220/33kv 100 MVA Transformer 3 @Ghodbunder R/S | IntraState                | 11/11/2019   | 13.10        | 11/11/2019 | 15.23      | HT          | Preventive Maintance                                     |
| 220/100 Kv 200 MVA ICT-I @Borivali             | IntraState                | 11/11/2019   | 13.25        | 11/11/2019 | 15.19      | PO          | Attending Hot Spot                                       |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage