

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Nov/2020 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	129.068	1305.840	1) Gujrat	-0.170	13.151
2) Hydro	6.258	54.929	2) Madhya Pradesh	6.297	64.932
3) Gas	6.711	66.460	3) Chattisgarh	7.420	66.400
Total MSPGCL	142.037	1427.229	4) Maharashtra	132.314	1255.886
B) 1) APML	57.447	638.828	5) Goa (Amona)	-1.083	-11.426
2) JSWEL	17.117	173.874	Total	144.778	1388.943
3) VIPL	0.000	0.000	a) Mumbai Schedule	17.853	222.819
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	21.430	233.943
5) WPCL	7.804	73.701	c) MSEDCL Bilateral *	30.470	284.266
6) Other IPP	15.228	130.974	Include PX	1.455	4.138
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	17.853	222.819
C) 1) TPCL Thermal	14.221	150.497	Include PX	9.164	136.765
2) TPCL Hydro	2.902	31.724	Standby	0.000	0.000
3) TPCL Gas	4.391	43.674	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.814	68.894	1) MSEDCL	385.067	3784.315
D) STATE			2) Mumbai Discoms	52.758	528.731
1) Thermal	250.699	2542.608	TOTAL STATE	437.825	4313.046
(A1+C1+C4+(B1-B6))					
2) Hydro	9.160	86.653			
(A2+C2)					
3) Gas	11.102	110.134			
(A3+B7+C3)					
4) Wind	15.166	117.254			
6) SOLAR	6.920	67.455			
TOTAL STATE	293.047	2924.104			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5728	5422	5637	4509
MSPGCL Hydro	101	106	991	62
MSPGCL Gas	267	267	280	283
MSPGCL Total Generation	6096	5795	6908	4854
Central Sector Receipt	6800	7216	6106	4887
WIND	1011	679	355	827
CPP / IPP Thermal	4324	3961	4028	3950
CPP / IPP Gas	0	0	0	0
SOLAR	1057	1023	0	0
Exchange with Mumbai	-1083	-1072	-813	-1004
MSEDCL DEMAND MET	18205	17602	16584	13514
Load Shedding	0	0	0	0
MSEDCL DEMAND	18205	17602	16584	13514
TPCL GENERATION	1006	994	1227	598
AEML GENERATION	499	498	500	282
MUMBAI DEMAND	2588	2564	2540	1884
STATE DEMAND MET	20793	20166	19124	15398
STATE DEMAND	20793	20166	19124	15398
Frequency (Hz)	50.02	49.98	50.01	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 18.01 Hrs	49.82 Hz at 17.39 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 10/Nov/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.56	112.32	556	370
Unit 9	11.29	75.30	520	370
Unit 10	0.00	71.95	0	0
Total	22.85	259.57		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.98	94.39	500	280
Unit 5	9.61	74.12	490	280
Total	19.58	168.51		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	8.84	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.41	44.36	250	190
Total	5.41	53.20		
Chandrapur				
Unit 3	3.88	38.30	175	120
Unit 4	3.74	36.22	165	135
Unit 5	8.86	90.18	420	275
Unit 6	9.30	92.56	420	280
Unit 7	0.00	0.00	0	0
Unit 8	11.76	74.95	495	480
Unit 9	11.67	112.36	495	478
Total	49.21	444.57		
Paras				
Unit 3	5.39	55.53	240	181
Unit 4	4.62	53.56	249	119
Total	10.01	109.09		
Khaparkheda				
Unit 1	3.65	36.24	165	120
Unit 2	3.92	39.20	175	140
Unit 3	4.03	39.81	185	135
Unit 4	4.13	40.44	190	140
Unit 5	0.00	76.16	0	0
Total	15.73	231.86		
Nasik				
Unit 3	3.10	5.36	143	120
Unit 4	3.17	33.69	150	125
Unit 5	0.00	0.00	0	0
Total	6.27	39.04		
Uran				
All Units	6.71	66.46	294	256
Total	6.71	66.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.37	1.86	58	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.37	1.86		
Koyna				
Stage 1-2	2.88	27.06	370	40
Stage 4	1.34	6.18	377	0
Stage 3	0.72	7.91	160	0
Total	4.94	41.14		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.11	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.20	1.99	40	0
RNGR+BHTSA	0.35	3.54	15	14
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.93	0	0
SMLHY_PTN	0.03	0.28	2	1
GHATGHAR	0.74	6.94	125	0
Total	1.32	13.78		
Wind				
Total	15.17	117.25	0	0
Total	15.17	117.25		
CPP				
APML(Mus)	57.45	638.83	0	0
JSWEL(Mus)	17.12	173.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	7.80	73.70	0	0
Other(Mus)	15.23	130.97	0	0
Total	97.60	1017.38		
SOLAR				
Total	6.92	67.46	0	0
Total	6.92	67.46		
Tata				
Trombay 5	9.27	98.43	462	275
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	27.86	118	116
Trombay 7B	1.58	15.81	67	65
Trombay 8	4.95	52.07	234	136
TATA Hydro	2.90	31.72	382	2
Total	21.51	225.90		
AEML				
DTPS U-1&2	9.81	68.89	500	282
Total	9.81	68.89		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	129.07	1305.84	MSPGCL Total	142.04	1427.23
			MSPGCL Thml+Gas	135.78	1372.30	Koyna 1,2 & 4 Total	4.22	33.23
			MSPGCL Hydro	6.26	54.93	State Total	293.05	2924.10

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Nov/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4567	67	292	4926	843	3895	0	0	5424	5306	-1130	13840	0	13840	2011	15851	49.98
2	4509	62	283	4854	827	3950	0	0	5362	4887	-1004	13514	0	13514	1884	15398	50.00
3	4532	72	294	4898	806	3889	0	0	5253	4989	-891	13691	0	13691	1772	15463	50.01
4	4571	62	293	4926	861	3835	0	0	5111	5004	-809	13817	0	13817	1689	15506	50.00
5	4903	72	293	5268	890	3919	0	0	5071	5315	-784	14608	0	14608	1663	16271	50.00
6	5693	57	284	6034	864	4114	0	0	5244	5478	-829	15661	0	15661	1711	17372	50.02
7	5839	67	293	6199	846	4693	0	8	5725	5633	-648	16731	0	16731	1763	18494	49.99
8	5840	71	294	6205	742	4950	0	187	6164	6125	-505	17704	0	17704	1887	19591	50.04
9	5748	121	292	6161	639	5055	0	496	6198	6068	-710	17709	0	17709	2105	19814	50.02
10	5750	59	270	6079	754	4963	0	755	6698	6680	-992	18239	0	18239	2365	20604	50.03
11	5691	106	269	6066	933	4299	0	899	7085	7183	-1120	18260	0	18260	2531	20791	50.02
12	5728	101	267	6096	1011	4324	0	1057	7160	6800	-1083	18205	0	18205	2588	20793	50.02
13	5422	106	267	5795	679	3961	0	1023	7108	7216	-1072	17602	0	17602	2564	20166	49.98
14	5602	386	266	6254	563	3686	0	959	6656	7111	-1025	17548	0	17548	2487	20035	50.01
15	5773	508	266	6547	327	3928	0	771	6697	6778	-1040	17311	0	17311	2506	19817	50.02
16	5718	579	256	6553	294	4188	0	508	6872	7002	-953	17592	0	17592	2482	20074	50.01
17	5730	621	266	6617	259	4385	0	222	6420	6389	-734	17138	0	17138	2487	19625	49.98
18	5624	749	268	6641	289	4446	0	35	6029	5975	-721	16665	0	16665	2476	19141	49.97
19	5637	991	280	6908	355	4028	0	0	6068	6106	-813	16584	0	16584	2540	19124	50.01
20	5649	836	280	6765	340	3724	0	0	6180	6149	-780	16198	0	16198	2496	18694	50.02
21	5625	174	272	6071	408	3538	0	0	6180	5791	-884	14924	0	14924	2419	17343	50.02
22	5354	140	292	5786	459	3254	0	0	5637	5732	-958	14273	0	14273	2255	16528	50.04
23	4901	145	282	5328	533	3270	0	0	5719	5571	-950	13752	0	13752	2080	15832	49.99
24	4662	106	292	5060	644	3302	0	0	5721	5490	-995	13501	0	13501	1997	15498	50.02
MUs	129.07	6.26	6.71	142.04	15.17	97.60	0.00	6.92	145.78	144.78	-21.43	385.07	0.00	385.07	52.76	437.82	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Nov/2020

Position as on 6.30 Hrs of 11/Nov/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Parli Unit 7	250	22/10/2020	20.00		Continued.	Zero Schedule By MSEDCL	
IPP	JSW (J) U2	300	01/11/2020	04.44		Continued.	No Schedule	
MSPGCL	Parli Unit 6	250	02/11/2020	23.28		Continued.	Excess DM water consumption.	
MSPGCL	Khaparkheda Unit 5	500	08/11/2020	14.01		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 10	660	09/11/2020	01.28		Continued.	Air heater problem	
IPP	Adani U-1	660	10/11/2020	09.52	10/11/2020	20.38	APH 1B Tripping.	
IPP	Adani U-3	660	10/11/2020	18.28		Continued.	APH 3B gear box problem.	
MSPGCL	Paras Unit 4	250	11/11/2020	04.00		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 11/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT-II @ Koradi-III	IntraState	10/11/2020	09.35	10/11/2020	19.43	PO	ICT Maintenance Activities.
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	19/10/2020	23.01		Continued.	PO	Abnormal sound from main tank of smoothing reactor at Chandrapur end
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	07/11/2020	19.43	10/11/2020	09.29	HT	Over Voltage
Wardha (PG)-Warora II	InterState	10/11/2020	12.04		Continued.	PO	DCRM,CB Timing,CRM IR Values Of CB,Diagnostic Testing measurement by Rapid task Force.
Dhule Sar'Sarovar I	InterState	10/11/2020	18.08		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Akola II - RPL(Rattanindia) Ckt I	IntraState	06/11/2020	22.04	10/11/2020	08.18	HT	Over Voltage
Koradi-Bhusawal	IntraState	09/11/2020	09.23	11/11/2020	06.49	PO	Restranging Of Conductor between Tower No 06-16.
Dhule - Bableswhar - II	IntraState	09/11/2020	19.15	10/11/2020	08.08	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	09/11/2020	23.32	10/11/2020	08.35	HT	Over Voltage
Karad - Lonikand 1	IntraState	10/11/2020	14.28	10/11/2020	21.20	PO	Emergency Outage for CT ration Changing from 1000/1A To 2000/1A in Relay & metering & Its Testing,CT Tan Delta Measurement.
karad -kolhapur-II	IntraState	10/11/2020	15.48	10/11/2020	17.10	T	Tripped during CT ratio change work.
Bus Coupler @ Karad	IntraState	10/11/2020	15.48	10/11/2020	16.53	T	Tripped during CT ratio change work.
karad -kolhapur-I	IntraState	10/11/2020	15.48	10/11/2020	17.00	T	Tripped during CT ratio change work.
Dhule - Bableswhar - II	IntraState	10/11/2020	19.48	11/11/2020	07.15	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	10/11/2020	20.20		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/11.5 KV 80 MVA Stn T/F - I @ Chandrapur	InterState	05/11/2020	13.29	10/11/2020	18.30	EO	Attending Oil Leakage
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	01/11/2020	03.34	10/11/2020	23.14	T	Differential protection
400/220/33 Kv 315 MVA ICT- 2 @Nagothane	IntraState	10/11/2020	08.45	10/11/2020	21.50	HT	Testing Work
400/220KV 500MVA ICT-II@Taptitanda	IntraState	10/11/2020	12.04	10/11/2020	16.31	PO	Diagnostic Testing work.
400/220kv 315 Mva ICT III @Karad	IntraState	10/11/2020	15.48	10/11/2020	17.04	T	Tripped during CT ratio change work.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	11/11/2020	04.10		Continued.	T	Buchholz alarm.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 11/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Tillari Amona	InterState	02/11/2020	14.30		Continued.	PO	220 kv Amona Bay old CB Replacement (civil,Erection & Commissioning,testing)Work at 220 kv Tillari Switch yard.
EKLAHARE (OCR) Nasik - Navsari I	InterState	07/11/2020	13.59		Continued.	HT	Outage at navsari end.
Kharghar-Borivali ckt II	IntraState	11/08/2020	01.45		Continued.	T	Special Repair Cable work.
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Lonikand1 (400 Kv)-Theur II	IntraState	06/10/2020	08.54	10/11/2020	18.46	PO	HTLS Stringing work.
chandrapur-Tadali	IntraState	10/11/2020	09.09	10/11/2020	18.02	PO	Diagnostic Testing work.
Kanhan-Bhandara I	IntraState	10/11/2020	09.19	10/11/2020	17.54	PO	Diagnostic Testing work.
Chinchwad-Hinjewadi I	IntraState	10/11/2020	09.52	10/11/2020	20.05	T	Tripping of Kandalgaon Pophali line.
Peth- Mudshingi -I	IntraState	10/11/2020	10.00	10/11/2020	14.22	PO	Line Signature Analysis Of Line by tourus kit.
Karad - Vita Ckt- I	IntraState	10/11/2020	10.03	10/11/2020	12.58	PO	C & Tan Delta Testing of CTs Of Line Bay.
Tata Borivli MSETCL Borivli 4	IntraState	10/11/2020	10.04		Continued.	PO	Annual Diagnostic Testing Work.
Raymond - TKES	IntraState	10/11/2020	10.08	10/11/2020	16.52	PO	Commissioning of AMR Panel & Bus Isolator Maintenance Work.
Bombay Dyeing - Sahara	IntraState	10/11/2020	10.17	10/11/2020	18.50	PO	Replacment Of polymer Insulator by Long rod porcelain Loc No-116,117,117A,118,119,120,123.E arthwire replacment Work At Loc no.120-123.
AKOLA ANJANGAON (VIHIGAON) CKT-I	IntraState	10/11/2020	10.18	10/11/2020	14.20	PO	Suspension Clamp fixing Work at loc No. 07 & 10, & Loc no. 05,07,12,90 Jumper Tightening Work.
Nanded-Ghatodi	IntraState	10/11/2020	10.20	10/11/2020	13.56	PO	Diagnostic Testing work.
Boisar Versova Line	IntraState	10/11/2020	10.38	10/11/2020	14.55	PO	Bay Equipment Diagnostic Testing Work & maintenance Work.
Aurangabad - Chitegaon	IntraState	10/11/2020	11.11	10/11/2020	17.07	PO	Routine Maintenance Work & Diagnostic Testing work.
Kandalgaon - Koyna (Pophali)	IntraState	10/11/2020	11.53	10/11/2020	15.15	T	Distance Protection
Balapur-Malegaon	IntraState	10/11/2020	12.08	10/11/2020	17.00	PO	Line Maintenance work
NERUL - SEAWOOD CABLE CKT - 1	IntraState	10/11/2020	14.01	10/11/2020	16.07	PO	Resolve the Problem Of Floating Pt Voltage.
Karad - Vita Ckt- II	IntraState	10/11/2020	14.03	10/11/2020	18.13	PO	C & Tan Delta Testing Of CTs Of Line Bay.
220 KV ICT Outages/Trippings							
220/132-110/11kv 200mva Aditya Vid Ptr 3 @Miraj	IntraState	07/11/2020	09.50		Continued.	PO	OLTC overhauling work.
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	09/11/2020	23.15	10/11/2020	00.49	EO	For removal of Damage Radiator.
220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-Ii (Mudshingi)	IntraState	10/11/2020	10.00	10/11/2020	17.30	PO	IR,PI Test & Earth Resistance Measurement Work.
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	10/11/2020	10.23	10/11/2020	16.27	PO	Attending Oil Leakage Work, Diagnostic Test,Bay Maintenance Work & RMW.
220/132 Kv 200 Mva Bbl Ict 4	IntraState	10/11/2020	10.54	10/11/2020	18.40	PO	Diagnostic Testing work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 11/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
@Padegaon							
220/132 Kv 100 Mva Cgl Ict 2 @Ranjangaon	IntraState	10/11/2020	12.45	10/11/2020	17.50	PO	For RTF Work Purpose Diagnostic Testing Work.
220/132 KV ICT-2 @Nagar	IntraState	10/11/2020	14.32	10/11/2020	18.35	PO	HV & LV CT, Bushing & Winding Tan Delta Measurement & HV CB Timing Meassurement by RTF Nashik & Bableshtar Unit.
220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI	IntraState	10/11/2020	14.50	10/11/2020	19.58	PO	SFRA & Diagnostic Testing,RM Work.