

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Nov/2024 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	154.869	1423.737	1) Gujrat	6.560	20.995
2) Hydro	5.048	62.961	2) Madhya Pradesh	1.482	49.426
3) Gas	3.675	66.429	3) Chattisgarh	6.120	68.960
Total MSPGCL	163.592	1553.127	4) Maharashtra	211.058	2079.618
B) 1) APLM	59.065	524.576	5) Goa (Amona)	-2.067	-20.608
2) JSWEL	25.560	246.588	Total	223.153	2198.391
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.166	413.956
4) RPL(AMT)	21.849	239.389	b) Mumbai Drawl	42.285	481.241
5) SWPGPL	9.137	91.170	c) MSEDCL Bilateral *	97.603	926.375
6) Other IPP	8.999	77.452	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.166	413.946
C) 1) TPCL Thermal	4.158	40.236	Include PX	0.000	0.000
2) TPCL Hydro	2.776	37.854	Standby	0.000	0.010
3) TPCL Gas	2.338	38.799	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.959	75.920	1) MSEDCL	481.739	4586.842
D) STATE			2) Mumbai Discoms	59.516	674.038
1) Thermal	291.596	2719.068	3) Other Discoms	12.233	123.532
(A1+C1+C4+(B1-B6))			TOTAL STATE	553.488	5384.412
2) Hydro	7.824	100.815			
3) Gas	6.013	105.228			
4) Wind	7.554	71.121			
6) SOLAR	17.348	189.801			
TOTAL STATE	330.335	3186.033			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6321	6006	6612	6178
MSPGCL Hydro	173	252	465	40
MSPGCL Gas	139	135	140	296
MSPGCL Total Generation	6633	6393	7217	6514
Central Sector Receipt	10336	9935	9332	8715
WIND	207	131	471	628
CPP / IPP Thermal	5163	5080	5581	4374
CPP / IPP Gas	0	0	0	0
SOLAR	2449	2532	0	0
Exchange with Mumbai	-1921	-1928	-1737	-1862
MSEDCL DEMAND MET	22334	21614	20298	17861
Load Shedding	0	0	0	0
MSEDCL DEMAND	22334	21614	20298	17861
TPCL GENERATION	299	359	547	474
AEML GENERATION	290	308	392	310
MUMBAI DEMAND	2510	2595	2676	2646
OTHER DISCOM DEMAND	533	529	566	508
STATE DEMAND MET	25377	24738	23540	21015
STATE DEMAND	25377	24738	23540	21015
Frequency (Hz)	50.03	49.95	49.95	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 06.01 Hrs	49.79 Hz at 22.35 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Nov/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.20	40.38	183	157
Unit 8	13.70	58.95	608	503
Unit 9	13.33	102.32	605	485
Unit 10	10.24	128.46	605	0
Total	41.47	330.10		
Bhusawal				
Unit 3	3.22	16.76	165	120
Unit 4	9.40	85.69	490	285
Unit 5	8.85	70.40	475	285
Total	21.47	172.85		
Parli				
Unit 6	3.80	19.93	227	138
Unit 7	3.64	19.23	198	119
Unit 8	3.87	38.01	230	144
Total	11.31	77.17		
Chandrapur				
Unit 3	4.07	38.73	180	153
Unit 4	3.39	32.14	156	125
Unit 5	8.85	82.60	400	320
Unit 6	8.44	77.21	420	290
Unit 7	0.84	74.78	308	0
Unit 8	6.54	76.54	350	248
Unit 9	3.22	64.64	413	0
Total	35.34	446.63		
Paras				
Unit 3	4.94	47.48	224	163
Unit 4	4.82	44.88	245	182
Total	9.76	92.36		
Khaparkheda				
Unit 1	3.82	40.38	175	155
Unit 2	4.18	42.12	194	152
Unit 3	3.55	15.45	151	137
Unit 4	4.10	42.35	181	138
Unit 5	11.37	94.27	480	448
Total	27.02	234.57		
Nasik				
Unit 3	3.17	22.35	149	121
Unit 4	3.05	33.04	151	120
Unit 5	2.27	14.66	102	89
Total	8.49	70.05		
Uran				
All Units	3.68	66.43	296	133
Total	3.68	66.43		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.19	2.70	47	0
Total	0.19	2.70		
Koyna				
Stage 1-2	1.74	18.04	245	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	3.96	0	0
Stage 3	0.43	5.06	140	0
Total	2.17	27.07		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.25	1.50	62	0
BHIRA T.R.	0.24	2.30	40	0
SMLHY_PTN	2.39	30.71	122	0
GHATGHAR	0.00	1.38	0	0
Total	2.88	35.89		
Wind				
Total	7.55	71.12	0	0
Total	7.55	71.12		
CPP				
APML(Mus)	59.06	524.58	0	0
JSWEL(Mus)	25.56	246.59	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	21.85	239.39	0	0
SWPGPL-Mus	9.14	91.17	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.33	49.86	266	257
Other(Mus)	0.88	9.05	0	0
JPL	1.79	18.55	76	72
Total	124.61	1179.18		
SOLAR				
Total	17.35	189.80	0	0
Total	17.35	189.80		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.60	24.57	109	0
Trombay 7B	0.74	14.23	63	0
TATA Hydro	2.78	37.85	252	66
Trombay 8	4.16	40.24	202	141
Total	9.27	116.89		
AEML				
DTPS U-1&2	7.96	75.92	482	290
Total	7.96	75.92		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	154.87	1423.74	MSPGCL Total	163.59	1553.13
			MSPGCL Thml+Gas	158.54	1490.17	Koyna 1,2 & 4 Total	1.74	22.00
			MSPGCL Hydro	5.05	62.96	State Total	330.34	3186.03

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Nov/2024

Position as on 6.30 Hrs of 11/Nov/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/11/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/11/2024
MSPGCL	Chandrapur Unit 9	500	08/11/2024	00:15	10/11/2024	13:49	Suspected BTL.	10/11/2024
MSPGCL	Uran Unit 7	108	10/11/2024	00:15	10/11/2024	20:32	For fine filter replacement work.	10/11/2024
MSPGCL	Chandrapur Unit 7	500	10/11/2024	03:00		Continued.	Air heater problem	15/11/2024
MSPGCL	Koradi Unit-10	660	10/11/2024	18:29	10/11/2024	21:51	Flame Failure	
MSPGCL	Koradi Unit-10	660	11/11/2024	01:20	11/11/2024	03:51	GV Valve problem.	11/11/2024
MSPGCL	Chandrapur Unit 6	500	11/11/2024	06:27		Continued.	Boiler Tube Leakage	14/11/2024
MSPGCL	Paras Unit 3	250	11/11/2024	09:13		Continued.	FURNACE DRAFT VERY HIGH.	12/11/2024
Total Capacity MSPGCL		3423						
TPC-G								
TPC-G	Trombay 5	500	22/09/2024	16:14		Continued.	Emergency withdrwan due to fire in cable vault.	
TPC-G	Trombay 7B	60	10/11/2024	03:03	10/11/2024	14:07	Outage for reconnection of UAT (Unit Auxiliary Transformer) Work.	10/11/2024
TPC-G	Trombay 7A	120	10/11/2024	03:25	10/11/2024	10:30	Outage for reconnection of UAT (Unit Auxiliary Transformer) Work.	10/11/2024
Total Capacity TPC-G		680						
IPP								
IPP	RPL(AMT) U-3	270	23/07/2024	00:47		Continued.	Turbine Vibration High	20/11/2024
IPP	JPL Unit 1	150	20/10/2024	15:11		Continued.	Turbine bearing Vabration high	15/11/2024
Total Capacity IPP		420						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		4843						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	06/11/2024	19:19		Continued.	Due to no schedule from MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Nov/2024

Position as on 6.30 Hrs of 11/Nov/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	09/11/2024	19:05		Continued.	Due to no schedule from MSEDCL.	
Total Capacity MSPGCL		216						
IPP								
IPP	SWPGPL U-1	135	30/10/2024	00:00		Continued.	Unit Out due to Non-avaialbility of Schedule	
Total Capacity IPP		135						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		351						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 11/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (405) OF ICT-2 & FUTURE CKT - 2 @ KORADI 3	IntraState	11/11/2024	09:41			PO	Bay Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY-422 OF STATION TF - 1 @ KORADI -2	IntraState	11/11/2024	10:08			PO	Diagnostic Testing of CB
400 KV LINE Outages/Trippings							
400KV-PADGHE(PG)-NAVI MUMBAI(PG)-1	InterState	09/11/2024	21:29	10/11/2024	02:09	HT	Emergency outage for attending hotspot at Navi Mumbai PG end.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/10/2024	08:31			HT	H/T for load management.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2024	16:09			HT	For load management
DABHOL - NEW KOYNA CKT - 1	IntraState	09/11/2024	20:10	10/11/2024	11:30	T	Line tripped on distance protection.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400 KV BR Outages/Trippings							
BUS REACTOR (80 MVAR) - 1 @ BABHALESHWAR	IntraState	07/10/2024	09:40			PO	The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order
BUS REACTOR (125 MVAR) - 2 @ KOLHAPUR (TALANDGE)	IntraState	05/11/2024	08:47			PO	Main Bay AMP and CB Overhauling work
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 11/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
GHODBUNDER - GORAI	IntraState	29/07/2024	12:14			PO	Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.
220kV Koradi-2 - Uppalwadi ckt 2	IntraState	28/08/2024	00:14			T	Distance Protection
EKLAHARE (OCR) - PADGHE	IntraState	24/09/2024	07:48			HT	For load mgmt
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
KARAD - DASGAON	IntraState	14/10/2024	15:46			PO	i)Dismantling of Exst. S/C Tower Loc. No. 160 of 220 KV KaradDasgaon (Pedambe) line. ii) Foundation of In-Line M/C Narrow Base Tower (MCN+3). iii) Erection of Tower & stringing of 220 KV Karad - Dasgaon & 220 Karad Koyna line
KALWA - PRINT HOUSE LINE	IntraState	15/10/2024	16:31			HT	Hand tripped at Kalwa end for load management.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	16/10/2024	16:01			HT	Line Hand tripped for load management on 220kV Ulve - Waghivali ckt no 1.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	17/10/2024	06:26			HT	H/T for controlling load of 220kV Ulve-Waghivali ckt-1
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
KALWA - PRINT HOUSE LINE	IntraState	17/10/2024	12:23			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	05/11/2024	17:03			HT	Line hand trip for load management on 220kv Nashik Babhaleshawr ckt 1,2.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	05/11/2024	20:07			HT	Line hand trip for load management on 220kv Nashik Babhaleshawr ckt 1,2.
KALWA - BORIVALI	IntraState	07/11/2024	23:16	10/11/2024	21:08	PO	For Stringing of conductor on newly erected Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
BORIVALI - CTRLS CKT	IntraState	07/11/2024	23:19	10/11/2024	20:37	PO	For Stringing of conductor on newly erected Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
SAHARA-URSE	IntraState	09/11/2024	23:32	10/11/2024	04:47	HT	H/T For load management for outage on 220kV Talegaon Ambi-Talegaon PG ckt-1
KALWA - COLOURCHEM	IntraState	09/11/2024	23:53	10/11/2024	02:53	EO	To attend red hotspot from middle ph jumper cone at TL No. 5
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	10/11/2024	01:15	10/11/2024	04:32	PO	Diagnostic Testing
SAWANGI-BHOKARDAN CKT	IntraState	10/11/2024	05:45	10/11/2024	06:09	T	Distance protection operated
PADGHE - NALASOPARA - VASAI (T)	IntraState	10/11/2024	08:29	10/11/2024	10:00	EO	Emergency shifting of 220kV Padghe- Nalasopara -Vasai (T) line on TBC for attending hot spot on CB R ph lower pad.(Temp. 84 °C)
KALWA - PAWANE GIS	IntraState	10/11/2024	10:55	10/11/2024	14:47	HT	Handtrip for safety purpose for stringing of 220kV Kalwa- Print house line.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 11/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GIS BHANDUP - BORIVALI	IntraState	10/11/2024	11:19	10/11/2024	12:01	T	Line tripped on distance protection.
MULUND - GIS BHANDUP	IntraState	10/11/2024	11:19			T	MULUND - BHANDUP GIS Line tripped on distance protection.Simultaneously 220kv Borivali - Bhandup GIS line tripped hence 220Kv Bhandup GIS went into dark.
KALWA - COLOURCHEM	IntraState	10/11/2024	14:07	10/11/2024	15:05	T	Tripped On Dist. Protectio
TROMBAY DHARAVI - 6	IntraState	10/11/2024	15:48	10/11/2024	17:40	EO	Removing hanging object in span 18-19
MAIN BUS SECTION - 2 @ NERUL	IntraState	10/11/2024	23:54	11/11/2024	05:57	EO	1) R ph 220KV main bus conductor replacement work will be carried out. 2) LBB Relay retrofitting and Annual relay testing by PAC Kalwa, 3)To attend Hotspots on Kharghar line Wavetrap Top B-ph temp:- 100deg. , Bus Sec-2 Kharghar line side 29A Isolator-Y Phase temp:- 109deg.& B-Phase temp:-97deg.
KHARGHAR - NERUL	IntraState	11/11/2024	05:57	11/11/2024	09:14	EO	1) R ph 220KV main bus conductor replacement work will be carried out. 2) LBB Relay retrofitting and Annual relay testing by PAC Kalwa, 3)To attend Hotspots on Kharghar line Wavetrap Top B-ph temp:- 100deg. , Bus Sec-2 Kharghar line side 29A Isolator-Y Phase temp:- 109deg.& B-Phase temp:-97deg.
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	11/11/2024	09:02			PO	Replacement of damaged conductors at various locations
MUDSHINGI- BELEWADI LINE	IntraState	11/11/2024	09:15			PO	for attending hot spot
220 KV ICT Outages/Trippings							
220/22KV 50MVA PTR 3 @ BHOSARI 2	IntraState	24/07/2024	23:02			T	Tripped due to caught fire.
220/132 KV 100 MVA ICT I @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/132 KV 100 MVA ICT II @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	29/10/2024	14:20			EO	To check I.R. value for Core to frame of 200MVA 220/100kv ICT-4
100 MVA 220/132 KV ICT - II @ KARNJA	IntraState	10/11/2024	10:15	10/11/2024	13:30	PO	Testing work.
220 / 110 / 23kv 250 MVA ICT 3 @ SALSETTE	IntraState	10/11/2024	14:31	10/11/2024	15:22	EO	Bird nest removal from gantry
220/132 KV 150 MVA PTR NO 7 @ CHINCHWAD	IntraState	11/11/2024	03:05			T	Bucholz Protection
220/132-110KV 100MVA PTR 1@WATHAR	IntraState	11/11/2024	09:27			PO	For attending oil leakage from Main tank top joint & Conservator tank oil indicator by agency
220/33kv 50MVA TF-3 @ 5 STAR MIDC	IntraState	11/11/2024	09:35			PO	For diagnostic testing, LTS implementation and quarterly maintenance work
220 KV BUSBAR Outages/Trippings							
MAIN BUS-2 @ SAKI (AEML)	IntraState	11/11/2024	09:28			PO	preventive maintenance of Main Bus 2 and Bus 2 side isolators
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	26/09/2024	14:40			HT	H/T at 132KV Pench end
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 11/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV BUSBAR Outages/Trippings							
BUS ZONE - 1 @ BHOKARPADA	IntraState	10/11/2024	10:58	10/11/2024	15:32	PO	R/M
ZONE - 1 @ KALYAN	IntraState	11/11/2024	00:09	11/11/2024	03:22	PO	R/M

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage