

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Dec/2019 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	147.296	1226.504	1) Gujrat	3.987	47.631
2) Hydro	20.664	169.371	2) Madhya Pradesh	6.271	99.959
3) Gas	5.949	82.496	3) Chattisgarh	6.900	70.550
Total MSPGCL	173.909	1478.371	4) Maharashtra	116.083	1154.892
B) 1) APMIL	75.338	743.316	5) Goa (Amona)	-0.748	-6.996
2) JSWEL	23.240	235.110	Total	132.493	1366.036
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.730	278.535
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	30.347	298.686
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	28.237	301.974
6) Other IPP	13.905	137.955	Include PX	3.942	74.214
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.730	278.535
C) 1) TPCL Thermal	9.942	98.778	Include PX	6.650	101.796
2) TPCL Hydro	6.229	51.624	Standby	0.000	0.000
3) TPCL Gas	2.487	32.847	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.922	108.236	1) MSEDCL	398.521	3846.328
D) STATE			2) Mumbai Discoms	59.927	590.170
1) Thermal	280.643	2549.899	TOTAL STATE	458.448	4436.498
(A1+C1+C4+(B1-B6))					
2) Hydro	26.893	220.995			
(A2+C2)					
3) Gas	8.436	115.343			
(A3+B7+C3)					
4) Wind	4.562	134.103			
6) SOLAR	5.421	50.123			
TOTAL STATE	325.955	3070.463			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6305	6327	6506	5508
MSPGCL Hydro	1550	1539	1066	96
MSPGCL Gas	265	244	261	237
MSPGCL Total Generation	8120	8110	7833	5841
Central Sector Receipt	6693	6398	5175	4496
WIND	220	164	158	264
CPP / IPP Thermal	4888	4883	4880	4452
CPP / IPP Gas	0	0	0	0
SOLAR	843	796	0	0
Exchange with Mumbai	-1564	-1498	-1402	-1093
MSEDCL DEMAND MET	19200	18853	16644	13960
Load Shedding	0	0	0	0
MSEDCL DEMAND	19200	18853	16644	13960
TPCL GENERATION	1032	1031	1040	413
AEML GENERATION	502	501	500	374
MUMBAI DEMAND	3098	3030	2942	1880
STATE DEMAND MET	22298	21883	19586	15840
STATE DEMAND	22298	21883	19586	15840
Frequency (Hz)	49.99	49.98	49.99	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 22.01 Hrs	49.74 Hz at 06.45 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 10/Dec/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.12	120.19	480	450
Unit 9	11.24	118.54	550	370
Unit 10	11.46	46.35	560	430
Total	33.82	285.08		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.54	65.46	480	201
Unit 5	10.19	76.58	480	350
Total	19.73	142.04		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.68	56.03	250	193
Unit 7	5.58	33.38	249	194
Unit 8	5.60	40.03	248	198
Total	16.86	129.44		
Chandrapur				
Unit 3	4.34	41.76	190	163
Unit 4	3.70	33.18	175	143
Unit 5	8.79	88.21	380	350
Unit 6	10.65	105.44	485	360
Unit 7	0.00	0.00	0	0
Unit 8	10.83	104.62	500	360
Unit 9	10.40	104.50	480	360
Total	48.72	477.72		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	2.75	2.76	175	40
Unit 2	3.23	3.28	180	50
Unit 3	3.52	3.61	178	93
Unit 4	4.34	38.47	195	160
Unit 5	10.23	101.92	490	361
Total	24.07	150.04		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	4.11	42.18	189	155
Total	4.11	42.18		
Uran				
All Units	5.95	82.50	280	226
Total	5.95	82.50		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	1.18	40	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.06	1.18		
Koyna				
Stage 1-2	6.13	48.75	505	35
Stage 4	9.95	81.21	760	0
Stage 3	3.20	27.38	320	0
Total	19.28	157.34		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.38	3.02	80	0
RNGR+BHTSA	0.37	3.67	16	15
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.10	2.53	5	4
GHATGHAR	0.54	2.81	125	0
Total	1.38	12.03		
Wind				
Total	4.56	134.10	0	0
Total	4.56	134.10		
CPP				
APML(Mus)	75.34	743.32	0	0
JSWEL(Mus)	23.24	235.11	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	13.90	137.96	0	0
Total	112.48	1116.38		
SOLAR				
Total	5.42	50.12	0	0
Total	5.42	50.12		
Tata				
Trombay 5	9.94	98.68	479	305
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.38	19.76	63	52
Trombay 7B	1.11	13.09	50	42
Trombay 8	0.00	0.10	0	0
TATA Hydro	6.23	51.62	459	0
Total	18.66	183.25		
AEML				
DTPS U-1&2	10.92	108.24	502	373
Total	10.92	108.24		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	147.30	1226.50	MSPGCL Total	173.91	1478.37
			MSPGCL Thml+Gas	153.24	1309.00	Koyna 1,2 & 4 Total	16.08	129.96
			MSPGCL Hydro	20.66	169.37	State Total	325.96	3070.46

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Dec/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5378	186	235	5799	367	4457	0	0	5032	4868	-1365	14126	0	14126	2146	16272	49.96
2	5672	96	237	6005	355	4462	0	0	4866	4659	-1205	14276	0	14276	1993	16269	50.01
3	5508	96	237	5841	264	4452	0	0	4698	4496	-1093	13960	0	13960	1880	15840	49.98
4	5486	261	237	5984	174	4439	0	0	4639	4668	-1005	14260	0	14260	1803	16063	49.94
5	5897	136	237	6270	140	4424	0	0	4734	4737	-960	14611	0	14611	1775	16386	49.97
6	6105	556	236	6897	134	4459	0	0	5134	5370	-824	16036	0	16036	1900	17936	49.99
7	6178	1252	226	7656	278	4489	0	7	5417	5663	-772	17321	0	17321	2069	19390	49.95
8	6239	1619	237	8095	261	4771	0	91	5169	5841	-723	18336	0	18336	2210	20546	49.90
9	6293	1647	237	8177	320	4779	0	321	5466	5967	-966	18598	0	18598	2495	21093	49.98
10	6308	1684	278	8270	306	4803	0	551	5845	5843	-1280	18493	0	18493	2811	21304	49.98
11	6272	1560	278	8110	294	4821	0	770	6150	6461	-1486	18970	0	18970	3019	21989	50.02
12	6305	1550	265	8120	220	4888	0	843	6741	6693	-1564	19200	0	19200	3098	22298	49.99
13	6327	1539	244	8110	164	4883	0	796	6573	6398	-1498	18853	0	18853	3030	21883	49.98
14	6338	1182	238	7758	152	4844	0	737	6660	6495	-1388	18598	0	18598	2924	21522	50.01
15	6382	1263	239	7884	100	4840	0	630	6745	6662	-1429	18687	0	18687	2967	21654	49.93
16	6427	1495	228	8150	106	4874	0	453	6488	6432	-1452	18563	0	18563	2988	21551	49.95
17	6465	1281	239	7985	53	4869	0	197	6084	5818	-1424	17498	0	17498	2957	20455	49.91
18	6493	1219	239	7951	108	4877	0	25	5571	5578	-1386	17153	0	17153	2926	20079	49.99
19	6506	1066	261	7833	158	4880	0	0	5254	5175	-1402	16644	0	16644	2942	19586	49.99
20	6519	730	277	7526	122	4878	0	0	4949	4731	-1300	15957	0	15957	2836	18793	49.97
21	6612	54	279	6945	88	4762	0	0	4896	4694	-1329	15160	0	15160	2283	17443	49.98
22	6103	59	280	6442	111	4561	0	0	5164	4993	-1479	14628	0	14628	2276	16904	50.03
23	5757	54	247	6058	144	4505	0	0	5189	5184	-1533	14358	0	14358	2327	16685	49.99
24	5726	79	238	6043	143	4466	0	0	5145	5067	-1484	14235	0	14235	2272	16507	49.98
MUs	147.30	20.66	5.95	173.91	4.56	112.48	0.00	5.42	132.61	132.49	-30.35	398.52	0.00	398.52	59.93	458.45	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Dec/2019

Position as on 6.30 Hrs of 11/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
MSPGCL	Nasik Unit 4	210	20/11/2019	04.15		Continued.	ID Fan Problem(Converted for Zero Schedule from 05.00hrs DT. 21-11-2019 and Continued for Annual Overhaul From 01.12.2019	
TPC_G	Trombay 8	250	01/12/2019	00.50		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-4	250	06/12/2019	12.00		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 10/Dec/2019

Position as on 6.30 Hrs of 11/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	30/11/2019	19.14		Continued.	Over Speed Bolt Trip.	
MSPGCL	Uran Unit B0	120	07/12/2019	07:14		Continued.	Gas shortage	
MSPGCL	Uran Unit 7	108	07/12/2019	07:14		Continued.	Gas shortage	
IPP	JSW (J) U1	300	11/12/2019	23.58		Continued.	Governing Valve Rectification Work	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 10/Dec/2019

Statement-VII

Position as on 6.30 Hrs of 11/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Tripping							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	09/12/2019	19.24	11/12/2019	07.12	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	11/12/2019	19.07		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/12/2019	09.54		Continued.	PO	Construction Work
Koradi-Bhusawal	IntraState	04/12/2019	08.41		Continued.	PO	Restrining of Conductor
Warora -IEPL	IntraState	10/12/2019	08.28	10/12/2019	15.31	PO	Routine Maintenance Work & Testing Work.
New Koyna - Dabhol - II	IntraState	10/12/2019	10.10	10/12/2019	19.53	PO	Maintenance Work,Earth wire Replacement Work.
Koradi III(Adani)-Korad II Ckt-I	IntraState	10/12/2019	10.25	10/12/2019	13.46	PO	For Investigation & Racti.Of Low SF6 Gas.
New Koyna - Dabhol - II	IntraState	11/12/2019	09.14	11/12/2019	20.14	PO	Earth Wire Replacement.
Deepnagar Taptitanda	IntraState	11/12/2019	11.49	11/12/2019	16.13	PO	Replacement of Faulty String & AMC Work.
400 KV ICT Outages/Tripping							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220kv 315 Mva ICT I @Karad	IntraState	10/12/2019	10.17	10/12/2019	16.25	PO	Quarterly Maintainance Work
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	10/12/2019	10.27		Continued.	PO	For Replacment Of Y-PH UNIT By Overhauled Unit.
400/220/33kv, 500 Mva Ict-2 @Khaparkheda	IntraState	11/12/2019	09.28	11/12/2019	17.56	PO	Diagnostic Testing and Routine Maintenance Work.
400/132 Kv 200 Mva Ict 2 @Khadka	IntraState	11/12/2019	10.12	11/12/2019	14.32	PO	Online Nitrogen Filling.
400/132 KV 200MVA ICT II @Bhusawal	IntraState	11/12/2019	14.10	11/12/2019	14.35	PO	Refilling of Nitrogen Gas In CTR By Online.
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	11/12/2019	16.15	11/12/2019	23.45	PO	To Attend R Phase CT Oil Leakage.
220 KV LINE Outages/Tripping							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BADNERA - WARDHA (PG) (Deoli)	InterState	10/12/2019	08.31	10/12/2019	10.54	PO	To Control OD.
A'bad(PG)-Shendra Ckt II	InterState	11/12/2019	11.48	11/12/2019	18.10	T	Replacement of U Bolts of Suspension Clamps.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	10/12/2019	08.50	10/12/2019	18.27	PO	Repalcement of Disc.Insulator.
Peth- Mudshingi -I	IntraState	10/12/2019	09.31	10/12/2019	17.07	PO	For Destrining of old Earth Wire With New Earth Wire.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	10/12/2019	09.33	10/12/2019	17.09	PO	For Destrining of old Earth Wire With New Earth Wire.
Parli 2-(Girwali) -Murud	IntraState	10/12/2019	10.49	10/12/2019	14.19	EO	Attending Hot Spot
Vita - Ghatnandre	IntraState	10/12/2019	10.56	10/12/2019	12.41	PO	Emergency Tree Cutting.
Nanded-Ghatodi	IntraState	10/12/2019	11.04	10/12/2019	14.16	PO	CT Tan Delta & Relay Testing Work.
Centuri Enka- Bhosari	IntraState	10/12/2019	11.53	10/12/2019	13.13	PO	CRM Measurement Of CB & Timing Test Of CB.
Paras-Chikhali Ckt No-I	IntraState	10/12/2019	13.45	10/12/2019	15.30	HT	In View Of 220KV Akola Bus Section 2 Outage.
Eklahare (Ocr)Nasik - Padghe 2	IntraState	10/12/2019	14.34	10/12/2019	14.38	PO	For managing Load On GCR-Bableswhar CKT-2.
Eklahara(Gcr)(Nasik)- Bableswhar-I	IntraState	10/12/2019	14.35	10/12/2019	19.42	T	Distance Protection
Pedambe-Nerle	IntraState	10/12/2019	18.37	10/12/2019	18.57	T	Distance Protection
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	11/12/2019	09.01	11/12/2019	18.23	T	Replacement of Old Disc Insulators By Procprocelain Long Rod Insulator.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Dec/2019

Statement-VII

Position as on 6.30 Hrs of 11/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SIEMENS - RELIANCE GIS	IntraState	11/12/2019	09.32	11/12/2019	19.50	PO	Stringing of OPGW Cable.
Mahad - Pedambe	IntraState	11/12/2019	09.35	11/12/2019	19.20	EO	Tree Cutting.
Raymond - TKES	IntraState	11/12/2019	09.42	11/12/2019	19.26	PO	Breaker Work.
Lamboti - Pandharpur li	IntraState	11/12/2019	10.20	11/12/2019	15.55	PO	Replacement of Flash Over Insulator.
Kharghar-Borivali ckt II	IntraState	11/12/2019	10.39	11/12/2019	19.14	PO	Stringing of OPGW Cable.
K'Kheda- Suryalakshmi	IntraState	11/12/2019	11.42	11/12/2019	15.28	PO	CT, CVT Capacitance & Tan Delta Measurement & Routine Bay Maintenance Work.
Kandalgaon - Sona Alloys	IntraState	11/12/2019	12.35	11/12/2019	13.00	T	Distance Protection
Lonikand-II- Kathapur	IntraState	11/12/2019	12.50	11/12/2019	19.01	T	Distance Protection
Bapgaon - Kalwa	IntraState	11/12/2019	15.56	11/12/2019	19.29	PO	Replacement of Earthwire With OPGW Wire.
Pophali - Pedambe II	IntraState	11/12/2019	22.25		Continued.	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Pophali - Nerale	IntraState	11/12/2019	22.40		Continued.	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Pophali - New Koyna	IntraState	11/12/2019	22.45		Continued.	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Bus Section II @ Pophali	IntraState	11/12/2019	23.00		Continued.	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
220 KV ICT Outages/Trippings							
220/132 Kv 200 Mva Vijay Ict 1 @Chaligaon	IntraState	10/12/2019	09.56	10/12/2019	13.21	PO	Tan Delta Measurment of CTs
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	10/12/2019	13.28	10/12/2019	16.05	PO	100Kv Isolator Service & Alidnment.RMW.
220/132 Kv 200 Mva Vijay Ict 2 @Chaligaon	IntraState	10/12/2019	14.12	10/12/2019	18.20	PO	diagnostic Testing Work.
220/22 Kv 50mva Telk Ptr No 2 @Chinchwad	IntraState	11/12/2019	05.52	11/12/2019	10.20	T	Differential protection
220/132 kV 200MVA ICT II @ Girwali	IntraState	11/12/2019	10.02	11/12/2019	11.24	PO	HV CT Hot Spot Attending Work And Bay Maintenance Work.
220/132 Kv 200 Mva Emco Ict 2 @Ambazari	IntraState	11/12/2019	10.12	11/12/2019	17.19	PO	CTR Trail.
220/132 Kv 200 Mva Bbl Ict 1 @Kalmeshwar	IntraState	11/12/2019	10.33	11/12/2019	17.02	PO	Tan Delta Measurment of CTs

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage