

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 10/Dec/2021 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	138.265	1347.190	1) Gujrat	-5.100	-63.494
2) Hydro	4.749	72.988	2) Madhya Pradesh	-7.072	16.730
3) Gas	5.542	40.184	3) Chattisgarh	5.910	55.360
Total MSPGCL	148.556	1460.362	4) Maharashtra	140.922	1308.270
B) 1) APLM	56.077	528.831	5) Goa (Amona)	-1.952	-17.725
2) JSWEL	14.276	143.269	Total	132.708	1299.141
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.059	252.542
4) RPL(AMT)	26.840	243.569	b) Mumbai Drawl	30.624	267.310
5) SWPGPL	7.938	73.231	c) MSEDCL Bilateral *	56.651	413.000
6) Other IPP	37.755	346.265	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.059	252.542
C) 1) TPCL Thermal	7.254	94.967	Include PX	0.000	1.590
2) TPCL Hydro	5.618	44.826	Standby	0.000	0.000
3) TPCL Gas	2.797	27.121	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.358	95.480	1) MSEDCL	403.247	3866.450
D) STATE			2) Mumbai Discoms	55.651	529.701
1) Thermal	297.763	2872.802	3) Other Discoms	10.091	98.089
(A1+C1+C4+(B1-B6))			TOTAL STATE	468.989	4494.240
2) Hydro	10.367	117.814			
(A2+C2)					
3) Gas	8.339	67.305			
(A3+B7+C3)					
4) Wind	13.907	86.537			
6) SOLAR	5.905	50.644			
TOTAL STATE	336.281	3195.102			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6179	5804	6320	4782
MSPGCL Hydro	281	203	286	147
MSPGCL Gas	194	228	232	239
MSPGCL Total Generation	6654	6235	6838	5168
Central Sector Receipt	6613	6827	5631	4897
WIND	790	454	497	680
CPP / IPP Thermal	6076	5614	6689	5203
CPP / IPP Gas	0	0	0	0
SOLAR	821	949	6	0
Exchange with Mumbai	-1621	-1701	-1247	-991
MSEDCL DEMAND MET	8611	8102	7095	6962
Load Shedding	0	0	0	0
MSEDCL DEMAND	8611	8102	7095	6962
TPCL GENERATION	727	721	1006	398
AEML GENERATION	422	367	483	337
MUMBAI DEMAND	2770	2789	2736	1726
OTHER DISCOM DEMAND	370	354	390	276
STATE DEMAND MET	22103	21167	21150	16683
STATE DEMAND	22103	21167	21150	16683
Frequency (Hz)	50.02	49.99	49.96	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 06.01 Hrs	49.75 Hz at 06.57 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 10/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.54	34.94	185	115
Unit 7	0.00	0.00	0	0
Unit 8	14.39	139.90	660	430
Unit 9	14.44	77.30	660	450
Unit 10	13.39	132.23	625	412
Total	45.76	384.36		
Bhusawal				
Unit 3	0.00	6.30	0	0
Unit 4	8.36	85.58	410	280
Unit 5	8.42	84.04	425	275
Total	16.78	175.92		
Parli				
Unit 6	0.00	3.90	0	0
Unit 7	0.00	0.00	0	0
Unit 8	4.01	19.51	205	146
Total	4.01	23.41		
Chandrapur				
Unit 3	3.56	13.59	174	120
Unit 4	3.50	26.06	160	120
Unit 5	2.97	54.96	140	115
Unit 6	9.21	62.35	440	271
Unit 7	8.22	80.08	385	280
Unit 8	9.30	91.75	404	355
Unit 9	10.22	93.72	445	406
Total	46.98	422.52		
Paras				
Unit 3	4.20	40.95	220	137
Unit 4	4.52	42.14	243	143
Total	8.72	83.09		
Khaparkheda				
Unit 1	0.00	24.87	0	0
Unit 2	0.00	25.46	0	0
Unit 3	0.00	27.06	0	0
Unit 4	0.00	20.47	0	0
Unit 5	9.70	97.56	500	280
Total	9.70	195.42		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.01	30.38	147	118
Unit 5	3.30	32.09	188	119
Total	6.31	62.47		
Uran				
All Units	5.54	40.18	250	174
Total	5.54	40.18		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.22	0.91	33	0
Total	0.22	0.91		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.45	21.16	195	40
Stage 4	0.00	5.30	0	0
Stage 3	0.01	6.07	10	0
Total	1.46	32.53		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.04	0	0
TILLARI	0.46	2.29	58	0
BHIRA T.R.	0.30	2.64	80	0
SMLHY_PTN	2.52	35.50	112	93
GHATGHAR	0.00	0.00	0	0
Total	3.29	40.46		
Wind				
Total	13.91	86.54	0	0
Total	13.91	86.54		
CPP				
APML(Mus)	56.08	528.83	0	0
JSWEL(Mus)	14.28	143.27	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.84	243.57	0	0
SWPGPL-Mus	7.94	73.23	0	0
Other(Mus)	37.76	346.26	0	0
Total	142.89	1335.16		
SOLAR				
Total	5.90	50.64	0	0
Total	5.90	50.64		
Tata				
Trombay 5	7.25	73.16	472	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.61	16.11	117	49
Trombay 7B	1.18	11.01	68	40
Trombay 8	0.00	21.80	0	0
TATA Hydro	5.62	44.83	444	0
Total	15.67	166.91		
AEML				
DTPS U-1&2	9.36	95.48	489	321
Total	9.36	95.48		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	138.26	1347.19	MSPGCL Total	148.56	1460.36
			MSPGCL Thml+Gas	143.81	1387.37	Koyna 1,2 & 4 Total	1.45	26.46
			MSPGCL Hydro	4.75	72.99	State Total	336.28	3195.10

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 10/Dec/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4879	159	244	5282	741	5195	0	0	5138	4994	-1164	14729	0	14729	1936	319	16984	50.01
2	4738	148	239	5125	724	5195	0	0	5117	5040	-1068	14726	0	14726	1816	290	16832	50.00
3	4782	147	239	5168	680	5203	0	0	4968	4897	-991	14681	0	14681	1726	276	16683	50.02
4	4799	153	250	5202	703	5210	0	0	4912	4874	-935	14780	0	14780	1664	273	16718	50.02
5	5254	143	237	5634	799	5254	0	0	4950	4900	-951	15327	0	15327	1666	309	17302	50.06
6	5909	153	237	6299	745	5720	0	0	5228	5166	-934	16672	0	16672	1730	324	18726	50.03
7	6140	157	247	6544	634	6161	0	0	5555	5211	-878	17322	0	17322	1847	350	19519	50.01
8	6238	298	238	6774	551	6590	0	85	5719	6033	-890	18788	0	18788	2034	355	21176	49.96
9	6263	181	237	6681	385	6586	0	274	6271	6375	-1156	18771	0	18771	2319	374	21464	50.01
10	6158	273	208	6639	494	6423	0	570	6883	6736	-1474	19012	0	19012	2594	376	21982	49.96
11	6179	281	194	6654	790	6076	0	821	7140	6613	-1621	18963	0	18963	2770	370	22103	50.02
12	6156	289	174	6619	675	6001	0	929	6782	6346	-1544	18662	0	18662	2824	364	21850	50.00
13	5804	203	228	6235	454	5614	0	949	6731	6827	-1701	18024	0	18024	2789	354	21167	49.99
14	5739	251	224	6214	359	5524	0	860	6590	6902	-1664	17842	0	17842	2674	353	20869	50.10
15	6107	215	224	6546	322	5826	0	696	6654	6646	-1637	18044	0	18044	2675	355	21074	49.98
16	6268	210	226	6704	314	6291	0	449	6368	6159	-1569	17986	0	17986	2707	362	21055	50.03
17	6267	188	239	6694	345	6439	0	214	5821	5381	-1427	17275	0	17275	2706	371	20352	49.99
18	6284	159	230	6673	392	6512	0	51	5367	4998	-1218	17023	0	17023	2700	385	20108	49.97
19	6320	286	232	6838	497	6689	0	6	5710	5631	-1247	18024	0	18024	2736	390	21150	49.96
20	6376	197	234	6807	630	6748	0	1	5467	4680	-1303	17170	0	17170	2627	393	20190	50.04
21	5960	177	242	6379	696	6428	0	0	4773	4235	-1284	16071	0	16071	2485	383	18939	50.02
22	5630	157	237	6024	692	5921	0	0	4731	4536	-1339	15462	0	15462	2343	372	18177	50.03
23	5153	157	235	5545	676	5623	0	0	5088	4797	-1326	14964	0	14964	2174	351	17489	49.94
24	4862	167	247	5276	609	5658	0	0	5052	4731	-1303	14652	0	14652	2109	319	17080	49.92
MUs	138.27	4.75	5.54	148.56	13.91	142.89	0.00	5.90	137.01	132.71	-30.62	404.97	0.00	404.97	55.65	8.37	468.99	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 10/Dec/2021

Position as on 6.30 Hrs of 11/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-4	660	10/11/2021	23.58	10/12/2021	17:14	Capital Overhauling	10/12/2021
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09.55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51	11/12/2021	17:47	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Parli Unit 7	250	28/11/2021	23.57		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	02/12/2021	00:00		Continued.	ZERO SCHEDULE	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	02/12/2021	23:25	11/12/2021	17:25	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 3	210	09/12/2021	00:01		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56		Continued.	CHP coal feeding problem	
MSPGCL	Chandrapur Unit 5	500	10/12/2021	23:57		Continued.	PA Fan Vibration Problem	15/12/2021
MSPGCL	Koradi Unit 9	660	11/12/2021	03:20		Continued.	Boiler Tube Leakage	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22		Continued.	withdrawn against case 4 to dhariwal	
MSPGCL	Koradi Unit 8	660	11/12/2021	23:00		Continued.	oil leakage of metering ct	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 11/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
DHULE - KHANDWA CKT - 2	InterState	08/12/2021	08:53		Continued.	PO	Simultaneous outage of 400kV Khandwa-Dhule-1 & 2 for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam
DHULE - KHANDWA CKT - 1	InterState	08/12/2021	08:53		Continued.	PO	Simultaneous outage of 400kV Khandwa-Dhule-1 & 2 for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam
JAIGAD - KARAD CKT - 2	IntraState	09/12/2021	21:49	10/12/2021	09:07	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	09/12/2021	21:57	10/12/2021	09:06	HT	HT FOR OVERVOLTAGE
NEW KOYNA - DABHOL CKT - 1	IntraState	10/12/2021	10:04		Continued.	PO	Cold washing work
MAIN BUS - 1 @ WARORA	IntraState	10/12/2021	10:30	10/12/2021	17:27	PO	Routine maintainance and diagonastic testing such as CVT/ CT tan delta, and, isolater maintainance work.
KORADI - KHADKA	IntraState	10/12/2021	11:25	11/12/2021	19:03	PO	For removal of Live 400 KV Main Bus-1&2 section jumpers of 400 KV Akola & Aurangabad section (i.e removal of jumpers between Koradi and Aurangabad bay) by Hot line unit Jalgaon for hot man clearance
KHADKA-AURANGABAD	IntraState	10/12/2021	11:50		Continued.		For replacement of Faulty Disc insulator found in Monkey patrolling
JAIGAD - KARAD CKT - 1	IntraState	10/12/2021	21:52	11/12/2021	09:23	HT	HT DUE TO OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	10/12/2021	22:00	11/12/2021	09:24	HT	HT DUE TO OVERVOLTAGE
AKOLA - KHADKA (BHUSAWAL)	IntraState	11/12/2021	09:34		Continued.	PO	for replacement of 400 KV Damage Main Bus (1&2) section of Akola & Aurangabad bay
400 KV ICT Outages/Trippings							
400/220/33KV SPARE ICT @ KORADI 2	IntraState	10/12/2021	10:48	10/12/2021	17:50	PO	Tan delta measurement of bushings of spare ICT unit.
400/220 KV 500 MVA ICT @ ALKUD	IntraState	11/12/2021	09:15	11/12/2021	17:57	PO	For QM & testing work
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	10/12/2021	07:24	10/12/2021	13:55	PO	For safety purpose for the scheme of Replacement of all phase conductor of 220kv Boisar - PGCIL line no.02 at loc. No. 16 & 16A.
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
KALWA - TFIPL	IntraState	08/12/2021	08:13		Continued.	PO	For carrying out jumpering at Loc. 48 to LILO Loc. No 01 to form 220 KV Kharghar Tiffil Borivali TAP Line during the period 07.12.2021 to 09.12.2021.
KHARGHAR - BORIVALI CKT - 1	IntraState	08/12/2021	13:02	10/12/2021	19:48	PO	For carrying out the Jumpering for making LILO at Loc. No 48 of 220 KV Kharghar Borivali Ckt-1 Line for Power supply of 30 MVA (1 50MVA) to Newly proposed 220/22 KV GIS S/St at M/S CTRLS Mahape
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB
TROMBAY - SALSETTE CKT - 1	IntraState	09/12/2021	22:52	10/12/2021	03:04		Metro work
TROMBAY SALSETTE LINE-2	IntraState	09/12/2021	23:01	10/12/2021	02:55		Metro work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 10/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 11/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NERLE - PEDAMBE	IntraState	10/12/2021	09:50	10/12/2021	17:45	PO	For replacement of , Damaged conductor at both side of Y-B phase at Loc No. 57; Damaged conductor at both side of R-Y-B phase at Loc No. 58; Damaged conductor at both side of B phase & at Pedhambe side of R-phase at Loc No. 60.
PHALTAN MIDC - CSSK BHAVANI NAGAR	IntraState	10/12/2021	10:18	10/12/2021	16:06	EO	Replace flashover insulator string at Loc no.38 R Ph
PADGHE - JAMBHUL 2	IntraState	10/12/2021	10:53	10/12/2021	19:13	PO	1. Retrofitting of Master 86 relay 2. Diagnostic testing work 3. Attending hotspot on R Phase CT
DAHANU - VERSOVA	IntraState	10/12/2021	13:58		Continued.	PO	NHSRCL Project activityModification / relocation of existing tower no SS 221 & SS 222. Details of activity to be carried out:1. De-stringing of existing conductors & OPGW cable.2. Dismantling of existing tower.3. Erection of Monopoles.4. Re-stringing of conductors & OPGW cable.
BOISAR - VERSOVA	IntraState	10/12/2021	14:07		Continued.	PO	NHSRCL Project activity Modification / relocation of existing tower no SS 221 & SS 222. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing tower. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable.
NIWALI - PAWAS LINE	IntraState	11/12/2021	08:12	11/12/2021	18:51	PO	Replacement of insulators, detected critical in PID testing.
SONKHAR - TROMBAY	IntraState	11/12/2021	11:56	11/12/2021	18:56	PO	Diagnostic Testing work of equipment & RM work
NERUL - SEAWOOD CABLE CKT - 2	IntraState	11/12/2021	12:06	11/12/2021	17:49	PO	1)Tan delta of CT 2) CRM 3) CB timing 4)Relay checking by testing Team at both ends
PADGHE - JAMBHUL 1	IntraState	11/12/2021	13:24	11/12/2021	19:47	PO	1. Retrofitting of Master 86 relay 2. Diagnostic testing work 3. Attending hotspot on R Phase CT
WARDHA (PG) - BADNERA	IntraState	11/12/2021	13:45	11/12/2021	20:19	PO	To be shifted on Transfer Bus with TBC to attend alignment of Bus-1 side isolator.
WARDHA - WARDHA (PG)	IntraState	11/12/2021	15:24	11/12/2021	20:18	PO	For replacement of Bus-1 side isolator
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	11/12/2021	19:10	11/12/2021	21:01	EO	Loc.No-102 single string to DSN string found flashover and other string damage in view of tripping at 15:29Hrs today.(Photo attached)
220 KV ICT Outages/Trippings							
220 / 110 / 22KV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 2 @ BHANDUP GIS	IntraState	10/12/2021	08:51	10/12/2021	17:39	PO	For Diagnostic testing work & Bushing, winding SFRA,PI,10KV Excitation, Tan-δ, PI of TF2.
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	10/12/2021	09:25	10/12/2021	11:34	PO	diagnostic and Relay testing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 10/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 11/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	10/12/2021	09:40	10/12/2021	14:34	PO	1)Quatrlly bay maintenance work 2) HV CB CRM testing work
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	10/12/2021	14:47	10/12/2021	18:20	PO	diagnostic and Relay testing work
220/22 KV 50 MVA PTR 3 @ MAHAPE	IntraState	11/12/2021	09:00	11/12/2021	13:52	PO	1) OLTC Overhauling work 2) Bay maintenance & diagnostic testing work
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	10/12/2021	11:25	10/12/2021	17:25	EO	Outage required for Y phase protection ct replacement work due to higher tan delta value
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	08/12/2021	06:14		Continued.		For formation of three terminal line Kalyan Mukund Kalwa line
KALYAN KALWA SALSETTE 2	IntraState	10/12/2021	06:20	10/12/2021	06:48	PO	Both KKS 1 & 2 lines remain out. For External parties work.
KALYAN KALWA SALSETTE 1	IntraState	10/12/2021	06:25	10/12/2021	16:33	PO	Both KKS 1 & 2 lines remain out. For External parties work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage