

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Feb/2021 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	148.991	1726.277	1) Gujrat	0.626	0.407
2) Hydro	15.739	115.086	2) Madhya Pradesh	7.185	61.288
3) Gas	6.861	70.717	3) Chattisgarh	4.850	59.370
Total MSPGCL	171.591	1912.080	4) Maharashtra	135.443	1434.922
B) 1) APMIL	56.665	615.256	5) Goa (Amona)	-0.874	-10.935
2) JSWEL	11.065	134.943	Total	147.230	1545.052
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.487	224.868
4) RPL(AMT)	28.710	299.569	b) Mumbai Drawl	21.722	236.988
5) WPCL	8.588	88.191	c) MSEDCL Bilateral *	30.182	301.509
6) Other IPP	18.562	205.302	Include PX	0.196	-28.120
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.487	220.821
C) 1) TPCL Thermal	5.558	113.139	Include PX	7.765	52.086
2) TPCL Hydro	6.173	43.948	Standby	0.000	4.047
3) TPCL Gas	4.228	38.439	H) ENERGY CATERED (MUs)		
4) AEML Thermal	12.032	102.540	1) MSEDCL	432.906	4759.518
D) STATE			2) Mumbai Discoms	49.713	535.056
1) Thermal	290.171	3285.217	TOTAL STATE	482.619	5294.574
(A1+C1+C4+(B1-B6))					
2) Hydro	21.912	159.034			
(A2+C2)					
3) Gas	11.089	109.156			
(A3+B7+C3)					
4) Wind	4.243	109.157			
6) SOLAR	7.974	86.956			
TOTAL STATE	335.389	3749.520			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6364	6231	6169	5814
MSPGCL Hydro	1718	1284	486	100
MSPGCL Gas	269	268	281	295
MSPGCL Total Generation	8350	7782	6936	6210
Central Sector Receipt	7205	6916	5576	5349
WIND	73	66	289	197
CPP / IPP Thermal	5519	5470	5569	4270
CPP / IPP Gas	0	0	0	0
SOLAR	1109	1177	0	0
Exchange with Mumbai	-1229	-1215	-1039	-575
MSEDCL DEMAND MET	21028	20196	17332	15450
Load Shedding	0	0	0	0
MSEDCL DEMAND	21028	20196	17332	15450
TPCL GENERATION	791	799	849	447
AEML GENERATION	499	500	501	502
MUMBAI DEMAND	2519	2514	2389	1524
STATE DEMAND MET	23546	22710	19720	16974
STATE DEMAND	23546	22710	19720	16974
Frequency (Hz)	50.00	49.99	50.03	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.31 Hz at 18.02 Hrs	49.77 Hz at 06.12 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Feb/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	6.21	0	0
Unit 7	0.00	5.60	0	0
Unit 8	11.81	129.41	565	376
Unit 9	11.63	132.03	570	375
Unit 10	0.00	95.67	0	0
Total	23.44	368.92		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.44	117.30	480	475
Unit 5	11.12	114.10	480	435
Total	22.56	231.40		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.53	59.39	250	200
Unit 7	5.46	58.93	248	200
Unit 8	5.55	60.31	250	199
Total	16.54	178.63		
Chandrapur				
Unit 3	3.41	38.39	151	120
Unit 4	3.79	38.08	166	130
Unit 5	0.00	56.32	0	0
Unit 6	8.89	105.14	441	285
Unit 7	8.28	92.37	375	285
Unit 8	11.30	124.93	499	440
Unit 9	11.53	121.10	493	461
Total	47.20	576.33		
Paras				
Unit 3	5.17	57.50	230	191
Unit 4	5.50	58.10	248	206
Total	10.67	115.60		
Khaparkheda				
Unit 1	3.22	36.26	160	110
Unit 2	3.46	39.96	170	115
Unit 3	4.06	48.28	200	130
Unit 4	4.04	44.40	195	130
Unit 5	9.84	48.77	440	390
Total	24.60	217.66		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.97	37.75	198	128
Unit 5	0.00	0.00	0	0
Total	3.97	37.75		
Uran				
All Units	6.86	70.72	306	256
Total	6.86	70.72		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	3.49	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	3.49		
Koyna				
Stage 1-2	3.84	36.24	520	40
Stage 4	5.67	27.91	951	0
Stage 3	2.37	14.30	240	0
Total	11.88	78.45		
Hydro				
KDPH	0.44	5.51	19	19
VTRNA	0.64	3.66	60	0
TILLARI	0.00	1.06	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.37	2.26	80	0
RNGR+BHTSA	0.36	3.95	16	15
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.50	5.00	21	20
GHATGHAR	1.54	15.19	250	0
Total	3.86	36.64		
Wind				
Total	4.24	109.16	0	0
Total	4.24	109.16		
CPP				
APML(Mus)	56.66	615.26	0	0
JSWEL(Mus)	11.06	134.94	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	28.71	299.57	0	0
WPCL(Mus)	8.59	88.19	0	0
Other(Mus)	18.56	205.30	0	0
Total	123.59	1343.26		
SOLAR				
Total	7.97	86.96	0	0
Total	7.97	86.96		
Tata				
Trombay 5	0.00	62.20	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.66	24.16	115	84
Trombay 7B	1.57	14.28	68	57
Trombay 8	5.56	50.94	234	213
TATA Hydro	6.17	43.95	435	24
Total	15.96	195.53		
AEML				
DTPS U-1&2	12.03	102.54	502	499
Total	12.03	102.54		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	148.99	1726.28	MSPGCL Total	171.59	1912.08
			MSPGCL Thml+Gas	155.85	1796.99	Koyna 1,2 & 4 Total	9.51	64.15
			MSPGCL Hydro	15.74	115.09	State Total	335.39	3749.52

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Feb/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6200	96	294	6590	278	4328	0	0	5430	5538	-757	15976	0	15976	1706	17682	49.93
2	5870	96	295	6260	251	4271	0	0	5512	5546	-624	15704	0	15704	1589	17294	49.99
3	5814	100	295	6210	197	4270	0	0	5539	5349	-575	15450	0	15450	1524	16974	50.00
4	5938	100	306	6344	158	4262	0	0	5503	5350	-533	15582	0	15582	1471	17052	50.00
5	6200	104	296	6600	191	4423	0	0	5474	5621	-539	16296	0	16296	1477	17774	49.99
6	6402	236	306	6944	216	4836	0	0	5654	5763	-620	17140	0	17140	1559	18698	49.99
7	6481	712	295	7488	182	5452	0	2	6043	5829	-661	18292	0	18292	1659	19952	50.02
8	6527	1734	297	8558	122	5612	0	103	5959	5967	-626	19736	0	19736	1826	21562	50.02
9	6440	1860	296	8596	97	5613	0	404	6298	6324	-800	20234	0	20234	2084	22318	50.03
10	6396	1860	293	8550	111	5611	0	710	6773	6954	-984	20952	0	20952	2321	23272	50.02
11	6379	1558	291	8228	84	5620	0	967	7145	7042	-1147	20794	0	20794	2489	23282	50.02
12	6364	1718	269	8350	73	5519	0	1109	7235	7205	-1229	21028	0	21028	2519	23546	50.00
13	6231	1284	268	7782	66	5470	0	1177	7171	6916	-1215	20196	0	20196	2514	22710	49.99
14	6189	590	267	7046	73	5476	0	1094	7045	7090	-1076	19704	0	19704	2399	22102	49.99
15	6166	750	256	7172	71	5464	0	1012	7278	7340	-1068	19990	0	19990	2418	22408	49.94
16	6251	758	276	7286	76	5461	0	787	7315	7160	-1075	19694	0	19694	2425	22120	49.93
17	6309	644	268	7220	78	5556	0	468	6608	6697	-1077	18942	0	18942	2423	21366	50.02
18	6291	456	269	7016	148	5543	0	137	6189	6152	-1038	17958	0	17958	2390	20348	50.04
19	6198	182	291	6670	217	5550	0	4	5797	5800	-1040	17202	0	17202	2392	19594	50.02
20	6169	486	281	6936	289	5569	0	0	5466	5576	-1039	17332	0	17332	2389	19720	50.03
21	6167	126	282	6574	286	5311	0	0	5287	5070	-1049	16192	0	16192	2242	18434	50.00
22	6077	94	293	6464	390	4939	0	0	5820	5527	-1101	16218	0	16218	2108	18326	49.98
23	6022	98	283	6404	321	4721	0	0	5755	5662	-979	16128	0	16128	1959	18088	49.95
24	5910	98	294	6302	268	4713	0	0	5620	5752	-870	16166	0	16166	1830	17996	49.95
MUs	148.99	15.74	6.86	171.59	4.24	123.59	0.00	7.97	147.92	147.23	-21.72	432.91	0.00	432.91	49.71	482.62	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Feb/2021

Position as on 6.30 Hrs of 12/Feb/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U4	300	28/01/2021	01.34		Continued.	Annual Overhaul	
TPC-G	Trombay 5	500	08/02/2021	00.10		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	Economizer Tube Leakage. (Zero Schedule from 18:45hrs of 05.12.2020)	
IPP	Adani U-5	660	18/01/2021	21.00		Continued.	zero scheduled	
MSPGCL	Koyna Unit 11	80	19/01/2021	10.05		Continued.	Tripped on stator earth fault (will not be available till dt.18.04.21)	
MSPGCL	Bhusawal Unit 3	210	26/01/2021	00.00		Continued.	Zero schedule.	
IPP	JSW (J) U1	300	01/02/2021	18.00		Continued.	Due to turbine vibration high	
MSPGCL	Koradi Unit 6	210	02/02/2021	20.30		Continued.	ZERO Schedule by MSEDCL	
MSPGCL	Koradi Unit 7	210	02/02/2021	20.50		Continued.	ZERO Schedule by MSEDCL	
MSPGCL	Chandrapur Unit 5	500	06/02/2021	20.16		Continued.	Clinker Formation In Boiler.	
MSPGCL	Koradi Unit 10	660	09/02/2021	15.10		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit-8	500	12/02/2021	21.21		Continued.	Drum level high.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Feb/2021

Statement-VII

Position as on 6.30 Hrs of 12/Feb/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	10/02/2021	19.27	11/02/2021	05.40	HT	Over Voltage
Chandrapur II - Dhariwal -I	InterState	11/02/2021	11.20	11/02/2021	19.48	EO	Attending hot spot of jumper pad.
Dhule Sar'Sarovar I	InterState	11/02/2021	18.10	12/02/2021	05.53	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	12/02/2021	18.21		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	10/02/2021	22.25	11/02/2021	05.48	HT	Over Voltage
Koradi III(Adani)-Korad II Ckt-I	IntraState	11/02/2021	09.47	11/02/2021	20.15	PO	Line Signature Test and line maintenance work.
Bus Coupler @ Karad	IntraState	11/02/2021	09.51	11/02/2021	13.19	EO	Air leakage in Compressor.
Lonikand 1 - Talegaon(Pgcil)	IntraState	11/02/2021	15.25	11/02/2021	18.50	T	R-ph to Earth fault,Air lockout,fault current 7.5 KAMP,23.5Km from Lonikand end.
Khadka-Aurangabad (Waluj)	IntraState	11/02/2021	19.27	12/02/2021	05.58	HT	Over Voltage
Dhule- Bableshwar - I	IntraState	11/02/2021	20.08	12/02/2021	06.36	HT	Over Voltage
Koradi III(Adani)-Koradi II ckt 2	IntraState	12/02/2021	08.50	12/02/2021	20.31	PO	Line Signature Test and line maintenance work.
Cahndrapur II - Dhariwal II	IntraState	12/02/2021	08.51	12/02/2021	20.06	PO	Attending Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	12/02/2021	19.59		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	09/02/2021	08.08	11/02/2021	19.15	PO	Routine Maintenance Work
400/220/33kv 315MVA ICT-I @Lonikand	IntraState	11/02/2021	10.50	12/02/2021	10.37	PO	DT/Routine Maintenance.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12	12/02/2021	10.15	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Aurangabad PG (Chitepimpalgaon)-Chitegaon Ckt-I	InterState	11/02/2021	11.30	11/02/2021	18.27	PO	For lie equipment AMP Works.
Tillari Amona	InterState	11/02/2021	21.37	11/02/2021	22.06	T	Distance Protection
Mahalakshmi Amona	InterState	12/02/2021	01.35	12/02/2021	03.31	T	Distance Protection
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Chandrapur GCR -MIDC (Chandrapur)	IntraState	11/02/2021	08.21	11/02/2021	20.25	PO	Jumper Nut bolt tightening.
Niwali - Pawas Line	IntraState	11/02/2021	08.23	11/02/2021	19.50	PO	Cold washing of insulator strings.
chandrapur-Tadali	IntraState	11/02/2021	08.24	11/02/2021	20.26	PO	Jumper Nut bolt tightening.
Trombay - Kalwa	IntraState	11/02/2021	09.46	11/02/2021	17.30	PO	Live Line OPGW stringing between loc. no.39 to 68 in AR Mode Off position.
220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 2	IntraState	11/02/2021	10.44	11/02/2021	18.15	PO	Line Stringing Work.
TPC Borivali Aarey Line 1	IntraState	11/02/2021	11.25	11/02/2021	12.28	PO	Removal of Foreign material from conductor / insulator / hardware on.VAB 50.52.53.74A.
KORADI 2 - KAULEWADA CKT - I	IntraState	11/02/2021	11.36	11/02/2021	15.10	PO	Routine Maintenance Work
Phursungi-Parvati	IntraState	11/02/2021	12.05	11/02/2021	13.22	PO	To attend hot spot at B phase drop of 220kV Phursungi line bay C.T.(85 degree Celsius).

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Feb/2021

Statement-VII

Position as on 6.30 Hrs of 12/Feb/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Karad - Kadegaon	IntraState	11/02/2021	14.07	11/02/2021	19.19	PO	Conversion of Single Suspension disc insulator string to Double Suspension Long Rod Porcelain Insulator string at Loc No.29-30 & 66-67 road crossing.
Jejuri (400 Kv)-Jejuri ckt-I	IntraState	11/02/2021	16.35	11/02/2021	20.34	PO	C & Tand measurement work of CTs.
JATH SHEDYAL	IntraState	11/02/2021	17.40	11/02/2021	19.35	PO	Equipment testing work at 220 kV Shedyal end.
Main Bus-III @ Mudshingi	IntraState	12/02/2021	07.25	12/02/2021	07.38	T	Bus Bar Broken Operated.
Bus B @ Padaghe	IntraState	12/02/2021	07.40	12/02/2021	18.59	PO	For replacement of Broken conductor of 220kV B Bus hybrid pass from bushing to main Bus conductor of R, Y & B Phase.
Niwali - Pawas Line	IntraState	12/02/2021	08.08	12/02/2021	18.54	PO	Cold washing of insulator strings.
chandrapur-Tadali	IntraState	12/02/2021	08.45	12/02/2021	09.20	PO	Jumper Nut bolt tightening.
220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 2	IntraState	12/02/2021	08.45	12/02/2021	18.05	PO	Stringing work and erection Work of n 220kv KRISHNOOR ckt 1 At loc no 1.
Chandrapur GCR -MIDC (Chandrapur)	IntraState	12/02/2021	08.48	12/02/2021	19.32	PO	Jumper Nut bolt tightening.
Topworth - Kharghar	IntraState	12/02/2021	09.24		Continued.	PO	Replacement of flash over polymer insulator at Loc no. 665 (Cut point) Top - B-phase.(Breaker problem at Topworth From 15.30 hrs
Dahanu Versova	IntraState	12/02/2021	09.37	12/02/2021	11.47	PO	Removal of Foreign material from conductor / insulator / hardware on SS 209, 246, 274, 278 & 280.
Koyna (Pophali) - Kdph	IntraState	12/02/2021	10.20	12/02/2021	17.35	PO	For replacement of damaged conductor & jumper at Loc no. 20 & replacement of conductor hardware at Loc no. 21.
Butibori - VIPL Ckt I	IntraState	12/02/2021	10.51	12/02/2021	17.40	PO	For diagnostic Testing work.
Chitegaon-Shendra Ckt-Ii	IntraState	12/02/2021	11.10	12/02/2021	19.41	PO	220kV Shendra 2 PGCIL Ckt No. II, 245kV Circuit Breaker Servicing & Overhauling work by Agency & Quarterly Maint. & 89C Isolator Maintenance work.
Solapur(Bale) - Tuljapur	IntraState	12/02/2021	11.46	12/02/2021	14.31	PO	Routine Relay Testing work by Testing unit Latur.
Boisar Versova Line	IntraState	12/02/2021	12.02	12/02/2021	13.22	PO	Removal of Foreign material from conductor / insulator / hardware on SS 209, 246, 274, 278 & 280.
Kalwa Panchanand	IntraState	12/02/2021	12.28	12/02/2021	17.04	PO	Relay testing and other diagnostic works.
Kharghar - Nerul	IntraState	12/02/2021	13.12	12/02/2021	19.59	PO	For OPGW Stringing work in between Loc. No.3 to Nerul Gantry.
Shivajinagar - Malegaon	IntraState	12/02/2021	15.40	12/02/2021	19.30	PO	For replacement of Jumpers with Jump Cone with new One at Loc.No.201,202.&204.
220 KV ICT Outages/Trippings							
220/132 Kv 200 Mva Emco Ict 2 @Ambazari	IntraState	03/02/2021	11.34	11/02/2021	17.56	PO	Commissioning of New T/F Protector(Fire Protection scheme)
220/33kV 100 MVA Transformer 2 @Ghodbunder R/S	IntraState	11/02/2021	08.12	11/02/2021	23.31	PO	33 Kv AIS To GIS WORK.
220/33kv 100 Mva Transformer 1 @Ghodbunder R/S	IntraState	12/02/2021	08.29	12/02/2021	18.35	PO	33kV AIS to GIS work (Foundation preparation for fabrication of cable support structure near NGT 1).
220/132 Kv 200mva Kanohar Ict 3 @Bale (Solapur 2)	IntraState	12/02/2021	16.20		Continued.	PO	Outage is required for Oil Filtration work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage