

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Mar/2015 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	129.034	1318.322	1) Gujrat	-2.889	-33.540
2) Hydro	8.541	92.292	2) Madhya Pradesh	13.775	143.803
3) Gas	10.591	87.544	3) Chattisgarh	5.340	51.380
Total MSPGCL	148.166	1498.158	4) Maharashtra Net	81.771	817.556
B) 1) APLM	45.860	457.380	5) Goa	-6.537	-67.260
2) JSWEL	16.010	127.511	6) TAPS 1&2 Injection	3.609	40.409
3) VIPL	9.375	102.903	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	6.050	58.660	8) Pench (MS)	0.135	1.087
5) WPCL	2.623	28.274	9) Pench (Excess)	-0.135	-1.125
6) Other IPP	9.042	97.657	Total	94.934	951.223
C) 1) TPCL Thermal	15.077	144.387	a) Mumbai Schedule	19.759	200.703
2) TPCL Hydro	3.144	24.956	b) Mumbai Drawl	23.354	203.519
3) TPCL Gas	3.852	30.607	c) MSEDCL Bilateral *	22.504	238.515
4) R-INFRA Thermal	10.967	112.913	Include PX	-0.654	-3.564
D) STATE			d) Mumbai Bilateral *	19.759	200.703
1) Thermal	244.038	2448.007	Include PX	0.688	0.862
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	11.685	117.248	H) ENERGY CATERED (MUs)		
3) Gas	14.443	118.151	1) MSEDCL	316.019	3217.492
4) Wind	5.935	83.241	2) Mumbai Discoms	56.392	516.374
6) SOLAR	1.378	14.917	TOTAL STATE	372.411	3733.866
TOTAL STATE	277.479	2781.564			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5399	5459	5415	5177
MSPGCL Hydro	355	291	511	126
MSPGCL Gas	426	434	438	441
MSPGCL Total Generation	6180	6184	6364	5744
Central Sector Receipt	5313	5032	4498	2582
WIND	151	114	227	469
CPP / IPP	3908	3960	3920	3364
SOLAR	205	200	0	0
Exchange with Mumbai	-1219	-1222	-1114	-662
MSEDCL DEMAND MET	14538	14268	13895	11497
Load Shedding	65	67	60	56
MSEDCL DEMAND	14603	14335	13955	11553
TPCL GENERATION	1200	1184	1089	655
R-INFRA GENERATION	514	519	519	385
MUMBAI DEMAND	2933	2925	2755	1709
STATE DEMAND MET	17471	17193	16650	13206
STATE DEMAND	17536	17260	16710	13262
Frequency (Hz)	49.98	49.90	49.89	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 06.02 Hrs	49.66 Hz at 13.38 Hrs	49.94	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Mar/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	3.86	41.35	170	150
Unit 7	3.80	41.56	165	140
Total	7.66	82.91		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	4.06	43.70	185	165
Unit 4	9.16	70.82	485	365
Unit 5	9.23	102.18	485	365
Total	22.45	216.70		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	3.32	30.95	178	3
Unit 5	3.62	22.64	160	146
Unit 6	4.55	51.37	195	186
Unit 7	4.47	36.95	195	151
Total	15.96	141.91		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.28	36.18	141	127
Unit 3	4.02	46.49	172	163
Unit 4	4.05	44.33	186	159
Unit 5	9.12	76.06	410	360
Unit 6	8.82	89.17	405	350
Unit 7	9.01	96.15	429	357
Total	38.31	388.38		
Paras				
Unit 3	4.63	51.34	201	180
Unit 4	0.00	18.35	0	0
Total	4.63	69.70		
Khaparkheda				
Unit 1	4.30	44.46	195	155
Unit 2	3.86	41.42	180	150
Unit 3	4.54	40.33	210	182
Unit 4	4.36	46.00	197	170
Unit 5	10.18	106.00	500	400
Total	27.24	278.21		
Nasik				
Unit 3	4.33	47.16	195	165
Unit 4	4.27	47.05	183	169
Unit 5	4.19	46.30	183	164
Total	12.78	140.52		
Uran				
All Units	10.59	87.54	456	426
Total	10.59	87.54		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.14	1.09	33	0
Total	0.14	1.09		
Koyna				
Stage 1-2	2.50	31.53	455	40
Stage 4	1.68	13.28	493	0
Stage 3	0.76	9.78	156	0
Total	4.94	54.59		
Hydro				
KDPH	0.44	2.10	19	18
VTRNA	1.09	11.39	61	0
TILLARI	0.26	2.59	64	0
BHTGR/VEER	0.05	0.06	2	1
BHIRA T.R.	0.12	1.03	80	0
RNGR+BHTSA	0.32	3.13	14	13
BHANDARDRA	0.47	1.48	20	19
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.85	5.51	36	35
GHATGHAR	0.00	10.41	0	0
Total	3.60	37.70		
Wind				
Total	5.94	83.24	0	0
Total	5.94	83.24		
CPP				
APML(Mus)	45.86	457.38	0	0
JSWEL(Mus)	16.01	127.51	0	0
VIPL(Mus)	9.38	102.90	0	0
RPLAMT(Mus)	6.05	58.66	0	0
WPCL(Mus)	2.62	28.27	0	0
Other(Mus)	9.04	97.66	0	0
Total	88.96	872.38		
SOLAR				
Total	1.38	14.92	0	0
Total	1.38	14.92		
Tata				
Trombay 5	9.64	86.48	501	312
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.37	18.04	125	67
Trombay 7B	1.49	12.57	71	52
Trombay 8	5.44	57.91	253	199
TATA Hydro	3.14	24.96	348	0
Total	22.07	199.95		
R-INFRA				
1-2	10.97	112.91	520	385
Total	10.97	112.91		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	129.03	1318.32
MSPGCL Thml+Gas	139.62	1405.87

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	8.54	92.29
MSPGCL Total	148.17	1498.16

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	4.18	44.81
State Total	277.48	2781.56

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Mar/2015

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	5144	186	452	5782	627	3232	0	2874	3371	-832	12180	86	12266	1871	14137	49.94
2	5177	126	441	5744	469	3364	0	2764	2582	-662	11497	56	11553	1709	13262	49.95
3	5191	132	451	5774	368	3288	0	2710	3055	-584	11901	56	11957	1620	13577	49.97
4	5256	142	450	5848	245	3267	0	2703	2823	-516	11667	56	11723	1563	13286	49.95
5	5296	137	449	5882	247	3320	0	2975	2731	-526	11654	56	11710	1578	13288	49.95
6	5323	127	449	5899	342	3444	0	3681	3190	-619	12256	58	12314	1676	13990	49.95
7	5371	128	453	5952	352	3676	1	4695	4176	-803	13354	111	13465	1851	15316	49.99
8	5374	244	456	6074	299	3582	20	4834	4845	-923	13897	111	14008	2007	16015	50.01
9	5877	193	442	6512	240	3924	73	5119	4585	-969	14365	109	14474	2274	16748	49.98
10	5595	318	442	6355	243	3841	116	5241	4965	-1214	14306	76	14382	2677	17059	49.95
11	5451	484	435	6370	237	3840	181	5416	5084	-1233	14479	62	14541	2857	17398	49.98
12	5399	355	426	6180	151	3908	205	5432	5313	-1219	14538	65	14603	2933	17536	49.98
13	5459	291	434	6184	114	3960	200	5310	5032	-1222	14268	67	14335	2925	17260	49.90
14	5434	202	435	6071	77	3809	196	5057	4727	-1101	13779	68	13847	2793	16640	49.86
15	5428	377	436	6241	72	3736	174	5010	5014	-1110	14127	65	14192	2829	17021	49.86
16	5371	607	435	6413	91	3680	113	4957	4964	-1117	14144	60	14204	2839	17043	49.87
17	5357	569	432	6358	134	3786	64	4661	4708	-1033	14017	64	14081	2820	16901	49.91
18	5360	850	432	6642	152	3796	33	3204	3306	-1059	12870	72	12942	2777	15719	49.94
19	5368	1145	433	6946	179	3836	2	3295	3131	-1107	12987	58	13045	2716	15761	49.94
20	5415	511	438	6364	227	3920	0	4753	4498	-1114	13895	60	13955	2755	16710	49.89
21	5334	230	441	6005	279	3869	0	4722	3544	-1072	12625	60	12685	2662	15347	49.98
22	5363	413	441	6217	287	4027	0	3501	3539	-1167	12903	60	12963	2444	15407	49.99
23	5362	502	445	6309	280	3942	0	3326	2738	-1138	12131	60	12191	2261	14452	49.91
24	5324	272	443	6039	223	3913	0	3305	3013	-1014	12174	60	12234	2092	14326	49.95
MUs	129.03	8.54	10.59	148.16	5.93	88.96	1.38	99.54	94.93	-23.35	316.01	1.66	317.67	56.53	374.20	49.94

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 11/Mar/2015

Position as on 6.30 Hrs of 12/Mar/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Parli Unit 3	210	13/02/2013	23:50		Continued.	Water Shortage	
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling Work. (60 Days)	
MSPGCL	Paras Unit 4	250	05/03/2015	00.00		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	WPCL U-2	135	18/02/2014	00.02		Continued.	Ash conveying Problem	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	PA Fan Vibration Problem	
MSPGCL	Koradi Unit 5	200	17/06/2014	11:53		Continued.	Economic Shutdown	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
CPP	WPCL U-1	135	30/10/2014	00.43		Continued.	ESP bag Filter Damaged	
TPC-G	Trombay 6	500	17/02/2015	21.50		Continued.	Economic shutdown	
MSPGCL	Koyna STG- IV Unit - 1	250	20/02/2015	09.00		Continued.	Sperical valve servo motor maintance work	
IPP	RPL(AMT) U-2	270	03/03/2015	23.23		Continued.	PA Fan problem	
IPP	JSW (J) U4	300	05/03/2015	00.15		Continued.	Boiler Tube Leakage	
IPP	WPCL U-3	135	06/03/2015	00.08		Continued.	Withdrawn	
MSPGCL	Parli Unit 4	210	08/03/2015	17.20	11/03/2015	01.00	PA Fan problem	
MSPGCL	Parli Unit 4	210	12/03/2015	13.09	12/03/2015	16.00	Loss of fuel	
TPC-G	Trombay 5	500	12/03/2015	17.17	12/03/2015	23.00	Turbine Control problem	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2015

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Pune(PG)-Solapur(PG)	InterState	06/03/2015	23:51		Continued.	HT	Over Voltage
Wardha(PG)-Aurangabad(PG)- II	InterState	09/03/2015	10.29	11/03/2015	10.52	HT	Over Voltage
Wardha(PG)-Aurangabad(PG) I	InterState	11/03/2015	14.39	11/03/2015	19.44	PO	To Attend Hot Spot on Line.
Wardha(PG)-Aurangabad(PG) I	InterState	12/03/2015	13.25		Continued.	HT	For Availing Outage on ICT @ Aurangabad PG.
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	10/03/2015	22.29	11/03/2015	03.42	EO	High DC voltage problem
400 KV LINE Outages/Trippings							
Kolhapur Mapusa I	InterState	11/03/2015	17.04	12/03/2015	10.11	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	11/03/2015	17.49	12/03/2015	07.10	HT	Over Voltage
Waluj Aurangabad(PG) II	InterState	12/03/2015	12.23		Continued.	HT	Taken on TBC Due to Heavy Sparking on Isolator.
Kolhapur Mapusa II	InterState	12/03/2015	16.13		Continued.	HT	Over Voltage
Taptitanda Waluj	IntraState	27/01/2015	18.20		Continued.	HT	B Ph Jumper Open.
Babhaleshwar-Taptitanda ckt-I	IntraState	27/02/2015	19.15	12/03/2015	15.26	HT	For Overloading Padgha-Bablsr.
Nagothane - Dabhol-II	IntraState	06/03/2015	03.17		Continued.	T	Over Voltage
karad -kolhapur-I	IntraState	10/03/2015	16.49	11/03/2015	06.48	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	10/03/2015	17.07	11/03/2015	10.57	HT	Over Voltage
karad -kolhapur-II	IntraState	10/03/2015	19.13	11/03/2015	09.08	T	Over Voltage
Karad - Lonikand 1	IntraState	10/03/2015	19.13	11/03/2015	08.54	T	Distance Protection
Bhusawal-Aurangabad	IntraState	10/03/2015	21.46	11/03/2015	06.00	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	10/03/2015	23.42	11/03/2015	06.46	HT	Over Voltage
Padghe - Nagothane - II	IntraState	11/03/2015	08.55	11/03/2015	18.15	PO	Taken on TBC Breaker Testing Work.
karad -kolhapur-II	IntraState	11/03/2015	16.40	12/03/2015	08.52	HT	Over Voltage
Karad - Jaigad - II	IntraState	11/03/2015	17.01	12/03/2015	09.03	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	11/03/2015	17.09	12/03/2015	06.34	HT	Over Voltage
Chandrapur-Parali III	IntraState	11/03/2015	19.44	12/03/2015	06.28	T	Closing Coil Burnt @ Parly End
Lonikand I - Koyna stage-IV	IntraState	11/03/2015	22.08	12/03/2015	07.11	HT	Over Voltage
Chandrapur-Parali 2	IntraState	12/03/2015	12.39	12/03/2015	19.49	PO	Bay Maint.Work,Replacement of Broken Spacer Cum Vibration Damper.
karad -kolhapur-I	IntraState	12/03/2015	16.09		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	12/03/2015	16.15		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	12/03/2015	21.24		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	12/03/2015	22.58		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220 KV 500 MVA ICT- 2 @Warora	IntraState	16/02/2015	10:43		Continued.	HT	Attending CTR Fire System Nitrogen Leakage
400/220 KV 500 MVA ICT- I @Warora	IntraState	16/02/2015	18.56		Continued.	PO	Attending Oil Leakage
400/220kv 315 Mva Ict 1 @Karad	IntraState	10/03/2015	19.22	11/03/2015	08.49	T	NDR Operated
400/220kv, 500 Mva Ict-2 @Deepnagar	IntraState	11/03/2015	10.15	11/03/2015	19.43	PO	Tan Delta Measurment of CTs
400/220/33 Kv 500 Mva ICT III @Waluj	IntraState	11/03/2015	22.53	12/03/2015	00.59	T	NDR
220 KV LINE Outages/Trippings							
Nasik Navsari I	InterState	10/03/2015	17.59		Continued.	T	Over Voltage
Talange Chikodi	InterState	11/03/2015	12.40	11/03/2015	18.16	PO	Insulator Cleaning Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2015

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Borivali - Tarapur	InterState	12/03/2015	11.47	12/03/2015	12.20	T	Distance Protection
TBC @ Parli-II	IntraState	07/01/2015	15.48		Continued.	PO	Shifting of control panel
Butibori-Butibori Rly Tss	IntraState	18/02/2015	09:56		Continued.	PO	Erection of CB and CC, Dismantling of CB, Aligment of Line Isolator.
Kalwa Salsette III	IntraState	24/02/2015	09.03		Continued.	PO	Strengthening work,line taken in service on 02.03.15 at 11.39 hrs.to attend hot spot on kalwa-s'sette IV.again H/T on 03.03.15 at 10.23 Hrs.
Sahara-Urse	IntraState	03/03/2015	11.06		Continued.	PO	Tower erection work
Bableshwar -Waluj	IntraState	05/03/2015	06.35		Continued.	HT	Over Voltage
Solapur(Bale) - Tuljapur	IntraState	05/03/2015	08.46		Continued.	HT	Hand Tripped.
Osmanabad - Solapur (Bale)	IntraState	05/03/2015	08.46		Continued.	HT	Hand Tripped.
Uran - Apta IV	IntraState	09/03/2015	13.27		Continued.	PO	Shifted on TBC for 4 days
Dhule-Amalner(220kv)	IntraState	10/03/2015	21.18	11/03/2015	01.30	PO	Replacement of Faulty Insulator String.
Bableshwar- Alephata	IntraState	11/03/2015	06.51	11/03/2015	17.11	HT	Due to ICT O/L.
Pusad - Hingoli	IntraState	11/03/2015	08.41	11/03/2015	19.16	PO	Stringing of 220KV Ghatodi-Hingoli.
Talandge-Hamidwada	IntraState	11/03/2015	09.20	11/03/2015	18.13	PO	For Cleaning of Insulator Disc.
Badnera - Amravati	IntraState	11/03/2015	10.55	11/03/2015	14.52	PO	B Ph Insulator String Replacement.
Waluj - Jalna 1	IntraState	11/03/2015	11.20	11/03/2015	14.09	PO	Y Ph LA Replacement Work.
Butibori-Vipl1	IntraState	11/03/2015	13.02	11/03/2015	17.30	PO	Tan Delta Measurment of CTs
Aurangabad (Waluj)-Bhenda	IntraState	11/03/2015	23.01	12/03/2015	01.19	HT	NDR Protection Operated,H/T to Control A'bad 500 MVA ICT Tripped.
Chalisingaon -Babhaleshwar	IntraState	12/03/2015	00.04	12/03/2015	00.26	T	Distance Protection
Kalwa-Salsette-VI	IntraState	12/03/2015	01.38	12/03/2015	07.34	EO	Attending Hot Spot
New Koyna - Niwali	IntraState	12/03/2015	08.34	12/03/2015	16.05	PO	Line Maintenance work
Talandge-Hamidwada	IntraState	12/03/2015	09.15	12/03/2015	17.33	PO	Polluted Insulator Cleaning Work.
Lonand-Baramati	IntraState	12/03/2015	09.20	12/03/2015	20.00	PO	Old Insulator String Replaced.
Bableshwar- Ranjangaon	IntraState	12/03/2015	09.41	12/03/2015	17.57	PO	For Work of SSN to DSN Conversion.
Karad - Vita Ckt- I	IntraState	12/03/2015	10.00	12/03/2015	14.44	PO	Line Signature Test.
Pusad - Hingoli	IntraState	12/03/2015	10.06	12/03/2015	17.47	PO	Stringing of 220KV Ghatodi-Hingoli ckt on M/C Tower.
Karad - Vita Ckt- II	IntraState	12/03/2015	14.48	12/03/2015	18.14	PO	Line Signature Test.
Dondaicha(220)-Amalner(220)	IntraState	12/03/2015	18.12	12/03/2015	20.44	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Monkey Fault
220/100 Kv 200 MVA ICT IV @Apta	IntraState	10/03/2015	11.37		Continued.	PO	shifting Lv ct from old rcc structure to new structure
220/100 kv 200 MVA ICT-II @Kalwa	IntraState	11/03/2015	06.16	11/03/2015	18.29	PO	Testing Work
220/132 Kv 200 MVA ICT-III @Phursungi	IntraState	12/03/2015	09.05	12/03/2015	14.05	PO	CTR Fire Protection Work.
220/132 Kv 200 MVA ICT II @Babhleshwar	IntraState	12/03/2015	09.25	12/03/2015	13.30	PO	Annual Maintenance Work
220/100 Kv 200 MVA ICT I @Pal-Dombivali	IntraState	12/03/2015	10.03	12/03/2015	16.55	PO	Tan Delta Testing Work.
220/100 Kv 200 MVA ICT IV @Padghe	IntraState	12/03/2015	10.05	12/03/2015	18.59	PO	Diagnostic Testing Work.
132 KV LINE Outages/Trippings							
Jalna (220)-Ambad	IntraState	11/03/2015	22.53	12/03/2015	00.22	T	Load Trimming Scheme Optd @ Aurangabad S/S.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2015

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Padegaon-Pishor	IntraState	11/03/2015	22.53	12/03/2015	01.33	T	Load Trimming Scheme Optd @ Aurangabad S/S.