

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Mar/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	168.535	1808.621	1) Gujrat	0.862	35.917
2) Hydro	10.872	98.117	2) Madhya Pradesh	3.719	46.359
3) Gas	4.539	45.626	3) Chattisgarh	4.390	42.830
Total MSPGCL	183.946	1952.364	4) Maharashtra	172.368	1778.834
B) 1) APML	75.130	749.830	5) Goa (Amona)	-2.165	-16.255
2) JSWEL	26.309	276.426	Total	179.174	1887.685
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.569	332.538
4) RPL(AMT)	31.235	326.496	b) Mumbai Drawl	34.708	398.271
5) SWPGPL	10.415	110.402	c) MSEDCL Bilateral *	87.981	949.827
6) Other IPP	40.086	465.400	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.569	332.538
C) 1) TPCL Thermal	10.591	121.070	Include PX	0.000	0.000
2) TPCL Hydro	2.817	30.343	Standby	0.000	0.000
3) TPCL Gas	2.861	27.852	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.496	121.246	1) MSEDCL	523.697	5540.183
D) STATE			2) Mumbai Discoms	62.473	698.782
1) Thermal	373.797	3979.491	3) Other Discoms	10.071	110.335
(A1+C1+C4+(B1-B6))			TOTAL STATE	596.241	6349.300
2) Hydro	13.689	128.460			
3) Gas	7.400	73.478			
4) Wind	7.250	130.177			
6) SOLAR	14.931	150.009			
TOTAL STATE	417.067	4461.615			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6677	7074	7135	7258
MSPGCL Hydro	634	449	1318	155
MSPGCL Gas	169	171	187	208
MSPGCL Total Generation	7480	7694	8640	7621
Central Sector Receipt	8763	9045	6958	6129
WIND	237	108	219	502
CPP / IPP Thermal	7493	7528	7809	7543
CPP / IPP Gas	0	0	0	0
SOLAR	2049	1263	0	0
Exchange with Mumbai	-1810	-1958	-1337	-1077
MSEDCL DEMAND MET	23762	23220	21838	20406
Load Shedding	0	0	0	0
MSEDCL DEMAND	23762	23220	21838	20406
TPCL GENERATION	709	575	1041	494
AEML GENERATION	490	497	470	486
MUMBAI DEMAND	3009	3030	2848	2057
OTHER DISCOM DEMAND	450	460	452	312
STATE DEMAND MET	27221	26710	25137	22775
STATE DEMAND	27221	26710	25137	22775
Frequency (Hz)	49.96	49.96	50.02	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 22:01 Hrs	49.79 Hz at 18:40 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.76	50.46	205	185
Unit 8	14.93	147.64	643	582
Unit 9	14.52	145.46	649	552
Unit 10	0.00	102.93	0	0
Total	34.20	446.49		
Bhusawal				
Unit 3	3.42	36.23	160	115
Unit 4	10.26	103.68	495	200
Unit 5	11.16	111.04	500	290
Total	24.84	250.94		
Parli				
Unit 6	5.27	49.76	250	145
Unit 7	5.12	48.84	245	148
Unit 8	3.82	36.85	170	139
Total	14.21	135.46		
Chandrapur				
Unit 3	3.57	39.37	175	125
Unit 4	3.42	35.51	149	128
Unit 5	7.24	41.03	370	78
Unit 6	8.77	92.72	400	295
Unit 7	9.17	90.37	435	292
Unit 8	11.81	116.85	504	473
Unit 9	11.42	119.04	498	450
Total	55.40	534.89		
Paras				
Unit 3	5.38	53.70	243	185
Unit 4	5.53	58.08	236	225
Total	10.91	111.77		
Khaparkheda				
Unit 1	2.78	30.58	125	110
Unit 2	3.30	34.26	145	116
Unit 3	3.38	41.51	182	0
Unit 4	4.35	42.39	192	128
Unit 5	11.32	111.31	500	450
Total	25.14	260.04		
Nasik				
Unit 3	0.00	0.97	0	0
Unit 4	0.00	29.97	0	0
Unit 5	3.83	38.08	174	139
Total	3.83	69.02		
Uran				
All Units	4.54	45.63	209	167
Total	4.54	45.63		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	1.38	33	0
Total	0.06	1.38		
Koyna				
Stage 1-2	2.22	24.66	380	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.06	17.67	732	0
Stage 3	1.16	9.28	160	0
Total	6.44	51.61		
Hydro				
KDPH	0.86	9.06	36	36
VTRNA	1.04	11.11	61	0
TILLARI	0.35	1.33	58	0
BHIRA T.R.	0.10	1.43	40	0
SMLHY_PTN	2.01	22.19	90	77
GHATGHAR	0.00	0.00	0	0
Total	4.37	45.12		
Wind				
Total	7.25	130.18	0	0
Total	7.25	130.18		
CPP				
APML(Mus)	75.13	749.83	0	0
JSWEL(Mus)	26.31	276.43	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.24	326.50	0	0
SWPGPL-Mus	10.42	110.40	0	0
Dhariwal	6.06	65.58	272	242
IEPL	4.92	56.16	250	196
Other(Mus)	29.12	343.65	0	0
Total	183.18	1928.55		
SOLAR				
Total	14.93	150.01	0	0
Total	14.93	150.01		
Tata				
Trombay 5	7.04	79.95	377	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.66	16.28	107	42
Trombay 7B	1.20	11.57	65	39
TATA Hydro	2.82	30.34	317	7
Trombay 8	3.55	41.12	185	131
Total	16.27	179.26		
AEML				
DTPS U-1&2	11.50	121.25	499	389
Total	11.50	121.25		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	168.54	1808.62	MSPGCL Total	183.95	1952.36
			MSPGCL Thml+Gas	173.07	1854.25	Koyna 1,2 & 4 Total	5.28	42.33
			MSPGCL Hydro	10.87	98.12	State Total	417.07	4461.62

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 11/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6933	220	205	7358	362	7528	0	0	6871	6660	-1394	20142	0	20142	2427	372	22941	49.94
2	7051	306	206	7563	370	7574	0	0	6549	6429	-1255	20346	0	20346	2272	336	22953	49.92
3	7198	255	205	7658	417	7567	0	0	6548	6283	-1156	20441	0	20441	2154	328	22923	49.97
4	7258	155	208	7621	502	7543	0	0	6759	6129	-1077	20406	0	20406	2057	312	22775	49.99
5	7283	155	205	7643	572	7617	0	0	6771	6514	-1069	20934	0	20934	2039	343	23316	50.00
6	7271	440	209	7920	580	7808	0	0	6707	6639	-1080	21481	0	21481	2109	385	23976	49.98
7	7288	1132	209	8629	522	7870	0	19	6753	6573	-995	22203	0	22203	2172	415	24790	50.02
8	7307	1158	208	8673	422	7862	0	277	6811	6712	-986	22532	0	22532	2252	428	25212	50.04
9	7186	379	209	7774	311	7616	0	861	8003	7734	-1323	22524	0	22524	2418	448	25391	50.01
10	7011	468	167	7646	295	7595	0	1476	8187	7937	-1415	23082	0	23082	2673	452	26207	50.01
11	6961	416	173	7550	326	7522	0	1899	8747	8680	-1704	23811	0	23811	2909	463	27182	50.01
12	6677	634	169	7480	237	7493	0	2049	8734	8763	-1810	23762	0	23762	3009	450	27221	49.96
13	6442	530	172	7144	179	7432	0	2231	8792	8437	-1785	23173	0	23173	3007	465	26645	49.94
14	6291	360	173	6824	140	7385	0	2042	8976	9043	-1920	23068	0	23068	2898	446	26412	49.98
15	6757	374	172	7303	104	7390	0	1707	9030	9168	-2022	23224	0	23224	2962	426	26612	49.98
16	7074	449	171	7694	108	7528	0	1263	8924	9045	-1958	23220	0	23220	3030	460	26710	49.96
17	7207	234	182	7623	164	7627	0	806	8628	8522	-1713	22575	0	22575	2974	455	26003	50.00
18	7272	266	177	7715	163	7635	0	286	8132	8084	-1566	21869	0	21869	2888	448	25205	49.97
19	7210	363	182	7755	176	7786	0	15	7265	7434	-1491	21221	0	21221	2839	454	24514	49.95
20	7135	1318	187	8640	219	7809	0	0	6828	6958	-1337	21838	0	21838	2848	452	25137	50.02
21	6985	520	189	7694	249	7717	0	0	6851	6866	-1429	20657	0	20657	2733	440	23830	50.03
22	6964	272	186	7422	286	7701	0	0	6985	6598	-1434	20124	0	20124	2642	448	23215	50.04
23	6915	169	183	7267	256	7757	0	0	6834	7162	-1407	20604	0	20604	2576	431	23611	50.02
24	6859	299	192	7350	290	7813	0	0	6640	6804	-1382	20459	0	20459	2585	416	23460	49.97
MUs	168.54	10.87	4.54	183.95	7.25	183.18	0.00	14.93	181.32	179.17	-34.71	523.70	0.00	523.70	62.47	10.07	596.24	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Mar/2023

Position as on 6.30 Hrs of 12/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Koradi Unit-10	660	09/03/2023	11:11		Continued.	Boiler Tube Leakage	14/03/2023
MSPGCL	Nasik Unit 4	210	09/03/2023	15:55	12/03/2023	01:55	FD Fan Problem.	11/03/2023
MSPGCL	Nasik Unit 3	210	10/03/2023	15:22		Continued.	Axial shift high	17/03/2023
MSPGCL	Uran Unit B0	120	11/03/2023	09:02		Continued.	Bearing vibration high	25/03/2023
MSPGCL	Khaparkheda Unit 3	210	11/03/2023	20:07		Continued.	Boiler Tube Leakage	14/03/2023
MSPGCL	Chandrapur Unit 5	500	11/03/2023	23:36		Continued.	PA Fan problem	13/03/2023
IPP	Adani U-2	660	12/03/2023	18:02		Continued.	turbine left hand side MS drain leakage	15/03/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ EKTUNI	IntraState	11/03/2023	12:29	11/03/2023	18:30	PO	Diagnostic, Relay Testing & Routine Maintenance
400 KV LINE Outages/Trippings							
PADGHE - NAGOTHANE CKT - 1	IntraState	09/03/2023	09:30			PO	CB replacement work
DEEPNAGAR - THAPTI TANDA	IntraState	10/03/2023	20:46	11/03/2023	05:02	T	Tripped on distance protection
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	11/03/2023	06:54	11/03/2023	11:09	EO	To attend Hot Spot of 89C PG Isolator pad. (Line iso. Side Pad and CT side Pad)
GT-10 @ KORADI-2	IntraState	11/03/2023	12:41	11/03/2023	14:32		1) nut bolt tightning/clamp replacement of jumper connection of CT, Isolator & other equipment 2)Routine Bay maintenance work.
NEW KOYNA-KARAD CKT - 2	IntraState	11/03/2023	12:50	11/03/2023	20:06	PO	PID Faulty disc insulator replacement work & Cold line washing work
DABHOL - NAGOTHANE CKT - 1	IntraState	11/03/2023	13:03	11/03/2023	14:21	T	Tripped at Dabhol end only
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	11/03/2023	15:14	11/03/2023	18:22	HT	For load management
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	12/03/2023	11:31	12/03/2023	16:59	PO	Spacer replacement work
BABHALESHWAR - PADGHE CKT - 2	IntraState	12/03/2023	18:04	12/03/2023	23:10	EO	1) To attend the Hot Spot on Rph CT 149 deg , Yph CT 102 deg , Bph CT 92 deg . 2) Repair/replacement of Rph jumper between CT to gantry as conductor strand found broken .
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	11/03/2023	11:47	11/03/2023	13:05	PO	MTAMC work. No outage required only pemiission for shorting metering core to replace MFM meter
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	12/03/2023	10:40	12/03/2023	18:17	PO	The erection work 220kv D- type tower.
220 KV MAINBAY Outages/Trippings							
TBC @ HINJEWADI-1	IntraState	11/03/2023	10:45	11/03/2023	16:22	PO	Yearly bay maintenance work
220KV BUS SECTION 1	IntraState	11/03/2023	17:41	11/03/2023	18:48	PO	Diagnostic testing CRM, Timing test and tan delta test
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	11/03/2023	05:52	11/03/2023	06:25	T	AR successful at Nalasopara end, tripped at PG end
NALASOPARA - BOISAR PG	InterState	12/03/2023	09:49	12/03/2023	22:05	PO	Bay Maintenance Work & Line Maintenance Work
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
CTRLS - NET MAGIC GIS	IntraState	07/03/2023	12:43			T	Distance Protection.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	09/03/2023	15:27	12/03/2023	06:05	HT	H/T Due to load management.
PADGHE - KAMBA 2	IntraState	10/03/2023	14:37	11/03/2023	12:30	PO	220KV CGL make CB overhauling work by agency and bay maintenance.
WARDHA (PG) - BADNERA	IntraState	11/03/2023	02:44	11/03/2023	13:08	T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VERSOVA - GHODBUNDER	IntraState	11/03/2023	06:54	11/03/2023	11:38	PO	Lifting of Pier Cap by MMRDA between Span LS 276-LS 277 for metro 09 project.
PHALTAN MIDC - SWARAJ CO GEN	IntraState	11/03/2023	07:15	11/03/2023	20:25	PO	For shifting of 220kV Phaltan MIDC-Swaraj line from loc no.20-23
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	11/03/2023	07:30	11/03/2023	07:48	PO	For raising SF6 gas pressure.
SADAWAGHAPUR KARAD CKT 2	IntraState	11/03/2023	09:21	11/03/2023	13:45	PO	Cold washing of insulator
PETH- MUDSHINGI 1 LINE	IntraState	11/03/2023	09:44	11/03/2023	12:53	T	Tripped on Distance Protection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/03/2023	09:48	11/03/2023	12:48	PO	Replacement of old pilot insulator strings of R & Y ph at loc. No. 401.
CHAKAN (400KV) - VOLKSWAGEN	IntraState	11/03/2023	10:01	11/03/2023	16:56	PO	SCADA Trial and Commissioning work & Diagnostic testing work in opportunity outage
CHAKAN PH II - VOLKSWAGEN	IntraState	11/03/2023	10:02	11/03/2023	16:53	PO	SCADA Trial and Commissioning work & Diagnostic testing work in opportunity outage
BORIVALI - TARAPUR	IntraState	11/03/2023	12:42	11/03/2023	20:23	PO	Replacement of Rusted Hardware, conductor & old earthwire.
LONIKAND 2 - VSNL	IntraState	11/03/2023	14:39	11/03/2023	17:31	EO	1) Fixing of repair sleeve between loc No-16-17 (B ph) due to broken strands 2) Replacement of flashover string at loc no-08 (R ph). 3) Removal of internet wire which is stuck at BPh,Loc 26 .
JAMDE-DONDAICHA 1	IntraState	11/03/2023	15:08	11/03/2023	18:08	PO	Replacement of back up O/C E/F relay and bay maintenance work.
DASTURI-KANDALGAON LINE	IntraState	11/03/2023	16:40	11/03/2023	23:20	PO	Jumper replacement at Loc.No.197,Cold washing of insulator string,Outage tree cutting and other line maintenance work.
KARAD -MUDSHINGI CKT- 4	IntraState	11/03/2023	16:45	11/03/2023	18:03	T	Tripped on distance protection
MHAISAL - ALKUD	IntraState	11/03/2023	17:44	11/03/2023	19:08	PO	Disc replacement work at Loc No.22 R ph.
TALANDGE - MUDSHINGI CKT - 1	IntraState	11/03/2023	18:40	11/03/2023	21:26	PO	To attend hot spot observed in thermoscaning at loc no. 1 (R ph), M/C- 8 (B ph), M/C- 12 (Y ph).
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	11/03/2023	19:03	11/03/2023	19:35	HT	To control overdrawal
CHIKHALI-JALNA II	IntraState	12/03/2023	07:06	12/03/2023	18:35	PO	To Facilitate Outage on 400kv Akola ICT
CHIKHALI-JALNA I	IntraState	12/03/2023	07:06	12/03/2023	18:35	PO	To Facilitate Outage on 400kv Akola ICT
BADNERA - AMRAVATI	IntraState	12/03/2023	07:32	12/03/2023	18:24	PO	To Facilitate Outage on 400kv Akola ICT
BADNERA - NANDGAON PETH	IntraState	12/03/2023	07:32	12/03/2023	18:24	PO	To Facilitate Outage on 400kv Akola ICT
MAIN BUS - 1 @ BOISAR II	IntraState	12/03/2023	08:38	12/03/2023	16:21	PO	Bus Isolator R/M & other R/M Work.
BUS SECTION - 2 @ TROMBAY	IntraState	12/03/2023	09:25	12/03/2023	14:33	PO	1) Main Bus R ph Conductor binding work. & 2) Bus Section bay maintenance work.
BOISAR - VERSOVA	IntraState	12/03/2023	10:43	12/03/2023	12:08	HT	220kV A Bus Isolator maintenance during 220kV A Bus outage dt 12.03.2023.
KALWA - AIROLI KNOWLEDGE PARK	IntraState	12/03/2023	14:41	12/03/2023	17:36	PO	1] Diagnostic testing CT Tan Delta 2] Aux. Isolator maintenance work and 3] R & M work at 220KV AKP S/Stn.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY MSETCL TIE - 1	IntraState	12/03/2023	15:56	12/03/2023	20:59	PO	Attending gas leakage from A phase pole at Trombay MSETCL end.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/03/2023	11:09			EO	Replacement of Diverter shaft
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	11/03/2023	15:10	11/03/2023	16:30	EO	Attending red hot on HV (220 KV) side Y ph bushing stud
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	12/03/2023	12:20	12/03/2023	12:43	T	Tripped on Overload
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	12/03/2023	12:20	12/03/2023	15:35	T	Cable Diff. Protection
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
KHOPOLI - DAVDI	IntraState	10/03/2023	08:46			PO	Breaker O/H

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage