

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Mar/2024 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.708	1751.493	1) Gujrat	5.158	52.800
2) Hydro	16.051	97.531	2) Madhya Pradesh	12.225	136.892
3) Gas	7.215	71.415	3) Chattisgarh	3.950	46.630
Total MSPGCL	180.974	1920.439	4) Maharashtra	171.375	1874.422
B) 1) APLM	66.508	617.709	5) Goa (Amona)	-1.876	-20.434
2) JSWEL	27.312	284.852	Total	190.832	2090.310
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.451	319.951
4) RPL(AMT)	26.220	337.127	b) Mumbai Drawl	32.898	356.726
5) SWPGPL	12.337	125.042	c) MSEDCL Bilateral *	94.984	1068.691
6) Other IPP	46.001	513.129	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.451	319.951
C) 1) TPCL Thermal	11.427	116.977	Include PX	0.000	0.000
2) TPCL Hydro	5.284	39.900	Standby	0.000	0.000
3) TPCL Gas	3.446	37.844	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.229	93.447	1) MSEDCL	536.766	5747.400
D) STATE			2) Mumbai Discoms	62.284	644.890
1) Thermal	356.742	3839.776	3) Other Discoms	10.888	118.216
(A1+C1+C4+(B1-B6))			TOTAL STATE	609.938	6510.506
2) Hydro	21.335	137.431			
(A2+C2)					
3) Gas	10.661	109.259			
(A3+B7+C3)					
4) Wind	13.263	144.338			
6) SOLAR	17.105	189.396			
TOTAL STATE	419.106	4420.200			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5743	6726	6872	6472
MSPGCL Hydro	1461	289	1811	195
MSPGCL Gas	281	280	378	305
MSPGCL Total Generation	7485	7295	9061	6972
Central Sector Receipt	8899	9427	7083	6996
WIND	208	209	542	861
CPP / IPP Thermal	7113	7516	7886	7028
CPP / IPP Gas	0	0	0	0
SOLAR	2367	1557	0	0
Exchange with Mumbai	-1641	-1865	-1154	-1039
MSEDCL DEMAND MET	23925	23645	22933	20469
Load Shedding	0	0	261	0
MSEDCL DEMAND	23925	23645	23194	20469
TPCL GENERATION	1055	893	1260	555
AEML GENERATION	500	340	502	291
MUMBAI DEMAND	3196	3098	2916	1885
OTHER DISCOM DEMAND	506	494	485	349
STATE DEMAND MET	27627	27237	26334	22703
STATE DEMAND	27627	27237	26595	22703
Frequency (Hz)	49.99	49.97	49.96	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 18:02 Hrs	49.73 Hz at 22:08 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.39	47.00	190	170
Unit 8	13.21	151.98	600	416
Unit 9	0.00	105.92	0	0
Unit 10	10.99	129.24	466	450
Total	28.60	434.13		
Bhusawal				
Unit 3	4.03	36.26	185	135
Unit 4	11.60	107.40	500	350
Unit 5	0.00	82.11	0	0
Total	15.63	225.77		
Parli				
Unit 6	4.86	43.78	250	145
Unit 7	4.70	42.89	248	140
Unit 8	0.92	22.79	228	0
Total	10.48	109.46		
Chandrapur				
Unit 3	3.46	34.52	150	135
Unit 4	1.28	24.61	167	0
Unit 5	9.88	87.39	430	340
Unit 6	10.32	88.64	455	380
Unit 7	9.75	89.08	449	308
Unit 8	9.72	99.55	420	334
Unit 9	11.35	98.56	490	403
Total	55.77	522.36		
Paras				
Unit 3	5.58	59.94	242	221
Unit 4	5.63	61.95	242	226
Total	11.22	121.90		
Khaparkheda				
Unit 1	4.14	39.04	180	160
Unit 2	4.30	41.29	200	155
Unit 3	3.96	40.53	176	153
Unit 4	4.24	42.51	189	147
Unit 5	11.79	105.80	500	465
Total	28.42	269.17		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.98	38.90	183	119
Unit 5	3.62	29.82	161	128
Total	7.60	68.71		
Uran				
All Units	7.22	71.42	378	274
Total	7.22	71.42		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	0.93	47	0
Total	0.12	0.93		
Koyna				
Stage 1-2	3.56	20.02	470	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.96	14.99	787	0
Stage 3	1.98	8.12	240	0
Total	10.50	43.12		
Hydro				
KDPH	0.86	9.50	36	36
VTRNA	0.66	7.06	60	0
TILLARI	0.41	5.16	64	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.76	27.74	124	109
GHATGHAR	0.73	4.02	250	0
Total	5.42	53.49		
Wind				
Total	13.26	144.34	0	0
Total	13.26	144.34		
CPP				
APML(Mus)	66.51	617.71	0	0
JSWEL(Mus)	27.31	284.85	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.22	337.13	0	0
SWPGPL-Mus	12.34	125.04	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.14	65.00	267	246
Other(Mus)	35.36	401.88	0	0
JPL	4.50	46.25	211	166
Total	178.38	1877.86		
SOLAR				
Total	17.10	189.40	0	0
Total	17.10	189.40		
Tata				
Trombay 5	7.42	76.68	455	199
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.10	22.91	108	38
Trombay 7B	1.35	14.93	65	35
TATA Hydro	5.28	39.90	411	120
Trombay 8	4.00	40.30	239	132
Total	20.16	194.72		
AEML				
DTPS U-1&2	9.23	93.45	502	288
Total	9.23	93.45		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.71	1751.49	MSPGCL Total	180.97	1920.44
			MSPGCL Thml+Gas	164.92	1822.91	Koyna 1,2 & 4 Total	8.52	35.00
			MSPGCL Hydro	16.05	97.53	State Total	419.11	4420.20

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6300	196	305	6801	957	7091	0	0	7523	7035	-1193	20283	0	0	20283	2137	408	22828	49.98
2	6387	191	305	6883	942	6979	0	0	7230	7363	-1146	20648	0	0	20648	1999	373	23020	49.98
3	6472	195	305	6972	861	7028	0	0	6983	6996	-1039	20469	0	0	20469	1885	349	22703	49.97
4	6530	197	305	7032	925	7130	0	0	7036	6902	-969	20663	0	0	20663	1823	357	22843	50.00
5	6610	205	306	7121	948	7163	0	0	7167	7184	-943	21124	0	0	21124	1806	349	23279	49.98
6	6581	569	307	7457	951	7224	0	0	7561	7657	-1032	21879	0	0	21879	1921	378	24178	49.99
7	6628	1202	308	8138	898	7411	0	18	7368	7395	-954	22485	0	6	22485	2101	421	25007	49.98
8	6599	1736	306	8641	713	7557	0	325	7288	7375	-877	23280	0	1	23280	2309	454	26043	50.03
9	6552	736	298	7586	470	7622	0	1048	8144	8095	-1215	23110	0	0	23110	2631	496	26237	50.01
10	6288	657	292	7237	368	7217	0	1661	9086	9131	-1574	23543	0	0	23543	2899	497	26939	49.94
11	6568	984	283	7835	271	7346	0	2097	9475	8239	-1579	23713	0	319	23713	3103	496	27312	50.01
12	5743	1461	281	7485	208	7113	0	2367	9253	8899	-1641	23925	0	527	23925	3196	506	27627	49.99
13	6112	838	275	7225	147	6997	0	2342	9252	9218	-1867	23560	0	8	23560	3143	502	27205	49.95
14	6354	298	276	6928	146	7284	0	2288	8873	8966	-1817	23304	0	8	23304	3007	491	26802	49.95
15	6489	280	274	7043	158	7091	0	2057	9434	9652	-1862	23662	0	8	23662	3055	477	27194	50.02
16	6726	289	280	7295	209	7516	0	1557	9590	9427	-1865	23645	0	5	23645	3098	494	27237	49.97
17	6764	478	284	7526	311	7731	0	987	9243	8994	-1801	23246	0	7	23246	3094	502	26842	49.98
18	6747	804	286	7837	319	7788	0	350	8510	8366	-1729	22418	0	5	22418	3021	513	25952	50.03
19	6701	1269	350	8320	428	7878	0	8	7623	7464	-1299	22285	0	0	22285	2956	514	25755	49.99
20	6872	1811	378	9061	542	7886	0	0	7227	7083	-1154	22933	261	0	23194	2916	485	26595	49.96
21	6968	800	327	8095	608	7888	0	0	7432	7189	-1274	22028	0	0	22028	2752	478	25258	49.99
22	6931	407	291	7629	518	7856	0	0	7458	7300	-1426	21398	0	0	21398	2573	479	24450	49.95
23	6897	244	295	7436	649	7733	0	0	7693	7360	-1382	21340	0	0	21340	2470	456	24266	49.92
24	6889	204	298	7391	716	7849	0	0	7599	7542	-1260	21824	0	0	21824	2389	414	24627	49.98
MUs	157.71	16.05	7.21	180.97	13.26	178.38	0.00	17.10	194.05	190.83	-32.90	536.77	0.26	0.89	537.03	62.28	10.89	610.20	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR Carried out due to 132kV BBLR - Rahuri Line Over Load Alarm at 132kV Rahuri s/stn.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Mar/2024

Position as on 6.30 Hrs of 12/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29	11/03/2024	18:17	For open cycle No schedule from MSEDCL.	
MSPGCL	Parli Unit 8	250	07/03/2024	03:06	11/03/2024	16:01	Air heater problem	11/03/2024
MSPGCL	Chandrapur Unit 4	210	08/03/2024	10:00	11/03/2024	13:20	SUSPECTED BTL	11/03/2024
MSPGCL	Koradi Unit 9	660	09/03/2024	13:49		Continued.	SUSPECTED BTL	14/03/2024
MSPGCL	Bhusawal Unit 5	500	09/03/2024	22:00		Continued.	Boiler Tube Leakage	12/03/2024
MSPGCL	Ghatghar Unit-1	125	11/03/2024	18:40		Continued.	GM Link Fault	
MSPGCL	Koyna STG-IV Unit-3	250	11/03/2024	18:40	11/03/2024	19:35	Auxiliary Transformer Fault.	
MSPGCL	Ghatghar Unit-2	125	11/03/2024	18:55	11/03/2024	19:35	GM Link Fault	
MSPGCL	Uran Unit 6	108	11/03/2024	20:26		Continued.	For open cycle No schedule from MSEDCL.	
Total Capacity MSPGCL		2456						
IPP								
IPP	Adani U-5	660	08/03/2024	06:27	11/03/2024	05:35	Mill inlet bellow leakage	11/03/2024
IPP	RPL(AMT) U-5	270	11/03/2024	03:00		Continued.	Air heater problem	18/03/2024
Total Capacity IPP		930						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3706						
FORCED OUTAGE DUE TO NO PPA								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Mar/2024

Position as on 6.30 Hrs of 12/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 11/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Tripping							
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	IntraState	11/03/2024	12:33	11/03/2024	18:54	PO	Annual Maintenance of CB at Koradi-III SS.
400 KV TIEBAY Outages/Tripping							
TBC @ PADGHE	IntraState	06/03/2024	12:01			PO	1. Replacement of CT with New ratio of 3000/1 Amp. 2. Diagnostic Testing work. 3. Bay Maintenance Work.
TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	IntraState	08/03/2024	09:56			PO	Replacement of non-PIR CB by with PIR CB
400 KV MAINBAY Outages/Tripping							
BUS COUPLER @ CHANDRAPUR	IntraState	11/03/2024	13:46			PO	1. For attending the high CRM problem of CB by excuting the pole overhauling work. 2.Measurement of tandelta & capacitance of CT. 3. Bay routine maintenance work
400 KV LR Outages/Tripping							
400KV RPL LINE REACTOR @ 400KV KORADI	IntraState	11/03/2024	09:25	11/03/2024	17:55	PO	Retrofitting of old YTG33 Backup Impedance relay by New GE make P443
400 KV LINE Outages/Tripping							
CHAKAN - TALEGAON(PG)	InterState	11/03/2024	10:28	11/03/2024	10:53	T	Line tripped on distance protection at Chakan end only.
LONIKAND I - TALEGAON (PGCIL)	InterState	11/03/2024	10:28	11/03/2024	11:37	T	Line tripped on distance protection.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
KORADI-NANDGAONPETH (RPL)	IntraState	11/03/2024	08:30	11/03/2024	09:25	PO	400kV RPL line to be hand tripped for taking Line Reactor out of service; there after 400kV RPL Line to be charged without reactor.
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	11/03/2024	16:38	11/03/2024	20:53	PO	-
KORADI-NANDGAONPETH (RPL)	IntraState	11/03/2024	17:15	11/03/2024	17:55	PO	400kV RPL line to be hand tripped for taking Line Reactor in Service.
KORADI-NANDGAONPETH (RPL)	IntraState	12/03/2024	01:15	12/03/2024	08:02	T	The tripping was initiated in zone 2 by the relay under normal condition while the zone 1 protection of the relay did not pick up.
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV MAINBAY Outages/Trippings							
220 KV BUS SECTION II	IntraState	11/03/2024	11:28	11/03/2024	17:50	HT	1) 220kv isolator alignment and maintenance work. 2) diagnostic and routine maintenance work of 100mva 220/132kv ict-ii(measurment of hv/lv bushing tan-delta, winding tandelta,etc) 220kv phumabri bhokardan, 220/132kv,100mva ict-ii 220/33kv 25mva ptr-ii h/t.
220KV BUSBAR PROTECTION	IntraState	11/03/2024	12:56	11/03/2024	18:15	HT	For relay testing work by protection unit, yavatmal at 220/132/33 kv pandharkawada substation.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kv Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kv cable at 220kv Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kv KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kv Karad-Koyana line
KHARGHAR - BORIVALI CKT - 2	IntraState	10/03/2024	23:23	11/03/2024	08:09	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KALWA - BORIVALI	IntraState	10/03/2024	23:26	11/03/2024	08:14	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
GIS BHANDUP - BORIVALI	IntraState	10/03/2024	23:29	11/03/2024	08:28	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
BORIVALI - CTRLS CKT	IntraState	10/03/2024	23:38	11/03/2024	08:20	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
220 KV DEVGAONRANGARI - BABHALESHWAR CKT	IntraState	11/03/2024	08:10	11/03/2024	15:16	HT	Outage at bableshwar end.
BABHALESHWAR - DEOGAON RANGARI	IntraState	11/03/2024	08:21	11/03/2024	15:16	PO	Replacement of old disc insulator with long rod .
132 KV CHITEGAON - GARWARE CKT	IntraState	11/03/2024	12:50	11/03/2024	14:05	HT	Attending hotspot observed on rphase ct jump.
VILE BHAGAD - KANDHALGAON	IntraState	11/03/2024	14:37	11/03/2024	19:42	PO	1.Diagnostic testing work at vilebhagad S/s end & K'gaon S/s end 2.Realy testing work by testing team kandalgaon
KARAD - KADEGAON	IntraState	11/03/2024	16:22	11/03/2024	20:38	PO	Replacement of faulty disc Insulator Strings at various locations
132 KV HINGOLI - KURUNDA CKT	IntraState	11/03/2024	17:05	11/03/2024	22:40	HT	Attend broken earth wire near kurunda.
132 KV HINGOLI (220 KV) - ELICHPUR CKT	IntraState	11/03/2024	17:07	11/03/2024	22:37	HT	Attend broken earth wire near kurunda.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 12/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BABLESHWAR-BABLESHWAR(400KV)-I	IntraState	11/03/2024	18:29	12/03/2024	00:04	PO	Replacement of the old disc insulator with long rod polymer under scheme.
BELEWADI - MUMEWADI LINE	IntraState	12/03/2024	06:11			PO	Reorientation work at Mumewadi s/S.
MUMEWADI -HALKARNI 1 LINE	IntraState	12/03/2024	06:21			PO	Reorientation work at Mumewadi s/S.
220 KV ICT Outages/Trippings							
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	IntraState	05/03/2024	07:40			PO	ICI 1 overhauling ,Testing ,CRP replacement of CPLR 1-2 ,ICT 1
220/132 KV 100 MVA ICT 2 @ CHITEGAON	IntraState	11/03/2024	10:35	11/03/2024	14:27	HT	Carry out sfra & routine maint. work.
220/22 KV 50 MVA PTR 3 @ RANJANGAON	IntraState	11/03/2024	12:10			PO	For 220KV A-Bus Isolator (29A) alingnment work by Hot line unit method. . During Outage load of said bay will be transferred to 220KV TBC bay
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	11/03/2024	09:02	11/03/2024	18:23	PO	For earthwire replacement & other Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
AMBERNATH - KALYAN CKT - 2	IntraState	11/03/2024	13:00	11/03/2024	16:18	PO	Closer inspection
AMBERNATH - KALYAN CKT - 1	IntraState	11/03/2024	16:48	11/03/2024	18:32	PO	Closing loops at loc. 10 OFA North side after completion of above said job by Kalyan Node.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage