

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Apr/2015 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	127.067	1363.759	1) Gujrat	0.099	0.153
2) Hydro	14.466	243.636	2) Madhya Pradesh	14.079	184.530
3) Gas	3.463	52.567	3) Chattisgarh	3.120	60.990
Total MSPGCL	144.996	1659.962	4) Maharashtra Net	93.485	963.087
B) 1) APML	42.750	506.150	5) Goa	-7.816	-76.354
2) JSWEL	19.849	244.632	6) TAPS 1&2 Injection	3.543	39.893
3) VIPL	11.852	126.852	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	5.380	86.239	8) Pench (MS)	0.000	0.611
5) WPCL	2.512	29.752	9) Pench (Excess)	0.000	-0.611
6) Other IPP	7.597	93.913	Total	106.510	1171.688
C) 1) TPCL Thermal	16.436	203.730	a) Mumbai Schedule	21.173	243.578
2) TPCL Hydro	4.886	40.188	b) Mumbai Drawl	23.774	249.650
3) TPCL Gas	2.157	26.547	c) MSEDCL Bilateral *	22.350	246.410
4) R-INFRA Thermal	11.431	129.994	Include PX	-0.425	-23.926
D) STATE			d) Mumbai Bilateral *	21.173	243.578
1) Thermal	244.874	2785.021	Include PX	0.017	2.224
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	19.352	283.824	H) ENERGY CATERED (MUs)		
3) Gas	5.620	79.114	1) MSEDCL	326.308	3811.008
4) Wind	7.797	126.934	2) Mumbai Discoms	58.682	650.108
6) SOLAR	0.839	13.925	TOTAL STATE	384.990	4461.116
TOTAL STATE	278.482	3288.818			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	5477	5626	5002	5035
MSPGCL Hydro	1744	1483	421	810
MSPGCL Gas	143	140	144	145
MSPGCL Total Generation	7364	7249	5567	5990
Central Sector Receipt	4830	4883	4593	4081
WIND	53	176	470	374
CPP / IPP	3971	3808	3722	3525
SOLAR	96	142	0	0
Exchange with Mumbai	-1074	-1074	-1277	-1231
MSEDCL DEMAND MET	15240	15184	13075	12739
Load Shedding	39	39	32	32
MSEDCL DEMAND	15279	15223	13107	12771
TPCL GENERATION	1299	1296	1040	752
R-INFRA GENERATION	516	517	378	379
MUMBAI DEMAND	2889	2887	2695	2362
STATE DEMAND MET	18129	18071	15770	15101
STATE DEMAND	18168	18110	15802	15133
Frequency (Hz)	49.94	49.91	49.96	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.23 Hz at 06.02 Hrs	49.6 Hz at 00.12 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Apr/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	3.47	25.16	175	129
Unit 6	0.00	0.00	0	0
Unit 7	3.54	43.66	175	130
Total	7.01	68.82		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	3.88	44.32	180	140
Unit 4	10.83	107.35	505	375
Unit 5	9.95	109.01	500	290
Total	24.66	260.68		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	2.93	20.88	146	97
Unit 5	3.59	37.20	152	146
Unit 6	4.85	52.20	250	187
Unit 7	3.34	50.98	250	0
Total	14.71	161.27		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.18	35.52	137	130
Unit 3	4.60	50.13	204	169
Unit 4	1.63	44.26	171	0
Unit 5	9.68	108.61	420	365
Unit 6	9.50	104.66	420	362
Unit 7	9.00	101.75	432	295
Total	37.59	444.94		
Paras				
Unit 3	4.59	53.67	225	127
Unit 4	4.98	21.63	224	193
Total	9.57	75.30		
Khaparkheda				
Unit 1	4.16	46.06	190	155
Unit 2	0.00	0.44	0	0
Unit 3	0.00	11.38	0	0
Unit 4	4.63	27.90	198	189
Unit 5	11.21	124.11	502	375
Total	19.99	209.89		
Nasik				
Unit 3	4.61	50.70	195	185
Unit 4	4.45	49.63	192	176
Unit 5	4.49	42.54	193	177
Total	13.55	142.87		
Uran				
All Units	3.46	52.57	149	138
Total	3.46	52.57		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.00	0.61	0	0
Total	0.00	0.61		
Koyna				
Stage 1-2	2.61	61.58	415	40
Stage 4	5.20	92.47	979	0
Stage 3	1.92	33.75	240	0
Total	9.73	187.80		
Hydro				
KDPH	0.44	7.08	19	18
VTRNA	1.07	12.11	61	0
TILLARI	0.37	4.03	64	0
BHTGR/VEER	0.05	0.63	3	2
BHIRA T.R.	0.29	2.08	80	0
RNGR+BHTSA	0.29	2.61	13	12
BHANDARDRA	0.46	5.40	44	10
ELDARY	0.00	0.72	0	0
SMLHY_PTN	0.98	10.80	41	40
GHATGHAR	0.79	10.36	250	0
Total	4.74	55.84		
Wind				
Total	7.80	126.93	0	0
Total	7.80	126.93		
CPP				
APML(Mus)	42.75	506.15	0	0
JSWEL(Mus)	19.85	244.63	0	0
VIPL(Mus)	11.85	126.85	0	0
RPLAMT(Mus)	5.38	86.24	0	0
WPCL(Mus)	2.51	29.75	0	0
Other(Mus)	7.60	93.91	0	0
Total	89.94	1087.54		
SOLAR				
Total	0.84	13.92	0	0
Total	0.84	13.92		
Tata				
Trombay 5	10.70	120.08	494	319
Trombay 6	0.00	19.93	0	0
Trombay 7A	1.20	14.79	50	49
Trombay 7B	0.96	11.76	41	39
Trombay 8	5.74	63.72	251	201
TATA Hydro	4.89	40.19	471	0
Total	23.48	270.46		
R-INFRA				
1-2	11.43	129.99	520	378
Total	11.43	129.99		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	127.07	1363.76
MSPGCL Thml+Gas	130.53	1416.33

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	14.47	243.64
MSPGCL Total	145.00	1659.96

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	7.81	154.05
State Total	278.48	3288.82

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Apr/2015

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	5294	644	147	6085	456	3877	0	4161	4107	-887	13638	69	13707	2320	16027	49.76
2	5233	315	147	5695	398	3797	0	4320	4049	-776	13163	39	13202	2149	15351	49.93
3	5149	272	147	5568	287	3837	0	4410	4235	-702	13225	39	13264	2017	15281	49.92
4	5124	257	147	5528	325	3862	0	4352	4289	-579	13425	39	13464	1925	15389	49.95
5	5163	218	147	5528	307	3782	0	4237	4150	-530	13237	39	13276	1878	15154	49.93
6	5328	223	148	5699	297	3911	0	4412	4407	-579	13735	39	13774	1926	15700	49.98
7	5466	348	149	5963	179	3815	0	4460	4871	-608	14220	39	14259	1954	16213	50.05
8	5469	683	149	6301	69	3898	22	4566	4607	-649	14248	39	14287	2019	16306	50.03
9	5548	1064	145	6757	53	3793	48	4711	4608	-764	14495	39	14534	2251	16785	49.95
10	5522	1370	145	7037	48	3785	77	4790	4472	-927	14492	39	14531	2564	17095	50.00
11	5531	1741	144	7416	27	3976	77	4850	4532	-1108	14920	39	14959	2854	17813	49.91
12	5477	1744	143	7364	53	3971	96	4898	4830	-1074	15240	39	15279	2889	18168	49.94
13	5626	1483	140	7249	176	3808	142	4957	4883	-1074	15184	39	15223	2887	18110	49.91
14	5660	925	138	6723	313	3730	131	4967	4688	-1065	14520	41	14561	2769	17330	49.95
15	5676	280	138	6094	531	3705	133	4967	4850	-1122	14191	30	14221	2788	17009	49.92
16	5483	157	138	5778	681	3637	63	4736	4347	-1140	13366	30	13396	2791	16187	49.98
17	5130	162	142	5434	482	3613	36	4469	4354	-1162	12757	30	12787	2737	15524	49.99
18	4953	191	142	5286	462	3523	13	4160	4344	-1242	12386	30	12416	2659	15075	50.03
19	4961	302	142	5405	391	3537	1	4030	3961	-1247	12048	32	12080	2597	14677	50.02
20	5002	421	144	5567	470	3722	0	4729	4593	-1277	13075	32	13107	2695	15802	49.96
21	5065	280	145	5490	515	3767	0	4936	4470	-1369	12873	32	12905	2628	15533	50.01
22	5091	198	146	5435	503	3511	0	4516	4298	-1395	12352	32	12384	2555	14939	49.98
23	5080	378	145	5603	400	3558	0	4013	4485	-1267	12779	32	12811	2470	15281	49.90
24	5035	810	145	5990	374	3525	0	3843	4081	-1231	12739	32	12771	2362	15133	49.96
MUs	127.07	14.47	3.46	144.99	7.80	89.94	0.84	108.49	106.51	-23.77	326.31	0.89	327.20	58.68	385.88	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Apr/2015

Position as on 6.30 Hrs of 12/Apr/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Parli Unit 3	210	13/02/2013	23:50		Continued.	Water Shortage	
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling Work. (60 Days)	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Renovation and Modification work	
MSPGCL	Khaparkheda Unit 2	210	01/04/2015	03.16		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	WPCL U-2	135	18/02/2014	00.02		Continued.	Ash conveying Problem	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	PA Fan Vibration Problem	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
CPP	WPCL U-1	135	30/10/2014	00.43	11/04/2015	19.31	ESP Bag Filter Damaged	
CPP	WPCL U-4	135	18/03/2015	02.34		Continued.	Withdrawn	
IPP	RPL(AMT) U-1	270	21/03/2015	23.28		Continued.	Turbine vibration high.	
MSPGCL	Chandrapur Unit-8	500	29/03/2015	18.26		Continued.	Withdrawn	
MSPGCL	Koradi Unit-8	660	30/03/2015	20.22		Continued.	BLR Tripped.	
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage	
MSPGCL	Uran Unit 8	108	01/04/2015	17.50		Continued.	Gas shortage	
IPP	RPL(AMT) U-4	270	03/04/2015	11.42		Continued.	Boiler feed Pump problem.	
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.	
MSPGCL	Uran Unit A0	120	04/04/2015	14.38		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	04/04/2015	14.39		Continued.	Gas shortage	
CENT.SECTOR	TARAPUR-3	540	04/04/2015	20.15		Continued.	Reheater Problem	
MSPGCL	Khaparkheda Unit 3	210	04/04/2015	22.52		Continued.	Gland Steam Temp. High.	
IPP	RPL(AMT) U-3	270	05/04/2015	22.01		Continued.	Governor AVR Problem.	
MSPGCL	Koyna Unit 10	80	06/04/2015	08.15	11/04/2015	20.10	To attend leakages.	
TPC-G	Trombay 6	500	06/04/2015	16.27		Continued.	Economic shut down.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Apr/2015

Position as on 6.30 Hrs of 12/Apr/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	Adani U-2	660	09/04/2015	15.50		Continued.	Boiler feed Pump Problem.	
MSPGCL	Koyna Unit 7	80	10/04/2015	10.20		Continued.	Defector servomotor Replacement Work.	
MSPGCL	Chandrapur Unit 4	210	10/04/2015	18.37	11/04/2015	11.58	Station Board Tripped.	
IPP	JSW (J) U1	300	11/04/2015	13.53	11/04/2015	18.50	Generator CT Problem.	
MSPGCL	Parli Unit 7	250	11/04/2015	16.25	12/04/2015	02.25	Auxiliary supply failure	
IPP	WPCL U-3	135	11/04/2015	23.56		Continued.	ID Fan Vibration Problem.	
MSPGCL	Chandrapur Unit 5	500	12/04/2015	14.38		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2015

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Wardha(PG)-Aurangabad(PG)- II	InterState	28/03/2015	12.37		Continued.	PO	For Construction Crossing & Swapping Work of Comissioning of New 765kv Wardha-A'bad 3&4 for 3 Days.
Wardha PG - Aurangabad PG IV	IntraState	03/04/2015	21.57		Continued.	HT	Over Voltage
400 KV LINE Outages/Trippings							
Akola II - RPL(Rattanindia) Ckt I	InterState	07/04/2015	00.27		Continued.	T	Over Current Protection
Kolhapur Mapusa I	InterState	10/04/2015	17.55	11/04/2015	07.11	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	10/04/2015	22.19	11/04/2015	07.02	HT	Over Voltage
Kolhapur Mapusa I	InterState	11/04/2015	16.28		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	11/04/2015	18.17		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt-II	InterState	11/04/2015	19.35		Continued.	T	Distance Protection
Kolhapur Solapur(PG) I	InterState	12/04/2015	18.21		Continued.	HT	Over Voltage
Babhaleshwar-Taptitanda ckt-I	IntraState	08/04/2015	22.45		Continued.	HT	HT For Controlling 400KV BABLESHWER - PADGHA
Chandrapur - Khaperkheda	IntraState	10/04/2015	09.18	12/04/2015	15.16	PO	Strining of Conductor Between 765kv Raipur-Wardha 2 line (2 days).
karad -kolhapur-I	IntraState	10/04/2015	16.34	11/04/2015	07.51	HT	Over Voltage
Karad-Jaigad - I	IntraState	10/04/2015	17.02	11/04/2015	08.36	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	10/04/2015	17.44	11/04/2015	08.48	HT	Over Voltage
Chandrapur - Khaperkheda	IntraState	11/04/2015	09.18	11/04/2015	15.16	PO	Opportunity Outage for Relay Testing.
Bhusawal-Aurangabad	IntraState	11/04/2015	11.02	11/04/2015	13.30	PO	PID Work.
Karad - Lonikand 1	IntraState	11/04/2015	13.20	11/04/2015	14.20	T	Distance Protection
karad -kolhapur-II	IntraState	11/04/2015	17.14	12/04/2015	08.51	HT	Over Voltage
Karad-Jaigad - I	IntraState	11/04/2015	17.36	12/04/2015	08.55	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	11/04/2015	17.57	12/04/2015	09.33	HT	Over Voltage
Akola-Indiabulls	IntraState	11/04/2015	19.35	11/04/2015	21.28	T	Distance Protection
Lonikand I - Koyna stage-IV	IntraState	12/04/2015	03.00	12/04/2015	07.23	HT	Over Voltage
Akola-Indiabulls	IntraState	12/04/2015	1352	12/04/2015	14.35	T	Distance Protection
karad -kolhapur-II	IntraState	12/04/2015	16.16		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	12/04/2015	16.33		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	12/04/2015	17.03		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	12/04/2015	17.19		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220 KV 315 MVA ICT- I @Koradi	IntraState	10/04/2015	21.21	11/04/2015	13.02	T	NDR.
400/220 Kv 500 MVA ICT II @Lamboti	IntraState	11/04/2015	01.25	11/04/2015	04.45	T	NDR.
400/220kv, 500 Mva Ict-2 @Deepnagar	IntraState	11/04/2015	08.43	11/04/2015	18.17	PO	Attending Persisting CTR Indication and Testing Work.
400/220kv 315 Mva ICT I @Karad	IntraState	11/04/2015	13.39	11/04/2015	14.42	T	NDR Operated
400/220/33 Kv 315 Mva Ict 2 @Babhleshwar	IntraState	11/04/2015	15.05	11/04/2015	16.35	T	220kv A Bus LBB Operated.
400/220/33 Kv 315 Mva Ict 1 @Babhleshwar	IntraState	11/04/2015	15.05	11/04/2015	16.09	T	220kv A Bus LBB Operated.
400/220kv, 500 Mva Ict-3 @Babhleshwar	IntraState	11/04/2015	15.05	11/04/2015	15.38	T	Over Loading.
400/220 Kv 600 Mva Ict-2 @Kalwa	IntraState	11/04/2015	18.11	11/04/2015	18.22	T	Buccholz Protection Optd
400/220/33 315mva Ict @Khadka	IntraState	11/04/2015	21.35	11/04/2015	23.10	PO	R-Phase Wdg. High.
220 KV LINE Outages/Trippings							

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2015

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Nasik Navsari I	InterState	10/04/2015	18.23		Continued.	HT	From Nashik end to Control Bus section Loading.
TBC @ Parli-II	IntraState	07/01/2015	15.48		Continued.	PO	Shifting of control panel
Sahara-Urse	IntraState	03/03/2015	11.06		Continued.	PO	Tower erection work (90Days)
Trombay - Kalwa	IntraState	19/03/2015	14.27		Continued.	PO	Pannel Replacemen Work(Outage for 8 Days).open at location 14 b
Waluj - Degaon Rangari	IntraState	31/03/2015	21.40	11/04/2015	15.24	HT	handtripped
Chandrapur Gcr - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Chandrapur Gcr - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Umred-Virangana 1	IntraState	11/04/2015	10.20	11/04/2015	19.30	PO	Tan Delta Measurment of CTs
Mahad - Pedambe	IntraState	11/04/2015	10.20	11/04/2015	20.00	PO	Cold Line Washing.
Babhaleshwar-Nagar-I	IntraState	11/04/2015	10.43	11/04/2015	23.10	PO	Making LILO arrangement for Jeur S/S.
Hinjawadi I- Chinchwad	IntraState	11/04/2015	10.48	11/04/2015	18.12	HT	Over Voltage
Babhaleshwar - Degaon Rangari	IntraState	11/04/2015	15.05		Continued.	T	R-Ph Fault , Pole Stuck up . Cause of LBB Operated.
Chalisingaon -Babhaleshwar	IntraState	11/04/2015	15.05	11/04/2015	15.57	T	220kv A Bus LBB Operated.
Eklahara(Gcr)(Nasik)- Bableswhar-I	IntraState	11/04/2015	15.05	11/04/2015	16.27	T	220kv A Bus LBB Operated.
Bableswhar -Bhenda	IntraState	11/04/2015	15.05	12/04/2015	18.43	T	220kv A Bus LBB Operated.
Bableswhar- Bableswhar-II	IntraState	11/04/2015	15.05	11/04/2015	15.40	T	220kv A Bus LBB Operated.
Bableswhar- Bableswhar-I	IntraState	11/04/2015	15.05	11/04/2015	16.20	T	220kv A Bus LBB Operated.
Eklahara(Gcr)(Nasik)- Bableswhar 2	IntraState	11/04/2015	15.05	11/04/2015	15.55	T	220kv A Bus LBB Operated.
Parli New Tps - Beed Ckt 2	IntraState	11/04/2015	16.26	11/04/2015	19.37	T	220kv Bus I Bus Bar Protn. Operated.
Arli 3(Old Gcr)-Parli Newtps Ckt 1	IntraState	11/04/2015	16.26	11/04/2015	19.35	T	220kv Bus I Bar Protn. Operated.
Parli 3 (Old Gcr)-Osmanabad	IntraState	11/04/2015	16.58	11/04/2015	19.28	T	Distance Protection
Bhugaon-Pusad	IntraState	11/04/2015	19.13	11/04/2015	19.30	T	Distance Protection
Kharghar Trombay	IntraState	12/04/2015	12.49	12/04/2015	20.01	PO	Conductor Repl.work.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Monkey Fault
220/100 Kv 200 Mva Emco Ict 2 @Kolshet	IntraState	11/04/2015	10.27	11/04/2015	18.06	PO	Routine Maintenance Work
220/132 Kv 200 Mva Vijay Elect Ict 2 @Kalmeshwar	IntraState	12/04/2015	07.50	12/04/2015	08.50	T	132KV Bus Bar Prot.Optd.
132 KV LINE Outages/Trippings							
Kalmeshwar-Saoner 2	IntraState	12/04/2015	07.50	12/04/2015	08.47	T	132KV Bus Bar Prot.Optd.
Kalmeshwar-Katol	IntraState	12/04/2015	07.50	12/04/2015	08.40	T	132KV Bus Bar Prot.Optd.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage