

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Apr/2019 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	137.589	1601.090	1) Gujrat	0.743	12.205
2) Hydro	29.298	181.215	2) Madhya Pradesh	15.795	173.900
3) Gas	6.913	72.924	3) Chattisgarh	4.510	48.200
Total MSPGCL	173.800	1855.229	4) Maharashtra	129.245	1293.042
B) 1) APLM	68.337	824.879	5) Goa (Amona)	-0.418	-5.346
2) JSWEL	24.975	255.337	Total	149.875	1522.001
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.328	313.451
4) RPL(AMT)	12.655	128.991	b) Mumbai Drawl	29.179	334.182
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	21.882	157.755
6) Other IPP	14.261	149.611	Include PX	-3.638	-83.340
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.328	313.451
C) 1) TPCL Thermal	16.465	160.420	Include PX	20.444	217.168
2) TPCL Hydro	4.624	40.616	Standby	0.000	0.000
3) TPCL Gas	4.202	45.478	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.741	114.046	1) MSEDCL	436.464	4674.967
D) STATE			2) Mumbai Discoms	66.211	694.746
1) Thermal	286.023	3234.374	TOTAL STATE	502.675	5369.713
(A1+C1+C4+(B1-B6))					
2) Hydro	33.922	221.831			
(A2+C2)					
3) Gas	11.115	118.402			
(A3+B7+C3)					
4) Wind	14.676	194.885			
6) SOLAR	7.064	78.216			
TOTAL STATE	352.800	3847.708			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5872	5746	5713	5642
MSPGCL Hydro	1811	2023	1367	369
MSPGCL Gas	270	281	285	292
MSPGCL Total Generation	7953	8050	7365	6303
Central Sector Receipt	6553	6594	6171	5969
WIND	445	505	635	659
CPP / IPP Thermal	4718	4801	4917	5163
CPP / IPP Gas	0	0	0	0
SOLAR	915	640	0	0
Exchange with Mumbai	-1521	-1566	-1334	-765
MSEDCL DEMAND MET	19063	19024	17754	17329
Load Shedding	0	0	0	0
MSEDCL DEMAND	19063	19024	17754	17329
TPCL GENERATION	1252	1246	1134	825
AEML GENERATION	499	500	500	483
MUMBAI DEMAND	3272	3312	2968	2073
STATE DEMAND MET	22335	22336	20722	19402
STATE DEMAND	22335	22336	20722	19402
Frequency (Hz)	49.97	50.00	49.92	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 13.01 Hrs	49.78 Hz at 02.46 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Apr/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.02	42.74	180	150
Unit 7	0.00	0.00	0	0
Unit 8	8.71	95.53	405	340
Unit 9	0.00	0.00	0	0
Unit 10	8.64	111.57	460	300
Total	21.37	249.83		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	103.16	0	0
Unit 5	11.83	120.40	500	470
Total	11.83	223.57		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.70	59.22	249	199
Total	5.70	59.22		
Chandrapur				
Unit 3	4.61	46.09	195	184
Unit 4	4.38	48.13	188	180
Unit 5	9.79	109.16	416	400
Unit 6	0.00	0.00	0	0
Unit 7	10.41	115.86	447	420
Unit 8	11.04	117.03	480	440
Unit 9	11.20	123.67	480	455
Total	51.42	559.95		
Paras				
Unit 3	6.07	63.13	256	250
Unit 4	4.53	63.29	250	0
Total	10.60	126.41		
Khaparkheda				
Unit 1	2.44	40.76	115	80
Unit 2	3.92	30.00	170	155
Unit 3	4.52	47.83	193	168
Unit 4	4.57	46.22	193	190
Unit 5	11.62	120.41	500	460
Total	27.07	285.22		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.86	48.78	210	163
Unit 5	4.73	48.11	205	158
Total	9.60	96.89		
Uran				
All Units	6.91	72.92	305	270
Total	6.91	72.92		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.09	1.42	22	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.09	1.42		
Koyna				
Stage 1-2	7.93	61.80	540	55
Stage 4	13.30	56.99	1000	0
Stage 3	4.61	26.49	320	80
Total	25.84	145.28		
Hydro				
KDPH	0.86	9.45	36	36
VTRNA	0.99	10.58	61	0
TILLARI	0.54	5.01	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.23	2.03	40	0
RNGR+BHTSA	0.28	3.12	12	11
BHANDARDRA	0.00	0.62	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.38	4.32	16	15
GHATGHAR	0.18	0.81	116	0
Total	3.46	35.94		
Wind				
Total	14.68	194.88	0	0
Total	14.68	194.88		
CPP				
APML(Mus)	68.34	824.88	0	0
JSWEL(Mus)	24.98	255.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	12.66	128.99	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	14.26	149.61	0	0
Total	120.23	1358.82		
SOLAR				
Total	7.06	78.22	0	0
Total	7.06	78.22		
Tata				
Trombay 5	11.07	104.10	479	372
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.65	28.72	117	79
Trombay 7B	1.55	16.75	67	55
Trombay 8	5.39	56.32	235	201
TATA Hydro	4.62	40.62	398	0
Total	25.29	246.51		
AEML				
DTPS U-1&2	11.74	114.05	502	385
Total	11.74	114.05		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	137.59	1601.09	MSPGCL Total	173.80	1855.23
			MSPGCL Thml+Gas	144.50	1674.01	Koyna 1,2 & 4 Total	21.23	118.78
			MSPGCL Hydro	29.30	181.22	State Total	352.80	3847.71

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Apr/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5469	877	300	6646	817	5509	0	0	5844	5989	-1111	17850	0	17850	2592	20442	50.00
2	5507	734	290	6531	570	5274	0	0	6150	6096	-964	17507	0	17507	2365	19872	49.98
3	5571	547	289	6407	645	5229	0	0	6045	6120	-840	17561	0	17561	2200	19761	49.90
4	5642	369	292	6303	659	5163	0	0	5935	5969	-765	17329	0	17329	2073	19402	49.94
5	5597	389	303	6289	684	5188	0	0	5907	6019	-725	17455	0	17455	2031	19486	49.97
6	5659	1133	295	7087	552	5186	0	0	5937	6204	-755	18274	0	18274	2069	20343	49.96
7	5834	1332	295	7461	560	5437	0	19	6095	6322	-757	19042	0	19042	2142	21184	49.97
8	5865	869	305	7039	464	5343	0	199	6244	6382	-883	18544	0	18544	2282	20826	50.03
9	5852	490	291	6633	485	5235	0	477	6372	6405	-1150	18085	0	18085	2575	20660	49.99
10	5818	1033	289	7140	419	4896	0	715	6478	6767	-1482	18455	0	18455	2920	21375	49.97
11	5881	1578	285	7744	438	4871	0	847	6532	6415	-1634	18681	0	18681	3170	21851	50.02
12	5872	1811	270	7953	445	4718	0	915	6646	6553	-1521	19063	0	19063	3272	22335	49.97
13	5817	1779	280	7876	324	4837	0	941	6665	6548	-1541	18985	0	18985	3284	22269	50.04
14	5794	1471	280	7545	291	4817	0	874	6595	6731	-1477	18781	0	18781	3190	21971	49.99
15	5747	1779	279	7805	380	4788	0	822	6648	6767	-1514	19048	0	19048	3259	22307	49.93
16	5746	2023	281	8050	505	4801	0	640	6700	6594	-1566	19024	0	19024	3312	22336	50.00
17	5715	2104	273	8092	519	4815	0	429	6548	6570	-1498	18927	0	18927	3256	22183	50.02
18	5698	1665	283	7646	535	4798	0	174	6532	6331	-1435	18049	0	18049	3130	21179	50.07
19	5686	1124	284	7094	666	4799	0	12	6409	6328	-1300	17599	0	17599	2978	20577	50.00
20	5713	1367	285	7365	635	4917	0	0	6219	6171	-1334	17754	0	17754	2968	20722	49.92
21	5790	1298	288	7376	840	4897	0	0	5765	5679	-1252	17540	0	17540	2866	20406	49.95
22	5770	941	287	6998	1240	4916	0	0	5601	5458	-1201	17411	0	17411	2762	20173	49.93
23	5814	1090	299	7203	1121	4903	0	0	5507	5537	-1227	17537	0	17537	2765	20302	49.95
24	5732	1495	290	7517	882	4891	0	0	5594	5920	-1247	17963	0	17963	2750	20713	49.95
MUs	137.59	29.30	6.91	173.80	14.68	120.23	0.00	7.06	148.97	149.87	-29.18	436.46	0.00	436.46	66.21	502.67	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Apr/2019

Position as on 6.30 Hrs of 12/Apr/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30	12/04/2019	22.10	Zero Schedule	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 6	500	20/02/2019	22.07		Continued.	Rotor Earth Fault	
MSPGCL	Koradi Unit 9	660	31/03/2019	15.13		Continued.	Furnace Pressure High	
IPP	RPL(AMT) U-1	270	06/04/2019	00.00	12/04/2019	22.58	No Schedule By MSEDCL.	
MSPGCL	Bhusawal Unit 4	500	10/04/2019	12.44	12/04/2019	12.45	Boiler Tube Leakage	
MSPGCL	Paras Unit 4	250	10/04/2019	22.16	11/04/2019	01.48	Drum Level High Protection.	
IPP	Adani U-2	660	11/04/2019	11.08		Continued.	Boiler stop valve bonnet leakage	
MSPGCL	Parli Unit 8	250	12/04/2019	06.11	12/04/2019	11.15	Drum level High.	
MSPGCL	Khaparkheda Unit 1	210	12/04/2019	08.35	12/04/2019	09.56	AIR FLOW LOW PROTECTION.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Apr/2019

Position as on 6.30 Hrs of 12/Apr/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 3	210	12/04/2019	12.25		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit-8	500	12/04/2019	15.24	12/04/2019	19.17	BUS BAR OPERATED AT CHANDRAPUR 2 S/S & DUE TO HEAVY ELECTRICAL JERK.	
IPP	Dhariwal	300	12/04/2019	15.25	12/04/2019	19.14	BUS BAR OPERATED AT CHANDRAPUR 2 S/S & DUE TO HEAVY ELECTRICAL JERK.	
MSPGCL	Chandrapur Unit 9	500	12/04/2019	15.25	12/04/2019	20.49	BUS BAR OPERATED AT CHANDRAPUR 2 S/S & DUE TO HEAVY ELECTRICAL JERK.	
MSPGCL	Nasik Unit 4	210	12/04/2019	21.35		Continued.	R PHASE CT CUBAICAL BURST	
MSPGCL	Khaparkheda Unit 1	210	12/04/2019	21.59		Continued.	AIR FLOW LOW PROTECTION.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 11/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
Koradi-III - Akola-II ckt-I	IntraState	12/04/2019	09.43	12/04/2019	12.27	PO	SF6 Gas Analysis Breakers.
765 KV ICT Outages/Tripping							
765/400KV 1500MVA ICT II @ Ektuni	IntraState	12/04/2019	11.50	12/04/2019	15.08	PO	Testing Work & Routine Maintenance Work.
400 KV LINE Outages/Tripping							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	10/04/2019	17.54		Continued.	HT	Over Voltage
Dabhol New koyna I	InterState	12/04/2019	11.06	12/04/2019	12.53	EO	LE Scheme.
Dabhol Nagothane I	InterState	12/04/2019	13.17	12/04/2019	20.30	PO	Insulator String Replacement & Cold Washing Work.
Chandrapur Bhadravati IV	InterState	12/04/2019	14.33	12/04/2019	17.02	T	DT RECEIVED C.B ON AT CHANDRAPUR END.
Lamboti - Solapur (PG)	InterState	12/04/2019	18.26	12/04/2019	19.13	T	Distance Protection B-Ph, E/F.
Khadka-Aurangabad (Waluj)	IntraState	10/04/2019	18.16	11/04/2019	08.56	HT	Over Voltage
Kala Kudus Ckt-II	IntraState	11/04/2019	06.25	11/04/2019	16.31	T	Distance Protection Zone 1 Y phase
Deepnagar Taptitanda	IntraState	11/04/2019	06.36	11/04/2019	20.04	PO	Replacement Of Faulty Dead End & Mid Span Joint.
Khadka - Bableshtar	IntraState	11/04/2019	07.46	11/04/2019	18.08	PO	Replacement Of R-Ph Conductor Of 400KV Deepnagar T.T. CKT.
Chandrapur-Parali III	IntraState	11/04/2019	10.26	11/04/2019	19.00	PO	Replacement Of Broken Spacer Cum Vibration Damper.
Kalwa - Talegaon(PG)	IntraState	11/04/2019	16.13	11/04/2019	18.54	EO	Replacement of decapped R-Phase pilot string at LOC. no.180.
Bhusawal-Aurangabad	IntraState	11/04/2019	20.13	12/04/2019	11.32	HT	Over Voltage
Deepnagar Taptitanda	IntraState	12/04/2019	06.52	12/04/2019	14.41	PO	Routine Maintenance Work
Karad - Talandge Ckt 2	IntraState	12/04/2019	09.09	12/04/2019	15.16	PO	Replacement Of Faulty Insulator String Found In PID.
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	12/04/2019	11.59		Continued.	T	Over Voltage
Deepnagar - Aurangabad	IntraState	12/04/2019	12.50	12/04/2019	13.29	T	Due To DC Leakage.
Girwali- Lonikand 2	IntraState	12/04/2019	17.48		Continued.	EO	Retrofitting Of Distance Relay.
Bhusawal-Aurangabad	IntraState	12/04/2019	18.00		Continued.	HT	Over Voltage
Chandrapur-Parali III	IntraState	12/04/2019	18.18		Continued.	T	Distance Protection
400 KV ICT Outages/Tripping							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 315 MVA ICT -I @Kharghar	IntraState	26/03/2019	11.02		Continued.	PO	Overhauling work
400/220kv 315 Mva ICT II @Karad	IntraState	08/04/2019	09.03	12/04/2019	18.56	PO	OLTC Overhauling Work.
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	11/04/2019	06.43	11/04/2019	15.35	PO	Quarterly Maintainance Work
400/220KV 500MVA ICT1@koradi 2	IntraState	12/04/2019	07.30	12/04/2019	13.49	PO	Testing Work
400/220/33 Kv 315 MVA ICT-II @Waluj	IntraState	12/04/2019	12.50	12/04/2019	13.19	T	Due To DC Leakage.
400/220/33 Kv 315 MVA ICT-I @Waluj	IntraState	12/04/2019	12.50	12/04/2019	13.17	T	Due To DC Leakage
400/220/33 Kv 500 Mva Ict 1 @Chandrapur 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
220 KV LINE Outages/Tripping							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Borivali - Tarapur	InterState	12/04/2019	09.10	12/04/2019	18.00	PO	Testing Work
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	No 86 & 107 And De-energising The Line Bet.86 To 107. For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Adlabs - Pedambe	IntraState	08/04/2019	10.25	11/04/2019	12.00	PO	Preventive Maintenance Work.
Uran - Kharghar 2	IntraState	09/04/2019	11.08	11/04/2019	14.33	PO	Carrying out Reorientation of said line
Parli New Tps - Beed Ckt 2	IntraState	10/04/2019	04.15	11/04/2019	16.25	PO	Restraining Work OF Conductor Railway Crossing.
Kalwa - Mulund 2	IntraState	11/04/2019	04.44	12/04/2019	10.05	EO	Red Hot Spot Attending Work.
Jamde-Dondaicha 1	IntraState	11/04/2019	07.15	11/04/2019	10.20	PO	Testing Work
Pohali-Nerle	IntraState	11/04/2019	08.30	11/04/2019	10.35	PO	Replacement Of conductor At Loc 46B
Ghodbunder - Gorai	IntraState	11/04/2019	08.58	11/04/2019	16.14	EO	Attending Hot Spot
Chalisgaon - Deepnagar	IntraState	11/04/2019	09.04	11/04/2019	12.52	PO	Bay Maint.Work Diagnostic Testing Work.
Hamidwada-Mumewadi	IntraState	11/04/2019	12.35	11/04/2019	15.27	PO	Relay testing and hot spot attending work.
Dondaicha- Shahada	IntraState	11/04/2019	14.33	11/04/2019	15.10	T	Distance Protection PDR Operated PH AR Successful.
Uran - Kharghar I	IntraState	11/04/2019	15.58	11/04/2019	21.28	PO	Conductor Broken, taken in service.
Kanhan-Umred 1	IntraState	11/04/2019	20.50	11/04/2019	21.13	T	Distance Protection Z1,18.5KM,Y-B PH,IF 2.13KA & 2.09KA.
BHUGAON WARORA CKT-II	IntraState	11/04/2019	22.25	12/04/2019	01.54	T	BHUGAON=Distance Protection operated, 1.5KM,IF=15KA,B-E Wrore=Distance Protection operated. B-E,Z1.65.3KM.2.36KA.
Butibori-VIPL-IV GIS Bay	IntraState	11/04/2019	22.27	11/04/2019	23.31	T	Butibori=Distance Protection Operated,B-E,0.27KA,AR Optd.C.B On VIPL= Line Differential protection Operated.B-
Jamde-Dondaicha 2	IntraState	12/04/2019	06.41	12/04/2019	09.45	PO	TAN DELTA MEASUREMENT OF CT, TAN DELTA OF CT BAY MAINTENANCE WORK.
Badnera - Nandgaonpeth	IntraState	12/04/2019	08.27	12/04/2019	12.12	PO	ATTENDING HOT SPOT ON LINE AND LINE SIGNATURE ANALYSIS.
Sawantwadi-Bidri	IntraState	12/04/2019	09.10	12/04/2019	18.00	PO	For Insulator Cleaning.
Temghar - Kalwa	IntraState	12/04/2019	09.47	12/04/2019	17.29	PO	Testing Work & Attending Hot Spot.
Uran - Jnpt	IntraState	12/04/2019	11.25	12/04/2019	15.52	PO	Flash Over String Replacement.
Bhugaon-WardhaPG (Deoli)	IntraState	12/04/2019	11.40	12/04/2019	13.33	PO	Y-PHASE LA REPLACEMENT.
Dhule-Chalisagaon	IntraState	12/04/2019	11.57	12/04/2019	12.42	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Bucholz Trip.
220/110 Kv 200 MVA ICT-III @Kolhapur-II (Mudshingi)	IntraState	05/04/2019	10.03		Continued.	PO	Quarterly Maintainance Work
220/132 KV ICT-2 @Nagar	IntraState	05/04/2019	10.45	11/04/2019	13.20	PO	oil Filtration.
220/22kV 100MVA T/F-I @ Nalasopara	IntraState	11/04/2019	05.25	11/04/2019	16.20	T	Differential protection
220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	IntraState	11/04/2019	08.36	11/04/2019	13.25	PO	OLTC OIL Top Up.
220/132 Kv 100 Mva Cgl Ict 1 @Amalner	IntraState	11/04/2019	09.28	11/04/2019	11.28	EO	C.T.Hot Spot Attending Work.
220/132 Kv 200 MVA ICT-III @Girwali	IntraState	11/04/2019	10.50	11/04/2019	21.46	PO	Testing Work
220/33kV 100 MVATransformer 2 @Versova R/S	IntraState	11/04/2019	10.55	11/04/2019	19.36	PO	Attending Oil Leakage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	12/04/2019	07.48	12/04/2019	10.33	PO	TO CHANGE OIL OF OLTC.
220/132kv 150MVA ICT-II @ Bhenda	IntraState	12/04/2019	08.48	12/04/2019	20.05	PO	For R PH LV Bushing And Oil Filtration Work.
220/33KV 50MVA T/F -II @BoiserII	IntraState	12/04/2019	14.44	12/04/2019	17.22	PO	Earthing Work.
132 KV LINE Outages/Trippings							
Mansar Pench	InterState	07/03/2019	15.40		Continued.	HT	Hand trip Form Pench end for system requirment.
Kanhan-Pench	IntraState	22/01/2019	18.44		Continued.	HT	After Completion of Outage.
Deepnagar- Nimbhora	IntraState	11/04/2019	12.59	11/04/2019	13.59	T	Distance Protection Z1 R PH 9.99KA 5.9KM.
Lupin -Boiser	IntraState	11/04/2019	19.25	12/04/2019	21.25	T	Y-Phase CT & Breaker Brust Due To Which BB Operated.
lol - Boisar Midc	IntraState	11/04/2019	21.00	12/04/2019	02.53	T	Y-Phase CT Smoke Observed, Hence 100 MW Load Curt led.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage