

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Apr/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	155.025	1803.250	1) Gujrat	-4.637	-49.610
2) Hydro	45.576	399.647	2) Madhya Pradesh	8.979	112.816
3) Gas	6.624	69.608	3) Chattisgarh	4.270	54.050
Total MSPGCL	207.225	2272.505	4) Maharashtra	150.166	1790.897
B) 1) APML	76.293	830.376	5) Goa (Amona)	-1.879	-19.033
2) JSWEL	20.661	200.330	Total	156.899	1889.120
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.935	322.594
4) RPL(AMT)	31.544	334.566	b) Mumbai Drawl	32.790	355.760
5) SWPGPL	9.410	99.642	c) MSEDCL Bilateral *	65.172	758.978
6) Other IPP	33.464	382.775	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.897	322.550
C) 1) TPCL Thermal	16.284	171.730	Include PX	0.000	0.000
2) TPCL Hydro	4.456	37.477	Standby	0.038	0.044
3) TPCL Gas	4.155	34.056	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.769	127.322	1) MSEDCL	512.771	5798.750
D) STATE			2) Mumbai Discoms	69.454	726.348
1) Thermal	354.450	3949.991	3) Other Discoms	9.423	98.748
(A1+C1+C4+(B1-B6))			TOTAL STATE	591.648	6623.846
2) Hydro	50.032	437.124			
(A2+C2)					
3) Gas	10.779	103.664			
(A3+B7+C3)					
4) Wind	10.873	145.603			
6) SOLAR	8.615	98.341			
TOTAL STATE	434.749	4734.723			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6161	6162	6599	6407
MSPGCL Hydro	2229	2006	2267	2090
MSPGCL Gas	267	266	268	292
MSPGCL Total Generation	8657	8434	9134	8789
Central Sector Receipt	8673	8893	5853	4992
WIND	191	267	429	713
CPP / IPP Thermal	6936	6968	7009	7072
CPP / IPP Gas	0	0	0	0
SOLAR	1153	1015	0	0
Exchange with Mumbai	-1953	-1870	-1268	-933
MSEDCL DEMAND MET	23360	23415	20852	20468
Load Shedding	319	853	781	305
MSEDCL DEMAND	23679	24268	21633	20773
TPCL GENERATION	988	993	1267	823
AEML GENERATION	489	477	500	501
MUMBAI DEMAND	3430	3340	3035	2257
OTHER DISCOM DEMAND	430	426	438	293
STATE DEMAND MET	27220	27181	24325	23018
STATE DEMAND	27539	28034	25106	23323
Frequency (Hz)	50.00	49.82	49.70	49.91

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 18.02 Hrs	49.48 Hz at 06.01 Hrs	49.92	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.01	38.58	190	95
Unit 7	0.00	0.00	0	0
Unit 8	13.30	149.97	601	462
Unit 9	14.13	150.25	607	560
Unit 10	0.00	60.94	0	0
Total	31.43	399.74		
Bhusawal				
Unit 3	3.29	14.76	145	125
Unit 4	3.92	100.54	375	0
Unit 5	9.20	104.88	425	355
Total	16.41	220.17		
Parli				
Unit 6	4.32	41.96	187	173
Unit 7	4.12	43.19	186	166
Unit 8	3.34	37.58	152	132
Total	11.78	122.73		
Chandrapur				
Unit 3	4.54	49.11	192	185
Unit 4	4.07	44.60	173	166
Unit 5	8.23	96.48	380	314
Unit 6	7.27	71.49	315	295
Unit 7	8.76	97.38	394	334
Unit 8	10.97	115.19	462	439
Unit 9	10.19	111.68	433	409
Total	54.02	585.92		
Paras				
Unit 3	5.35	58.70	238	208
Unit 4	4.96	55.07	222	189
Total	10.31	113.77		
Khaparkheda				
Unit 1	3.16	35.22	155	120
Unit 2	3.14	36.38	145	120
Unit 3	3.62	43.29	190	128
Unit 4	3.77	42.88	180	130
Unit 5	10.92	118.42	475	430
Total	24.63	276.19		
Nasik				
Unit 3	2.58	40.12	196	0
Unit 4	3.86	44.62	187	116
Unit 5	0.00	0.00	0	0
Total	6.44	84.74		
Uran				
All Units	6.62	69.61	293	246
Total	6.62	69.61		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.22	1.52	37	0
Total	0.22	1.52		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	9.07	81.43	540	40
Stage 4	21.60	177.18	1020	200
Stage 3	6.91	55.39	320	152
Total	37.58	314.00		
Hydro				
KDPH	0.84	9.43	35	35
VTRNA	0.81	7.97	59	0
TILLARI	0.35	5.01	58	0
BHIRA T.R.	0.22	1.78	77	0
SMLHY_PTN	5.27	59.65	225	214
GHATGHAR	0.30	0.30	125	0
Total	7.78	84.13		
Wind				
Total	10.87	145.60	0	0
Total	10.87	145.60		
CPP				
APML(Mus)	76.29	830.38	0	0
JSWEL(Mus)	20.66	200.33	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.54	334.57	0	0
SWPGPL-Mus	9.41	99.64	0	0
Other(Mus)	33.46	382.78	0	0
Total	171.37	1847.69		
SOLAR				
Total	8.62	98.34	0	0
Total	8.62	98.34		
Tata				
Trombay 5	10.98	115.70	476	435
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.61	20.13	114	77
Trombay 7B	1.54	13.93	66	55
TATA Hydro	4.46	37.48	403	27
Trombay 8	5.31	56.03	241	152
Total	24.90	243.26		
AEMIL				
DTPS U-1&2	11.77	127.32	502	467
Total	11.77	127.32		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	155.02	1803.25	MSPGCL Total	207.22	2272.50
			MSPGCL Thml+Gas	161.65	1872.86	Koyna 1,2 & 4 Total	30.67	258.60
			MSPGCL Hydro	45.58	399.65	State Total	434.75	4734.72

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 11/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6620	2095	282	8997	1180	7212	0	3	5571	5705	-1203	21563	0	21563	2730	331	24624	50.01
2	6441	2099	282	8822	828	7201	0	0	5415	5601	-1082	21044	0	21044	2538	326	23908	49.99
3	6431	2089	281	8801	759	7207	0	0	5118	5539	-968	21035	319	21354	2381	303	24038	49.94
4	6407	2090	292	8789	713	7200	0	0	5195	4992	-933	20468	305	20773	2257	293	23323	49.91
5	6403	2102	293	8798	704	7232	0	0	5032	5242	-841	20832	226	21058	2213	303	23574	49.98
6	6476	1914	273	8663	678	7250	0	0	5064	5207	-873	20594	844	21438	2317	331	24086	50.02
7	6624	1973	293	8890	664	7230	0	26	5188	5313	-968	20787	651	21438	2368	368	24174	50.04
8	6755	1966	293	9014	486	7178	0	203	5439	5568	-1085	20965	0	20965	2469	399	23833	50.05
9	6848	1106	281	8235	237	7180	0	523	6484	6683	-1421	21019	0	21019	2758	418	24195	50.00
10	6723	1201	280	8204	171	7125	0	827	7356	7696	-1667	21937	0	21937	3096	419	25452	49.89
11	6321	2066	269	8656	126	7141	0	1074	7829	8209	-1852	22917	308	23225	3326	437	26988	49.98
12	6161	2229	267	8657	191	7069	0	1153	8024	8673	-1953	23360	319	23679	3430	430	27539	50.00
13	6157	1481	267	7905	164	6858	0	1216	9146	9351	-1962	23103	0	23103	3432	429	26964	50.01
14	6227	1559	246	8032	205	6813	0	1151	9256	9355	-1850	23288	33	23321	3264	418	27003	50.02
15	6162	2006	266	8434	267	7102	0	1015	8127	8893	-1870	23415	853	24268	3340	426	28034	49.82
16	6176	1907	266	8349	285	7125	0	808	6954	7156	-1716	21574	1926	23500	3367	433	27300	49.76
17	6197	1902	266	8365	292	7105	0	424	6659	6721	-1596	20881	1271	22152	3293	430	25875	49.76
18	6304	1724	269	8297	304	7151	0	170	6140	6206	-1442	20254	1216	21470	3185	432	25087	49.92
19	6409	1894	268	8571	320	7107	0	22	5645	6004	-1285	20291	587	20878	3050	448	24376	49.75
20	6599	2267	268	9134	429	7142	0	0	5531	5853	-1268	20852	781	21633	3035	438	25106	49.70
21	6656	1895	280	8831	503	7135	0	0	5509	5609	-1255	20397	619	21016	2975	426	24417	49.90
22	6622	2039	281	8942	420	7176	0	0	5518	5611	-1201	20541	579	21120	2889	407	24416	49.92
23	6642	2127	270	9039	484	7207	0	0	5667	5888	-1221	20987	596	21583	2865	410	24858	49.86
24	6664	1845	291	8800	463	7226	0	0	5807	5824	-1278	20667	451	21118	2876	368	24362	49.96
MUs	155.02	45.58	6.62	207.23	10.87	171.37	0.00	8.62	151.67	156.90	-32.79	512.77	11.88	524.66	69.45	9.42	603.53	49.92

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Apr/2022

Position as on 6.30 Hrs of 12/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	11/03/2022	01:25	12/04/2022	06:05	TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.(PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22)	12/04/2022
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Nasik Unit 5	210	22/03/2022	23:40		Continued.	Withdrawn	
MSPGCL	Uran Unit B0	120	01/04/2022	19:02	12/04/2022	16:29	Filter Replacement work.(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Uran Unit 8	108	01/04/2022	19:21	12/04/2022	09:35	Filter Replacement work.(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Koradi Unit-10	660	07/04/2022	08:08		Continued.	Condenser Cleaning work.	
MSPGCL	Bhusawal Unit 4	500	11/04/2022	00:44	11/04/2022	05:15	HP bypass impulse line leakage work	
MSPGCL	Bhusawal Unit 4	500	11/04/2022	10:17	11/04/2022	13:07	Low furnace pressure	
MSPGCL	Nasik Unit 3	210	11/04/2022	10:24	11/04/2022	19:30	GENERATOR SEAL HYDROGEN LEAKAGE	
MSPGCL	Bhusawal Unit 4	500	11/04/2022	13:53	11/04/2022	17:12	Flame Failure	
MSPGCL	Uran Unit 6	108	12/04/2022	17:29		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
400 KV AKOLA - AURANGABAD(PG) CKT -1	InterState	12/04/2022	19:52	12/04/2022	22:37	HT	EMERGENCY OUTAGE AVAILABLE AT PG END FOR ATTENDING HOT SPOT
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	29/03/2022	13:28			T	HT FOR LOAD MANAGEMENT
CHANDRAPUR 2 - DHARIWAL CKT - 1	IntraState	11/04/2022	09:19	11/04/2022	17:17	PO	For replacement of main BCU of 400KV Chandrapur2 - Dhariwal ckt. I at Dhariwal end
NAGOTHANE - DABHOL CKT - 1	IntraState	11/04/2022	13:32	11/04/2022	19:32	PO	Cold washing work
NAGOTHANE - DABHOL CKT - 1	IntraState	12/04/2022	14:36	12/04/2022	19:55	PO	Cold washing work
PARLI - KARJAT CKT - 2	IntraState	12/04/2022	18:15	12/04/2022	22:43	T	Distance protection
400 KV ICT Outages/Trippings							
400/220KV 105 MVA SPARE ICT @ KARAD	IntraState	23/03/2022	10:14			EO	Spare ICT -1 will be taken into service through RRS in place of ICT-I R ph unit due to rising trend of various gases in ICT-I R ph unit
167 MVA SPARE ICT @ TALANDGE	IntraState	09/04/2022	13:25			PO	Isolator, BPI erection for Rapid Restoration scheme at 400 KV Talandage S/stn.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	11/04/2022	09:01	11/04/2022	20:05	PO	400 KV BPI erection for R4pid Restoration scheme at 400 KV Tatandage S/s
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	12/04/2022	08:02	12/04/2022	16:04	PO	Diagnostic testing & Relay testing work & Routine maint. Work
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	11/04/2022	11:39	11/04/2022	13:36	PO	checking of CB compressor mechanism
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	12/04/2022	18:36		Continued.	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	CABLE FAULT
EKLAHARE (GCR) - GHATGHAR	IntraState	02/04/2022	12:29	11/04/2022	20:46	PO	Samruddhi Highway Monopole work, 13 No's (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	02/04/2022	12:51	11/04/2022	20:52	PO	Samruddhi Highway Monopole work, 13 No's (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
CHEMBUR (AEML) - NERUL (M)	IntraState	10/04/2022	13:41	11/04/2022	00:42	PO	To Check Non operation of Autorelclose of Nerul-Chembur(adani) line by personals from M/s Adani , M/s COSPHI and Testing team Kalwa.
BHIRA - KARANJADE 7	IntraState	11/04/2022	00:20	11/04/2022	03:51	PO	FOR TWFL CT AND PT WIRING
NIWALI - PAWAS LINE	IntraState	11/04/2022	02:09	11/04/2022	12:03	T	Distance Protection
BHIRA - KARANJADE 8	IntraState	11/04/2022	04:08	11/04/2022	06:48	PO	FOR TWFL CT AND PT WIRING
KADEGAON-MIRAJ	IntraState	11/04/2022	09:44	11/04/2022	20:34	PO	Tower painting
MUMEWADI -HALKARNI 1 LINE	IntraState	11/04/2022	09:48	12/04/2022	17:24	PO	For Overhauling of 245 KV CGL make Circuit Breaker & maintenance work.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - MUDSHINGI CKT - 1	IntraState	11/04/2022	10:09	11/04/2022	18:58	PO	1.QM Work Bay by S/S 2. Line maintenance Work by Line Sdn
TALANDGE - MUDSHINGI CKT - 1	IntraState	11/04/2022	10:09	11/04/2022	18:58	EO	For replacement of polymer pilot insulator strings of R phase jump by disc insulator strings at tower location nos. M/C 11. In stormy and heavy wind condition due to less weight of polymer insulator R phase jump swinging more towards cross arm. Sparking is observed to crossarm.
VITA - GHATNANDRE	IntraState	11/04/2022	11:22	11/04/2022	17:18	PO	Replacement of pilot string at Loc no.23 Y pH by HLU
WARDHA (PG) - BADNERA	IntraState	11/04/2022	13:15	11/04/2022	23:50	PO	For replacement of PT selection relay
MUDSHINGI - CHIKODI	IntraState	11/04/2022	14:55	11/04/2022	22:16	EO	1. Chemical washing planned for 100 locations 2. Arial Patrolling of Total 275 locations planned 3. Thermovision Target :- 100% 4. Earthing rennovation is planned for 50 locations
JEJURI (400 KV)-JEJURI- II	IntraState	11/04/2022	16:31	11/04/2022	20:30	EO	TO ATTEND HOTSPOT OF R & Y PH ISOLATOR
EKLAHARE (GCR) - GHATGHAR	IntraState	11/04/2022	16:42	11/04/2022	20:46	EO	Bunching is done at loc.no.107 towards Kalwa side so it's need to be remove before final charging.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/04/2022	16:42	11/04/2022	20:52	EO	Bunching is done at loc.no.107 towards Kalwa side so it's need to be remove before final charging.
PADGHE - JINDAL	IntraState	11/04/2022	23:15	12/04/2022	00:49	EO	1) For replacement of faulty Power Supply module of Backup Relay.
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	12/04/2022	05:38	12/04/2022	06:15	HT	H/T FROM SOLAPUR PG END ONLY TO CONTROL O/D AT LOW FREQUENCY.
TALOJA II - OCIL 1	IntraState	12/04/2022	08:03	12/04/2022	18:13	PO	220kV SF6 Circuit Breakers & Isolator maintenance
NEW KOYNA - NIWALI	IntraState	12/04/2022	12:18	12/04/2022	18:02	PO	For cold washing of insulator strings from Loc no 01 to 53(Niwali LILO Line), 56 to 195.
BOMBAY DYEING - SAHARA	IntraState	12/04/2022	13:05	12/04/2022	18:10	T	TRIPPED ON DIST.PROTN.
KANDALGAON - SONA ALLOYS	IntraState	12/04/2022	18:32		Continued.	EO	Damaged conductor to be attended at Loc.No.2B,15B,43B,46B,48B and other line maintenance work.
BHUGAON - WARDHA (PG)	IntraState	12/04/2022	19:15		Continued.	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	12/04/2022	19:18		Continued.	HT	H/T FOR HIGH O/D AT LOW FREQUENCY
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	12/04/2022	19:19		Continued.	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
WALUJ - CHITEGAON I	IntraState	12/04/2022	21:45		Continued.	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
OSMANABAD - PARLY (PG)	IntraState	12/04/2022	22:15		Continued.	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220 / 110 / 33KV 315 MVA ICT 6 @ CARNAC	IntraState	03/04/2022	11:00			PO	FOR SHIFTING ON NEW 110 KV GIS
220 / 11 KV 200 MVA GT @ BHIRA (T)	IntraState	11/04/2022	00:35	11/04/2022	05:15	PO	GT OIL TOP UP
220/33-33KV 100MVA TF NO. - 1 @ CHALKARANJI - II	IntraState	11/04/2022	09:15	11/04/2022	17:27	PO	1)Quarterly bay maintenance work 2) Bay diagnostic testing work 3) Replacement of OTI meter along with capillary tube. 4) Attending Oil Leakage
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	11/04/2022	15:23	11/04/2022	20:17	EO	For Oil leakage attending work
110 KV LINE Outages/Trippings							
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage