

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Apr/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	160.940	1741.429	1) Gujrat	-6.892	-42.012
2) Hydro	33.067	225.255	2) Madhya Pradesh	7.174	93.833
3) Gas	0.102	27.868	3) Chattisgarh	6.170	54.470
Total MSPGCL	194.109	1994.552	4) Maharashtra	182.765	1975.481
B) 1) APML	76.244	813.064	5) Goa (Amona)	-1.436	-15.242
2) JSWEL	26.214	263.469	Total	187.781	2066.530
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.009	352.706
4) RPL(AMT)	31.272	311.161	b) Mumbai Drawl	38.262	394.472
5) SWPGPL	12.325	119.817	c) MSEDCL Bilateral *	90.851	1058.634
6) Other IPP	21.366	250.815	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.009	352.706
C) 1) TPCL Thermal	14.466	117.810	Include PX	0.000	0.000
2) TPCL Hydro	7.211	53.143	Standby	0.000	0.000
3) TPCL Gas	3.306	27.691	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.383	116.772	1) MSEDCL	525.703	5623.074
D) STATE			2) Mumbai Discoms	74.628	709.888
1) Thermal	354.210	3734.337	3) Other Discoms	10.319	110.635
(A1+C1+C4+(B1-B6))			TOTAL STATE	610.650	6443.597
2) Hydro	40.278	278.398			
(A2+C2)					
3) Gas	3.408	55.559			
(A3+B7+C3)					
4) Wind	9.819	141.869			
6) SOLAR	15.154	166.904			
TOTAL STATE	422.869	4377.067			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6465	6750	6679	6726
MSPGCL Hydro	699	1090	1597	1895
MSPGCL Gas	19	0	0	0
MSPGCL Total Generation	7183	7840	8276	8621
Central Sector Receipt	9326	9898	7675	6243
WIND	183	160	557	527
CPP / IPP Thermal	6751	6733	7131	7081
CPP / IPP Gas	0	0	0	0
SOLAR	2089	1209	0	0
Exchange with Mumbai	-2205	-2081	-1485	-1026
MSEDCL DEMAND MET	22849	23285	21680	21126
Load Shedding	0	0	0	0
MSEDCL DEMAND	22849	23285	21680	21126
TPCL GENERATION	922	1145	1250	941
AEML GENERATION	440	448	482	488
MUMBAI DEMAND	3567	3674	3217	2455
OTHER DISCOM DEMAND	478	474	474	320
STATE DEMAND MET	26894	27433	25371	23901
STATE DEMAND	26894	27433	25371	23901
Frequency (Hz)	49.94	49.99	49.98	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 18.02 Hrs	49.62 Hz at 14.55 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.72	51.09	205	160
Unit 8	14.00	150.71	615	552
Unit 9	0.00	21.00	0	0
Unit 10	13.77	145.38	613	550
Total	32.49	368.17		
Bhusawal				
Unit 3	3.43	36.92	160	120
Unit 4	10.59	87.92	500	360
Unit 5	10.82	119.90	495	370
Total	24.84	244.74		
Parli				
Unit 6	5.50	55.09	250	147
Unit 7	5.41	51.97	248	144
Unit 8	4.32	42.35	192	147
Total	15.24	149.41		
Chandrapur				
Unit 3	3.83	41.39	168	140
Unit 4	0.00	23.71	0	0
Unit 5	9.61	98.61	410	359
Unit 6	9.48	95.98	415	335
Unit 7	10.27	103.52	446	395
Unit 8	11.42	121.62	487	444
Unit 9	11.18	71.73	481	440
Total	55.79	556.56		
Paras				
Unit 3	5.09	45.31	230	193
Unit 4	5.03	42.02	218	199
Total	10.11	87.33		
Khaparkheda				
Unit 1	3.06	32.24	135	125
Unit 2	2.57	24.74	120	91
Unit 3	4.32	46.18	184	177
Unit 4	4.48	46.54	192	174
Unit 5	0.00	101.02	0	0
Total	14.43	250.70		
Nasik				
Unit 3	4.07	43.75	181	155
Unit 4	3.97	12.46	180	137
Unit 5	0.00	28.30	0	0
Total	8.04	84.51		
Uran				
All Units	0.10	27.87	77	0
Total	0.10	27.87		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	1.49	46	0
Total	0.15	1.49		
Koyna				
Stage 1-2	7.88	55.66	540	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	15.24	91.68	1034	0
Stage 3	5.53	31.49	320	0
Total	28.64	178.83		
Hydro				
KDPH	0.83	9.36	35	34
VTRNA	1.20	12.99	60	0
TILLARI	0.00	1.82	0	0
BHIRA T.R.	0.41	2.93	80	0
SMLHY_PTN	1.84	17.84	79	75
GHATGHAR	0.00	0.00	0	0
Total	4.28	44.93		
Wind				
Total	9.82	141.87	0	0
Total	9.82	141.87		
CPP				
APML(Mus)	76.24	813.06	0	0
JSWEL(Mus)	26.21	263.47	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.27	311.16	0	0
SWPGPL-Mus	12.32	119.82	0	0
Dhariwal	6.36	64.95	300	238
IEPL	5.64	55.90	268	198
Other(Mus)	9.36	129.97	0	0
Total	167.42	1758.33		
SOLAR				
Total	15.15	166.90	0	0
Total	15.15	166.90		
Tata				
Trombay 5	9.28	77.48	436	271
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.98	15.74	107	41
Trombay 7B	1.32	11.95	65	38
TATA Hydro	7.21	53.14	441	152
Trombay 8	5.19	40.33	241	171
Total	24.98	198.64		
AEML				
DTPS U-1&2	11.38	116.77	501	381
Total	11.38	116.77		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	160.94	1741.43	MSPGCL Total	194.11	1994.55
			MSPGCL Thml+Gas	161.04	1769.30	Koyna 1,2 & 4 Total	23.11	147.35
			MSPGCL Hydro	33.07	225.26	State Total	422.87	4377.07

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	6762	2001	0	8763	313	7116	0	0	6730	6908	-1343	21364	0	0	21364	3002	393	24759	50.00
2	6805	2012	0	8817	306	7092	0	0	6643	6708	-1206	21361	0	0	21361	2814	356	24531	50.00
3	6769	2010	0	8779	444	7063	0	0	6357	6430	-1090	21285	0	0	21285	2623	341	24249	49.99
4	6726	1895	0	8621	527	7081	0	0	6450	6243	-1026	21126	0	0	21126	2455	320	23901	49.97
5	6679	2041	0	8720	464	7099	0	0	6476	6553	-993	21507	0	0	21507	2396	336	24239	49.94
6	6678	2000	0	8678	515	7141	0	0	6587	7153	-1035	22087	0	0	22087	2480	365	24932	49.90
7	6676	2023	0	8699	548	7137	0	78	7025	7293	-1047	22321	0	0	22321	2594	387	25302	50.01
8	6694	1346	0	8040	397	6948	0	518	7503	7691	-1236	21934	0	0	21934	2640	424	24998	50.03
9	6773	640	0	7413	310	6865	0	1091	8204	8111	-1715	21628	0	0	21628	2886	447	24961	49.97
10	6814	469	6	7289	383	6799	0	1601	8599	8392	-2052	21950	0	0	21950	3212	462	25624	50.00
11	6449	576	77	7102	235	6740	0	1981	9335	9132	-2105	22617	0	0	22617	3454	468	26539	49.95
12	6465	699	19	7183	183	6751	0	2089	9641	9326	-2205	22849	0	0	22849	3567	478	26894	49.94
13	6557	481	0	7038	167	6810	0	2083	9376	9508	-2166	22986	0	0	22986	3585	454	27025	49.93
14	6772	365	0	7137	142	6774	0	1921	9618	9176	-2174	22520	0	26	22520	3519	456	26495	49.95
15	6792	449	0	7241	133	6767	0	1585	10416	9897	-2302	22863	0	26	22863	3607	458	26928	49.82
16	6750	1090	0	7840	160	6733	0	1209	9702	9898	-2081	23285	0	73	23285	3674	474	27433	49.99
17	6828	1528	0	8356	258	6894	0	707	8549	8919	-1886	22775	0	0	22775	3575	473	26823	49.76
18	6852	1686	0	8538	448	6856	0	264	8244	8135	-1822	21928	0	0	21928	3434	491	25853	50.05
19	6826	1371	0	8197	532	7087	0	27	7400	7208	-1571	20991	0	0	20991	3236	489	24716	50.02
20	6679	1597	0	8276	557	7131	0	0	7401	7675	-1485	21680	0	0	21680	3217	474	25371	49.98
21	6655	1605	0	8260	560	7142	0	0	6850	6946	-1447	20993	0	0	20993	3154	468	24615	50.02
22	6654	1566	0	8220	706	7171	0	0	6683	6687	-1421	20904	0	0	20904	3139	459	24502	49.94
23	6647	1595	0	8242	847	7125	0	0	6665	6695	-1420	21053	0	0	21053	3174	436	24663	49.92
24	6638	2022	0	8660	684	7099	0	0	6760	7097	-1434	21694	0	0	21694	3191	412	25297	50.00
MUS	160.94	33.07	0.10	194.11	9.82	167.42	0.00	15.15	187.21	187.78	-38.26	525.70	0.00	0.13	525.70	74.63	10.32	610.65	49.96

NOTE : ALL VALUES IN MW
Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

- 1) Due overloading of 220 KV Jejuri Lonand line.
- 2) Due to overloading of 220kV Nashik - Babhaleshwar DC (Already 220kV Nashik - AKP line handtripped for load management purpose)

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Apr/2023

Position as on 6.30 Hrs of 12/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 8	80	11/04/2023	08:20	11/04/2023	19:00	Preventive Maintenance Work	11/04/2023
MSPGCL	Uran Unit 6	108	11/04/2023	11:17		Continued.	NO SCHEDULE	
MSPGCL	Uran Unit 8	108	11/04/2023	11:19		Continued.	NO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	12/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Uran Unit 6	108	29/03/2023	08:33	11/04/2023	09:51	Zero Schedule	
MSPGCL	Chandrapur Unit 4	210	08/04/2023	00:00		Continued.	Boiler Tube Leakage	13/04/2023
MSPGCL	Koradi Unit 9	660	08/04/2023	11:01		Continued.	Boiler Tube Leakage	12/04/2023
MSPGCL	Nasik Unit 5	210	08/04/2023	20:20		Continued.	Boiler Tube Leakage	12/04/2023
MSPGCL	Khaparkheda Unit 5	500	10/04/2023	09:50	12/04/2023	15:57	Boiler Tube Leakage	13/04/2023
MSPGCL	Uran Unit B0	120	10/04/2023	19:07		Continued.	I&C Fault	
MSPGCL	Uran Unit 8	108	10/04/2023	19:07	11/04/2023	11:08	I&C Fault	
AEML	AEML Unit 1	250	12/04/2023	00:47		Continued.	Boiler Tube Leakage	15/04/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 1	IntraState	09/04/2023	22:22			T	Tripped on distance protection
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	11/04/2023	04:20	11/04/2023	06:00	EO	Emergency shutdown of HVDC Pole-2 BASE FILTER Z21-Z1 � R-ph for attending hot spot at jumper connecting to capacitor bushing
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	11/04/2023	04:20	11/04/2023	06:00	EO	Emergency Shutdown of HVDC Pole-1 BASE FILTER Z11-Z1/Z2 for attending Hotspots at various locations in all the three phase
400 KV LR Outages/Trippings							
400KV RPL LINE REACTOR @ 400KV KORADI	IntraState	12/04/2023	05:26			PO	Bushings TAN Delta
50 MVAR LINE REACTOR OF BHUSAWAL LINE @ 400 KV KORADI	IntraState	12/04/2023	05:26	12/04/2023	16:51	PO	Bushings TAN Delta
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
MAIN BUS - 1 @ TALANDGE	IntraState	10/04/2023	14:36			PO	For PG isolator alignment with bus hanger in bay augmentation work of Kolhapur(PG)-Kolhapur(MSETCL)#2 Bay at MSETCL, Talandage(Kolhapur)
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA 2	IntraState	11/04/2023	10:32	11/04/2023	16:44	PO	High Level Tightening work
KARAD - TALANDGE CKT - 2	IntraState	11/04/2023	16:11	11/04/2023	21:55	PO	1. C bus isolator OH work 2. QM of Bay
KARAD - TALANDGE CKT - 2	IntraState	11/04/2023	16:11	11/04/2023	21:25	PO	PID Faulty disc insulator replacement work & Cold line washing work
RPL(AMT) NANDGAON PETH - KORADI	IntraState	12/04/2023	05:26	12/04/2023	05:59	HT	for outage on line reactor
CHANDRAPUR - KHAPERKHEDA	IntraState	12/04/2023	11:14	12/04/2023	13:45	PO	Diagnostic Testing of CBs
KORADI-NANDGAONPETH (RPL)	IntraState	12/04/2023	16:35	12/04/2023	16:51	PO	400kv KORADI-NANDGAONPETH (RPL) line will be out from 17:00hrs to 17:30hrs for work of Bushings TAN Delta of 400KV RPL LINE REACTOR @ 400KV KORADI
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	11/04/2023	12:35	11/04/2023	18:48	PO	Regular Maint work and Dignostic testing work
400/220/33KV 315MVA ICT - 2 @ LONIKAND	IntraState	12/04/2023	11:23	12/04/2023	11:52	T	At 400kv Lonikand 1 ss, Under voltage stage 1 & 2 LTS operated, meanwhile 400/220kv ICT-2 HV & LV tripped on operation of master trip relay. The details investigation about operation of 86 relay is in process
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	12/04/2023	12:42			PO	Regular Maint work and Dignostic testing work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV BR Outages/Trippings							
BUS REACTOR (125 MVar) - 2 @ KOLHAPUR (TALANDGE)	IntraState	12/04/2023	11:36	12/04/2023	14:10	PO	Quarterly maintenance work
220 KV TBC Outages/Trippings							
TBC @ PAL-DOMBIVALI-220 kV	InterState	12/04/2023	10:02	12/04/2023	13:32	PO	CB Diagnostic & RM Work.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AEML BORIVALI - TPC BORIVALI LINE	IntraState	20/03/2023	00:14	11/04/2023	14:41	T	Tripped due to cable joint failure.
NEW KOYNA - NIWALI	IntraState	10/04/2023	10:20			PO	TBC Shifting for replacement of Dynamic seal of circuit breaker R.PH.
NANDED CITY - GIS KONDHWA	IntraState	10/04/2023	17:45	12/04/2023	20:10	EO	Replacement of B Phase string at loc. No. 73 A STN.
BHUGAON - WARDHA (PG)	IntraState	11/04/2023	05:59	11/04/2023	08:00	HT	To control state overdrawl
WARORA - WARDHA	IntraState	11/04/2023	08:38	11/04/2023	15:30	PO	Tan Delta Measurement
KALMESHWAR-PANDHURNA	IntraState	11/04/2023	09:05	11/04/2023	19:36	PO	s/d is for Re-sagging work at loc no 03R-278, 278-294
BOISAR II - TARAPUR	IntraState	11/04/2023	09:07			PO	Replacement of Rusted Hardware work under scheme at Loc No.28 To 50, by M/s.BNC Power Project.
AKOLA-PARAS CKT NO-II	IntraState	11/04/2023	10:37	11/04/2023	17:33	PO	Flash over Disc replacement work
POPHLI PEDHMBE LINE- 2	IntraState	11/04/2023	11:20	11/04/2023	22:00	PO	For Bay P/M work
KANDALGAON - ONGC PANVEL	IntraState	11/04/2023	11:23	11/04/2023	12:54	T	TRIPPED ON DIST.PROTECTION
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/04/2023	12:35	11/04/2023	18:47	HT	h/t for load management
DAHANU - VIRAJ	IntraState	11/04/2023	15:20	11/04/2023	18:34	HT	H/T for controlling MVAR at Dahanu end.
GHATGHAR - BAPGAON	IntraState	11/04/2023	17:13	11/04/2023	18:13	T	Distance Protection
NERLE - DASGAON	IntraState	12/04/2023	08:28	12/04/2023	13:02	PO	Cold line chemical washing & Maintenance Work.
KALMESHWAR-PANDHURNA	IntraState	12/04/2023	09:27			PO	s/d is for Re-sagging work at loc no 03R-278, 278-294
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	12/04/2023	09:45			HT	For load management
TEMBHURNI - JEUR	IntraState	12/04/2023	12:22	12/04/2023	16:30	PO	Outage is required for Replacement of Yph problematic CC by new CC
NERLE - PEDAMBE	IntraState	12/04/2023	12:52	12/04/2023	16:25	T	TRIPPED ON DIST.PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132-110 KV 200MVA ICT - 3 @ OGLEWADI	IntraState	11/04/2023	10:13	11/04/2023	17:25	PO	Diagnostic Testing Work
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	12/04/2023	09:07	12/04/2023	15:43	PO	For Tan Delta Testing
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	12/04/2023	10:00	12/04/2023	15:52	PO	1) OLTC Servicing & Overhauling Work. 2) Bay RM Work.
132 KV LINE Outages/Trippings							
KANHAN-MANSAR	IntraState	12/04/2023	09:55	12/04/2023	15:45	PO	Routine Maint. Work
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 12/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	04/04/2023	21:59			PO	FOR 400 KV KVPTL WORK
WAGHIVALI - MANKHURD	IntraState	04/04/2023	23:57			PO	FOR 400 KV KVPTL WORK
110 KV BUSBAR Outages/Trippings							
ZONE 1 (BUS SECTION 1& 2) @ KHOPOLI	IntraState	11/04/2023	01:34	11/04/2023	03:40	PO	Removal of Bus jumper 110 KV KHP-Karnajade Bkr

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage