

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/May/2020 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	73.963	791.337	1) Gujrat	7.227	80.131
2) Hydro	10.724	193.480	2) Madhya Pradesh	13.308	149.980
3) Gas	6.681	73.960	3) Chattisgarh	6.990	92.520
Total MSPGCL	91.368	1058.777	4) Maharashtra	136.003	1593.531
B) 1) APLM	68.434	772.664	5) Goa (Amona)	-0.572	-4.510
2) JSWEL	15.396	171.060	Total	162.956	1911.652
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.886	257.659
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.238	272.457
5) WPCL	2.595	29.415	c) MSEDCL Bilateral *	56.658	705.676
6) Other IPP	6.756	78.310	Include PX	34.394	451.065
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.886	257.659
C) 1) TPCL Thermal	6.505	70.979	Include PX	16.741	183.210
2) TPCL Hydro	5.954	53.467	Standby	0.000	0.000
3) TPCL Gas	4.401	48.278	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.221	99.741	1) MSEDCL	342.185	4035.307
D) STATE			2) Mumbai Discoms	50.317	544.921
1) Thermal	182.870	2013.506	TOTAL STATE	392.502	4580.228
(A1+C1+C4+(B1-B6))					
2) Hydro	16.678	246.947			
(A2+C2)					
3) Gas	11.082	122.238			
(A3+B7+C3)					
4) Wind	11.448	202.580			
6) SOLAR	7.470	83.306			
TOTAL STATE	229.548	2668.577			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2839	3204	3537	2700
MSPGCL Hydro	482	587	752	120
MSPGCL Gas	261	283	272	297
MSPGCL Total Generation	3582	4074	4561	3117
Central Sector Receipt	7663	8178	5570	6147
WIND	299	235	786	636
CPP / IPP Thermal	3602	4194	4303	3627
CPP / IPP Gas	0	0	0	0
SOLAR	1031	838	0	0
Exchange with Mumbai	-1111	-1133	-929	-900
MSEDCL DEMAND MET	15066	16386	14291	12627
Load Shedding	0	0	0	0
MSEDCL DEMAND	15066	16386	14291	12627
TPCL GENERATION	576	667	942	749
AEML GENERATION	398	373	373	373
MUMBAI DEMAND	2085	2173	2244	2022
STATE DEMAND MET	17151	18559	16535	14649
STATE DEMAND	17151	18559	16535	14649
Frequency (Hz)	49.96	49.98	49.97	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 06.02 Hrs	49.82 Hz at 12.13 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/May/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	0.00	0.00	0	0
Total	0.00	0.00		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	3.05	3.05	248	0
Unit 8	0.00	35.76	0	0
Total	3.05	38.81		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	9.44	111.03	460	360
Unit 7	9.16	79.91	432	360
Unit 8	9.89	122.87	480	360
Unit 9	9.61	111.60	450	360
Total	38.09	425.42		
Paras				
Unit 3	5.34	44.01	250	190
Unit 4	5.43	61.93	256	200
Total	10.77	105.94		
Khaparkheda				
Unit 1	0.01	0.01	10	0
Unit 2	4.05	30.57	190	160
Unit 3	4.07	29.34	194	158
Unit 4	4.13	46.30	196	160
Unit 5	9.79	114.95	500	365
Total	22.05	221.17		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.68	73.96	297	261
Total	6.68	73.96		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.02	1.23	21	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.02	1.23		
Koyna				
Stage 1-2	3.76	55.70	435	35
Stage 4	3.35	81.36	715	0
Stage 3	1.34	29.97	160	0
Total	8.45	167.03		
Hydro				
KDPH	0.63	8.52	33	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.38	3.00	80	0
RNGR+BHTSA	0.28	3.15	12	11
BHANDARDRA	0.47	5.17	37	11
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.51	6.60	30	19
GHATGHAR	0.00	0.00	0	0
Total	2.28	26.45		
Wind				
Total	11.45	202.58	0	0
Total	11.45	202.58		
CPP				
APML(Mus)	68.43	772.66	0	0
JSWEL(Mus)	15.40	171.06	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.60	29.42	0	0
Other(Mus)	6.76	78.31	0	0
Total	93.18	1051.45		
SOLAR				
Total	7.47	83.31	0	0
Total	7.47	83.31		
Tata				
Trombay 5	6.50	70.98	299	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	30.85	117	116
Trombay 7B	1.59	17.43	67	66
Trombay 8	0.00	0.00	0	0
TATA Hydro	5.95	53.47	459	71
Total	16.86	172.72		
AEML				
DTPS U-1&2	9.22	99.74	501	371
Total	9.22	99.74		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	73.96	791.34	MSPGCL Total	91.37	1058.78
			MSPGCL Thml+Gas	80.64	865.30	Koyna 1,2 & 4 Total	7.11	137.07
			MSPGCL Hydro	10.72	193.48	State Total	229.55	2668.58

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 11/May/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2696	306	286	3288	811	3288	0	0	6145	6534	-1129	12792	0	12792	2361	15153	50.02
2	2698	419	288	3405	670	3562	0	0	5982	6313	-1026	12924	0	12924	2238	15162	50.03
3	2693	154	277	3124	457	3624	0	0	6316	6323	-952	12576	0	12576	2121	14697	50.04
4	2700	120	297	3117	636	3627	0	0	6270	6147	-900	12627	0	12627	2022	14649	50.03
5	2712	116	288	3116	580	3532	0	0	6382	6455	-891	12792	0	12792	1985	14777	50.07
6	2783	111	288	3182	546	3586	0	0	6768	6777	-872	13219	0	13219	1984	15203	50.01
7	2801	140	289	3230	304	3643	0	77	7467	6973	-769	13458	0	13458	1887	15345	50.04
8	2766	196	286	3248	307	3508	0	258	6964	7295	-825	13791	0	13791	1863	15654	50.03
9	2760	198	282	3240	339	3575	0	520	6944	7011	-1028	13657	0	13657	1924	15581	50.03
10	2777	236	269	3282	433	3568	0	743	7027	6970	-1003	13993	0	13993	2004	15997	50.03
11	2786	295	277	3358	404	3430	0	969	7055	7152	-1015	14298	0	14298	2067	16365	50.02
12	2839	482	261	3582	299	3602	0	1031	7559	7663	-1111	15066	0	15066	2085	17151	49.96
13	3069	157	270	3496	322	3920	0	1029	8024	7763	-1152	15378	0	15378	2102	17480	49.97
14	3097	132	261	3490	204	4244	0	946	8025	7976	-1168	15692	0	15692	2118	17810	49.96
15	3204	587	283	4074	235	4194	0	838	7968	8178	-1133	16386	0	16386	2173	18559	49.98
16	3483	878	263	4624	230	4171	0	597	7852	7764	-1022	16364	0	16364	2178	18542	49.97
17	3579	877	266	4722	241	4229	0	320	7494	7505	-918	16099	0	16099	2096	18195	50.04
18	3579	587	276	4442	532	4216	0	117	6860	6722	-1068	14961	0	14961	1972	16933	50.03
19	3420	295	270	3985	575	4212	0	25	5832	5790	-1012	13575	0	13575	1909	15484	50.04
20	3370	661	282	4313	737	4273	0	0	5632	5956	-1126	14153	0	14153	2048	16201	50.01
21	3555	777	290	4622	687	4297	0	0	5428	5457	-977	14086	0	14086	2157	16243	50.00
22	3537	752	272	4561	786	4303	0	0	5530	5570	-929	14291	0	14291	2244	16535	49.97
23	3503	1144	283	4930	587	4293	0	0	6073	6167	-1060	14917	0	14917	2343	17260	49.96
24	3556	1104	277	4937	526	4284	0	0	6458	6495	-1152	15090	0	15090	2438	17528	49.96
MUs	73.96	10.72	6.68	91.37	11.45	93.18	0.00	7.47	162.05	162.96	-24.24	342.19	0.00	342.19	50.32	392.50	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/May/2020

Position as on 6.30 Hrs of 12/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45	11/05/2020	03.52	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06	12/05/2020	07.37	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29	12/05/2020	00.15	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30	12/05/2020	05.57	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/May/2020

Position as on 6.30 Hrs of 12/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	22/04/2020	20.45	11/05/2020	23.32	Zero Schedule By MSEDCL	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Parli Unit 8	250	10/05/2020	13.03	12/05/2020	16.26	Boiler Tube Leakage	
MSPGCL	Koyna Unit 1	70	11/05/2020	12.00		Continued.	Cooler Leakage	
MSPGCL	Uran Unit 6	108	11/05/2020	23.55	12/05/2020	10.40	Generator protection	
MSPGCL	Koyna STG-IV Unit-4	250	12/05/2020	06.12	12/05/2020	07.45	Shaft Seal Temperature very high	
MSPGCL	Koyna STG-IV Unit-3	250	12/05/2020	07.00	12/05/2020	08.30	Shaft Seal Water circulation flow lost	
MSPGCL	Chandrapur Unit 4	210	12/05/2020	12.05	12/05/2020	18.37	Tripped On CVSM Problem.	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/May/2020

Statement-VII

Position as on 6.30 Hrs of 12/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	30/04/2020	17.40		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot(RFC 29.04.2020 Over voltage).
Chandrapur - Parli	IntraState	19/04/2020	02.20		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Girwali- Lonikand 2	IntraState	03/05/2020	17.48	11/05/2020	11.39	HT	Controlling loading of Parli Parli (PG) D/C.
Dhule - Bableshwar - II	IntraState	06/05/2020	21.26		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	09/05/2020	18.17	11/05/2020	15.43	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	10/05/2020	18.01		Continued.	HT	Over Voltage
Koradi-Bhusawal	IntraState	10/05/2020	18.05	11/05/2020	13:00	T	Distance Protection
Koradi-Khaperkheda I	IntraState	10/05/2020	18.06	11/05/2020	09:36	T	Over Voltage
Koradi-RattanIndia	IntraState	10/05/2020	18.08	11/05/2020	09:16	T	Distance Protection
karad -kolhapur-II	IntraState	10/05/2020	18.39	11/05/2020	11:46	HT	Over Voltage
Main Bus-I @ Koradi III	IntraState	11/05/2020	09.41	11/05/2020	12.48	PO	Maintenance of Bus related equipments
Girwali - Lonikand 1	IntraState	11/05/2020	12.20		Continued.	PO	Changing 400KV CT Ratio(RFC 18.35Hrs To Control Loading Parli -Parli PG)
Akola-Nandgaonpeth (RPL)	IntraState	12/05/2020	09.13	12/05/2020	18.52	EO	In view Of Pre monsoon activity it is necessary to replace string.
Chandrapur - Khaperkheda	IntraState	12/05/2020	09.24	12/05/2020	15.40	PO	Diagnostic testing and routine maint work.
Nagothane - Dabhol I	IntraState	12/05/2020	10.13	12/05/2020	15.52	EO	For emergency tree cutting work at Loc no 302.
Khadka-Aurangabad (Waluj)	IntraState	12/05/2020	18.55		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv 315MVA ICT-I @Talegaon(PG)	InterState	11/05/2020	09.00	11/05/2020	21.41	PO	Premonsoon maintenance work
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19	11/05/2020	06.10	PO	Attending Hot Spot
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	11/05/2020	06.18		Continued.	PO	Over Voltage
400/220/33 315MVA ICT-III @ KHADKA	IntraState	11/05/2020	06.21	11/05/2020	13.00	PO	Routine Maintenance Work
400/220kv 315 Mva ICT III @Karad	IntraState	11/05/2020	07.39	11/05/2020	14.22	PO	Replacement of Y Phase 400KV Bushing
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	11/05/2020	08.24	11/05/2020	15.42	PO	Routine Maintenance Work
400/220kv 315 Mva ICT II @Karad	IntraState	12/05/2020	07.00	12/05/2020	17.33	EO	Replacement of Y ph inner side 52 KV tertiary Bushing.
400/220KV 500MVA ICT 2@koradi 2	IntraState	12/05/2020	07.00	12/05/2020	12.33	PO	IR, Tan delta measurement of Bushing.
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	12/05/2020	07.25	12/05/2020	20.10	PO	For diagnostic testing and premansoon maint. Work.
400/220kv, 500 Mva ICT-1 @Deepnagar	IntraState	12/05/2020	08.38	12/05/2020	15.21	PO	LVCT Tan delta testing work also HV LV Bay Pre monsoon maint work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/May/2020

Statement-VII

Position as on 6.30 Hrs of 12/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Tata Borivli MSETCL Borivli 4	IntraState	10/05/2020	10.42	11/05/2020	17.25	PO	LA replacement.
Karad - Kadegaon	IntraState	10/05/2020	18.11	11/05/2020	09:01	T	Distance Protection
Paras-Chikhali Ckt No-Ii	IntraState	10/05/2020	18.22	11/05/2020	10.54	T	Distance Protection
Badnera-Akola Ii	IntraState	10/05/2020	20.00	11/05/2020	02.49	T	Distance Protection
Amalner - Bambhori	IntraState	11/05/2020	06.46	11/05/2020	16.52	PO	Disc Insulator Replacement Work
Badnera-Akola I	IntraState	11/05/2020	09.20	11/05/2020	12.30	PO	Line Maintenance work
Kalwa - Mulund 1	IntraState	11/05/2020	09.29	11/05/2020	14.12	PO	Insulator Cleaning work
Kharghar-Borivali ckt II	IntraState	11/05/2020	10.05	11/05/2020	15.00	PO	Insulator cleaning work
Dasturi-Kandalgaon Line	IntraState	11/05/2020	10.05	11/05/2020	18.40	PO	Tree Cutting
Gadchandur-Ultratech I	IntraState	11/05/2020	13.10	11/05/2020	15.30	PO	Testing Work
Kandalgaon-POSCO	IntraState	11/05/2020	15.38	11/05/2020	20.00	T	Distance Protection
Pophali - Pedambe II	IntraState	12/05/2020	07.00	12/05/2020	14.00	PO	Routine Maintenance Work
Deepnagar Bambhori	IntraState	12/05/2020	07.20	12/05/2020	13.18	PO	For Replacement Of Faulty Disc Insulator string At Various location.
Waluj - Degaon Rangari	IntraState	12/05/2020	07.25	12/05/2020	16.34	T	Distance Protection
OSMANABAD PARANDA	IntraState	12/05/2020	08.56	12/05/2020	19.01	PO	Quarterly Maintainance Work
Kadegaon-Miraj	IntraState	12/05/2020	09.24	12/05/2020	16.40	PO	For replacement of insulator string at Loc No. 190 R phase and 192 R phase.
Peth- Mudshingi -I	IntraState	12/05/2020	10.30	12/05/2020	13.30	PO	realignment of earthwire of existing circuits.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	12/05/2020	10.31	12/05/2020	18.43	PO	Realignment of earthwire of existing circuits.
Apta - Taloja	IntraState	12/05/2020	10.32	12/05/2020	12.38	PO	Attending Hot Spot
Deepnagar Bambhori	IntraState	12/05/2020	13.28		Continued.	T	Distance Protection
Wathar - Mudshingi 3 Line	IntraState	12/05/2020	15.00	12/05/2020	18.44	PO	Realignment of earthwire of existing circuits.
Pedambe-Pophali	IntraState	12/05/2020	22.45	12/05/2020	23.00	PO	Replacement Of P8 Contacter.
220 KV ICT Outages/Trippings							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	27/04/2020	17.15	11/05/2020	10.08	HT	Over Voltage
220/132Kv 200MVA ICT-I @ Chikhali	IntraState	09/05/2020	14.06		Continued.	PO	Oil Filtration work
220/132 kv 100MVA ICT I @ Balapur	IntraState	11/05/2020	10.30	11/05/2020	21.30	PO	Testing Work
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	11/05/2020	12.36	11/05/2020	14.52	PO	To change the CT Ratio
220/132 Kv 200 MVA ICT-III @Girwali	IntraState	11/05/2020	14.57	11/05/2020	17.27	PO	To change the CT Ratio
200/100KV 100MVA ICT-1@Satara MIDC	IntraState	12/05/2020	10.06	12/05/2020	13.05	PO	Quarterly Maintainance Work
220/132kv 100 Mva Ict 2 @Peth	IntraState	12/05/2020	10.27	12/05/2020	11.48	PO	Pre-monsoon maintenance work PRV & buccholz covering with plastic paper.
220/132-110kv 100mva Imp Ptr 2 @Wathar	IntraState	12/05/2020	10.37	12/05/2020	14.25	PO	Pre-monsoon maintenance and diagnostic testing work.
220/132kv 100MVA ICT II @Satara Midc	IntraState	12/05/2020	14.15	12/05/2020	17.15	PO	Quarterly Maintainance Work
220/132KV 100MVA ICT-II@Shivajinagar	IntraState	12/05/2020	15.02	12/05/2020	18.44	PO	Diagnostic testing work.
220/132 kv 100MVA ICT-I @ Shivajinagar	IntraState	12/05/2020	18.48	12/05/2020	19.40	PO	Pre-monsoon maintenance and Diagnostic testing work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/May/2020

Statement-VII

Position as on 6.30 Hrs of 12/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage