

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/May/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	169.038	1900.912	1) Gujrat	-3.648	21.933
2) Hydro	16.973	187.347	2) Madhya Pradesh	10.632	80.501
3) Gas	6.843	76.306	3) Chattisgarh	6.720	42.360
Total MSPGCL	192.854	2164.565	4) Maharashtra	183.297	2077.829
B) 1) APML	69.565	703.759	5) Goa (Amona)	-1.954	-21.663
2) JSWEL	26.116	306.710	Total	195.047	2200.960
3) VIPL	0.000	0.000	a) Mumbai Schedule	42.570	462.897
4) RPL(AMT)	31.429	337.918	b) Mumbai Drawl	43.905	481.530
5) SWPGPL	12.225	134.192	c) MSEDCL Bilateral *	74.218	958.374
6) Other IPP	16.618	201.227	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	42.570	462.897
C) 1) TPCL Thermal	10.730	131.437	Include PX	0.000	0.000
2) TPCL Hydro	3.527	53.558	Standby	0.000	0.000
3) TPCL Gas	4.065	40.896	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.205	108.168	1) MSEDCL	515.730	5827.083
D) STATE			2) Mumbai Discoms	72.427	815.583
1) Thermal	345.926	3824.323	3) Other Discoms	11.451	125.321
(A1+C1+C4+(B1-B6))			TOTAL STATE	599.608	6767.987
2) Hydro (A2+C2)	20.500	240.905			
3) Gas (A3+B7+C3)	10.908	117.202			
4) Wind	11.920	188.207			
6) SOLAR	15.312	196.396			
TOTAL STATE	404.566	4567.033			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6698	7131	7199	6742
MSPGCL Hydro	158	538	672	602
MSPGCL Gas	278	280	285	288
MSPGCL Total Generation	7134	7949	8156	7632
Central Sector Receipt	8892	9241	7997	7907
WIND	170	468	639	319
CPP / IPP Thermal	5930	6165	6858	6605
CPP / IPP Gas	0	0	0	0
SOLAR	2133	1679	0	453
Exchange with Mumbai	-2102	-2073	-2068	-1579
MSEDCL DEMAND MET	21634	22930	21072	20871
Load Shedding	0	0	0	0
MSEDCL DEMAND	21634	22930	21072	20871
TPCL GENERATION	781	861	656	641
AEML GENERATION	503	504	408	295
MUMBAI DEMAND	3386	3438	3132	2515
OTHER DISCOM DEMAND	523	499	510	466
STATE DEMAND MET	25543	26867	24714	23852
STATE DEMAND	25543	26867	24714	23852
Frequency (Hz)	49.92	49.88	50.01	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 18:01 Hrs	49.72 Hz at 00:02 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.17	42.71	140	0
Unit 8	14.26	75.86	663	515
Unit 9	14.28	153.15	602	563
Unit 10	14.77	153.88	650	589
Total	43.48	425.60		
Bhusawal				
Unit 3	3.68	31.74	175	125
Unit 4	5.22	103.08	455	0
Unit 5	11.52	91.56	490	465
Total	20.42	226.38		
Parli				
Unit 6	4.72	49.84	244	144
Unit 7	4.15	48.00	233	140
Unit 8	4.94	49.74	250	145
Total	13.81	147.58		
Chandrapur				
Unit 3	3.73	39.16	160	145
Unit 4	3.78	40.43	164	150
Unit 5	9.45	95.89	425	335
Unit 6	8.08	89.77	375	280
Unit 7	9.36	100.70	459	325
Unit 8	10.59	114.85	460	430
Unit 9	11.21	122.82	477	454
Total	56.20	603.62		
Paras				
Unit 3	2.46	44.31	222	0
Unit 4	5.47	61.25	249	203
Total	7.93	105.56		
Khaparkheda				
Unit 1	3.78	38.28	170	125
Unit 2	3.93	44.81	186	145
Unit 3	3.78	42.15	173	141
Unit 4	4.25	40.55	190	163
Unit 5	2.12	111.97	490	0
Total	17.86	277.75		
Nasik				
Unit 3	3.79	34.66	176	133
Unit 4	1.86	41.06	186	0
Unit 5	3.69	38.69	169	122
Total	9.34	114.42		
Uran				
All Units	6.84	76.31	292	274
Total	6.84	76.31		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.86	3.38	53	0
Total	0.86	3.38		
Koyna				
Stage 1-2	3.73	39.56	405	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	7.06	79.83	1008	0
Stage 3	2.60	26.87	320	0
Total	13.39	146.25		
Hydro				
KDPH	0.47	7.44	28	0
VTRNA	0.81	9.74	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.19	21.80	96	86
GHATGHAR	0.12	2.12	100	0
Total	3.58	41.10		
Wind				
Total	11.92	188.21	0	0
Total	11.92	188.21		
CPP				
APML(Mus)	69.56	703.76	0	0
JSWEL(Mus)	26.12	306.71	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.43	337.92	0	0
SWPGPL-Mus	12.22	134.19	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.20	59.02	268	171
Other(Mus)	6.74	82.37	0	0
JPL	4.68	59.84	223	178
Total	155.95	1683.81		
SOLAR				
Total	15.31	196.40	0	0
Total	15.31	196.40		
Tata				
Trombay 5	8.35	92.62	469	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.54	25.11	108	101
Trombay 7B	1.53	15.79	64	62
TATA Hydro	3.53	53.56	351	65
Trombay 8	2.38	38.82	115	91
Total	18.32	225.89		
AEML				
DTPS U-1&2	10.20	108.17	504	295
Total	10.20	108.17		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	169.04	1900.91	MSPGCL Total	192.85	2164.56
			MSPGCL Thml+Gas	175.88	1977.22	Koyna 1,2 & 4 Total	10.79	119.38
			MSPGCL Hydro	16.97	187.35	State Total	404.57	4567.03

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7642	1717	289	9648	377	7034	0	0	7741	7550	-2034	22133	0	0	22133	3080	442	25655	49.93
2	7494	1363	290	9147	357	6990	0	0	7942	7649	-1871	21853	0	0	21853	2880	419	25152	49.97
3	7393	1396	290	9079	320	6897	0	0	7649	7453	-1689	21670	0	0	21670	2704	390	24764	50.00
4	7332	1280	291	8903	390	6868	0	0	7678	7532	-1609	21707	0	0	21707	2561	377	24645	49.99
5	7027	1508	292	8827	388	6917	0	0	7664	7441	-1578	21600	0	0	21600	2500	395	24495	49.98
6	6800	1683	292	8775	474	6860	0	2	7700	7552	-1509	21744	0	0	21744	2501	410	24655	50.01
7	6810	1160	289	8259	541	6755	0	89	8157	7725	-1410	21511	0	4	21511	2466	448	24425	50.02
8	6742	602	288	7632	319	6605	0	453	8101	7907	-1579	20871	0	8	20871	2515	466	23852	50.03
9	6461	501	288	7250	404	5792	0	958	8719	8730	-1737	20906	0	0	20906	2694	491	24091	50.01
10	6500	236	281	7017	325	5774	0	1493	9056	8989	-1958	21152	0	0	21152	2962	488	24602	50.01
11	6354	165	281	6800	192	5659	0	2006	9634	9628	-2131	21651	0	0	21651	3236	503	25390	49.98
12	6698	158	278	7134	170	5930	0	2133	9637	8892	-2102	21634	0	0	21634	3386	523	25543	49.92
13	6664	157	278	7099	151	5696	0	2165	9590	9460	-2056	22006	0	2	22006	3413	509	25928	49.94
14	6713	370	279	7362	202	5671	0	2012	9648	9416	-1995	22157	0	2	22157	3367	511	26035	49.95
15	7131	538	280	7949	468	6165	0	1679	9516	9241	-2073	22930	0	6	22930	3438	499	26867	49.88
16	7279	600	274	8153	536	6526	0	1200	9502	8815	-2008	22687	0	4	22687	3506	535	26728	49.96
17	7216	392	279	7887	405	6568	0	747	9040	8932	-1980	22025	0	6	22025	3397	534	25956	49.96
18	7314	395	282	7991	708	6726	0	330	8579	8164	-1895	21494	0	0	21494	3252	530	25276	50.01
19	7261	319	283	7863	711	6441	0	45	8280	8050	-1805	20774	0	0	20774	3123	531	24428	50.03
20	7199	672	285	8156	639	6858	0	0	8055	7997	-2068	21072	0	0	21072	3132	510	24714	50.01
21	7194	274	288	7756	769	6727	0	0	7991	7176	-1905	20010	0	0	20010	3100	513	23623	49.99
22	7112	264	288	7664	892	6538	0	0	7175	7144	-1739	20009	0	0	20009	3062	490	23561	50.02
23	7318	526	289	8133	1059	6983	0	0	6662	6568	-1540	20733	0	0	20733	3044	470	24247	50.02
24	7384	697	289	8370	1123	6973	0	0	6693	7036	-1634	21401	0	0	21401	3113	467	24981	50.01
MUs	169.04	16.97	6.84	192.85	11.92	155.95	0.00	15.31	200.41	195.05	-43.90	515.73	0.00	0.03	515.73	72.43	11.45	599.61	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR carried out due to overload of 132KV BBLSR-Rahuri line.2) DLS carried out due to overload of T/F at Lonikand-I S/S and load management of 132KV Chinchwad-Ganeshkhind line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/May/2024

Position as on 6.30 Hrs of 12/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Paras Unit 3	250	09/05/2024	00:45	11/05/2024	11:22	Boiler Tube Leakage	11/05/2024
MSPGCL	Bhusawal Unit 4	500	10/05/2024	04:30	11/05/2024	10:58	Boiler Tube Leakage	12/05/2024
MSPGCL	Koradi Unit 6	210	11/05/2024	01:18	12/05/2024	17:40	Boiler Tube Leakage	14/05/2024
MSPGCL	Khaparkheda Unit 5	500	11/05/2024	04:22		Continued.	Generator protection	15/05/2024
MSPGCL	Nasik Unit 4	210	11/05/2024	11:53	12/05/2024	12:58	BTL in economizer zone	13/05/2024
MSPGCL	Koradi Unit 6	210	12/05/2024	18:31		Continued.	GS WATER TANK LOW	13/05/2024
Total Capacity MSPGCL		2000						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2320						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	06/05/2024	23:54		Continued.	Zero Schedule given by MSEDCL	
MSPGCL	Uran Unit 5	108	09/05/2024	20:15		Continued.	No Schedule from MSEDCL	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/May/2024

Statement-VII

Position as on 6.30 Hrs of 12/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	11/05/2024	00:55	11/05/2024	02:48	HT	Emergency outage for removing drip irrigation pipe hanging on Pole-I conductor at Loc No. 1622
400 KV MAINBAY Outages/Trippings							
MAIN BAY (410)OF BHUSAWAL (KHADKA) @ AKOLA	IntraState	12/05/2024	14:38	12/05/2024	17:56	EO	Attending Isolator Hotspot
400 KV LINE Outages/Trippings							
400KV NANDED(KUMBHARGAON)-PARLY CKT 2	InterState	11/05/2024	19:35	12/05/2024	04:40	EO	Repairing broken conductor strands
KALWA - TALEGAON (PG)	InterState	12/05/2024	04:44	12/05/2024	10:23	HT	Emergency outage availed for attending hotspot at Kalwa S/S
DHULE - SSNNL CKT - 1	InterState	12/05/2024	16:10			T	Tripped on distance protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	01/05/2024	22:11			HT	For faciliating outage on 765 Kv Aurangabad - Padghe line.
BABHALESHWAR - PADGHE CKT - 2	IntraState	10/05/2024	09:56			PO	1. B Bus PG Isolator Replacement work under LES Scheme. 2. CB Diagnostic Testing Work. 3.400KV BBLR-II in service through TBC.
MAIN BUS - 2 @ PADGHE	IntraState	10/05/2024	10:23			PO	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	11/05/2024	05:15	11/05/2024	08:59	EO	To attend heavy DC leakage from FDS of line shunt reactor
DABHOL - NEW KOYNA CKT - 1	IntraState	11/05/2024	09:44	11/05/2024	19:43	PO	Bay Maintenance and testing
LONIKAND I - CHAKAN	IntraState	11/05/2024	22:08	12/05/2024	01:36	HT	Emergency outage for attending hotspot at Chakan end.
DABHOL - NEW KOYNA CKT - 1	IntraState	12/05/2024	11:01	12/05/2024	12:30	T	Distance Protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
200 MVA 220/132 KV ICT - 4 @ KHADKA	IntraState	11/05/2024	08:26	11/05/2024	15:00	PO	Maintenance and testing work
400220kv 167MVA SPARE ICT @ DEEPNAGAR	IntraState	11/05/2024	09:40	11/05/2024	14:22	PO	For Pre-Monsoon Maintenance Work, Tan Delta Measurement of Bushing and Winding with Chemical Washing
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
AAREY - AEML SAKI CKT - 2	IntraState	08/05/2024	21:48			T	Tripped on Yph to ground fault
BOMBAY DYEING - SAHARA	IntraState	10/05/2024	18:14	11/05/2024	00:29	T	Tripped due to Yph. PT burst at Sahara S/S
SAHARA-URSE	IntraState	10/05/2024	18:14	11/05/2024	00:11	T	Tripped due to Yph. PT burst at Sahara S/S

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/May/2024

Statement-VII

Position as on 6.30 Hrs of 12/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VSNL- KHADKI	IntraState	11/05/2024	08:07	11/05/2024	17:13	PO	For Stringing between New Monopole Loc No. 30 A to 30 B, stringing & destring of Old Loc No 30 & 31
PANDHARPUR - MALINAGAR	IntraState	11/05/2024	10:15	11/05/2024	20:48	PO	Outage is required for Destringing and stringing from Loc No. 37 to 46 to attain issue of low Ground clearance.
NEW KOYNA - NIWALI	IntraState	11/05/2024	12:07	11/05/2024	16:54	PO	For replacement of faulty string found in PID loc no. 132.
220 KV PADEGAON -WALUJ CKT I	IntraState	11/05/2024	13:02	11/05/2024	16:25	PO	to attend Hot Spot
220 KV KARJAT-BELWANDI-CKT-1	IntraState	11/05/2024	15:33	11/05/2024	20:23	T	Tripped on distance protection.
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	11/05/2024	15:33	11/05/2024	20:35	T	Tripped on distance protection
VANKUSWADE - KDPH	IntraState	11/05/2024	15:38	12/05/2024	10:50	T	Tripped on distance protect.
POPHALI - KDPH	IntraState	11/05/2024	16:40	12/05/2024	01:50	T	Tripped on distance protection
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	11/05/2024	17:20			T	H/T for load management
MAHALAXMI - AMONA	IntraState	11/05/2024	20:34	11/05/2024	22:24	T	Tripped from Amona end only
KHARGHAR - SONKHAR	IntraState	11/05/2024	22:51	12/05/2024	03:53	PO	For the installation of saver assembly sets at TL no. 678 & 679 (Total 6 sets out of 6 sets are to be installed)
KHARGHAR - NET MAGIC GIS	IntraState	11/05/2024	23:08	12/05/2024	03:37	PO	For the installation of saver assembly sets at TL no. 678 & 679 (Total 6 sets out of 6 sets are to be installed)
ADLABS - PEDAMBE	IntraState	12/05/2024	08:12	12/05/2024	10:38	PO	For replacement of rusted Hardware of all phases at loc no 104.
BORIVALI - BOISAR (PG)	IntraState	12/05/2024	11:22	12/05/2024	20:07	PO	Outage is required for safety purpose during applying repair sleeve for Damaged Conductor at Loc. No. 76-77.
BORIVALI - TARAPUR	IntraState	12/05/2024	11:37	12/05/2024	20:05	PO	For applying repair sleeve for work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
220KV DHAMANGAON-220KV AVAADA(DHAMANGAON) SOLAR CKT	IntraState	12/05/2024	12:31	12/05/2024	14:02	EO	Attending Hotspot
220 KV AMRAVATI - KARANJA CKT	IntraState	12/05/2024	15:35	12/05/2024	16:03	T	Distance protection
WARORA - WARDHA	IntraState	12/05/2024	22:53	12/05/2024	23:19	T	Distance protection
220 KV ICT Outages/Trippings							
220/132KV 200MVA ICT 2 @ LONAND	IntraState	11/05/2024	08:20	11/05/2024	12:00	PO	Inspecting & attending oil leakage from LV Y Ph Bushing
220/132 KV 150 MVA ICT 2 @ SATANA	IntraState	11/05/2024	12:02	11/05/2024	13:20	PO	For premansoon Maintenance work, Auxiliary Relay commissioning & Testing work & Fan Cubical setting work by agency.
220/132 KV 200 MVA ICT 1 @ SATANA	IntraState	11/05/2024	13:20	11/05/2024	16:32	PO	For premansoon Maintenance work & Fan Cubical setting work by agency.
220/132 KV 200 MVA ICT 2 @ BABHLESHWAR	IntraState	11/05/2024	15:10	11/05/2024	22:05	PO	Attending oil leakage of ICT from top plate.
220 / 110 / 33kV 250MVA AT 2 @ BACKBAY	IntraState	12/05/2024	10:07	12/05/2024	16:36	PO	R/M

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/May/2024

Statement-VII

Position as on 6.30 Hrs of 12/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KHOPOLI - KARANJADE	IntraState	12/05/2024	11:23	12/05/2024	13:36	PO	BIRD NEST REMOVAL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage