

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Jun/2016 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	113.666	1442.883	1) Gujrat	-2.758	-54.634
2) Hydro	1.753	47.677	2) Madhya Pradesh	11.742	104.737
3) Gas	9.221	79.343	3) Chattisgarh	7.210	77.710
Total MSPGCL	124.640	1569.903	4) Maharashtra Net	108.671	1259.242
B) 1) APML	12.163	143.858	5) Goa (Amona)	-0.686	-8.728
2) JSWEL	19.151	217.672	6) TAPS 1&2 Injection	3.555	39.190
3) VIPL	10.720	130.921	7) RGPPL Injection	11.532	124.761
4) RPL(AMT)	18.621	209.027	8) Pench (MS)	0.015	0.640
5) WPCL	2.774	38.294	9) Pench (Excess)	-0.015	-0.640
6) Other IPP	4.724	50.653	Total	139.251	1541.638
C) 1) TPCL Thermal	15.708	178.233	a) Mumbai Schedule	26.031	309.444
2) TPCL Hydro	1.879	33.244	b) Mumbai Drawl	32.957	394.562
3) TPCL Gas	4.214	30.756	c) MSEDCL Bilateral *	34.272	405.976
4) R-INFRA Thermal	9.936	123.163	Include PX	0.000	20.500
D) STATE			d) Mumbai Bilateral *	26.031	309.444
1) Thermal	207.463	2534.704	Include PX	6.422	70.478
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	3.632	80.921	H) ENERGY CATERED (MUs)		
3) Gas	13.435	110.099	1) MSEDCL	336.453	3776.488
4) Wind	36.338	257.259	2) Mumbai Discoms	64.693	759.956
6) SOLAR	1.028	11.825	TOTAL STATE	401.146	4536.444
TOTAL STATE	261.896	2994.808			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4780	4924	4895	4492
MSPGCL Hydro	131	56	147	65
MSPGCL Gas	384	420	425	295
MSPGCL Total Generation	5295	5400	5467	4852
Central Sector Receipt	5792	5891	5935	5824
WIND	1631	1761	1757	941
CPP / IPP	2980	2867	2935	2796
SOLAR	102	96	0	0
Exchange with Mumbai	-1517	-1323	-1359	-1313
MSEDCL DEMAND MET	14283	14692	14735	13100
Load Shedding	0	0	0	0
MSEDCL DEMAND	14283	14692	14735	13100
TPCL GENERATION	901	1126	1021	699
R-INFRA GENERATION	403	508	402	402
MUMBAI DEMAND	2821	2957	2782	2414
STATE DEMAND MET	17104	17649	17517	15514
STATE DEMAND	17104	17649	17517	15514
Frequency (Hz)	49.97	49.94	49.94	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 07.03 Hrs	49.85 Hz at 12.25 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Jun/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	3.07	35.94	145	115
Unit 6	0.00	0.00	0	0
Unit 7	3.62	41.24	156	140
Unit 8	8.06	134.79	570	0
Total	14.75	211.98		
Bhusawal				
Unit 2	2.62	32.76	150	0
Unit 3	2.67	41.78	165	0
Unit 4	0.00	94.90	0	0
Unit 5	9.04	110.71	510	345
Total	14.34	280.16		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	3.96	44.50	172	114
Unit 4	4.31	46.67	188	164
Unit 5	9.97	87.44	450	360
Unit 6	10.03	108.36	449	360
Unit 7	5.49	89.78	395	0
Total	33.76	376.76		
Paras				
Unit 3	5.76	61.42	258	173
Unit 4	5.84	62.70	257	199
Total	11.60	124.11		
Khaparkheda				
Unit 1	3.70	37.75	170	130
Unit 2	3.67	41.82	165	140
Unit 3	4.07	40.22	191	160
Unit 4	4.24	40.95	192	171
Unit 5	11.51	118.46	500	380
Total	27.19	279.19		
Nasik				
Unit 3	4.02	45.58	185	165
Unit 4	3.99	45.97	175	156
Unit 5	4.02	45.98	170	163
Total	12.02	137.53		
Uran				
All Units	9.22	79.34	438	283
Total	9.22	79.34		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.02	0.64	8	0
Total	0.02	0.64		
Koyna				
Stage 1-2	1.06	16.82	55	40
Stage 4	0.00	9.31	0	0
Stage 3	0.23	6.36	80	0
Total	1.29	32.49		
Hydro				
KDPH	0.00	1.21	0	0
VTRNA	0.00	0.16	0	0
TILLARI	0.00	2.38	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.20	2.26	80	0
RNGR+BHTSA	0.23	1.72	10	9
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.03	0.36	2	1
GHATGHAR	0.00	7.08	0	0
Total	0.46	15.18		
Wind				
Total	36.34	257.26	0	0
Total	36.34	257.26		
CPP				
APML(Mus)	12.16	143.86	0	0
JSWEL(Mus)	19.15	217.67	0	0
VIPL(Mus)	10.72	130.92	0	0
RPLAMT(Mus)	18.62	209.03	0	0
WPCL(Mus)	2.77	38.29	0	0
Other(Mus)	4.72	50.65	0	0
Total	68.15	790.42		
SOLAR				
Total	1.03	11.82	0	0
Total	1.03	11.82		
Tata				
Trombay 5	10.16	115.97	488	318
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.69	18.19	115	92
Trombay 7B	1.53	12.56	65	56
Trombay 8	5.55	62.26	251	199
TATA Hydro	1.88	33.24	265	36
Total	21.80	242.23		
R-INFRA				
1-2	9.94	123.16	509	401
Total	9.94	123.16		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
Chandrapur 8	0.00	14.80	MSPGCL Thermal	113.67	1442.88	MSPGCL Total	124.64	1569.90
Chandrapur 9	0.00	0.00	MSPGCL Thml+Gas	122.89	1522.23	Koyna 1,2 & 4 Total	1.06	26.13
Koradi 9	0.00	18.36	MSPGCL Hydro	1.75	47.68	State Total	261.90	2994.81
Parli 8	0.00	0.00						

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Jun/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	4780	140	418	5338	1704	2822	0	5905	5962	-1563	14263	0	14263	2986	17249	49.99
2	4654	82	419	5155	1708	2815	0	5748	5635	-1465	13848	0	13848	2740	16588	50.00
3	4490	50	358	4898	1682	2812	0	5628	5885	-1478	13799	0	13799	2582	16381	49.98
4	4486	50	284	4820	1609	2802	0	5552	5437	-1375	13293	0	13293	2474	15767	49.98
5	4492	65	295	4852	941	2796	0	5485	5824	-1313	13100	0	13100	2414	15514	50.01
6	4516	55	283	4854	1571	2785	0	5469	5889	-1316	13783	0	13783	2419	16202	49.99
7	4670	50	298	5018	1342	2778	5	5540	5793	-1215	13721	0	13721	2317	16038	50.01
8	4862	50	289	5201	1318	2812	27	5573	6018	-1202	14174	0	14174	2303	16477	50.05
9	4551	55	334	4940	1330	2945	60	5737	5990	-1290	13975	0	13975	2393	16368	50.00
10	4619	93	356	5068	1308	2973	75	5905	6175	-1413	14186	0	14186	2557	16743	49.98
11	4780	131	384	5295	1631	2980	102	6138	5792	-1517	14283	0	14283	2821	17104	49.97
12	4712	141	438	5291	1126	2889	143	6210	6118	-1392	14175	0	14175	2901	17076	49.96
13	4808	54	429	5291	1205	2824	152	6012	6151	-1357	14266	0	14266	2918	17184	49.92
14	4889	66	438	5393	1369	2835	131	5903	5962	-1292	14398	0	14398	2852	17250	49.97
15	4900	56	426	5382	1373	2845	131	5992	6097	-1300	14528	0	14528	2912	17440	49.96
16	4924	56	420	5400	1761	2867	96	6042	5891	-1323	14692	0	14692	2957	17649	49.94
17	4651	51	407	5109	1775	2828	74	5852	5605	-1409	13982	0	13982	2875	16857	49.99
18	4648	52	411	5111	1725	2642	27	5081	5303	-1418	13390	0	13390	2791	16181	49.98
19	4728	57	422	5207	1580	2644	5	5113	5081	-1390	13127	0	13127	2728	15855	50.01
20	4784	74	417	5275	1635	2688	0	5801	6011	-1335	14274	0	14274	2741	17015	49.95
21	4895	147	425	5467	1757	2935	0	5820	5935	-1359	14735	0	14735	2782	17517	49.94
22	4918	64	426	5408	1606	2996	0	5650	5588	-1345	14253	0	14253	2720	16973	49.91
23	5017	52	427	5496	1739	2952	0	5655	5500	-1421	14266	0	14266	2726	16992	49.97
24	4892	62	417	5371	1543	2887	0	5613	5606	-1469	13938	0	13938	2785	16723	49.98
MUs	113.67	1.75	9.22	124.64	36.34	68.15	1.03	137.42	139.25	-32.96	336.45	0.00	336.45	64.69	401.14	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jun/2016

Position as on 6.30 Hrs of 12/Jun/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
CENT.SECTOR	Tarapur 2	160	10/09/2015	12.55		Continued.	Refuelling work	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
CENT.SECTOR	TARAPUR-3	540	23/05/2016	20.30		Continued.	Annual Maintenance Work.	
IPP	JSW (J) U2	300	01/06/2016	00.30		Continued.	Annual Maintenance Work.	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No Schedule	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	Adani U-3	660	20/04/2016	03.33		Continued.	Furnace Pressure High	
IPP	Adani U-5	660	05/05/2016	23.09		Continued.	Due to Unavailblity of Water.	
RGPL	Dabhol 3A	230	07/05/2016	18.44		Continued.	Low Vaccum	
IPP	Adani U-1	660	13/05/2016	22.53		Continued.	Water Shortage	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule From MSEDCL	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
IPP	Adani U-2	660	25/05/2016	21.22		Continued.	Water Shortage.	
IPP	WPCL U-3	135	08/06/2016	02.00	12/06/2016	23.16	ESP Bag Filter Problem	
MSPGCL	Chandrapur Unit 7	500	09/06/2016	12.49	11/06/2016	06.49	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	10/06/2016	01.56	12/06/2016	00.22	Drum level low	
MSPGCL	Bhusawal Unit 4	500	10/06/2016	09.00		Continued.	BTL	
MSPGCL	Chandrapur Unit-8	500	10/06/2016	12.38		Continued.	Due to Station T/F trip.	
RGPL	Dabhol 2B	230	10/06/2016	13.46	12/06/2016	21.54	Change Over	
MSPGCL	Bhusawal Unit 2	210	11/06/2016	01.32	11/06/2016	06.02	132/11KV 25MVA T/F-1 Cought Fire At Deepnagr Ecr.	
MSPGCL	Bhusawal Unit 3	210	11/06/2016	01.32	11/06/2016	04.44	132/11KV 25MVA T/F-1 Cought Fire At Deepnagr	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jun/2016

Position as on 6.30 Hrs of 12/Jun/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							Ecr.	
MSPGCL	Uran Unit B0	120	11/06/2016	02.25	11/06/2016	10.36	Generation Transformer Bucholzt Protection Tripped.	
MSPGCL	Uran Unit 8	108	11/06/2016	02.25	11/06/2016	07.53	Generation Transformer Bucholzt Protection Tripped.	
MSPGCL	Bhusawal Unit 3	210	11/06/2016	04.47	11/06/2016	09.00	Drum level low	
MSPGCL	Koradi Unit-8	660	11/06/2016	08.21	11/06/2016	11.42	PA Fan problem	
MSPGCL	Chandrapur Unit 3	210	11/06/2016	23.54		Continued.	ID Fan Problem	
MSPGCL	Chandrapur Unit 9	500	12/06/2016	18.13		Continued.	Low furnace pressure	
RGPL	Dabhol 2A	230	12/06/2016	19.58		Continued.	Combustion Chamber problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2016

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Tirora ckt-II	IntraState	11/06/2016	17.04	11/06/2016	18.07	T	Distance Protection
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	10/06/2016	09.20	11/06/2016	01.03	PO	DC Bushing.
Chandrapur - Padghe Hvdc Pole 1	IntraState	11/06/2016	06.29	11/06/2016	11.04	T	Distance Protection
Chandrapur - Padghe Hvdc Pole 1	IntraState	12/06/2016	07.15	12/06/2016	20.15	PO	Cold washing and Insulator string repl.work
400 KV LINE Outages/Trippings							
Kolhapur Solapur (PG) II	InterState	10/06/2016	11.49	11/06/2016	10.24	T	Over Voltage
Dhule Sar'Sarovar I	InterState	10/06/2016	17.21	11/06/2016	08.03	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	11/06/2016	17.44		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	11/06/2016	17.46	12/06/2016	10.15	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	12/06/2016	17.28		Continued.	HT	Over Voltage
Ektuni-Bableshtar ckt II	IntraState	07/06/2016	19.35	11/06/2016	12.25	HT	To Control Bblr-Pdg Line Loading.
Karad-Jaigad - I	IntraState	08/06/2016	15.39	11/06/2016	10.15	T	Distance Protection Operated(RFC & 16.40 Hra).
karad -kolhapur-II	IntraState	08/06/2016	16.52		Continued.	HT	Over Voltage
Ektuni-Bableshtar ckt I	IntraState	08/06/2016	19.28		Continued.	HT	To control Load of Padgha-BBLSR Line
Nagothane - Dabhol-II	IntraState	10/06/2016	12.15	11/06/2016	08.20	EO	Emergency outage (RFC at 17:20hrs)
Babhaleshtar - Padghe-II	IntraState	11/06/2016	05.41	11/06/2016	06.02	T	Tripped Only From Padgha End Air Succesful From Babhaleshtar End.
Lonikand I - Koyna stage-IV	IntraState	11/06/2016	07.20	11/06/2016	19.13	PO	String Replacement Work.
Tapitanda Waluj	IntraState	11/06/2016	12.33	11/06/2016	15.54	EO	Attending Broken Jumper.
Karad-Jaigad - I	IntraState	11/06/2016	16.07		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	12/06/2016	04.05	12/06/2016	15.21	HT	Over Voltage
Padghe - Kharghar	IntraState	12/06/2016	06.11		Continued.	T	Distance Protection
Koradi-Bhusawal	IntraState	12/06/2016	11.37	12/06/2016	12.38	T	Distance Protection
Kalwa - Talegaon(PG)	IntraState	12/06/2016	15.10		Continued.	EO	Replace Decapped string
Girwali-Solapur (Lamboti)	IntraState	12/06/2016	17.11	12/06/2016	19.00	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220kv 315MVA ICT-I@Parly	IntraState	06/06/2016	09.36		Continued.	PO	Bushing replacement
400/220/33kv, 500 Mva Ict-2 @Khaparkheda	IntraState	11/06/2016	16.21	11/06/2016	18.04	T	Tripped On NDR.
220 KV LINE Outages/Trippings							
Nasik Navsari I	InterState	09/06/2016	09.40		Continued.	PO	Outage.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Padghe - Vasai	IntraState	24/01/2016	08.32		Continued.	PO	For Formation of Temp. Padgha-Borivali (Charge upto 51/1).
Jejuri-Parvati	IntraState	09/06/2016	07.00		Continued.	PO	Pune Ringmain Re-Orientation Work.
Padghe - Kamba	IntraState	11/06/2016	10.21	11/06/2016	13.57	T	Distance Protection
Nagothane - ACCIL	IntraState	11/06/2016	10.46	11/06/2016	17.01	EO	Tree Cutting Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2016

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kalwa - Airoli Knowledge Park	IntraState	11/06/2016	14.21	11/06/2016	16.18	T	LBB Opreted.
Eklahare (Gcr) - Airoli Know Park	IntraState	11/06/2016	14.21	11/06/2016	15.17	T	Tripped.
Kalwa - Borivali	IntraState	11/06/2016	14.21	11/06/2016	14.54	T	Distance Protection
Kalwa - Mulund 1	IntraState	11/06/2016	14.21	11/06/2016	15.06	T	Distance Protection
Kalwa 52B Interconnector CB	IntraState	11/06/2016	14.21	11/06/2016	15.24	T	LBB Opreted.
Hingoli- Girawali	IntraState	12/06/2016	00.53	12/06/2016	08.41	T	Distance Protection
Eklahare (Gcr) - Airoli Know Park	IntraState	12/06/2016	04.34	12/06/2016	15.06	T	Distance Protection
Khaparkheda-Kanhan	IntraState	12/06/2016	06.14	12/06/2016	12.29	PO	Repl.of Jumper and fixing of repair sleeve on damaged conductor
Goregaon Versova Line 2	IntraState	12/06/2016	09.11	12/06/2016	17.22	PO	Repl.of CVT
Babhaleshwar - Degaon Rangari	IntraState	12/06/2016	10.48	12/06/2016	15.34	PO	Line Maintenance work
Dhule - Dondaicha Ckt	IntraState	12/06/2016	15.15	12/06/2016	16.15	T	PT Pannel to control panel Cable Burst
Dondaicha(220)-Amalner(220)	IntraState	12/06/2016	15.15	12/06/2016	16.13	T	PT Pannel to control panel Cable Burst
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	08/06/2016	20.04		Continued.	HT	Due to Rise in Bus Sectionaliser Current.
220/132 Kv 200 Mva Vijai Ict 1 @Babhleshwar	IntraState	11/06/2016	10.55	11/06/2016	11.40	PO	Premonsoon Maintenance Work.
220/132 Kv 200 Mva Cgl Ict 3 @Babhleshwar	IntraState	11/06/2016	11.45	11/06/2016	13.30	PO	Premonsoon Maintenance Work.
220/100 Kv 200 Mva Vijai Ict 3 @Padghe	IntraState	11/06/2016	11.47	11/06/2016	13.39	PO	Premansoon Maintenance Work.
220/100 Kv 200 Mva Bhel Ict 1 @Kalwa	IntraState	11/06/2016	14.21	11/06/2016	15.17	T	LBB Opreted.
220/100 kV 200 MVA ICT-II @Kalwa	IntraState	11/06/2016	14.21	11/06/2016	15.20	T	LBB Opreted.
220/100 Kv 200 MVA ICT IV @Padghe	IntraState	11/06/2016	15.52	11/06/2016	17.32	PO	Maintenance Work An Premonsoon Work.
220/132 Kv 200 MVA ICT II @Babhleshwar	IntraState	11/06/2016	15.55	11/06/2016	17.20	PO	Premonsoon Maintenance Work.
220/132 kV 100MVA ICT I @Balapur	IntraState	12/06/2016	13.35	12/06/2016	14.08	T	132KV B phase PT Burst
132 KV LINE Outages/Trippings							
Babhleshwar - Sangamner	IntraState	11/06/2016	15.40	11/06/2016	17.15	PO	Diagnostic Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage