

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Jun/2020 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	98.221	997.611	1) Gujrat	2.706	38.864
2) Hydro	4.875	102.654	2) Madhya Pradesh	8.173	70.305
3) Gas	3.338	28.809	3) Chattisgarh	6.400	60.590
Total MSPGCL	106.434	1129.074	4) Maharashtra	129.398	1184.521
B) 1) APML	43.651	523.316	5) Goa (Amona)	-0.286	-2.156
2) JSWEL	17.278	182.615	Total	146.391	1352.124
3) VIPL	0.000	0.000	a) Mumbai Schedule	21.791	218.085
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	20.717	200.842
5) WPCL	2.697	27.941	c) MSEDCL Bilateral *	48.710	394.046
6) Other IPP	7.480	91.077	Include PX	24.580	122.592
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	21.791	218.085
C) 1) TPCL Thermal	7.355	84.390	Include PX	14.783	141.075
2) TPCL Hydro	5.005	48.631	Standby	0.000	0.000
3) TPCL Gas	4.395	48.457	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.033	111.455	1) MSEDCL	337.748	3484.901
D) STATE			2) Mumbai Discoms	48.493	493.770
1) Thermal	187.715	2018.405	TOTAL STATE	386.241	3978.671
(A1+C1+C4+(B1-B6))					
2) Hydro	9.880	151.285			
(A2+C2)					
3) Gas	7.733	77.266			
(A3+B7+C3)					
4) Wind	29.065	313.999			
6) SOLAR	5.469	65.597			
TOTAL STATE	239.862	2626.552			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4081	4176	4202	3517
MSPGCL Hydro	402	365	225	88
MSPGCL Gas	133	131	133	147
MSPGCL Total Generation	4616	4672	4560	3752
Central Sector Receipt	7235	7014	5521	5572
WIND	1055	1236	1605	1167
CPP / IPP Thermal	2956	2975	3003	2850
CPP / IPP Gas	0	0	0	0
SOLAR	592	526	0	0
Exchange with Mumbai	-1051	-800	-943	-796
MSEDCL DEMAND MET	15403	15623	13746	12545
Load Shedding	0	0	0	0
MSEDCL DEMAND	15403	15623	13746	12545
TPCL GENERATION	599	930	646	568
AEML GENERATION	501	500	411	375
MUMBAI DEMAND	2151	2230	2000	1739
STATE DEMAND MET	17554	17853	15746	14284
STATE DEMAND	17554	17853	15746	14284
Frequency (Hz)	50.04	50.00	49.98	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 06:04 Hrs	49.8 Hz at 12:00 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Jun/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	18.14	0	0
Unit 10	0.00	18.21	0	0
Total	0.00	36.35		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	2.50	0	0
Unit 5	0.00	4.40	0	0
Total	0.00	6.91		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	2.61	0	0
Total	0.00	2.61		
Chandrapur				
Unit 3	3.86	33.99	173	120
Unit 4	3.77	31.78	161	141
Unit 5	10.20	73.25	451	365
Unit 6	10.46	84.08	452	360
Unit 7	10.28	103.68	445	360
Unit 8	11.47	112.55	500	380
Unit 9	10.82	107.77	465	360
Total	60.84	547.11		
Paras				
Unit 3	5.44	56.80	244	187
Unit 4	5.72	59.03	250	190
Total	11.16	115.83		
Khaparkheda				
Unit 1	4.04	43.71	175	155
Unit 2	4.32	45.96	185	160
Unit 3	1.94	39.18	190	0
Unit 4	4.34	45.50	190	174
Unit 5	11.58	114.45	500	450
Total	26.22	288.80		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	3.34	28.81	148	131
Total	3.34	28.81		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	1.70	24	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.16	1.70		
Koyna				
Stage 1-2	2.40	36.52	255	35
Stage 4	0.00	30.87	0	0
Stage 3	0.35	15.43	80	0
Total	2.75	82.82		
Hydro				
KDPH	0.70	4.31	29	29
VTRNA	0.00	0.00	0	0
TILLARI	0.60	6.01	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.04	0.66	20	0
RNGR+BHTSA	0.25	2.56	11	10
BHANDARDRA	0.44	4.76	35	10
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.09	1.54	13	1
GHATGHAR	0.00	0.00	0	0
Total	2.12	19.83		
Wind				
Total	29.06	314.00	0	0
Total	29.06	314.00		
CPP				
APML(Mus)	43.65	523.32	0	0
JSWEL(Mus)	17.28	182.62	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.70	27.94	0	0
Other(Mus)	7.48	91.08	0	0
Total	71.11	824.95		
SOLAR				
Total	5.47	65.60	0	0
Total	5.47	65.60		
Tata				
Trombay 5	7.36	84.39	308	303
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	30.89	118	116
Trombay 7B	1.59	17.57	67	65
Trombay 8	0.00	0.00	0	0
TATA Hydro	5.00	48.63	449	70
Total	16.76	181.48		
AEML				
DTPS U-1&2	11.03	111.46	502	371
Total	11.03	111.46		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	98.22	997.61	MSPGCL Total	106.43	1129.07
			MSPGCL Thml+Gas	101.56	1026.42	Koyna 1,2 & 4 Total	2.40	67.39
			MSPGCL Hydro	4.88	102.65	State Total	239.86	2626.55

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Jun/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4095	218	135	4448	1224	2968	0	0	5284	5365	-785	13220	0	13220	2134	15354	50.03
2	4135	93	145	4373	1222	2947	0	0	5481	5278	-821	12999	0	12999	2013	15012	50.01
3	4135	88	136	4359	1131	2910	0	0	5464	5372	-890	12882	0	12882	1887	14769	50.03
4	3856	98	146	4100	1125	2858	0	0	5426	5323	-842	12564	0	12564	1784	14348	50.03
5	3517	88	147	3752	1167	2850	0	0	5525	5572	-796	12545	0	12545	1739	14284	50.00
6	3729	105	137	3971	1129	2853	0	0	6051	6268	-781	13440	0	13440	1723	15163	50.04
7	4047	115	147	4309	1069	2957	0	38	6537	6485	-654	14204	0	14204	1699	15903	50.03
8	4087	98	148	4333	1004	2942	0	155	6596	6667	-694	14407	0	14407	1714	16121	50.00
9	4068	158	135	4361	1152	2965	0	364	6634	6883	-892	14833	0	14833	1836	16669	49.99
10	4073	412	144	4629	1156	2985	0	538	6725	6696	-943	15061	0	15061	2011	17072	50.00
11	4081	402	133	4616	1055	2956	0	592	7094	7235	-1051	15403	0	15403	2151	17554	50.04
12	4093	203	142	4438	854	2934	0	698	7430	7399	-1090	15233	0	15233	2218	17451	50.04
13	4104	164	131	4399	836	2938	0	716	7550	7525	-1053	15361	0	15361	2200	17561	49.99
14	4127	211	132	4470	782	2958	0	637	7343	7451	-1064	15234	0	15234	2227	17461	49.96
15	4168	310	140	4618	955	2965	0	630	7164	7122	-865	15425	0	15425	2279	17704	50.01
16	4176	365	131	4672	1236	2975	0	526	7077	7014	-800	15623	0	15623	2230	17853	50.00
17	4219	345	141	4705	1399	2945	0	345	6525	6429	-699	15124	0	15124	2135	17259	50.00
18	4176	270	131	4577	1464	2978	0	188	5877	6018	-1041	14184	0	14184	2010	16194	50.04
19	4176	159	143	4478	1519	2986	0	42	5316	5316	-995	13346	0	13346	1928	15274	50.01
20	4202	225	133	4560	1605	3003	0	0	5416	5521	-943	13746	0	13746	2000	15746	49.98
21	4206	199	145	4550	1578	3045	0	0	5076	4982	-715	13440	0	13440	2081	15521	50.02
22	4263	194	135	4592	1492	3070	0	0	4724	4940	-672	13422	0	13422	2112	15534	49.99
23	4248	180	145	4573	1546	3106	0	0	4678	4697	-777	13145	0	13145	2183	15328	50.03
24	4240	175	136	4551	1365	3012	0	0	4845	4833	-854	12907	0	12907	2211	15118	50.03
MUs	98.22	4.88	3.34	106.43	29.06	71.11	0.00	5.47	145.84	146.39	-20.72	337.75	0.00	337.75	48.50	386.25	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jun/2020

Position as on 6.30 Hrs of 12/Jun/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Shaft Position	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Shaft position	
MSPGCL	Koradi Unit-8	660	31/05/2020	22.56		Continued.	Heavy steam Leakage in super heater.(Converted in To Zero schedule w.e.f	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jun/2020

Position as on 6.30 Hrs of 12/Jun/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							03.06.2020 01.28)	
MSPGCL	Bhusawal Unit 4	500	01/06/2020	07.16		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 5	500	01/06/2020	12.21		Continued.	Zero schedule By MSEDCL	
MSPGCL	Parli Unit 8	250	01/06/2020	13.13		Continued.	Zero schedule By MSEDCL	
MSPGCL	Koradi Unit 9	660	02/06/2020	15.42		Continued.	Flame Failure	
MSPGCL	Koradi Unit 10	660	03/06/2020	02.20		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-1	660	03/06/2020	15.02		Continued.	RSD	
IPP	Adani U-5	660	04/06/2020	12.29		Continued.	Zero Schedule.	
MSPGCL	Khaparkheda Unit 3	210	09/06/2020	18.39	11/06/2020	11.38	Boiler Tube Leakage	
IPP	Adani U-4	660	12/06/2020	10.30		Continued.	Zero Schedule	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	10/06/2020	18.05	11/06/2020	10.13	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	11/06/2020	17.25		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	02/06/2020	18.42		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/06/2020	02.40	12/06/2020	11.01	T	Over Voltage
Padghe - Nagothane - I	IntraState	05/06/2020	00.25		Continued.	HT	Over Voltage (RFC At 20:20Hrs)
Babhaleshtar - Padghe-I	IntraState	08/06/2020	09.45		Continued.	EO	Attend CB Problem & Testing Work.(RFC at 20:20 Dt-08.06.2020)
Akola II - RPL(Rattanindia) Ckt-II	IntraState	10/06/2020	17.13	11/06/2020	08.59	T	Distance Protection.
Khadka-Aurangabad (Waluj)	IntraState	10/06/2020	17.36	12/06/2020	07.49	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	10/06/2020	23.22		Continued.	HT	Over Voltage
N.Koyna-Karad - Ckt I	IntraState	11/06/2020	09.05	11/06/2020	18.43	PO	For attending the problem of faulty trip Ckt of CB.
BABHALESHWAR - RPL(NASHIK) CKT - 1	IntraState	11/06/2020	10.40		Continued.	HT	Over Voltage
Koradi-Bhusawal	IntraState	11/06/2020	21.10	12/06/2020	06.37	EO	Attending Hot Spot
Deepnagar - Aurangabad	IntraState	12/06/2020	00.13	12/06/2020	13.51	T	Distance Protection
Warora -IEPL	IntraState	12/06/2020	09.21	12/06/2020	20.10	PO	Routine Maintenance Work
Ektuni - Taptitanda Ckt I	IntraState	12/06/2020	12.02	12/06/2020	19.00	PO	Quarterly Maintenance Work
Khadka-Aurangabad (Waluj)	IntraState	12/06/2020	17.00		Continued.	HT	Over Voltage
Koradi-Bhusawal	IntraState	12/06/2020	21.36		Continued.	T	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	03/06/2020	08.28	12/06/2020	11.08	HT	Over Voltage
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	03/06/2020	15.30	11/06/2020	13.30	T	Oil Level low(Kept on Humming from 16.38Hrs DT.07-06-2020)
400/220kv, 500 MVA ICT-III @Babhaleshtar	IntraState	03/06/2020	17.37		Continued.	HT	Over Voltage
400/220KV 500MVA ICT 2@koradi 2	IntraState	05/06/2020	07.30	11/06/2020	13:23	PO	1) Tan delta measurement of bushing of ICT- 2.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	11/06/2020	06.26	11/06/2020	09.41	PO	Pre-monsoon maintenance work.
400/220 Kv 500 Mva ICT- I @Jejuri	IntraState	11/06/2020	09.08	11/06/2020	17.22	EO	To carry out the work of RTV coating on tertiary side equipment of ICT-I.
400/220kv, 500 Mva ICT-1 @Deepnagar	IntraState	12/06/2020	08.02	12/06/2020	18.20	HT	Damaged fire survival cable and fire assembly replacement work
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	12/06/2020	09.59	12/06/2020	14.33	PO	For changing tap from 13 to 9
400/220 Kv 315 Mva Ict -2 @New Koyna	IntraState	12/06/2020	10.32	12/06/2020	16.57	PO	For attending the problem of faulty trip ckt-II of CB
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	12/06/2020	15.23	12/06/2020	17.26	PO	Half yearly maintenance work
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Boiser(M)-Boiser(PG) -III	InterState	12/06/2020	11.26		Continued.	HT	Stringing of conductor and earthwire
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Bapgaon - Kalwa	IntraState	08/06/2020	07.33	11/06/2020	20.25	PO	Stringing work from old Tower to

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							New CTT Tower at both end, Connection of Jumpers to the cable termination kit.
Urse-Chinchwad (ST tap)	IntraState	11/06/2020	07.31	11/06/2020	11.16	EO	for Replacement of R PH LA & PDR Relay.
Sonkhar - Trombay	IntraState	11/06/2020	08.43	11/06/2020	17.00	PO	To Avail Outage On Trombay Bus -2.
Warora - Wardha	IntraState	11/06/2020	09.16	12/06/2020	09.21	PO	Routine Maintenance and testing work. Nut Bolt Tightening work
Talandge(400 Kv)- Mumewadi 2 Line	IntraState	11/06/2020	09.28	11/06/2020	14.46	PO	Annual Maintenance Work
Kolshet-Roma	IntraState	11/06/2020	09.42	11/06/2020	17.31	PO	220 KV Roma B Phase CT replacement , 2) Pre-monsoon maintenance , 3) Isolator Servicing & alignment ,4) Hot-spot attending 5) Bay Maint .
Butibori-Indorama	IntraState	11/06/2020	09.46	11/06/2020	18.56	PO	Replacement work
220 KV KRUSHNOOR - NANDED (KUMBHARGAON) CKT -1	IntraState	11/06/2020	14.18	11/06/2020	16.01	PO	Tan Delta.
220KV Chalisagaon-Kopergaon	IntraState	11/06/2020	22.35	12/06/2020	01.05	T	Distance Protection
Talandge(400)- Mudshingi 2 Line	IntraState	11/06/2020	23.43	12/06/2020	13.35	HT	CT Saturation.
Nalasopara-Boisar	IntraState	12/06/2020	09.05	12/06/2020	19.09	PO	Stringing of conductor and earthwire
Boisar Versova Line	IntraState	12/06/2020	09.52	12/06/2020	23.38	HT	Load Managment
Boisar(M) - Ghodbunder	IntraState	12/06/2020	10.12	12/06/2020	23.29	HT	Load Management
Waluj- Padegaon li	IntraState	12/06/2020	10.18	12/06/2020	21.07	PO	To replace Tan Delta CT
Boisar II - Boisar PG II	IntraState	12/06/2020	11.17	12/06/2020	23.18	PO	Stringing of conductor and earthwire
Hingoli- Girawali	IntraState	12/06/2020	11.25	12/06/2020	15.37	EO	LA Replacement work
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	11/06/2020	09.00	11/06/2020	09.35	PO	pre-monsoon maintenance ICT oil leakage attending work,hot spot attending.
220/33KV 100MVA ICT II @ chakan	IntraState	11/06/2020	14.17	11/06/2020	17.00	PO	OLTC Testing work.
220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	IntraState	12/06/2020	03.30	12/06/2020	09.53	EO	To attend Hot Spot
220/132 KV 100MVA ICT-I @ Belewadi	IntraState	12/06/2020	09.30	12/06/2020	13.34	PO	Testing Work
220/100 Kv 200MVA ICT-I @Padghe	IntraState	12/06/2020	09.48	12/06/2020	12.31	PO	For Oil topping work
220/132 Kv 200 Mva Ict - 2 @Harangul	IntraState	12/06/2020	10.06	12/06/2020	15.01	PO	LA Replacement work
220/132kv 100MVA ICT-2 @ Baramati	IntraState	12/06/2020	10.35	12/06/2020	13.55	PO	Premonsoon Maintenance work
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	12/06/2020	11.07	12/06/2020	19.30	EO	HV Side Unbalance current
220/132kv 100mva Vijai Ptr No 1 @Baramati	IntraState	12/06/2020	14.35	12/06/2020	16.10	PO	Premonsoon Maintenance work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage