

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Jun/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	148.214	1843.860	1) Gujrat	-8.162	-68.086
2) Hydro	8.900	142.522	2) Madhya Pradesh	3.866	40.050
3) Gas	6.417	51.519	3) Chattisgarh	2.230	23.280
Total MSPGCL	163.531	2037.901	4) Maharashtra	156.588	1910.368
B) 1) APLM	67.884	789.747	5) Goa (Amona)	-0.781	-10.835
2) JSWEL	18.120	188.006	Total	153.741	1894.777
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.467	380.246
4) RPL(AMT)	25.166	273.600	b) Mumbai Drawl	32.129	419.230
5) SWPGPL	6.287	92.856	c) MSEDCL Bilateral *	62.483	812.626
6) Other IPP	13.544	164.634	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.467	380.047
C) 1) TPCL Thermal	15.334	168.621	Include PX	0.000	0.000
2) TPCL Hydro	3.726	56.724	Standby	0.000	0.199
3) TPCL Gas	2.098	16.943	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.500	124.956	1) MSEDCL	446.463	5327.732
D) STATE			2) Mumbai Discoms	64.787	786.477
1) Thermal	306.049	3646.280	3) Other Discoms	8.971	104.252
(A1+C1+C4+(B1-B6))			TOTAL STATE	520.221	6218.461
2) Hydro (A2+C2)	12.626	199.246			
3) Gas (A3+B7+C3)	8.515	68.462			
4) Wind	31.083	304.778			
6) SOLAR	8.207	104.915			
TOTAL STATE	366.480	4323.681			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6073	6100	6277	6167
MSPGCL Hydro	386	360	612	288
MSPGCL Gas	259	264	286	277
MSPGCL Total Generation	6718	6724	7176	6732
Central Sector Receipt	8404	7701	5065	5236
WIND	760	1041	1311	1206
CPP / IPP Thermal	5078	5139	5883	5792
CPP / IPP Gas	0	0	0	0
SOLAR	1118	1171	0	0
Exchange with Mumbai	-1748	-1728	-1166	-1170
MSEDCL DEMAND MET	19926	19636	17872	17414
Load Shedding	0	0	0	0
MSEDCL DEMAND	19926	19636	17872	17414
TPCL GENERATION	799	847	1094	979
AEML GENERATION	493	498	489	453
MUMBAI DEMAND	3040	3073	2749	2602
OTHER DISCOM DEMAND	404	412	396	382
STATE DEMAND MET	23370	23122	21018	20398
STATE DEMAND	23370	23122	21018	20398
Frequency (Hz)	49.86	50.01	50.04	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 18.02 Hrs	49.73 Hz at 11.44 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.36	47.86	190	145
Unit 7	0.00	0.00	0	0
Unit 8	13.29	146.06	570	491
Unit 9	12.05	133.95	527	441
Unit 10	12.74	135.80	555	473
Total	42.43	463.66		
Bhusawal				
Unit 3	3.20	36.85	155	120
Unit 4	10.23	113.82	470	280
Unit 5	9.58	95.53	450	285
Total	23.02	246.20		
Parli				
Unit 6	4.30	52.84	235	150
Unit 7	4.17	46.00	227	140
Unit 8	3.12	34.25	135	126
Total	11.59	133.09		
Chandrapur				
Unit 3	3.02	30.85	133	123
Unit 4	2.89	33.20	130	116
Unit 5	7.80	93.64	376	295
Unit 6	8.90	100.89	405	290
Unit 7	2.42	89.38	396	0
Unit 8	10.18	118.28	456	365
Unit 9	0.00	84.83	0	0
Total	35.22	551.06		
Paras				
Unit 3	4.39	54.36	213	140
Unit 4	4.65	48.72	226	143
Total	9.05	103.07		
Khaparkheda				
Unit 1	2.60	34.80	130	90
Unit 2	3.50	39.16	155	130
Unit 3	3.52	45.37	184	0
Unit 4	0.00	13.16	0	0
Unit 5	10.24	119.78	475	350
Total	19.86	252.28		
Nasik				
Unit 3	3.53	41.58	183	123
Unit 4	3.53	27.75	180	122
Unit 5	0.00	25.17	0	0
Total	7.06	94.50		
Uran				
All Units	6.42	51.52	297	213
Total	6.42	51.52		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.22	3.50	21	0
Total	0.22	3.50		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.66	33.46	470	40
Stage 4	0.00	27.05	0	0
Stage 3	0.51	15.43	240	0
Total	3.17	75.94		
Hydro				
KDPH	0.49	5.62	21	21
VTRNA	0.00	0.00	0	0
TILLARI	0.29	1.12	58	0
BHIRA T.R.	0.24	3.35	80	0
SMLHY_PTN	4.48	51.99	203	167
GHATGHAR	0.00	1.01	0	0
Total	5.51	63.09		
Wind				
Total	31.08	304.78	0	0
Total	31.08	304.78		
CPP				
APML(Mus)	67.88	789.75	0	0
JSWEL(Mus)	18.12	188.01	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.17	273.60	0	0
SWPGPL-Mus	6.29	92.86	0	0
Other(Mus)	13.54	164.63	0	0
Total	131.00	1508.84		
SOLAR				
Total	8.21	104.92	0	0
Total	8.21	104.92		
Tata				
Trombay 5	9.93	109.70	447	279
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.14	11.14	54	45
Trombay 7B	0.95	5.80	44	38
TATA Hydro	3.73	56.72	374	0
Trombay 8	5.40	58.92	244	158
Total	21.16	242.29		
AEML				
DTPS U-1&2	11.50	124.96	500	449
Total	11.50	124.96		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	148.21	1843.86	MSPGCL Total	163.53	2037.90
			MSPGCL Thml+Gas	154.63	1895.38	Koyna 1,2 & 4 Total	2.66	60.51
			MSPGCL Hydro	8.90	142.52	State Total	366.48	4323.68

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 11/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6732	266	280	7278	1606	5972	0	0	6288	5706	-1279	18932	0	18932	2883	351	22166	50.03
2	6637	254	270	7162	1530	5788	0	0	5977	5879	-1159	18882	0	18882	2709	318	21908	50.00
3	6707	534	281	7522	1441	5945	0	0	5231	5297	-1142	18776	0	18776	2540	288	21604	49.99
4	6750	272	281	7302	1454	6005	0	0	5699	5124	-1100	18489	0	18489	2406	296	21192	50.01
5	6714	258	280	7252	1229	5951	0	0	5965	5507	-995	18639	0	18639	2290	306	21234	50.01
6	6735	316	281	7332	1160	5999	0	0	5936	5880	-1005	19040	0	19040	2281	326	21646	49.99
7	6639	548	280	7466	916	5936	0	79	6151	6077	-1035	19083	0	19083	2266	357	21706	49.94
8	6528	512	280	7320	759	5901	0	362	6530	6361	-1244	19084	0	19084	2320	374	21778	49.99
9	6123	382	270	6774	698	5503	0	730	7278	7192	-1477	19031	0	19031	2448	390	21868	50.05
10	5788	352	270	6410	700	5012	0	966	7684	7830	-1412	19110	0	19110	2669	396	22174	50.00
11	5673	396	270	6340	625	4917	0	1069	8107	8479	-1626	19416	0	19416	2910	388	22714	49.94
12	6073	386	259	6718	760	5078	0	1118	8389	8404	-1748	19926	0	19926	3040	404	23370	49.86
13	6100	360	264	6724	1041	5139	0	1171	8327	7701	-1728	19636	0	19636	3073	412	23122	50.01
14	5738	272	275	6286	1241	4860	0	1010	8332	8201	-1644	19576	0	19576	2946	378	22900	50.01
15	5864	342	237	6444	1345	4921	0	694	7722	7946	-1553	19411	0	19411	2987	385	22784	50.00
16	6188	264	220	6672	1829	5137	0	544	7065	6462	-1509	18739	0	18739	3010	397	22146	50.00
17	5658	230	214	6102	2241	5107	0	322	6685	6473	-1498	18341	0	18341	2932	407	21680	50.04
18	5020	414	213	5648	2042	4464	0	127	6441	6458	-1487	16828	0	16828	2834	424	20086	50.04
19	5596	386	259	6240	1980	4832	0	15	5788	5989	-1453	17200	0	17200	2778	404	20382	50.00
20	6005	680	286	6970	1614	5113	0	0	5099	5563	-1407	17438	0	17438	2877	415	20730	50.02
21	6277	612	286	7176	1311	5883	0	0	4814	5065	-1166	17872	0	17872	2749	396	21018	50.04
22	6286	288	287	6860	1267	5856	0	0	5595	5077	-1148	17511	0	17511	2656	402	20568	50.01
23	6167	288	277	6732	1206	5792	0	0	5682	5236	-1170	17414	0	17414	2602	382	20398	50.00
24	6216	288	297	6800	1088	5890	0	0	6127	5834	-1144	18090	0	18090	2581	378	21050	49.95
MUs	148.21	8.90	6.42	163.53	31.08	131.00	0.00	8.21	156.91	153.74	-32.13	446.46	0.00	446.46	64.79	8.97	520.22	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 11/Jun/2022

Position as on 6.30 Hrs of 12/Jun/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34	11/06/2022	17:36	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
IPP	RPL(AMT) U-4	270	31/05/2022	01:15		Continued.	Ash Conveyer problem.(Coal shortage From Dt 02.06.2022 @	
MSPGCL	Uran Unit 8	108	06/06/2022	23:03	11/06/2022	17:36	Gas shortage	
MSPGCL	Nasik Unit 5	210	08/06/2022	18:18	12/06/2022	08:31	ID Fan Problem	11/06/2022
MSPGCL	Koyna Unit 12	80	09/06/2022	07:40		Continued.	TO ATTEND BUTTERFLY VALVE PROBLEM.	
MSPGCL	Chandrapur Unit 9	500	09/06/2022	08:46		Continued.	Boiler Tube Leakage	13/06/2022
IPP	SWPGPL U-4	135	10/06/2022	23:00		Continued.	Boiler Bottom Ash System problem.	13/06/2022
MSPGCL	Chandrapur Unit 7	500	11/06/2022	07:00	12/06/2022	01:05	Air heater problem	12/06/2022
MSPGCL	Uran Unit 5	108	11/06/2022	14:29		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 3	210	11/06/2022	17:08	11/06/2022	19:34	Furnace Pressure High	
AEML	AEML Unit 1	250	11/06/2022	23:53		Continued.	Boiler Tube Leakage	13/06/2022
MSPGCL	Ghatghar Unit-2	125	12/06/2022	11:45		Continued.	CW Pump having heavy Vibration and Water leakage.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
400 KV AKOLA - AURANGABAD(PG) CKT -2	InterState	11/06/2022	18:59	11/06/2022	20:24	T	Tripped on Distance Protection.
DHULE - SSNNL CKT - 2	InterState	11/06/2022	19:42	12/06/2022	00:20	T	Tripped on Distance Protection.
DHULE - KHANDWA CKT - 2	InterState	12/06/2022	13:55	12/06/2022	18:22	HT	EMERGENCY OUTAGE AVAILABLE TO REPLACED FLASHOVER INSULATOR STRING REPLACEMENT
DHULE - SSNNL CKT - 2	InterState	12/06/2022	18:02			T	TRIPPED ON DISTANCE PROTECTION
DHULE - SSNNL CKT - 1	InterState	12/06/2022	19:27			T	TRIPPED ON DISTANCE PROTECTION
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/06/2022	16:32			HT	Load management
NEW KOYNA - DABHOL CKT - 2	IntraState	10/06/2022	12:50	11/06/2022	11:25	T	Distance Protection
KORADI - KHADKA	IntraState	10/06/2022	20:11	11/06/2022	02:15	T	Distance Protection
DEEPNAGAR - THAPTI TANDA	IntraState	10/06/2022	20:40	11/06/2022	16:10	T	Distance Protection
PADGHE - NAGOTHANE CKT - 1	IntraState	11/06/2022	07:00	11/06/2022	15:28	T	DP
CHANDRAPUR 2 - WARORA CKT-2	IntraState	11/06/2022	11:56	11/06/2022	21:38	HT	Line outage is required for restoration of broken OPGW between Tower No.477-478 of 400kV Bhadrawati-Ramagundam Ckt-2 line
CHANDRAPUR 2 - WARORA CKT-1	IntraState	11/06/2022	11:56	11/06/2022	21:34	HT	Line outage is required for restoration of broken OPGW between Tower No.477-478 of 400kV Bhadrawati-Ramagundam Ckt-2 line
EKTUNI - TAPTITANDA CKT - 1	IntraState	11/06/2022	13:10	11/06/2022	20:09	T	TRIPPED ON DISTANCE PROTECTION
PADGHE - NAGOTHANE CKT - 1	IntraState	11/06/2022	17:07	11/06/2022	23:47	T	Tripped on Distance Protection.
KHARGHAR - TALEGAON (PG)	IntraState	12/06/2022	06:58	12/06/2022	18:10	HT	PLAN OUTAGE AVAILABLE FOR SSN TO DSN AND CHEMICAL WASHING WORK
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2022	12:33			PO	For CB replacement work. ICT will be in service through TBC.
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)- BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
MUDSHINGI - CHIKODI	IntraState	06/06/2022	09:18			PO	Line reorientation work from D/C towers (Loc. 320 to 312 to M/C-9)) to M/C towers (Guide-D/C- M/C 3 to M/C 9) .
AAREY - AEML SAKI CKT - 1	IntraState	08/06/2022	11:19	11/06/2022	22:30	PO	Repair / restoration of 220 kV R- Phase with additional 2 nos. Joints. Repair of Y-Phase outer sheath.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
THEUR-JEJURI	IntraState	09/06/2022	09:20			PO	1)L.N.-9 old tower dismantling work , Errection of New tower, Destrining between L.N.- 8 to 9 & 9 to 10 , Stringing between L.N.- 8 to 9 & 9 to 10 (As L.N.- 9 bended & new tower foundation work completed) 2)L.N.-11, B, Pahgse,L.N.-18, B Phase, L.N.-21, B Phase 220 kV Jejuri Phursungi ckt I Double Jump ring work due to Hot spot Restrining between L.N.- 70 to 76 & 76 to 79 of 220 kV Theur Jejuri due to increased sag & ground clearance reduced
JEJURI-PHURSUNGI 1	IntraState	09/06/2022	09:43	11/06/2022	19:49	PO	1)L.N.-9 old tower dismantling work , Errection of New tower, Destrining between L.N.- 8 to 9 & 9 to 10 , Stringing between L.N.- 8 to 9 & 9 to 10 (As L.N.- 9 bended & new tower foundation work completed) 2)L.N.-11, B, Pahgse,L.N.-18, B Phase, L.N.-21, B Phase 220 kV Jejuri Phursungi ckt I Double Jump ring work due to Hot spot Restrining between L.N.- 70 to 76 & 76 to 79 of 220 kV Theur Jejuri due to increased sag & ground clearance reduced
URAN - KHARGHAR 1	IntraState	11/06/2022	01:19	11/06/2022	09:16	T	TRIPPED ON DIST. PROTN
NAGOTHANE - IPCL	IntraState	11/06/2022	05:05	11/06/2022	13:09	T	DP
NERLE - DASGAON	IntraState	11/06/2022	10:08	11/06/2022	17:21	PO	Insulator cleaning and jumper tightening
OSMANABAD - SOLAPUR (BALE)	IntraState	11/06/2022	10:24	11/06/2022	13:23	PO	Outage is required for Replacement of Suspension string at loc no. 2 & 3 R ph.
BOISAR II - BOISAR (PG) CKT - 1	IntraState	11/06/2022	10:29	12/06/2022	22:13	PO	220kV PGCIL Line 1 Bay Strengthening at 220kV Boisar 2 S/s (MSETCL).
A BUS @ BOISAR II	IntraState	11/06/2022	10:40	11/06/2022	21:00	PO	220kV PGCIL Line 1 Bay Strengthening at 220kV Boisar 2 S/s (MSETCL) however Stub Bus of PGCIL Line 1 passes over both 220kV A and 220kV B Bus, therefore for safety purpose 220kV A and 220kV B-Bus outage (from 11.06.2022 to 12.06.2022) is essential.
PANDHARPUR - MALINAGAR	IntraState	11/06/2022	10:45	11/06/2022	18:24	PO	Outage is required for changing / replacement of faulty string at loc no. LILO Portion - 12, 15, 19, 28, 78, 79, 81, 82.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	11/06/2022	11:39	11/06/2022	14:39	EO	220Kv BBLR Nashik line ckt No.1, LOC 231 Y ph BBLR side , 232 Y ph nasik side . 133 Y Ph Nasik side . 123 Y Ph Nasik side , 142 Y ph Nasik side . 144 Y ph Nasik side , 147 B ph . Jumper replacement 191 Y ph nasik side . as detected in the thermovision carried on dated 10.06.2022.
KALWA SALSETTE - 4	IntraState	12/06/2022	01:14	12/06/2022	03:50	EO	Emergency outage for replacing C Phase insulator.
SATANA - GANGAPUR	IntraState	12/06/2022	05:50	12/06/2022	07:55	T	Tripped on DP
BABLESHWAR -BHENDA	IntraState	12/06/2022	18:40	12/06/2022	20:00	EO	nut bolt tightening of B and Y ph jumper at loc no 89 will be carried out for Preventive B/Dn maintenance of

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AURANGABAD (WALUJ)-BHENDA	IntraState	12/06/2022	20:33	12/06/2022	22:46	EO	nut bolt tightening of B and Y ph jumper at loc no 89 will be carried out for Preventive B/Dn maintenance of line.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/22 KV 50 MVA PTR 1	IntraState	11/06/2022	06:40	11/06/2022	09:39	T	TRIPPED ON DIFFERENTIAL PROTECTION
220/22 KV 50 MVA PTR 4 @ COLOURCHEM	IntraState	11/06/2022	08:20	11/06/2022	09:40	PO	For Premonsoon maintenance work including transformer buccholz , PRV relay, MOG, OSR plastic paper wrapping work.
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	11/06/2022	10:49	11/06/2022	13:50	PO	For Attending Oil Leakage and Oil Top up of ICT
220/132 KV 100 MVA ICT 2 @ BELWANDI	IntraState	11/06/2022	14:02	11/06/2022	16:11	PO	For Attending Oil Leakage and Oil Top up of ICT
220/22 KV 50 MVA PTR 3 @ BHANDUP GIS	IntraState	12/06/2022	07:08	12/06/2022	08:08	PO	For plastic wrapping of meters/panels
220/22 KV 50 MVA PTR 2 @ BHANDUP GIS	IntraState	12/06/2022	08:32	12/06/2022	09:12	PO	For plastic wrapping of meters & panels.
220/22 KV 50 MVA PTR 1 @ BHANDUP GIS	IntraState	12/06/2022	09:15	12/06/2022	09:59	PO	For plastic wrapping of meters & panels
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shifting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shifting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage