

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Jun/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	155.507	1725.653	1) Gujrat	-0.465	7.138
2) Hydro	5.176	104.895	2) Madhya Pradesh	-4.717	17.876
3) Gas	6.935	76.289	3) Chattisgarh	1.020	26.920
Total MSPGCL	167.618	1906.837	4) Maharashtra	176.011	2181.517
B) 1) APMIL	40.906	657.809	5) Goa (Amona)	-1.914	-23.435
2) JSWEL	23.556	291.588	Total	169.935	2210.016
3) VIPL	0.000	0.000	a) Mumbai Schedule	13.545	469.686
4) RPL(AMT)	31.433	324.119	b) Mumbai Drawl	42.106	518.061
5) SWPGPL	12.197	134.097	c) MSEDCL Bilateral *	72.476	968.518
6) Other IPP	15.916	163.762	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	13.545	469.633
C) 1) TPCL Thermal	11.915	142.836	Include PX	0.000	0.000
2) TPCL Hydro	5.636	62.050	Standby	0.000	0.053
3) TPCL Gas	4.135	44.970	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.392	103.908	1) MSEDCL	444.294	5407.105
D) STATE			2) Mumbai Discoms	74.181	871.822
1) Thermal	301.822	3543.772	3) Other Discoms	11.722	127.753
(A1+C1+C4+(B1-B6))			TOTAL STATE	530.197	6406.680
2) Hydro	10.812	166.945			
(A2+C2)					
3) Gas	11.070	121.259			
(A3+B7+C3)					
4) Wind	24.742	198.155			
6) SOLAR	11.819	166.536			
TOTAL STATE	360.265	4196.667			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6260	6600	7171	6097
MSPGCL Hydro	121	122	328	187
MSPGCL Gas	288	281	285	295
MSPGCL Total Generation	6669	7003	7784	6579
Central Sector Receipt	8537	7536	7451	5938
WIND	681	1107	978	1289
CPP / IPP Thermal	4753	5103	5836	4849
CPP / IPP Gas	0	0	0	0
SOLAR	1520	894	0	0
Exchange with Mumbai	-2308	-2167	-1842	-1186
MSEDCL DEMAND MET	19322	18950	19661	17088
Load Shedding	0	0	0	0
MSEDCL DEMAND	19322	18950	19661	17088
TPCL GENERATION	874	956	976	709
AEML GENERATION	381	467	473	452
MUMBAI DEMAND	3563	3590	3291	2347
OTHER DISCOM DEMAND	530	526	546	381
STATE DEMAND MET	23415	23066	23498	19816
STATE DEMAND	23415	23066	23498	19816
Frequency (Hz)	49.99	50.01	50.01	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 08.01 Hrs	49.86 Hz at 13.47 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.97	45.11	188	129
Unit 8	13.64	150.61	614	405
Unit 9	13.34	122.70	600	409
Unit 10	12.40	140.62	570	434
Total	43.35	459.04		
Bhusawal				
Unit 3	3.20	18.49	155	120
Unit 4	10.01	113.14	485	300
Unit 5	9.96	103.66	490	295
Total	23.18	235.29		
Parli				
Unit 6	0.00	34.93	0	0
Unit 7	0.00	26.47	0	0
Unit 8	0.00	38.18	0	0
Total	0.00	99.58		
Chandrapur				
Unit 3	3.43	39.84	165	120
Unit 4	3.50	40.37	169	125
Unit 5	8.52	66.35	435	280
Unit 6	6.63	49.86	421	0
Unit 7	8.92	99.25	465	278
Unit 8	9.82	109.33	450	285
Unit 9	10.57	87.48	497	290
Total	51.38	492.48		
Paras				
Unit 3	4.63	49.81	223	149
Unit 4	0.00	7.43	0	0
Total	4.63	57.24		
Khaparkheda				
Unit 1	3.62	39.75	160	120
Unit 2	3.95	46.87	200	118
Unit 3	3.99	33.19	177	130
Unit 4	4.24	47.10	188	128
Unit 5	11.02	121.54	490	320
Total	26.82	288.45		
Nasik				
Unit 3	3.16	37.55	157	118
Unit 4	0.00	19.19	0	0
Unit 5	3.00	36.84	149	108
Total	6.15	93.58		
Uran				
All Units	6.94	76.29	296	281
Total	6.94	76.29		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.23	0.96	52	0
Total	0.23	0.96		
Koyna				
Stage 1-2	1.90	32.76	400	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	27.34	0	0
Stage 3	0.53	14.77	146	0
Total	2.43	74.87		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.82	7.04	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.92	18.26	84	72
GHATGHAR	0.00	1.77	0	0
Total	2.74	30.03		
Wind				
Total	24.74	198.16	0	0
Total	24.74	198.16		
CPP				
APML(Mus)	40.91	657.81	0	0
JSWEL(Mus)	23.56	291.59	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.43	324.12	0	0
SWPGPL-Mus	12.20	134.10	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.92	63.12	269	194
Other(Mus)	4.01	49.01	0	0
JPL	5.99	51.63	268	234
Total	124.01	1571.38		
SOLAR				
Total	11.82	166.54	0	0
Total	11.82	166.54		
Tata				
Trombay 5	7.82	94.89	433	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.60	28.18	109	108
Trombay 7B	1.54	16.79	65	64
TATA Hydro	5.64	62.05	414	93
Trombay 8	4.10	47.95	232	130
Total	21.69	249.86		
AEML				
DTPS U-1&2	10.39	103.91	502	324
Total	10.39	103.91		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	155.51	1725.65	MSPGCL Total	167.62	1906.84
			MSPGCL Thml+Gas	162.44	1801.94	Koyna 1,2 & 4 Total	1.90	60.10
			MSPGCL Hydro	5.18	104.90	State Total	360.26	4196.67

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6670	184	292	7146	1508	6057	0	0	6222	5350	-1343	18283	0	0	18283	2847	435	21565	50.05
2	6042	184	295	6521	1488	5444	0	0	6903	5612	-1443	17207	0	1	17207	2605	415	20227	50.02
3	5880	178	296	6354	1476	5005	0	0	6499	6279	-1229	17501	0	21	17501	2429	384	20314	50.03
4	6097	187	295	6579	1289	4849	0	0	6263	5938	-1186	17088	0	21	17088	2347	381	19816	50.02
5	6464	183	295	6942	1360	4859	0	0	6239	5688	-1136	17324	0	21	17324	2304	389	20017	49.98
6	6655	177	296	7128	1021	4935	0	0	6714	6136	-1154	17653	0	21	17653	2346	413	20412	49.99
7	6672	337	294	7303	714	4979	0	70	6677	6849	-1228	18246	0	21	18246	2403	441	21090	50.02
8	6972	349	294	7615	622	5077	0	326	6849	6949	-1394	18711	0	21	18711	2587	484	21782	50.07
9	6754	123	290	7167	617	4981	0	712	7612	7740	-1783	18933	0	21	18933	2933	501	22367	50.11
10	6422	129	288	6839	627	4767	0	1172	8597	8227	-2132	18964	0	21	18964	3302	536	22802	49.99
11	6260	121	288	6669	681	4753	0	1520	9042	8537	-2308	19322	0	21	19322	3563	530	23415	49.99
12	5821	126	288	6235	691	4696	0	1691	9096	8414	-2360	18831	0	21	18831	3680	536	23047	50.02
13	5416	120	284	5820	797	4688	0	1750	8793	8083	-2303	18303	0	21	18303	3650	532	22485	50.02
14	5034	125	285	5444	738	4435	0	1525	8792	8404	-2212	17822	0	21	17822	3514	512	21848	49.98
15	5554	192	283	6029	910	4744	0	1318	8607	8647	-2344	18770	0	21	18770	3553	534	22857	50.01
16	6600	122	281	7003	1107	5103	0	894	7985	7536	-2167	18950	0	21	18950	3590	526	23066	50.01
17	6437	523	284	7244	1055	5043	0	536	7534	7648	-2060	18922	0	21	18922	3556	544	23022	50.03
18	6859	181	285	7325	1143	4901	0	269	7755	7458	-2030	18528	0	21	18528	3482	538	22548	50.02
19	7087	203	285	7575	1068	5362	0	36	7908	7544	-1859	19180	0	21	19180	3322	546	23048	50.02
20	7171	328	285	7784	978	5836	0	0	7993	7451	-1842	19661	0	21	19661	3291	546	23498	50.01
21	7170	330	287	7787	1110	6021	0	0	7255	6715	-1640	19483	0	21	19483	3250	510	23243	50.02
22	7207	338	287	7832	1187	5950	0	0	6681	6087	-1569	18963	0	21	18963	3217	524	22704	50.04
23	7164	250	289	7703	1220	5716	0	0	6638	6472	-1670	18953	0	21	18953	3202	488	22643	50.02
24	7099	186	289	7574	1335	5807	0	0	6463	6171	-1714	18696	0	21	18696	3211	477	22384	50.01
MUs	155.51	5.18	6.93	167.62	24.74	124.01	0.00	11.82	179.12	169.93	-42.11	444.29	0.00	0.47	444.29	74.18	11.72	530.20	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out on rotational basis at OCR Eklahare due to failure of 132/33KV 50MVA T/F No. 1&2.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jun/2024

Position as on 6.30 Hrs of 12/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	16/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Chandrapur Unit 6	500	08/06/2024	00:14	11/06/2024	02:05	Boiler Tube Leakage	10/06/2024
Total Capacity MSPGCL		1205						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1525						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		966						
IPP								
IPP	Adani U-4	660	10/06/2024	16:16		Continued.	ZERO SCHEDULE BY MSEDCL	
Total Capacity IPP		660						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		1626						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jun/2024

Position as on 6.30 Hrs of 12/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) of WALUJ @ TAPTITANDA	IntraState	11/06/2024	13:42	11/06/2024	17:20	PO	Outage required on all the three bays 401 , 402 , 403 for routine maintenance and testing work.
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ PARLI	IntraState	11/06/2024	04:05			T	Tripped but no indication appears.
SPARE LINE-1 BAY (401) @ TAPTITANDA	IntraState	11/06/2024	13:42	11/06/2024	17:20	PO	Outage required on all the three bays 401 , 402 , 403 for routine maintenance, testing work.
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	IntraState	12/06/2024	08:06			PO	For the instalment of external cooling fans to enhance cooling in 400 kV, 125 MVAR, Bus Shunt Reactor.
400 KV LINE Outages/Trippings							
DHULE - KHANDWA CKT - 1	InterState	11/06/2024	02:45	11/06/2024	03:45	T	Tripped on distance protection from Dhule end only.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
DABHOL - NEW KOYNA CKT - 1	IntraState	11/06/2024	12:52	11/06/2024	13:55	T	tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	11/06/2024	08:35	11/06/2024	20:47	PO	1.Measurement of tandelta of Bushing & winding. 2.Measurement of tandelta & capacitance of CT. 3.Premonsoon maintenance work of ICT. 4. Bay routine maintenance work.
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	11/06/2024	10:53	11/06/2024	16:47	PO	ICT-1 Y & B Phase Oil Top up.
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	11/06/2024	16:00	11/06/2024	22:13	EO	Hot-spot observed at R-phase, BPI no 1 (BPI between CB & CT) & B-phase, C bus isolator L clamp
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	IntraState	11/06/2024	16:16	11/06/2024	19:39	EO	Hotspot on 220kV Yph LV Bushing clamp attending work
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	11/06/2024	19:20			T	REF Protection
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
EKLAHARE (OCR) - PADGHE	IntraState	10/06/2024	08:42			HT	H/T for load management
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	10/06/2024	14:35	11/06/2024	15:05	T	Distance protection
MHAISAL - ALKUD	IntraState	10/06/2024	18:07	11/06/2024	05:36	PO	Wedge connector work
WARORA - HINGANGHAT	IntraState	11/06/2024	08:09	11/06/2024	11:22	PO	Testing work
KORADI-KHAPERKHEDA	IntraState	11/06/2024	09:34	11/06/2024	14:47	PO	Replacement of Disc Insulator
KURKUMBH - SHIRSHUPHAL CKT	IntraState	11/06/2024	11:27	11/06/2024	15:22	PO	Outage is proposed for annual relay testing work and quarterly maintenance of line bay
HALKARNI-MAHALAXMI LINE	IntraState	11/06/2024	11:27	11/06/2024	16:03	PO	Replacement of flshover string at loc. 309
BHAMBORI AMALNER	IntraState	11/06/2024	12:04	11/06/2024	16:34	PO	Testing and maintenance work
220 KV VALVE-JAMDE CKT I	IntraState	11/06/2024	13:06	11/06/2024	16:17	PO	Testing work
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	11/06/2024	14:35	11/06/2024	15:05	T	Distance Protection
BHUGAON - WARDHA (PG)	IntraState	11/06/2024	17:21	11/06/2024	20:03	T	Distance Protection
BALAPUR-AKOLA I	IntraState	11/06/2024	17:48	11/06/2024	21:22	T	Tripped at Akola end on PDR
JAMDE-DONDAICHA 2	IntraState	11/06/2024	18:25			T	Distance Protection
NANDGAON PETH-AMRAVATI	IntraState	11/06/2024	18:29	11/06/2024	20:46	T	Distance Protection
NTT - BAPGAON	IntraState	11/06/2024	21:35	12/06/2024	01:08	PO	To re-connect jumpers of 220 kV AKP-Nashik line at TL No. 396 after erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/06/2024	21:35	12/06/2024	01:08	PO	To re-connect jumpers of 220 kV AKP-Nashik line at TL No. 396 after erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333.
LONAND-BOTHE	IntraState	12/06/2024	05:18	12/06/2024	06:04	T	Distance Protection
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/33 KV 50MVA T/F - 2 @ MIRAJ	IntraState	11/06/2024	09:05	11/06/2024	15:48	PO	Replacement of differential relay
220/33KV 50MVA PTR 1 @ KATHAPUR	IntraState	11/06/2024	09:22	11/06/2024	14:50	PO	Attending LV Bph Bushing Hotspot and Diagnostic testing Work.
220/110kV 100MVA ICT - 3 @ PETH	IntraState	11/06/2024	10:10	11/06/2024	12:03	PO	Premonsoon maintenance work
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	12/06/2024	09:38			PO	Pre-monsoon Maintenance Work
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	12/06/2024	09:42			PO	125 MVA 220/100 Kv ICT No:01 Premansoon activites /Dignostic testing
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 12/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS - 2 @ JEJURI	IntraState	11/06/2024	10:42	11/06/2024	18:01	PO	for alignment work of 29B isolator of 220 kV Lonand-1 & 2 line bay (gear box repairing work)and alignment work of 29B isolator of ICT 2 bay by taking main bay on TBC bay alternatively by external agency
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV LINE Outages/Trippings							
AMBERNATH - KALYAN CKT - 2	IntraState	12/06/2024	06:32			PO	INSULATOR REPLACEMENT

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage