

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 11/Jul/2015 SATURDAY**

| <b>I GENERATION (MUs)</b> |                |                 | <b>II EXCHANGES (MUs)</b>      |                |                 |
|---------------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| <b>A) MSPGCL</b>          | <b>Daily</b>   | <b>Monthly</b>  | <b>E) InterState Exchanges</b> | <b>Daily</b>   | <b>Monthly</b>  |
| 1) Thermal                | 87.116         | 1074.952        | 1) Gujrat                      | 1.202          | 41.493          |
| 2) Hydro                  | 15.395         | 85.529          | 2) Madhya Pradesh              | 17.561         | 163.247         |
| 3) Gas                    | 6.446          | 71.324          | 3) Chattisgarh                 | 5.660          | 60.890          |
| <b>Total MSPGCL</b>       | <b>108.957</b> | <b>1231.805</b> | 4) Maharashtra Net             | 106.456        | 1042.515        |
| <b>B) 1) APML</b>         | <b>54.740</b>  | <b>595.950</b>  | 5) Goa                         | -6.867         | -75.349         |
| 2) JSWEL                  | 16.644         | 200.802         | 6) TAPS 1&2 Injection          | 2.865          | 31.739          |
| 3) VIPL                   | 12.969         | 132.877         | 7) RGPPL Injection             | 0.000          | 0.000           |
| 4) RPL(AMT)               | 10.600         | 163.404         | 8) Pench (MS)                  | 0.103          | 1.631           |
| 5) WPCL                   | 1.648          | 32.604          | 9) Pench (Excess)              | -0.103         | -1.373          |
| 6) Other IPP              | 3.689          | 43.168          | <b>Total</b>                   | <b>126.774</b> | <b>1263.162</b> |
| <b>C) 1) TPCL Thermal</b> | <b>17.397</b>  | <b>180.437</b>  | a) Mumbai Schedule             | 31.815         | 303.168         |
| 2) TPCL Hydro             | 2.716          | 38.786          | b) Mumbai Drawl                | 29.890         | 318.510         |
| 3) TPCL Gas               | 4.174          | 38.514          | c) MSEDCL Bilateral *          | 35.945         | 343.204         |
| 4) R-INFRA Thermal        | 6.204          | 111.970         | Include PX                     | 13.119         | 62.137          |
| <b>D) STATE</b>           |                |                 | d) Mumbai Bilateral *          | 31.815         | 303.168         |
| 1) Thermal                | 211.007        | 2536.164        | Include PX                     | 7.800          | 39.174          |
| (A1+C1+C4+(B1-B6))        |                |                 | Include Standby                | 0.000          | 0.000           |
| 2) Hydro (A2+C2)          | 18.111         | 124.315         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas (A3+C3)            | 10.620         | 109.838         | 1) MSEDCL                      | 344.679        | 3789.172        |
| 4) Wind                   | 37.703         | 431.039         | 2) Mumbai Discoms              | 60.387         | 688.221         |
| 6) SOLAR                  | 0.845          | 11.498          | <b>TOTAL STATE</b>             | <b>405.066</b> | <b>4477.393</b> |
| <b>TOTAL STATE</b>        | <b>278.286</b> | <b>3212.854</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| <b>PARTICULARS</b>       | <b>A. Morning Peak at 12 Hrs</b> | <b>B. Day Peak at 13 Hrs</b> | <b>C. Evening Peak at 21 Hrs</b> | <b>D. Night Minimum at 5 Hrs</b> |
|--------------------------|----------------------------------|------------------------------|----------------------------------|----------------------------------|
| MSPGCL Thermal           | 3620                             | 3693                         | 3869                             | 3399                             |
| MSPGCL Hydro             | 818                              | 1042                         | 840                              | 148                              |
| MSPGCL Gas               | 265                              | 265                          | 267                              | 269                              |
| MSPGCL Total Generation  | 4703                             | 5000                         | 4976                             | 3816                             |
| Central Sector Receipt   | 6309                             | 5726                         | 5324                             | 4420                             |
| WIND                     | 1887                             | 1922                         | 985                              | 1519                             |
| CPP / IPP                | 3784                             | 3777                         | 4334                             | 4348                             |
| SOLAR                    | 94                               | 103                          | 0                                | 0                                |
| Exchange with Mumbai     | -1452                            | -1502                        | -1253                            | -871                             |
| <b>MSEDCL DEMAND MET</b> | <b>15325</b>                     | <b>15026</b>                 | <b>14366</b>                     | <b>13232</b>                     |
| Load Shedding            | 43                               | 43                           | 37                               | 43                               |
| MSEDCL DEMAND            | 15368                            | 15069                        | 14403                            | 13275                            |
| TPCL GENERATION          | 1208                             | 1194                         | 1167                             | 858                              |
| R-INFRA GENERATION       | 258                              | 257                          | 258                              | 259                              |
| <b>MUMBAI DEMAND</b>     | <b>2918</b>                      | <b>2953</b>                  | <b>2678</b>                      | <b>1988</b>                      |
| STATE DEMAND MET         | 18243                            | 17979                        | 17044                            | 15220                            |
| <b>STATE DEMAND</b>      | <b>18286</b>                     | <b>18022</b>                 | <b>17081</b>                     | <b>15263</b>                     |
| Frequency (Hz)           | 49.92                            | 49.99                        | 49.95                            | 49.96                            |

**FREQUENCY PARTICULARS**

| <b>MAXIMUM FREQ.</b>         | <b>MINIMUM FREQ.</b>         | <b>AVERAGE FREQ.</b> | <b>FREQ. BELOW 49.2 Hz</b> |
|------------------------------|------------------------------|----------------------|----------------------------|
| <b>50.14 Hz at 02.01 Hrs</b> | <b>49.71 Hz at 19.25 Hrs</b> | <b>49.95</b>         | <b>0 % of Time(min)</b>    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 11/Jul/2015

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 0.00         | 17.13         | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.53         | 27.71         | 175      | 0        |
| <b>Total</b>       | <b>3.53</b>  | <b>44.84</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.17         | 45.11         | 180      | 165      |
| Unit 4             | 5.46         | 78.83         | 460      | 0        |
| Unit 5             | 11.47        | 88.60         | 500      | 390      |
| <b>Total</b>       | <b>21.10</b> | <b>212.54</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.18          | 0        | 0        |
| Unit 5             | 0.00         | 19.87         | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 37.92         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>57.96</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 3.49         | 38.00         | 153      | 137      |
| Unit 3             | 4.37         | 47.00         | 195      | 157      |
| Unit 4             | 3.41         | 44.62         | 183      | 0        |
| Unit 5             | 1.55         | 93.36         | 352      | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 8.50         | 95.03         | 383      | 324      |
| <b>Total</b>       | <b>21.31</b> | <b>318.01</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.00         | 56.10         | 240      | 192      |
| Unit 4             | 5.39         | 55.75         | 250      | 202      |
| <b>Total</b>       | <b>10.39</b> | <b>111.85</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 4.03         | 41.04         | 185      | 145      |
| Unit 2             | 3.86         | 41.70         | 170      | 145      |
| Unit 3             | 4.07         | 43.15         | 177      | 156      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 9.44         | 111.22        | 450      | 320      |
| <b>Total</b>       | <b>21.40</b> | <b>237.11</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.70         | 51.28         | 205      | 190      |
| Unit 4             | 4.68         | 41.36         | 203      | 187      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>9.38</b>  | <b>92.64</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.45         | 71.32         | 274      | 265      |
| <b>Total</b>       | <b>6.45</b>  | <b>71.32</b>  |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Pench (MS)      | 0.10          | 1.63           | 33       | 0        |
| <b>Total</b>    | <b>0.10</b>   | <b>1.63</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 6.12          | 39.48          | 520      | 40       |
| Stage 4         | 5.43          | 19.20          | 448      | 0        |
| Stage 3         | 2.33          | 13.31          | 240      | 0        |
| <b>Total</b>    | <b>13.89</b>  | <b>71.99</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 0.00           | 0        | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.00          | 0.37           | 0        | 0        |
| BHTGR/VEER      | 0.08          | 0.53           | 4        | 3        |
| BHIRA T.R.      | 0.29          | 2.39           | 49       | 0        |
| RNGR+BHTSA      | 0.19          | 1.48           | 9        | 0        |
| BHANDARDRA      | 0.00          | 0.00           | 0        | 0        |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.05          | 1.13           | 8        | 0        |
| GHATGHAR        | 0.89          | 7.64           | 250      | 0        |
| <b>Total</b>    | <b>1.50</b>   | <b>13.54</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 37.70         | 431.04         | 0        | 0        |
| <b>Total</b>    | <b>37.70</b>  | <b>431.04</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 54.74         | 595.95         | 0        | 0        |
| JSWEL(Mus)      | 16.64         | 200.80         | 0        | 0        |
| VIPL(Mus)       | 12.97         | 132.88         | 0        | 0        |
| RPLAMT(Mus)     | 10.60         | 163.40         | 0        | 0        |
| WPCL(Mus)       | 1.65          | 32.60          | 0        | 0        |
| Other(Mus)      | 3.69          | 43.17          | 0        | 0        |
| <b>Total</b>    | <b>100.29</b> | <b>1168.80</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 0.84          | 11.50          | 0        | 0        |
| <b>Total</b>    | <b>0.84</b>   | <b>11.50</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 11.53         | 117.53         | 493      | 398      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.61          | 23.35          | 117      | 69       |
| Trombay 7B      | 1.56          | 15.16          | 67       | 52       |
| Trombay 8       | 5.87          | 62.91          | 250      | 200      |
| TATA Hydro      | 2.72          | 38.79          | 290      | 0        |
| <b>Total</b>    | <b>24.29</b>  | <b>257.74</b>  |          |          |
| <b>R-INFRA</b>  |               |                |          |          |
| 1-2             | 6.20          | 111.97         | 260      | 257      |
| <b>Total</b>    | <b>6.20</b>   | <b>111.97</b>  |          |          |

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 87.12       | 1074.95       |
| MSPGCL Thml+Gas | 93.56       | 1146.28       |

| Summary      |             |               |
|--------------|-------------|---------------|
| Particulars  | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 15.40       | 85.53         |
| MSPGCL Total | 108.96      | 1231.80       |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| Koyna 1,2 & 4 Total | 11.56       | 58.68         |
| State Total         | 278.29      | 3212.85       |

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 11/Jul/2015**

**Annexure-2**

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3674        | 223   | 269  | 4166   | 1789  | 4385         | 0     | 4406        | 4332        | -1214                | 13458                 | 59                   | 13517                     | 2412             | 15929           | 49.95         |
| 2                  | 3767        | 180   | 268  | 4215   | 1828  | 4545         | 0     | 4420        | 4130        | -1077                | 13641                 | 43                   | 13684                     | 2204             | 15888           | 49.99         |
| 3                  | 3732        | 61    | 269  | 4062   | 1760  | 4669         | 0     | 4070        | 4133        | -1021                | 13603                 | 43                   | 13646                     | 2062             | 15708           | 50.00         |
| 4                  | 3664        | 58    | 269  | 3991   | 1780  | 4568         | 0     | 4022        | 3921        | -987                 | 13273                 | 43                   | 13316                     | 2024             | 15340           | 49.93         |
| 5                  | 3399        | 148   | 269  | 3816   | 1519  | 4348         | 0     | 4015        | 4420        | -871                 | 13232                 | 43                   | 13275                     | 1988             | 15263           | 49.96         |
| 6                  | 3208        | 962   | 269  | 4439   | 1551  | 4383         | 0     | 4397        | 4613        | -872                 | 14114                 | 44                   | 14158                     | 2038             | 16196           | 49.94         |
| 7                  | 3220        | 1327  | 267  | 4814   | 1439  | 4368         | 8     | 4836        | 4955        | -859                 | 14725                 | 46                   | 14771                     | 2028             | 16799           | 49.89         |
| 8                  | 3285        | 1230  | 266  | 4781   | 1457  | 4347         | 17    | 5209        | 5370        | -912                 | 15060                 | 46                   | 15106                     | 2085             | 17191           | 49.98         |
| 9                  | 3375        | 724   | 268  | 4367   | 1779  | 4273         | 46    | 5663        | 5853        | -1121                | 15197                 | 49                   | 15246                     | 2319             | 17565           | 49.97         |
| 10                 | 3383        | 1099  | 267  | 4749   | 1813  | 3852         | 64    | 5725        | 5989        | -1338                | 15129                 | 49                   | 15178                     | 2639             | 17817           | 49.94         |
| 11                 | 3435        | 1053  | 265  | 4753   | 1844  | 3797         | 92    | 6033        | 6270        | -1469                | 15287                 | 45                   | 15332                     | 2862             | 18194           | 49.92         |
| 12                 | 3620        | 818   | 265  | 4703   | 1887  | 3784         | 94    | 5699        | 6309        | -1452                | 15325                 | 43                   | 15368                     | 2918             | 18286           | 49.92         |
| 13                 | 3693        | 1042  | 265  | 5000   | 1922  | 3777         | 103   | 5328        | 5726        | -1502                | 15026                 | 43                   | 15069                     | 2953             | 18022           | 49.99         |
| 14                 | 3654        | 877   | 273  | 4804   | 1981  | 3671         | 131   | 5275        | 5771        | -1514                | 14844                 | 43                   | 14887                     | 2874             | 17761           | 50.03         |
| 15                 | 3735        | 831   | 274  | 4840   | 1739  | 3814         | 103   | 5501        | 5949        | -1432                | 15013                 | 37                   | 15050                     | 2886             | 17936           | 49.89         |
| 16                 | 3704        | 701   | 274  | 4679   | 1730  | 3882         | 77    | 5692        | 6122        | -1428                | 15062                 | 37                   | 15099                     | 2869             | 17968           | 49.91         |
| 17                 | 3765        | 603   | 271  | 4639   | 1693  | 3900         | 60    | 5826        | 5998        | -1426                | 14864                 | 37                   | 14901                     | 2813             | 17714           | 49.93         |
| 18                 | 3831        | 104   | 272  | 4207   | 1590  | 4069         | 40    | 5526        | 5372        | -1418                | 13860                 | 37                   | 13897                     | 2705             | 16602           | 49.96         |
| 19                 | 3879        | 89    | 270  | 4238   | 1343  | 4192         | 10    | 5274        | 5382        | -1410                | 13755                 | 37                   | 13792                     | 2646             | 16438           | 49.89         |
| 20                 | 3734        | 585   | 266  | 4585   | 1133  | 4281         | 0     | 5067        | 5292        | -1389                | 13902                 | 37                   | 13939                     | 2690             | 16629           | 49.85         |
| 21                 | 3869        | 840   | 267  | 4976   | 985   | 4334         | 0     | 5056        | 5324        | -1253                | 14366                 | 37                   | 14403                     | 2678             | 17081           | 49.95         |
| 22                 | 3839        | 682   | 267  | 4788   | 1034  | 4325         | 0     | 4835        | 5058        | -1296                | 13909                 | 37                   | 13946                     | 2627             | 16573           | 49.96         |
| 23                 | 3840        | 425   | 269  | 4534   | 1041  | 4452         | 0     | 4828        | 5176        | -1293                | 13910                 | 37                   | 13947                     | 2548             | 16495           | 49.95         |
| 24                 | 3811        | 733   | 267  | 4811   | 1066  | 4274         | 0     | 4721        | 5309        | -1336                | 14124                 | 37                   | 14161                     | 2513             | 16674           | 49.98         |
| MUs                | 87.12       | 15.39 | 6.45 | 108.96 | 37.70 | 100.29       | 0.84  | 121.42      | 126.77      | -29.89               | 344.68                | 1.01                 | 345.69                    | 60.38            | 406.07          | 49.95         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 11/Jul/2015**

**Position as on 6.30 Hrs of 12/Jul/2015**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage              | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                               |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 12/10/2014   | 22:39        |            | Continued. | Refuelling work               |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 09/06/2015   | 23.58        |            | Continued. | COH                           |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 19/06/2015   | 23.57        |            | Continued. | Annual Overhaul               |               |
| MSPGCL                | Nasik Unit 5            | 210      | 30/06/2015   | 23.50        |            | Continued. | Annual Overhaul               |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                               |               |
| RGPPL                 | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                 |               |
| RGPPL                 | Dabhol 3A               | 230      | 06/06/2013   | 08.28        |            | Continued. | Gas Shortage                  |               |
| RGPPL                 | Dabhol 2A               | 230      | 06/06/2013   | 09.10        |            | Continued. | Gas Shortage                  |               |
| RGPPL                 | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                  |               |
| RGPPL                 | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                  |               |
| RGPPL                 | Dabhol 2X               | 290      | 15/07/2013   | 15.09        |            | Continued. | Gas Shortage                  |               |
| RGPPL                 | Dabhol 2B               | 230      | 08/08/2013   | 15.03        |            | Continued. | Gas Shortage                  |               |
| RGPPL                 | Dabhol 3X               | 290      | 29/12/2013   | 05.47        |            | Continued. | Gas Shortage                  |               |
| RGPPL                 | Dabhol 3B               | 230      | 29/12/2013   | 06.14        |            | Continued. | Gas Shortage                  |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                   |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.            |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 13/09/2014   | 12.43        |            | Continued. | Economic shutdown             |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown             |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 29/03/2015   | 18.26        |            | Continued. | Withdrawn                     |               |
| MSPGCL                | Koradi Unit-8           | 660      | 30/03/2015   | 20.22        |            | Continued. | BLR Tripped.                  |               |
| MSPGCL                | Uran Unit 6             | 108      | 01/04/2015   | 16.35        |            | Continued. | Gas shortage                  |               |
| IPP                   | RPL(AMT) U-5            | 270      | 03/04/2015   | 14.22        |            | Continued. | turbine Shaft Vibration high. |               |
| MSPGCL                | Uran Unit 7             | 108      | 17/04/2015   | 00.07        |            | Continued. | Gas turbine problem           |               |
| TPC-G                 | Trombay 6               | 500      | 05/06/2015   | 05.59        |            | Continued. | Economic Shutdown.            |               |
| MSPGCL                | Koyna STG- IV Unit - 1  | 250      | 09/06/2015   | 14.22        |            | Continued. | Excitation T/F Burst          |               |
| MSPGCL                | Parli Unit 3            | 210      | 14/06/2015   | 12.58        |            | Continued. | Water Shortage                |               |
| IPP                   | WPCL U-2                | 135      | 16/06/2015   | 00.00        |            | Continued. | No Schdule                    |               |
| CPP                   | WPCL U-1                | 135      | 16/06/2015   | 00.00        | 11/07/2015 | 10.54      | No Schdule                    |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                |               |
| IPP                   | Adani U-3               | 660      | 04/07/2015   | 15:03        |            | Continued. | Super heater drain leakage.   |               |
| IPP                   | WPCL U-3                | 135      | 04/07/2015   | 17:45        | 12/07/2015 | 06.48      | Not schdule.                  |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                |               |
| IPP                   | RPL(AMT) U-1            | 270      | 06/07/2015   | 00.37        |            | Continued. | Furnace Pressure High         |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.               |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 11/Jul/2015**

**Position as on 6.30 Hrs of 12/Jul/2015**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage      | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------|---------------|
| MSPGCL             | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage        |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 08/07/2015   | 15.15        | 11/07/2015 | 07.23      | Boiler Tube Leakage   |               |
| MSPGCL             | Koradi Unit 5           | 200      | 09/07/2015   | 19.19        |            | Continued. | ID Fan Problem        |               |
| RINFRA-G           | REL Unit 1              | 250      | 10/07/2015   | 04.57        |            | Continued. | Boiler Tube Leakage   |               |
| MSPGCL             | Chandrapur Unit 4       | 210      | 11/07/2015   | 03.47        | 11/07/2015 | 07.58      | Turbine tripped       |               |
| MSPGCL             | Chandrapur Unit 5       | 500      | 11/07/2015   | 04.43        |            | Continued. | Boiler Tube Leakage   |               |
| CPP                | WPCL U-4                | 135      | 11/07/2015   | 06.58        |            | Continued. | ID Fan Vibration High |               |
| IPP                | RPL(AMT) U-3            | 270      | 11/07/2015   | 08.30        | 11/07/2015 | 15.38      | Turbine Problem.      |               |
| MSPGCL             | Koradi Unit 7           | 210      | 11/07/2015   | 08.50        | 11/07/2015 | 11.02      | Flame Failure         |               |
| IPP                | RPL(AMT) U-4            | 270      | 11/07/2015   | 09.12        | 11/07/2015 | 20.15      | Turbine Problem.      |               |
| IPP                | WPCL U-3                | 135      | 12/07/2015   | 11.15        | 12/07/2015 | 12.11      | ESP Problem.          |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 11/Jul/2015**

**Statement-VII**

Position as on 6.30 Hrs of 12/Jul/2015

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                   |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                    |
| Raichur(PG)-Solapur(PG)- II               | InterState                | 11/07/2015   | 00.28        | 11/07/2015 | 21.03      | PO          | Routine Maintenance Work                                                                                           |
| <b>400 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                    |
| Dabhol Nagothane I                        | InterState                | 30/06/2015   | 16.53        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Dhule Sar'Sarovar II                      | InterState                | 09/07/2015   | 17.39        | 11/07/2015 | 08.39      | HT          | Over Voltage                                                                                                       |
| Kolhapur Mapusa II                        | InterState                | 10/07/2015   | 16.35        | 11/07/2015 | 08.53      | HT          | Over Voltage                                                                                                       |
| Kolhapur Mapusa I                         | InterState                | 11/07/2015   | 17.05        | 12/07/2015 | 09.05      | HT          | Over Voltage                                                                                                       |
| Dhule Sar'Sarovar I                       | InterState                | 11/07/2015   | 17.13        | 11/07/2015 | 23.07      | HT          | Over Voltage                                                                                                       |
| Dhule Sar'Sarovar II                      | InterState                | 11/07/2015   | 23.07        | 12/07/2015 | 16.06      | HT          | Over Voltage                                                                                                       |
| Kolhapur Mapusa II                        | InterState                | 12/07/2015   | 16.22        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Kolhapur Solapur(PG) I                    | InterState                | 12/07/2015   | 18.19        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Dhule Sar'Sarovar I                       | InterState                | 12/07/2015   | 21.17        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Akola II - Taptitanda                     | IntraState                | 20/05/2015   | 08.59        |            | Continued. | HT          | Ckt I and Ckt 2 new charged to control BBLSR ICT loading.                                                          |
| Babhaleshwar-Taptitanda ckt-I             | IntraState                | 09/07/2015   | 17.32        |            | Continued. | HT          | padgha-BBLSR Line Loading                                                                                          |
| karad -kolhapur-I                         | IntraState                | 10/07/2015   | 16.41        | 11/07/2015 | 10.55      | HT          | Over Voltage                                                                                                       |
| Karad-Jaigad - I                          | IntraState                | 10/07/2015   | 16.51        | 11/07/2015 | 08.37      | HT          | Over Voltage                                                                                                       |
| Bhusawal-Aurangabad                       | IntraState                | 10/07/2015   | 20.30        | 11/07/2015 | 06.47      | HT          | Over Voltage                                                                                                       |
| Dhule - Bableshwar - li                   | IntraState                | 11/07/2015   | 07.28        | 11/07/2015 | 20.19      | PO          | A/R Out.                                                                                                           |
| Dhule- Bableshwar - I                     | IntraState                | 11/07/2015   | 07.28        | 11/07/2015 | 20.19      | PO          | A/R Out.                                                                                                           |
| Padghe - Talegaon (PG)                    | IntraState                | 11/07/2015   | 08.12        | 11/07/2015 | 18.50      | PO          | A/R Out.                                                                                                           |
| Dhule- Bableshwar - I                     | IntraState                | 11/07/2015   | 12.27        | 11/07/2015 | 14.37      | T           | Distance Protection B Phase.                                                                                       |
| karad -kolhapur-I                         | IntraState                | 11/07/2015   | 16.35        | 12/07/2015 | 07.03      | HT          | Over Voltage                                                                                                       |
| Karad-Jaigad - I                          | IntraState                | 11/07/2015   | 16.38        | 12/07/2015 | 07.11      | HT          | Over Voltage                                                                                                       |
| Lonikand I - Koyna stage-IV               | IntraState                | 11/07/2015   | 21.04        | 11/07/2015 | 22.36      | T           | Distance Protection B Ph E/F.                                                                                      |
| Bhusawal-Aurangabad                       | IntraState                | 11/07/2015   | 21.26        | 12/07/2015 | 05.54      | HT          | Over Voltage                                                                                                       |
| Lonikand I - Koyna stage-IV               | IntraState                | 12/07/2015   | 10.20        | 12/07/2015 | 18.56      | EO          | Decapped B Ph String.                                                                                              |
| Bhusawal-Aurangabad                       | IntraState                | 12/07/2015   | 18.00        |            | Continued. | HT          | Over Voltage                                                                                                       |
| <b>400 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                    |
| 400/220/33 Kv 315 MVA ICT II @Babhleshwar | IntraState                | 11/07/2015   | 17.19        | 11/07/2015 | 20.35      | PO          | Maintenanace Work @ LV Side.                                                                                       |
| 400/220 Kv 600 MVA ICT-II @Kalwa          | IntraState                | 12/07/2015   | 05.29        | 12/07/2015 | 09.57      | PO          | Attending Hot Spot on Y Phase LV Bushing.                                                                          |
| <b>220 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                    |
| Borivali - Tarapur                        | InterState                | 11/07/2015   | 07.00        | 11/07/2015 | 07.30      | PO          | Taken on TBC.                                                                                                      |
| Nasik Navsari I                           | InterState                | 12/07/2015   | 06.02        | 12/07/2015 | 15.11      | T           | Y & B Ph to Earth Fault.                                                                                           |
| Chandrapur GCR - Warora - I               | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Chandrapur GCR - Wani                     | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Boisar Versova Line                       | IntraState                | 05/07/2015   | 08.08        |            | Continued. | PO          | Making LILO for 220KV Viraj S/S                                                                                    |
| Dahanu Boisar Line                        | IntraState                | 05/07/2015   | 08.32        |            | Continued. | PO          | Making LILO for 220KV Viraj S/S                                                                                    |
| Osmanabad - Solapur (Bale)                | IntraState                | 06/07/2015   | 15.06        |            | Continued. | HT          | For Controlling Rarly ICT Loading.                                                                                 |
| Chikhli-Jalna-II                          | IntraState                | 06/07/2015   | 16.58        |            | Continued. | HT          | For Akola ICT Loading.                                                                                             |
| Chikhli-Jalna-I                           | IntraState                | 06/07/2015   | 16.58        |            | Continued. | HT          | For Akola ICT Loading.                                                                                             |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 11/Jul/2015**

**Statement-VII**

Position as on 6.30 Hrs of 12/Jul/2015

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                  |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------|
| Babhaleshwar - Degaon Rangari                | IntraState                | 08/07/2015   | 12.21        |            | Continued. | HT          | construction of new 220kv chalisgaon Bay by hot line unit         |
| REL Borivali TPC Borivali line               | IntraState                | 10/07/2015   | 16.22        |            | Continued. | T           | Distance Protection                                               |
| Nashik-Padgha                                | IntraState                | 11/07/2015   | 07.26        | 11/07/2015 | 17.43      | PO          | A/R Out.                                                          |
| New Koyna - Loteparshuram                    | IntraState                | 11/07/2015   | 09.32        | 11/07/2015 | 15.13      | PO          | Hot Spot Attended @ Wavetrap.                                     |
| Aurangabad (Waluj)-Bhenda                    | IntraState                | 11/07/2015   | 10.18        | 11/07/2015 | 13.30      | PO          | R.M.Work.                                                         |
| Virur - Virur Rly Tss 2                      | IntraState                | 11/07/2015   | 11.15        | 11/07/2015 | 12.28      | PO          | To Carry Out Half Yearly Maint.Schedule of DP Isolator @ TSS End. |
| Bableshevar- Alephata                        | IntraState                | 11/07/2015   | 23.34        | 12/07/2015 | 17.06      | HT          | Babaleshwar ICT Over Loading.                                     |
| Bableshevar- Ranjangaon                      | IntraState                | 12/07/2015   | 06.02        | 12/07/2015 | 17.47      | HT          | Balsr ICT Over Loading.                                           |
| <b>220 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                   |
| 220/100 Kv 200 MVA ICT III @Borivali         | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Internal Fault                                                    |
| 220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded | IntraState                | 11/07/2015   | 08.19        | 11/07/2015 | 10.03      | PO          | Attending Hot Spot on Y Ph CT Clamp.                              |
| 220/22kv 40 Mva Cgl Ptr 1 @Sicom             | IntraState                | 11/07/2015   | 14.00        |            | Continued. | PO          | Cable Replacement & CT,PT Replacement Work.                       |
| <b>132 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                   |
| Boisar Midc - Dahanu 1                       | IntraState                | 12/07/2015   | 03.48        | 12/07/2015 | 09.23      | T           | Distance Protection                                               |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage