

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Jul/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	104.994	1362.423	1) Gujrat	-6.867	-108.308
2) Hydro	9.661	116.416	2) Madhya Pradesh	2.672	50.462
3) Gas	3.265	49.309	3) Chattisgarh	3.700	40.490
Total MSPGCL	117.920	1528.148	4) Maharashtra	124.125	1648.886
B) 1) APLM	39.266	510.661	5) Goa (Amona)	-1.795	-14.766
2) JSWEL	13.996	156.542	Total	121.835	1616.764
3) VIPL	0.000	0.000	a) Mumbai Schedule	42.220	370.744
4) RPL(AMT)	21.403	216.107	b) Mumbai Drawl	38.819	396.510
5) SWPGPL	7.685	85.642			
6) Other IPP	6.654	81.426	c) MSEDCL Bilateral *	78.956	855.020
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	10.053	101.071	d) Mumbai Bilateral *	42.220	368.701
2) TPCL Hydro	3.016	33.122	Include PX	0.000	0.000
3) TPCL Gas	0.000	6.389	Standby	0.000	2.044
4) AEML Thermal	7.362	108.120			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	211.413	2621.992	1) MSEDCL	350.025	4290.622
2) Hydro (A2+C2)	12.677	149.538	2) Mumbai Discoms	59.250	645.212
3) Gas (A3+B7+C3)	3.265	55.698	3) Other Discoms	8.853	97.493
4) Wind	64.715	519.754			
6) SOLAR	4.223	69.581	TOTAL STATE	418.128	5033.327
TOTAL STATE	296.293	3416.563			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5056	4234	4655	4085
MSPGCL Hydro	415	646	1005	219
MSPGCL Gas	140	140	140	140
MSPGCL Total Generation	5611	5020	5800	4444
Central Sector Receipt	5842	5810	4621	3894
WIND	2559	2742	2906	2434
CPP / IPP Thermal	4271	3590	4355	3616
CPP / IPP Gas	0	0	0	0
SOLAR	399	110	0	0
Exchange with Mumbai	-2043	-1948	-1536	-1047
MSEDCL DEMAND MET	16247	14913	15737	13045
Load Shedding	0	0	0	0
MSEDCL DEMAND	16247	14913	15737	13045
TPCL GENERATION	497	467	801	536
AEML GENERATION	315	308	321	314
MUMBAI DEMAND	2855	2723	2658	1897
OTHER DISCOM DEMAND	392	411	409	296
STATE DEMAND MET	19494	18047	18804	15238
STATE DEMAND	19494	18047	18804	15238
Frequency (Hz)	50.03	49.93	49.83	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 13:30 Hrs	49.63 Hz at 19:22 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.89	24.20	135	80
Unit 7	0.00	0.00	0	0
Unit 8	0.00	43.27	0	0
Unit 9	0.00	46.99	0	0
Unit 10	11.46	123.82	515	393
Total	14.34	238.28		
Bhusawal				
Unit 3	2.77	32.56	130	85
Unit 4	7.64	96.46	380	280
Unit 5	7.92	85.13	425	280
Total	18.33	214.15		
Parli				
Unit 6	4.29	53.01	245	150
Unit 7	3.14	45.49	205	0
Unit 8	0.01	0.01	12	0
Total	7.44	98.51		
Chandrapur				
Unit 3	0.00	20.97	0	0
Unit 4	1.93	26.84	102	66
Unit 5	6.69	78.98	295	265
Unit 6	5.59	70.44	249	215
Unit 7	0.00	0.00	0	0
Unit 8	9.09	108.58	469	300
Unit 9	8.90	108.62	449	305
Total	32.20	414.42		
Paras				
Unit 3	3.68	44.95	194	125
Unit 4	3.67	44.17	194	138
Total	7.35	89.11		
Khaparkheda				
Unit 1	2.90	30.62	130	105
Unit 2	3.14	32.17	150	115
Unit 3	3.56	31.91	173	130
Unit 4	0.00	0.00	0	0
Unit 5	8.32	106.00	440	275
Total	17.93	200.70		
Nasik				
Unit 3	2.99	39.44	140	61
Unit 4	2.41	35.89	135	30
Unit 5	2.01	31.92	138	0
Total	7.41	107.24		
Uran				
All Units	3.26	49.31	141	129
Total	3.26	49.31		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	1.45	23	0
Total	0.06	1.45		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.76	22.80	460	15
Stage 4	0.16	8.04	125	0
Stage 3	1.37	14.31	80	0
Total	3.28	45.16		
Hydro				
KDPH	0.00	0.65	0	0
VTRNA	0.63	6.54	60	0
TILLARI	0.46	3.75	58	0
BHIRA T.R.	0.44	3.41	80	0
SMLHY_PTN	4.78	55.46	203	188
GHATGHAR	0.00	0.00	0	0
Total	6.32	69.81		
Wind				
Total	64.72	519.75	0	0
Total	64.72	519.75		
CPP				
APML(Mus)	39.27	510.66	0	0
JSWEL(Mus)	14.00	156.54	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	21.40	216.11	0	0
SWPGPL-Mus	7.68	85.64	0	0
Other(Mus)	6.65	81.43	0	0
Total	89.00	1050.38		
SOLAR				
Total	4.22	69.58	0	0
Total	4.22	69.58		
Tata				
Trombay 5	6.55	56.56	350	254
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.82	0	0
Trombay 7B	0.00	2.57	0	0
TATA Hydro	3.02	33.12	314	70
Trombay 8	3.50	44.52	208	133
Total	13.07	140.58		
AEML				
DTPS U-1&2	7.36	108.12	321	293
Total	7.36	108.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	104.99	1362.42	MSPGCL Total	117.92	1528.15
			MSPGCL Thml+Gas	108.26	1411.73	Koyna 1,2 & 4 Total	1.92	30.85
			MSPGCL Hydro	9.66	116.42	State Total	296.29	3416.56

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 11/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4098	215	139	4452	2218	3669	0	0	4281	4369	-1291	13098	0	13098	2113	319	15530	50.02
2	4052	222	130	4404	2259	3560	0	0	4189	4226	-1166	12971	0	12971	1995	312	15278	49.99
3	4085	219	140	4444	2434	3616	0	0	4099	3894	-1047	13045	0	13045	1897	296	15238	50.03
4	4118	213	140	4471	2588	3621	0	0	4155	3788	-1002	13161	0	13161	1840	305	15306	50.06
5	4297	252	140	4689	2608	3665	0	0	4191	4109	-1041	13730	0	13730	1835	300	15865	50.02
6	4218	263	140	4621	2776	3689	0	0	5010	4965	-1156	14566	0	14566	1940	329	16835	49.99
7	4790	315	130	5235	2730	3700	0	34	5447	5622	-1315	15641	0	15641	2096	365	18102	49.99
8	4939	382	140	5461	2611	3925	0	147	5744	5859	-1497	16132	0	16132	2276	374	18782	50.03
9	5035	399	130	5564	2606	3992	0	263	5923	6092	-1798	16329	0	16329	2582	390	19301	50.05
10	5056	415	140	5611	2559	4271	0	399	6062	5842	-2043	16247	0	16247	2855	392	19494	50.03
11	4723	368	130	5221	2612	3754	0	481	6744	5972	-2206	15421	0	15421	3020	413	18854	50.01
12	4335	372	140	4847	2637	3226	0	569	6872	6191	-2234	14842	0	14842	3050	394	18286	49.94
13	4081	378	139	4598	2436	3201	0	618	6308	6024	-2182	14315	0	14315	2997	380	17692	50.02
14	4133	408	130	4671	2635	3155	0	556	5484	5578	-2072	14163	0	14163	2883	360	17406	50.06
15	3980	444	138	4562	2672	3130	0	468	5581	5694	-2070	14072	0	14072	2869	384	17325	50.00
16	4154	480	138	4772	2766	3117	0	357	5867	5544	-2033	14131	0	14131	2815	392	17338	50.08
17	4091	431	129	4651	2698	3315	0	207	5895	6007	-2002	14473	0	14473	2771	403	17647	50.00
18	4234	646	140	5020	2742	3590	0	110	5584	5810	-1948	14913	0	14913	2723	411	18047	49.93
19	4635	580	130	5345	2803	3876	0	14	5649	5651	-1864	15412	0	15412	2681	413	18506	49.94
20	4655	1005	140	5800	2906	4355	0	0	4882	4621	-1536	15737	0	15737	2658	409	18804	49.83
21	4666	462	130	5258	3075	4651	0	0	4804	4287	-1374	15485	0	15485	2537	412	18434	49.81
22	4531	421	141	5093	3090	4182	0	0	4257	4033	-1267	14747	0	14747	2378	384	17509	49.98
23	4234	384	130	4748	3238	3985	0	0	4251	3948	-1356	14205	0	14205	2263	358	16826	50.01
24	3854	387	141	4382	3016	3759	0	0	3949	3709	-1319	13191	0	13191	2176	356	15723	50.03
MUs	104.99	9.66	3.27	117.92	64.72	89.00	0.00	4.22	125.23	121.83	-38.82	350.03	0.00	350.03	59.25	8.85	418.13	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 11/Jul/2022

Position as on 6.30 Hrs of 12/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Parli Unit 8	250	25/06/2022	00:00	11/07/2022	23:33	Short overhauling	10/07/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Annual Overhaul	22/07/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	17/07/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	15/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	15/07/2022
IPP	SWPGPL U-1	135	04/07/2022	02:38		Continued.	PA Fan problem	15/07/2022
MSPGCL	Uran Unit 6	108	06/07/2022	17:51		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-1	250	06/07/2022	18:30		Continued.	Governor problem	16/07/2022
TPC-G	Trombay 7A	120	07/07/2022	01:09		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	07/07/2022	01:21		Continued.	Gas shortage	
MSPGCL	Koradi Unit 9	660	07/07/2022	13:54	12/07/2022	09:06	Boiler Tube Leakage	10/07/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jul/2022

Position as on 6.30 Hrs of 12/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 3	210	09/07/2022	11:58		Continued.	Furnace Pressure High	16/07/2022
MSPGCL	Nasik Unit 5	210	11/07/2022	17:00		Continued.	WET COAL	
MSPGCL	Parli Unit 7	250	11/07/2022	22:03		Continued.	Boiler Tube Leakage	14/07/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 11/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 12/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400 KV LINE Outages/Tripping							
DHULE - SSNNL CKT - 2	InterState	11/07/2022	03:17	12/07/2022	16:33	HT	HT for Overvoltage
SOLAPUR PG - ALKUD	InterState	12/07/2022	11:26	12/07/2022	20:28	PO	Quarterly Maintenance & Diagnostic testing Work
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24			HT	H/T FOR CONTROLLING LINE LOADING
KHADKA-AURANGABAD (WALUJ)	IntraState	10/07/2022	17:30			HT	To control OV
400 KV ICT Outages/Tripping							
400/220/33 KV 500 MVA ICT - 1 @ JEJURI	IntraState	11/07/2022	16:30	11/07/2022	18:13	EO	For cleaning of Tertiary delta of ICT I in view of NDR alarm.
220 KV MAINBAY Outages/Tripping							
MAIN BUS SECTION - 1 @ PARVATI	IntraState	12/07/2022	19:05		Continued.	T	DUE TO TREE BRANCH FALLEN ON PHURSINGI LINE.
220 KV LINE Outages/Tripping							
NALASOPARA - BOISAR PG	InterState	11/07/2022	18:16	11/07/2022	19:32	T	TRIPPED ON BACK UP PROTECTION
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
POPHALI - KDPH	IntraState	10/07/2022	14:22	12/07/2022	18:40	T	Tripped on DT
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	11/07/2022	09:29			PO	Relay replacement at MSETCL Bor Project work.
TALANDGE - ICHALKARANJI 1	IntraState	11/07/2022	10:17	11/07/2022	17:00	PO	1) Quarterly bay maintenance work at 220 kv Tilawani end. 2) Annual relay testing work. 3)MFM meter replacement work
OSMANABAD - SOLAPUR (BALE)	IntraState	11/07/2022	14:28	11/07/2022	17:43	HT	DUE TO EMERGENCY OUTAGE TO ATTEND CB PROBLEM AT OSMANABAD END.
BOISAR II - BOISAR (PG) CKT - 3	IntraState	11/07/2022	18:16	12/07/2022	09:16	T	TRIPPED ON BACKUP PROTECTION
PADGHE - NALASOPARA - VASAI (T)	IntraState	11/07/2022	18:16	11/07/2022	19:12	T	TRIPPED ON BACK UP PROTECTION
BOISAR II - VIRAJ	IntraState	11/07/2022	18:16	11/07/2022	19:12	T	TRIPPED FROM BOISER END
DAHANU - VIRAJ	IntraState	11/07/2022	18:16	11/07/2022	19:47	T	TRIPPED ON BACK UP PROTECTION
HALKARNI - TILARI LINE	IntraState	11/07/2022	18:17	12/07/2022	11:44	T	TRIPPED ON D/P
GOREGAON - VERSOVA CKT - 2	IntraState	11/07/2022	22:14	12/07/2022	02:07	T	Tripped at Versova end only
BOISAR - VERSOVA	IntraState	12/07/2022	00:08	12/07/2022	07:27	HT	Load management purpose , since outage on 220 kv Boisar MSETCL Boisar PG ckt 3
BOISAR II - BOISAR (PG) CKT - 1	IntraState	12/07/2022	00:22	12/07/2022	07:21	EO	Outage required for safety purpose to attend breakdown work of Boisar-PGCIL-3 line by opening of R-Phase jumper at Loc no 27.
THEUR-JEJURI	IntraState	12/07/2022	07:58	12/07/2022	21:15	T	TRIPPED ONLY FROM JEJURI END
JEJURI-LONAND	IntraState	12/07/2022	07:58	12/07/2022	07:43	T	TRIPPED ONLY FROM JEJURI END
JEJURI (400 KV)-JEJURI- II	IntraState	12/07/2022	07:58	12/07/2022	08:45	T	TRIPPED ONLY FROM JEJURI END
TEMGHAR - KALWA	IntraState	12/07/2022	10:36	12/07/2022	15:48	EO	Temghar line isolator alignment work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 12/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALMESHWAR-PANDHURNA	IntraState	12/07/2022	10:54	12/07/2022	19:15	PO	FOR LINE MAINTENANCE WORK
HALKARNI - TILARI LINE	IntraState	12/07/2022	13:00	12/07/2022	14:02	HT	HAND TRIPPED DUE TO CB PROBLEM AT TILLARI
THEUR-JEJURI	IntraState	12/07/2022	13:52	12/07/2022	21:15	EO	RELAY TESTING WORK AT JEJURI END
KANDALGAON - PIRANGUT	IntraState	12/07/2022	16:52	12/07/2022	17:26	T	TRIPPED FROM KANDALGAON END ON D/P
ADLABS - PEDAMBE	IntraState	12/07/2022	18:11			T	TRIPPED ON D/P
EKLAHARE (OCR) - PADGHE	IntraState	12/07/2022	18:59		Continued.	HT	H/T FOR NASIK(GCR)-BBLSR LINE LOADING
PHURSUNGI-PARVATI	IntraState	12/07/2022	19:03	12/07/2022	19:39	T	DUE TO TREE BRANCH FALLEN ON PHURSINGI LINE. (CHARGED VIA TBC)
POPHALI - KDPH	IntraState	12/07/2022	23:30			T	TRIPPED ON DIST.PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	11/07/2022	07:38	11/07/2022	15:36	T	Differential Protection
220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI	IntraState	12/07/2022	00:07	12/07/2022	10:24	T	Tripped on differential protection
220/132 KV 200MVA ICT 2 @ KURKUMBH	IntraState	12/07/2022	14:20	12/07/2022	16:35	PO	RELAY TESTING WORK
220/33 KV 50 MVA TF - 1@BELWANDI	IntraState	12/07/2022	16:35	12/07/2022	17:13	EO	SCADA maintenance works
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	12/07/2022	18:00	12/07/2022	19:02	T	ICT TRIPPED ON PRV
220/132 KV 200 MVA PTR NO 6 @ PARVATI	IntraState	12/07/2022	19:03	12/07/2022	19:26	T	DUE TO BUS SECTION-1 TRIPPED
220 KV BR Outages/Trippings							
BUS COUPLER @ BOISAR 2	IntraState	11/07/2022	18:16	11/07/2022	19:00	T	TRIPPED ON BACK UP PROTECTION
132 KV LINE Outages/Trippings							
BOISAR II - PALGHAR 2	IntraState	11/07/2022	18:16	11/07/2022	03:33	T	DISTANCE PROTECTION
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 12/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage