

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Jul/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	137.628	1525.808	1) Gujrat	0.730	15.158
2) Hydro	8.093	74.452	2) Madhya Pradesh	0.557	22.051
3) Gas	6.401	72.064	3) Chattisgarh	-0.260	11.990
Total MSPGCL	152.122	1672.324	4) Maharashtra	145.239	1652.464
B) 1) APML	61.214	642.835	5) Goa (Amona)	-1.635	-20.425
2) JSWEL	18.814	215.340	Total	144.631	1681.238
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.460	414.579
4) RPL(AMT)	22.130	247.387	b) Mumbai Drawl	34.001	446.109
5) SWPGPL	11.928	131.365	c) MSEDCL Bilateral *	89.945	1010.635
6) Other IPP	13.040	134.888	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.460	414.579
C) 1) TPCL Thermal	12.473	131.234	Include PX	0.000	0.000
2) TPCL Hydro	5.189	52.518	Standby	0.000	0.000
3) TPCL Gas	4.099	41.569	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.024	108.265	1) MSEDCL	438.887	4820.716
D) STATE			2) Mumbai Discoms	65.786	779.693
1) Thermal	287.251	3137.122	3) Other Discoms	11.417	124.490
(A1+C1+C4+(B1-B6))			TOTAL STATE	516.090	5724.899
2) Hydro	13.282	126.970			
(A2+C2)					
3) Gas	10.500	113.633			
(A3+B7+C3)					
4) Wind	42.966	507.835			
6) SOLAR	17.460	158.103			
TOTAL STATE	371.459	4043.663			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5684	5682	6300	6072
MSPGCL Hydro	177	178	1363	138
MSPGCL Gas	263	266	267	269
MSPGCL Total Generation	6124	6126	7930	6479
Central Sector Receipt	7466	6717	5805	4932
WIND	1556	2282	1852	1617
CPP / IPP Thermal	4754	4629	6150	5619
CPP / IPP Gas	0	0	0	0
SOLAR	1489	569	0	0
Exchange with Mumbai	-1954	-1801	-1400	-790
MSEDCL DEMAND MET	18913	17995	19817	17473
Load Shedding	0	0	0	0
MSEDCL DEMAND	18913	17995	19817	17473
TPCL GENERATION	707	801	1163	760
AEML GENERATION	430	313	393	488
MUMBAI DEMAND	3091	2915	2956	2038
OTHER DISCOM DEMAND	522	527	520	383
STATE DEMAND MET	22526	21437	23293	19895
STATE DEMAND	22526	21437	23293	19895
Frequency (Hz)	49.94	50.03	50.00	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 07.47 Hrs	49.83 Hz at 09.38 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Jul/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.13	43.85	186	130
Unit 8	10.87	126.66	520	378
Unit 9	10.72	128.86	551	358
Unit 10	11.24	81.51	515	400
Total	36.96	380.89		
Bhusawal				
Unit 3	3.46	36.38	170	110
Unit 4	0.00	0.00	0	0
Unit 5	9.75	108.70	485	290
Total	13.21	145.08		
Parli				
Unit 6	3.91	43.32	207	143
Unit 7	3.75	42.73	209	130
Unit 8	3.99	42.10	223	141
Total	11.65	128.15		
Chandrapur				
Unit 3	3.39	26.72	160	125
Unit 4	3.49	36.19	161	131
Unit 5	8.04	87.25	405	270
Unit 6	7.87	84.84	388	260
Unit 7	8.48	69.78	435	283
Unit 8	9.00	98.53	440	275
Unit 9	0.00	88.09	0	0
Total	40.27	491.41		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	4.86	53.92	238	145
Total	4.86	53.92		
Khaparkheda				
Unit 1	3.28	33.65	160	110
Unit 2	3.93	42.20	205	115
Unit 3	3.76	39.40	175	130
Unit 4	3.97	27.37	187	125
Unit 5	10.48	116.23	485	285
Total	25.42	258.85		
Nasik				
Unit 3	0.01	23.31	7	0
Unit 4	1.79	26.89	186	0
Unit 5	3.45	17.32	159	124
Total	5.25	67.52		
Uran				
All Units	6.40	72.06	271	261
Total	6.40	72.06		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	1.49	14.35	295	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.32	15.41	764	0
Stage 3	1.29	10.59	160	0
Total	5.09	40.35		
Hydro				
KDPH	0.05	0.05	13	0
VTRNA	0.00	1.01	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.40	3.72	80	0
SMLHY_PTN	2.30	26.67	101	89
GHATGHAR	0.25	2.66	125	0
Total	3.00	34.11		
Wind				
Total	42.97	507.84	0	0
Total	42.97	507.84		
CPP				
APML(Mus)	61.21	642.84	0	0
JSWEL(Mus)	18.81	215.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	22.13	247.39	0	0
SWPGPL-Mus	11.93	131.36	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.49	58.80	269	170
Other(Mus)	2.22	22.83	0	0
JPL	5.33	53.26	270	172
Total	127.13	1371.82		
SOLAR				
Total	17.46	158.10	0	0
Total	17.46	158.10		
Tata				
Trombay 5	8.08	85.35	410	262
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.58	25.63	109	104
Trombay 7B	1.52	15.94	64	62
TATA Hydro	5.19	52.52	379	102
Trombay 8	4.40	45.88	225	134
Total	21.76	225.32		
AEML				
DTPS U-1&2	10.02	108.26	497	293
Total	10.02	108.26		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	137.63	1525.81	MSPGCL Total	152.12	1672.32
			MSPGCL Thml+Gas	144.03	1597.87	Koyna 1,2 & 4 Total	3.81	29.76
			MSPGCL Hydro	8.09	74.45	State Total	371.46	4043.66

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Jul/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5983	321	267	6571	1123	5687	0	0	5572	5446	-905	17483	0	0	17483	2476	439	20398	50.01
2	5863	215	267	6345	1148	5770	0	0	5428	5094	-684	17258	0	0	17258	2288	415	19961	49.93
3	5921	372	268	6561	1345	5366	0	0	5435	5375	-756	17515	0	0	17515	2134	376	20025	50.01
4	6072	138	269	6479	1617	5619	0	0	5381	4932	-790	17473	0	0	17473	2038	383	19895	50.00
5	6077	145	269	6491	1676	5560	0	0	5470	4998	-724	17615	0	0	17615	2034	386	20035	49.98
6	6266	170	267	6703	1726	6134	0	0	5387	5298	-717	18710	0	0	18710	2151	434	21295	50.01
7	6368	1005	269	7642	1704	6236	0	125	5288	5535	-892	19883	0	0	19883	2311	467	22661	49.98
8	6377	238	267	6882	1874	6231	0	532	6117	5732	-1184	19581	0	0	19581	2502	486	22569	50.02
9	5731	177	267	6175	1603	5376	0	1060	7134	6874	-1713	18876	0	0	18876	2820	499	22195	50.01
10	5684	177	263	6124	1556	4754	0	1489	7693	7466	-1954	18913	0	0	18913	3091	522	22526	49.94
11	5318	165	261	5744	1729	4507	0	1978	7919	7430	-2266	18624	0	0	18624	3271	498	22393	50.03
12	4931	138	264	5333	1980	4404	0	2280	7890	6842	-2111	18233	0	0	18233	3260	495	21988	50.01
13	4608	136	264	5008	2147	4003	0	2186	7659	6643	-2057	17451	0	0	17451	3209	479	21139	49.99
14	4602	137	266	5005	2147	3985	0	2199	6303	6158	-1993	17026	0	0	17026	3117	474	20618	49.98
15	4629	135	267	5031	2316	4103	0	2100	6973	6623	-2014	17685	0	0	17685	3139	474	21298	49.97
16	4795	95	263	5153	2529	3923	0	1703	7327	6859	-1934	17736	0	0	17736	3144	497	21377	49.98
17	5152	108	265	5525	2523	4320	0	1122	6968	6631	-1960	17660	0	10	17660	3070	501	21231	49.95
18	5682	178	266	6126	2282	4629	0	569	6928	6717	-1801	17995	0	36	17995	2915	527	21437	50.03
19	6135	352	265	6752	2126	5404	0	117	6465	6318	-1621	18553	0	0	18553	2897	543	21993	50.03
20	6300	1363	267	7930	1852	6150	0	0	5987	5805	-1400	19817	0	0	19817	2956	520	23293	50.00
21	6344	1218	270	7832	1559	6293	0	0	5852	5693	-1290	19571	0	0	19571	2900	516	22987	49.99
22	6292	609	269	7170	1502	6276	0	0	5749	5584	-1147	18877	0	0	18877	2809	508	22194	49.99
23	6307	340	270	6917	1485	6252	0	0	5745	5267	-1095	18330	0	0	18330	2683	496	21509	49.97
24	6191	161	271	6623	1417	6145	0	0	5671	5311	-993	18020	0	0	18020	2571	483	21074	50.04
MUs	137.63	8.09	6.40	152.12	42.97	127.13	0.00	17.46	152.34	144.63	-34.00	438.89	0.00	0.05	438.89	65.79	11.42	516.09	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

- 1)BBLR-1 & 2 reaches upto 760Amp/273 MW
- 2)Generation unit no-3 & 4 out of bar, Generation unit no-5-127MW.
- 3) OCR-Navsari-1 & 2line H/T For load management.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jul/2024

Position as on 6.30 Hrs of 12/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	14/07/2024
MSPGCL	Paras Unit 3	250	30/06/2024	22:35		Continued.	Annual Overhaul	14/08/2024
MSPGCL	Koyna Unit 5	80	02/07/2024	11:00		Continued.	PLC upgradation work	27/07/2024
MSPGCL	Koyna Unit 3	70	09/07/2024	11:00		Continued.	Governor replacement work.	07/08/2024
Total Capacity MSPGCL		900						
IPP								
IPP	RPL(AMT) U-1	270	01/07/2024	07:00		Continued.	Annual Overhaul	01/08/2024
Total Capacity IPP		270						
Total Capacity PLANNED OUTAGE		1170						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Chandrapur Unit 9	500	10/07/2024	17:44		Continued.	Boiler Tube Leakage	14/07/2024
Total Capacity MSPGCL		745						
IPP								
IPP	RPL(AMT) U-5	270	07/07/2024	10:06	11/07/2024	04:13	Due to Bottom Ash Evacuation problem.	11/07/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1335						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	04/07/2024	23:59		Continued.	No Schedule by MSEDCL.	
MSPGCL	Uran Unit 5	108	10/07/2024	21:00		Continued.	Due to Zero schedule given by MSEDCL.	
Total Capacity MSPGCL		216						
IPP								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Jul/2024

Position as on 6.30 Hrs of 12/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	JSW (J) U2	300	01/07/2024	01:12		Continued.	Non availabilty of load schedule	
Total Capacity IPP		300						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		516						
UNIT OUT ON TOLLING *								
MSPGCL								
MSPGCL	Nasik Unit 3	210	08/07/2024	13:30	11/07/2024	23:52	24V Dc Supply Failed supply problem is restored.under tolling from 07:14 Hrs of dtd.	
MSPGCL	Nasik Unit 4	210	11/07/2024	12:03		Continued.	Tolling under case IV from 23:52 hrs of dt.11.07.2024	
Total Capacity MSPGCL		420						
Total Capacity UNIT OUT ON TOLLING *		420						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 12/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
SOLAPUR (PG) - PUNE (GIS)	InterState	11/07/2024	08:53	12/07/2024	06:56	PO	Due to Sant Tukaram Palkhi (Procession)-2024
400 KV TBC Outages/Trippings							
BUS COUPLER @ AURANGABAD (WALUJ)	IntraState	10/07/2024	14:38	11/07/2024	17:20	EO	To attend hotspot at 400 kV Bus Coupler bay at 89B PG Isolator Hanger & blade Contact
400 KV MAINBAY Outages/Trippings							
MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	IntraState	10/07/2024	11:25	11/07/2024	15:41	PO	ABB Breaker Mechanism overhauling work
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
KHADKA-AURANGABAD (WALUJ)	IntraState	12/07/2024	01:56			HT	For controlled overvoltage
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/06/2024	00:07			HT	H/T LV side only.
400/11kV STN-4A @ DEEPNAGAR	IntraState	26/06/2024	11:13			PO	For E/M for checking, cleaning and oil filtration work at MSPGCL End.
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	11/07/2024	05:58	11/07/2024	10:17	PO	RRS trial work completed. ICT II B phase unit has to be taken in service for normalcy
400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	11/07/2024	05:58	11/07/2024	09:42	PO	RRS trial work completed. ICT II B phase unit has to be taken in service for normalcy.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	11/07/2024	09:27	11/07/2024	18:20		For cold welding and maintenance of 400/220/33 KV 315 MVA ICT-02
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	11/07/2024	11:25	11/07/2024	20:32	EO	Faulty Differential relay replacement Work
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	11/07/2024	14:40	11/07/2024	19:55	EO	For attending Hotspot of 90.5 Deg. cel. on Y -phase of IV side jump (Stub Bus side)
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	11/07/2024	20:12	12/07/2024	01:49	EO	400/220/33 kV 3*105 MVA ICT-1 Y ph unit oil top up work and Buchholz relay replacement work.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV BUS SECTIONALIZER	IntraState	11/07/2024	10:49	11/07/2024	13:18	PO	FOR DIAGNOSTIC TESTING & ROUTINE MAINTENANCE WORK.
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 12/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
ALEPHATA-PARGAON(KATHAPUR)	IntraState	02/07/2024	14:56			HT	For controlling loading of Kharghar - Talegaon PG.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/07/2024	09:55			HT	For load managment on 220kv Nashik-Babhleshwar ckt 1&2
VANKUSWADE - KDPH	IntraState	10/07/2024	22:55	11/07/2024	16:28	T	Tripped on distance protection
TROMBAY - KALWA	IntraState	10/07/2024	23:29	11/07/2024	09:07	T	Distance Protection
KARAD -MUDSHINGI CKT 2-TAK	IntraState	11/07/2024	03:39	11/07/2024	04:18	T	Distance Protection
MHAISHAL - SHEDYAL	IntraState	11/07/2024	09:12	11/07/2024	10:57	PO	Y Ph LA Replacement Work
TPC BORIVALI - AAREY	IntraState	11/07/2024	09:52	11/07/2024	16:48	PO	To attend leakage in CT Chamber of bay (Chembur Nutbolt tightening activity will be done)
MAHAPE - TFIPL	IntraState	11/07/2024	10:20	11/07/2024	20:52	PO	For the LILO of newly proposed 220KV GIS S/St of M/S STT Data Centre.
URAN - APTA 3	IntraState	11/07/2024	10:35	11/07/2024	15:08	PO	Replacement of damaged Jumper at loc no 1. Replacement of disc insulator flashover at Loc no. 41
PEDHAMBE ONI LINE	IntraState	11/07/2024	11:05	11/07/2024	16:57	T	Tripped on distance protection
MHAISHAL- JATH	IntraState	11/07/2024	11:20	11/07/2024	12:36	PO	B Ph LA Replacement Work
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	11/07/2024	12:00	11/07/2024	13:11	PO	for checking SCADA operation of breaker
RANJANGAON-LONIKAND	IntraState	11/07/2024	12:34	11/07/2024	15:54	PO	for replacement of flashover disc insulator string at loc no.T-49 of 220kv Ranjangaon-Lonikand II Line.
TROMBAY - MULUND	IntraState	11/07/2024	18:02			T	Tripped on distance protection.
TROMBAY MSETCL TIE - 1	IntraState	11/07/2024	18:02	11/07/2024	20:15	HT	220KV BUS SECTION 3 AT TROMBAY MSETCL TRIP . Line tripped at TATA end only
BUS SECTION - 3 @ TROMBAY	IntraState	11/07/2024	18:02	11/07/2024	19:00	T	220KV BUS SECTION 3 AT TROMBAY MSETCL TRIP along with 220 kv Trombay Mulund line tripping.
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	11/07/2024	18:02	11/07/2024	19:28	T	220KV BUS SECTION 3 AT TROMBAY MSETCL TRIP . Line tripped at Chembur end only
220 KV ICT Outages/Trippings							
220/33kv 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	21/06/2024	12:50			PO	Augmentation of 100 MVA ICT-02 with 200 MVA ICT
220/132 KV 200 MVA ICT 2 @ BABHLESHWAR	IntraState	11/07/2024	10:10	11/07/2024	23:15	PO	Relay replacement and Attending oil leakage of ICT from top plate.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 12/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100MVA PTR NO 6 @CHINCHWAD	IntraState	11/07/2024	10:18	11/07/2024	19:13	PO	W.T.I & O.T.I METER CONTROL CABLE replacement work, fire detector installation work
220/22KV 50MVA PTR 2 @ RANJANGAON	IntraState	11/07/2024	11:10	11/07/2024	17:35	PO	For Diagnostic Testing of T/F as it delivers low voltage on 22KV Side
110 KV LINE Outages/Trippings							
AMBERNATH - KALYAN CKT - 1	IntraState	11/07/2024	09:53	11/07/2024	19:07	PO	INSULATOR REPLACEMENT

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage