

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Aug/2016 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	71.652	710.599	1) Gujrat	7.931	26.873
2) Hydro	14.182	156.278	2) Madhya Pradesh	11.650	119.586
3) Gas	7.103	96.040	3) Chattisgarh	7.040	76.240
Total MSPGCL	92.937	962.917	4) Maharashtra Net	70.310	656.812
B) 1) APML	26.772	343.243	5) Goa (Amona)	-0.846	-8.183
2) JSWEL	22.023	217.236	6) TAPS 1&2 Injection	7.636	82.367
3) VIPL	11.736	87.475	7) RGPPL Injection	11.580	129.198
4) RPL(AMT)	0.000	0.000	8) Pench (MS)	0.221	3.323
5) WPCL	4.912	49.113	9) Pench (Excess)	-0.221	-3.323
6) PGPL	1.913	2.045	Total	115.080	1079.570
7) Other IPP	2.029	24.732	a) Mumbai Schedule	19.677	191.240
C) 1) TPCL Thermal	13.998	140.594	b) Mumbai Drawl	24.421	264.095
2) TPCL Hydro	5.857	68.888	c) MSEDCL Bilateral *	26.484	290.267
3) TPCL Gas	4.273	38.550	Include PX	-0.029	-25.107
4) R-INFRA Thermal	10.425	108.249	d) Mumbai Bilateral *	19.677	191.240
D) STATE			Include PX	1.305	27.245
1) Thermal	163.547	1681.241	Include Standby	0.000	0.000
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro (A2+C2)	20.039	225.166	1) MSEDCL	296.218	3052.575
3) Gas (A3+B6+C3)	13.289	136.635	2) Mumbai Discoms	58.974	620.369
4) Wind	42.247	541.891	TOTAL STATE	355.192	3672.944
6) SOLAR	0.990	8.448			
TOTAL STATE	240.112	2593.381			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	3119	3050	3193	2816
MSPGCL Hydro	413	264	1495	423
MSPGCL Gas	290	282	281	290
MSPGCL Total Generation	3822	3596	4969	3529
Central Sector Receipt	5430	5911	5042	4412
WIND	1761	1912	1756	1658
CPP / IPP Thermal	3108	2793	2889	2548
CPP / IPP Gas	63	102	23	63
SOLAR	92	139	0	0
Exchange with Mumbai	-1243	-1580	-1019	-622
MSEDCL DEMAND MET	13033	12873	13660	11588
Load Shedding	0	0	0	0
MSEDCL DEMAND	13033	12873	13660	11588
TPCL GENERATION	1291	1046	1255	653
R-INFRA GENERATION	503	402	506	404
MUMBAI DEMAND	3037	3028	2780	1679
STATE DEMAND MET	16070	15901	16440	13267
STATE DEMAND	16070	15901	16440	13267
Frequency (Hz)	49.99	50.00	49.94	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.19 Hz at 18.01 Hrs	49.8 Hz at 19.26 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Aug/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.37	72.51	450	339
Total	9.37	72.51		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	26.14	0	0
Unit 4	3.63	34.52	178	100
Unit 5	7.87	85.64	350	305
Unit 6	8.76	70.71	410	330
Unit 7	8.91	89.70	400	345
Unit 8	7.06	33.05	343	221
Total	36.23	339.75		
Paras				
Unit 3	0.00	33.73	0	0
Unit 4	5.27	51.45	250	195
Total	5.27	85.17		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	10.54	108.07	500	400
Total	10.54	108.07		
Nasik				
Unit 3	4.08	41.65	195	160
Unit 4	4.11	36.25	198	160
Unit 5	0.00	10.04	0	0
Total	8.20	87.94		
Uran				
All Units	7.10	96.04	376	277
Total	7.10	96.04		
PGPL				
Unit 1	1.19	1.28	126	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	0.72	0.76	63	0
Total	1.91	2.04		
PENCH (MS)				
Pench (MS)	0.22	3.32	27	0
Total	0.22	3.32		
Koyna				
Stage 1-2	5.16	42.18	560	105
Stage 4	2.07	41.97	671	0
Stage 3	2.12	30.31	160	0
Total	9.36	114.46		
Hydro				
KDPH	0.86	3.39	36	36
VTRNA	1.16	9.70	58	0
TILLARI	0.36	2.30	61	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.50	5.43	80	0
RNGR+BHTSA	0.47	2.78	20	19
BHANDARDRA	0.34	5.91	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.42	3.75	24	14
GHATGHAR	0.71	8.56	120	0
Total	4.83	41.81		
Wind				
Total	42.25	541.89	0	0
Total	42.25	541.89		
CPP				
APML(Mus)	26.77	343.24	0	0
JSWEL(Mus)	22.02	217.24	0	0
VIPL(Mus)	11.74	87.48	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	4.91	49.11	0	0
Other(Mus)	2.03	24.73	0	0
Total	67.47	721.80		
SOLAR				
Total	0.99	8.45	0	0
Total	0.99	8.45		
Tata				
Trombay 5	8.82	86.53	485	312
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.69	23.47	116	82
Trombay 7B	1.58	15.08	67	56
Trombay 8	5.18	54.06	252	198
TATA Hydro	5.86	68.89	390	0
Total	24.13	248.03		
R-INFRA				
1-2	10.42	108.25	507	402
Total	10.42	108.25		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	2.05	17.16
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	71.65	710.60
MSPGCL Thml+Gas	78.76	806.64
MSPGCL Hydro	14.18	156.28

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	92.94	962.92
Koyna 1,2 & 4 Total	7.23	84.16
State Total	240.11	2593.38

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 11/Aug/2016

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2778	418	281	3477	1607	3016	62	0	4306	4322	-779	11706	0	11706	1983	13689	49.96
2	2785	413	290	3488	1606	2796	65	0	4221	4422	-705	11672	0	11672	1822	13494	49.96
3	2803	428	279	3510	1580	2556	64	0	4074	4502	-649	11562	0	11562	1734	13296	49.97
4	2816	423	290	3529	1658	2548	63	0	4350	4412	-622	11588	0	11588	1679	13267	49.98
5	2806	426	280	3512	1659	2547	62	0	4366	4423	-602	11601	0	11601	1679	13280	49.99
6	2852	592	290	3734	1716	2540	64	0	4570	4972	-617	12409	0	12409	1802	14211	49.98
7	2981	983	291	4255	1464	2759	65	2	4672	4937	-677	12805	0	12805	1966	14771	49.95
8	3098	862	279	4239	1511	3090	66	20	4816	5264	-650	13540	0	13540	2166	15706	50.02
9	3088	680	294	4062	1719	3102	66	50	5085	5165	-903	13261	0	13261	2484	15745	50.03
10	3089	522	291	3902	1628	3098	62	80	5280	5349	-1133	12986	0	12986	2844	15830	50.00
11	3119	413	290	3822	1761	3108	63	92	5407	5430	-1243	13033	0	13033	3037	16070	49.99
12	3049	307	284	3640	1907	3072	68	137	5616	5236	-1473	12587	0	12587	3092	15679	50.00
13	3050	264	282	3596	1912	2793	102	139	5401	5911	-1580	12873	0	12873	3028	15901	50.00
14	2958	284	292	3534	1950	2572	134	137	4851	5349	-1439	12238	0	12238	2880	15118	50.03
15	2966	327	292	3585	2075	2557	178	143	4679	4751	-1387	11902	0	11902	2878	14780	49.98
16	2888	422	288	3598	2165	2600	182	95	4551	4910	-1445	12105	0	12105	2882	14987	50.01
17	2926	400	277	3603	2248	2538	127	68	4288	4831	-1403	12012	0	12012	2842	14854	50.00
18	2915	519	288	3722	1997	2462	0	23	3984	3702	-1321	10585	0	10585	2815	13400	49.97
19	3031	892	280	4203	1908	2574	9	4	4179	4271	-1221	11748	0	11748	2775	14522	50.01
20	3193	1495	281	4969	1756	2889	23	0	4638	5042	-1019	13660	0	13660	2780	16440	49.94
21	3248	1337	302	4887	1796	3098	82	0	4625	4483	-911	13435	0	13435	2715	16150	49.99
22	3216	879	335	4430	1519	3113	157	0	4463	4323	-884	12658	0	12658	2527	15185	49.95
23	3070	483	371	3924	1638	3085	146	0	4573	4573	-907	12460	0	12460	2330	14790	49.98
24	2927	413	376	3716	1467	2959	0	0	4203	4498	-851	11789	0	11789	2234	14023	49.99
MUs	71.65	14.18	7.10	92.94	42.25	67.47	1.91	0.99	111.20	115.08	-24.42	296.22	0.00	296.22	58.97	355.19	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 11/Aug/2016

Position as on 6.30 Hrs of 12/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Koyana Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 1	210	25/06/2016	23.45		Continued.	Zero Schedule by MSEDCL from 00.00Hrs Dt.19-7-16 and A.O.H from 25/06/2016 to 18/07/2016	
MSPGCL	Bhusawal Unit 4	500	01/07/2016	23.55		Continued.	A.O.H from 19/07/2016 and Zero Shedule By MSEDCL from 1/07/2016 to 18/07/2016.	
MSPGCL	Khaparkheda Unit 3	210	05/07/2016	23.52		Continued.	Zero Shedule By MSEDCL, converted for AOH from 00 Hrs Dt.25-7-16	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-2	270	18/06/2016	06.54		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	30/06/2016	10.11		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	01/07/2016	02.23		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 7	210	01/07/2016	04.43		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-1	270	01/07/2016	18.40		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 5	500	01/07/2016	23.59		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 2	210	05/07/2016	23.46		Continued.	Zero Shedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Aug/2016

Position as on 6.30 Hrs of 12/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 4	210	08/07/2016	03.07		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	08/07/2016	23.57		Continued.	ID Fan Problem (Converted to Zero schedule by MSEDCL from 11-07-2016)	
IPP	Adani U-4	660	13/07/2016	02.22		Continued.	Zero Shedule By MSEDCL,Shedule Glven On 21/08/2016	
RGPL	Dabhol 2B	230	24/07/2016	17.13		Continued.	Change Over	
MSPGCL	Nasik Unit 5	210	03/08/2016	17.30		Continued.	Zero shedule	
IPP	Adani U-1	660	05/08/2016	11.44		Continued.	Zero Schedule from MSEDCL	
IPP	Adani U-5	660	06/08/2016	23.54		Continued.	Zero schedule given by MSDCL.	
MSPGCL	Paras Unit 3	250	08/08/2016	00.01		Continued.	Zero schedule given by MSDCL.	
MSPGCL	Chandrapur Unit 3	210	09/08/2016	00.08		Continued.	Zero Schedue	
MSPGCL	Uran Unit B0	120	09/08/2016	20.24	11/08/2016	23.23	Due To Gas Sortage.	
MSPGCL	Uran Unit 8	108	09/08/2016	20.33	11/08/2016	20.18	Due To Gas Sortage.	
MSPGCL	Chandrapur Unit 9	500	11/08/2016	22.11		Continued.	Oil Shortage.	
MSPGCL	Nasik Unit 4	210	12/08/2016	06.50		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 12/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Chandrapur Bhadravati II	InterState	03/08/2016	01.59		Continued.	HT	Over Voltage
Dhule Khandwa I	InterState	08/08/2016	13.20	12/08/2016	07.39	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	10/08/2016	16.04	11/08/2016	09.41	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	11/08/2016	03.00	11/08/2016	07.05	T	Over Voltage
Kolhapur Solapur(PG) I	InterState	11/08/2016	16.13	12/08/2016	07.05	HT	Over Voltage
Akola Wardha I	InterState	12/08/2016	11.07	12/08/2016	16.35	PO	Quarterly Maintanance Work
Chandrapur-II - Warora - I	InterState	12/08/2016	11.40	12/08/2016	14.04	PO	Repl.of Partially damage Corona Ring
Kolhapur Solapur(PG) I	InterState	12/08/2016	16.48		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	27/07/2016	13.09		Continued.	HT	Over Voltage
Ektuni-Bableshwar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Padghe - Kharghar	IntraState	07/08/2016	17.07		Continued.	PO	Shifted on TBC at kharghar end
N.Koyna-Karad -Ckt I	IntraState	08/08/2016	12.25		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	09/08/2016	14.48		Continued.	T	Over Voltage,Opportunity Outage from DT 16.08.2016.
Karad - Jaigad - II	IntraState	10/08/2016	17.33	11/08/2016	10.17	HT	Over Voltage
Padghe - Kalwa-II	IntraState	12/08/2016	08.26	12/08/2016	13.01	PO	While taking outage for PMU work Y Phase Breaker Pole is Stuck up at Kalwa end.
Main Bus I @ Kalwa	IntraState	12/08/2016	09.44	12/08/2016	10.19	T	Bus Bar Prot.Operated
Kalwa - Talegaon(PG)	IntraState	12/08/2016	09.44	12/08/2016	10.42	T	Bus Bar Protection Operated
Kalwa - Kharghar	IntraState	12/08/2016	09.44	12/08/2016	13.55	T	Bus Bar Protection Operated
400 KV ICT Outages/Trippings							
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	11/08/2016	06.16	11/08/2016	09.31	PO	To Attend CTR Problem.
400/220 KV 500 MVA ICT-II @Warora	IntraState	11/08/2016	08.26	11/08/2016	19.54	PO	CT & Tan Delta Testing Work.
400/220 Kv 500 MVA ICT II @Jejuri	IntraState	11/08/2016	09.36	11/08/2016	17.59	PO	A.M.Work.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	12/08/2016	09.44	12/08/2016	10.52	T	Bus Bar Protection Operated
400/220 KV 315 MVA ICT- I @Koradi	IntraState	12/08/2016	13.06	12/08/2016	17.11	EO	Fire dection alarm problem solving work.
220 KV LINE Outages/Trippings							
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Aurangabad (Waluj)-Bhenda	IntraState	22/06/2016	23.02		Continued.	HT	Hand Tripped.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableshwar- Alephata	IntraState	24/07/2016	07.57		Continued.	HT	Load Diversion.
Kalwa - Borivali	IntraState	10/08/2016	20.56	12/08/2016	10.08	PO	Shifted On TBC.
Loteparshuram- Dasturi Line	IntraState	11/08/2016	11.18	11/08/2016	16.08	EO	Attending Hot Spot
Telco- Chinchwad	IntraState	11/08/2016	11.19	11/08/2016	18.10	PO	Testing Work
Dasturi-Kandalgaon Line	IntraState	11/08/2016	11.45	11/08/2016	15.35	EO	Attending Hot Spot
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	11/08/2016	11.58	11/08/2016	18.19	PO	To Increase Y & B Ph,Phase to Phase Clearance,Line Signature Test.
Pophali - Kdph	IntraState	11/08/2016	12.05	12/08/2016	13.55	T	Y Ph Jumper Open Near Gantry.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 12/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Shivajinagar - Satana	IntraState	11/08/2016	22.17	12/08/2016	17.01	T	Distance Protection
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	12/08/2016	06.31	12/08/2016	12.24	T	Distance Protection
Mahad - Pedambe	IntraState	12/08/2016	12.09	12/08/2016	14.30	PO	Conductor replacement.
Virur - Gadchiroli	IntraState	12/08/2016	12.25	12/08/2016	16.26	PO	Replacement of faulty Disc
Mahad - Pedambe	IntraState	12/08/2016	12.30	12/08/2016	14.30	PO	Maintance work.
Malharpeth - Karad(400kv)	IntraState	12/08/2016	14.40	12/08/2016	16.31	PO	Replacement of Line Isolator
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 200 Mva Bbl Ict 2 @Beed	IntraState	12/08/2016	10.45	12/08/2016	17.40	PO	Measurment of Tan Delta and SFRA of ICT
220/132 Kv 100 Mva Gec Ict 1 @Pusad	IntraState	12/08/2016	15.26	12/08/2016	18.40	PO	Testing Work
132 KV LINE Outages/Trippings							
Dhule(220kv) - Dhule(132 Kv) 1	IntraState	11/08/2016	09.26	11/08/2016	12.48	T	Distance Protection
100 KV LINE Outages/Trippings							
Vasai-Ii - Vasai 1 Line	IntraState	29/06/2016	11.28		Continued.	HT	To Control Kalwa-Salsette-6 Line Loading.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage