

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 11/Aug/2020 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 109.705        | 1212.152        | 1) Gujrat                      | 0.162          | 5.758           |
| 2) Hydro            | 5.461          | 76.792          | 2) Madhya Pradesh              | 5.440          | 76.860          |
| 3) Gas              | 6.019          | 40.309          | 3) Chattisgarh                 | 4.580          | 49.860          |
| <b>Total MSPGCL</b> | <b>121.185</b> | <b>1329.253</b> | 4) Maharashtra                 | 107.066        | 1216.418        |
| B) 1) APML          | 25.964         | 304.630         | 5) Goa (Amona)                 | -1.294         | -16.586         |
| 2) JSWEL            | 14.757         | 178.211         | <b>Total</b>                   | <b>115.954</b> | <b>1332.310</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 27.314         | 271.285         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 28.082         | 274.972         |
| 5) WPCL             | 7.252          | 83.588          | c) MSEDCL Bilateral *          | 26.092         | 342.222         |
| 6) Other IPP        | 8.581          | 84.329          | Include PX                     | 3.848          | 38.236          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 27.314         | 271.285         |
| C) 1) TPCL Thermal  | 7.376          | 85.705          | Include PX                     | 16.307         | 168.449         |
| 2) TPCL Hydro       | 2.601          | 25.472          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.404          | 47.484          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 4.540          | 53.045          | 1) MSEDCL                      | 315.589        | 3533.445        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 47.003         | 486.673         |
| 1) Thermal          | 178.175        | 2001.660        | <b>TOTAL STATE</b>             | <b>362.592</b> | <b>4020.118</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 8.062          | 102.264         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 10.423         | 87.793          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 45.809         | 441.346         |                                |                |                 |
| 6) SOLAR            | 4.169          | 54.750          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>246.638</b> | <b>2687.813</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4543                      | 4570                  | 4857                      | 4189                      |
| MSPGCL Hydro             | 286                       | 123                   | 496                       | 172                       |
| MSPGCL Gas               | 240                       | 250                   | 250                       | 250                       |
| MSPGCL Total Generation  | 5069                      | 4943                  | 5603                      | 4611                      |
| Central Sector Receipt   | 6173                      | 5167                  | 4989                      | 4073                      |
| WIND                     | 1713                      | 2114                  | 1993                      | 1556                      |
| CPP / IPP Thermal        | 2599                      | 2260                  | 2753                      | 2139                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 501                       | 572                   | 0                         | 0                         |
| Exchange with Mumbai     | -1504                     | -1539                 | -1144                     | -920                      |
| <b>MSEDCL DEMAND MET</b> | <b>14551</b>              | <b>13517</b>          | <b>14194</b>              | <b>11459</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14551                     | 13517                 | 14194                     | 11459                     |
| TPCL GENERATION          | 621                       | 595                   | 720                       | 523                       |
| AEML GENERATION          | 189                       | 189                   | 189                       | 189                       |
| <b>MUMBAI DEMAND</b>     | <b>2314</b>               | <b>2323</b>           | <b>2053</b>               | <b>1632</b>               |
| STATE DEMAND MET         | 16865                     | 15840                 | 16247                     | 13091                     |
| <b>STATE DEMAND</b>      | <b>16865</b>              | <b>15840</b>          | <b>16247</b>              | <b>13091</b>              |
| Frequency (Hz)           | 50.02                     | 50.01                 | 49.99                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.19 Hz at 13.01 Hrs | 49.73 Hz at 18.25 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 11/Aug/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 6.03         | 112.98        | 416      | 0        |
| Unit 9             | 8.54         | 106.86        | 390      | 305      |
| Unit 10            | 8.51         | 50.72         | 400      | 300      |
| <b>Total</b>       | <b>23.08</b> | <b>270.56</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 8.74         | 47.84         | 440      | 360      |
| Unit 5             | 8.46         | 58.34         | 400      | 225      |
| <b>Total</b>       | <b>17.20</b> | <b>106.18</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 1.49         | 29.00         | 163      | 0        |
| Unit 4             | 3.24         | 38.53         | 152      | 117      |
| Unit 5             | 8.38         | 98.04         | 390      | 285      |
| Unit 6             | 8.77         | 98.92         | 390      | 330      |
| Unit 7             | 0.00         | 44.52         | 0        | 0        |
| Unit 8             | 8.78         | 67.95         | 450      | 150      |
| Unit 9             | 9.32         | 105.57        | 450      | 360      |
| <b>Total</b>       | <b>39.98</b> | <b>482.54</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.19         | 49.42         | 188      | 143      |
| Unit 4             | 4.49         | 47.89         | 198      | 160      |
| <b>Total</b>       | <b>8.68</b>  | <b>97.31</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.92         | 37.41         | 145      | 95       |
| Unit 2             | 3.17         | 35.57         | 170      | 115      |
| Unit 3             | 3.19         | 33.78         | 163      | 110      |
| Unit 4             | 3.28         | 43.10         | 150      | 115      |
| Unit 5             | 8.21         | 105.70        | 360      | 310      |
| <b>Total</b>       | <b>20.77</b> | <b>255.56</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.02         | 40.31         | 261      | 239      |
| <b>Total</b>       | <b>6.02</b>  | <b>40.31</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 1.00         | 9.66          | 54       | 24       |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>1.00</b>  | <b>9.66</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 1.90         | 27.90         | 335      | 35       |
| Stage 4         | 0.55         | 11.86         | 224      | 0        |
| Stage 3         | 1.44         | 20.00         | 160      | 0        |
| <b>Total</b>    | <b>3.89</b>  | <b>59.77</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.00         | 0.70          | 0        | 0        |
| VTRNA           | 0.00         | 0.00          | 0        | 0        |
| TILLARI         | 0.23         | 6.78          | 58       | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.37         | 3.61          | 40       | 0        |
| RNGR+BHTSA      | 0.00         | 0.20          | 0        | 0        |
| BHANDARDRA      | 0.07         | 0.95          | 16       | 0        |
| ELDARY          | 0.00         | 0.00          | 0        | 0        |
| SMLHY_PTN       | 0.90         | 4.79          | 38       | 37       |
| GHATGHAR        | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>1.57</b>  | <b>17.02</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 45.81        | 441.35        | 0        | 0        |
| <b>Total</b>    | <b>45.81</b> | <b>441.35</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 25.96        | 304.63        | 0        | 0        |
| JSWEL(Mus)      | 14.76        | 178.21        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00          | 0        | 0        |
| WPCL(Mus)       | 7.25         | 83.59         | 0        | 0        |
| Other(Mus)      | 8.58         | 84.33         | 0        | 0        |
| <b>Total</b>    | <b>56.55</b> | <b>650.76</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 4.17         | 54.75         | 0        | 0        |
| <b>Total</b>    | <b>4.17</b>  | <b>54.75</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 7.38         | 85.70         | 311      | 300      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 2.81         | 30.20         | 118      | 116      |
| Trombay 7B      | 1.60         | 17.28         | 67       | 66       |
| Trombay 8       | 0.00         | 0.00          | 0        | 0        |
| TATA Hydro      | 2.60         | 25.47         | 224      | 3        |
| <b>Total</b>    | <b>14.38</b> | <b>158.66</b> |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 4.54         | 53.04         | 190      | 189      |
| <b>Total</b>    | <b>4.54</b>  | <b>53.04</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 109.70      | 1212.15       | MSPGCL Total        | 121.18      | 1329.25       |
|                |             |         | MSPGCL Thml+Gas | 115.72      | 1252.46       | Koyna 1,2 & 4 Total | 2.44        | 39.77         |
|                |             |         | MSPGCL Hydro    | 5.46        | 76.79         | State Total         | 246.64      | 2687.81       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 11/Aug/2020

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4255        | 162  | 260  | 4677   | 1764  | 2203      | 0    | 0     | 4648        | 4280        | -1045                | 11879                 | 0                    | 11879                     | 1817             | 13696           | 50.00         |
| 2                  | 4068        | 297  | 250  | 4615   | 1798  | 2150      | 0    | 0     | 3855        | 3845        | -915                 | 11493                 | 0                    | 11493                     | 1709             | 13202           | 49.96         |
| 3                  | 4189        | 172  | 250  | 4611   | 1556  | 2139      | 0    | 0     | 4015        | 4073        | -920                 | 11459                 | 0                    | 11459                     | 1632             | 13091           | 49.99         |
| 4                  | 4264        | 167  | 251  | 4682   | 1472  | 2119      | 0    | 0     | 4175        | 4144        | -894                 | 11523                 | 0                    | 11523                     | 1578             | 13101           | 50.00         |
| 5                  | 4322        | 132  | 250  | 4704   | 1715  | 2100      | 0    | 0     | 4673        | 4187        | -867                 | 11839                 | 0                    | 11839                     | 1551             | 13390           | 49.96         |
| 6                  | 4351        | 77   | 260  | 4688   | 1730  | 2139      | 0    | 0     | 5114        | 4875        | -900                 | 12532                 | 0                    | 12532                     | 1585             | 14117           | 50.00         |
| 7                  | 4384        | 82   | 250  | 4716   | 1652  | 2318      | 0    | 17    | 5499        | 5479        | -903                 | 13279                 | 0                    | 13279                     | 1619             | 14898           | 49.98         |
| 8                  | 4585        | 77   | 250  | 4912   | 1782  | 2569      | 0    | 113   | 5839        | 5433        | -976                 | 13833                 | 0                    | 13833                     | 1738             | 15571           | 49.95         |
| 9                  | 4750        | 155  | 250  | 5155   | 1808  | 2607      | 0    | 234   | 6049        | 5966        | -1184                | 14586                 | 0                    | 14586                     | 1947             | 16533           | 49.99         |
| 10                 | 4568        | 175  | 250  | 4993   | 1578  | 2568      | 0    | 358   | 6252        | 6304        | -1403                | 14398                 | 0                    | 14398                     | 2168             | 16566           | 49.99         |
| 11                 | 4543        | 286  | 240  | 5069   | 1713  | 2599      | 0    | 501   | 6027        | 6173        | -1504                | 14551                 | 0                    | 14551                     | 2314             | 16865           | 50.02         |
| 12                 | 4607        | 186  | 249  | 5042   | 1853  | 2613      | 0    | 502   | 5864        | 5534        | -1581                | 13963                 | 0                    | 13963                     | 2368             | 16331           | 50.03         |
| 13                 | 4570        | 123  | 250  | 4943   | 2114  | 2260      | 0    | 572   | 5896        | 5167        | -1539                | 13517                 | 0                    | 13517                     | 2323             | 15840           | 50.01         |
| 14                 | 4599        | 128  | 249  | 4976   | 2226  | 2133      | 0    | 548   | 5642        | 5136        | -1497                | 13522                 | 0                    | 13522                     | 2249             | 15771           | 50.04         |
| 15                 | 4587        | 118  | 250  | 4955   | 2212  | 2150      | 0    | 562   | 4978        | 4691        | -1448                | 13122                 | 0                    | 13122                     | 2209             | 15331           | 50.00         |
| 16                 | 4624        | 183  | 239  | 5046   | 2123  | 2165      | 0    | 379   | 4769        | 4924        | -1308                | 13329                 | 0                    | 13329                     | 2171             | 15500           | 50.00         |
| 17                 | 4649        | 233  | 249  | 5131   | 2207  | 2146      | 0    | 253   | 4878        | 5008        | -1218                | 13527                 | 0                    | 13527                     | 2116             | 15643           | 50.00         |
| 18                 | 4674        | 672  | 260  | 5606   | 2115  | 2277      | 0    | 117   | 4709        | 4742        | -1236                | 13621                 | 0                    | 13621                     | 2072             | 15693           | 49.99         |
| 19                 | 4772        | 572  | 249  | 5593   | 2171  | 2561      | 0    | 13    | 4915        | 4626        | -1212                | 13752                 | 0                    | 13752                     | 2044             | 15796           | 49.91         |
| 20                 | 4857        | 496  | 250  | 5603   | 1993  | 2753      | 0    | 0     | 5076        | 4989        | -1144                | 14194                 | 0                    | 14194                     | 2053             | 16247           | 49.99         |
| 21                 | 5086        | 254  | 250  | 5590   | 2041  | 2864      | 0    | 0     | 4670        | 4125        | -1118                | 13502                 | 0                    | 13502                     | 2015             | 15517           | 50.01         |
| 22                 | 4865        | 249  | 250  | 5364   | 1995  | 2750      | 0    | 0     | 4095        | 4103        | -1081                | 13131                 | 0                    | 13131                     | 1962             | 15093           | 50.02         |
| 23                 | 4781        | 243  | 252  | 5276   | 2027  | 2242      | 0    | 0     | 4529        | 4195        | -1108                | 12632                 | 0                    | 12632                     | 1892             | 14524           | 50.01         |
| 24                 | 4755        | 222  | 261  | 5238   | 2164  | 2129      | 0    | 0     | 3887        | 3955        | -1081                | 12405                 | 0                    | 12405                     | 1871             | 14276           | 50.01         |
| MUs                | 109.71      | 5.46 | 6.02 | 121.18 | 45.81 | 56.55     | 0.00 | 4.17  | 120.05      | 115.95      | -28.08               | 315.59                | 0.00                 | 315.59                    | 47.00            | 362.59          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 11/Aug/2020**

**Position as on 6.30 Hrs of 12/Aug/2020**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                             |               |
| MSPGCL                | Koyna Unit 3            | 70       | 16/07/2020   | 08.55        |           | Continued. | Service Seal Leakage                                                                        |               |
| MSPGCL                | Koyna STG-IV Unit-3     | 250      | 03/08/2020   | 09.27        |           | Continued. | Annual Overhaul                                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                             |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                     |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                               |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                               |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                   | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |           | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                   | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                   | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL                | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |           | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 18/02/2020   | 00.25        |           | Continued. | Severe Hunting In Hydro Conduit Across MIV                                                  |               |
| MSPGCL                | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |           | Continued. | Gas shortage                                                                                |               |
| IPP                   | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 09/03/2020   | 10:50        |           | Continued. | Expansion joint leakage.                                                                    |               |
| IPP                   | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL                | Parli Unit 6            | 250      | 21/03/2020   | 17.31        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL                | Nasik Unit 4            | 210      | 25/03/2020   | 19.45        |           | Continued. | Reserve Shut Down.(Converted zero schedule from 25.03.2020)                                 |               |
| TPC_G                 | Trombay 8               | 250      | 11/04/2020   | 16.55        |           | Continued. | Zero Schedule.                                                                              |               |
| IPP                   | JSW (J) U3              | 300      | 30/04/2020   | 15.13        |           | Continued. | No Schedule                                                                                 |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/05/2020   | 19.34        |           | Continued. | Zero Schedule.                                                                              |               |
| MSPGCL                | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL                | Parli Unit 8            | 250      | 01/06/2020   | 13.13        |           | Continued. | Zero schedule By MSEDCL                                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 11/Aug/2020**

**Position as on 6.30 Hrs of 12/Aug/2020**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                        | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------|---------------|
| IPP                | Adani U-1               | 660      | 03/06/2020   | 15.02        |            | Continued. | Converted zero schedule from 03.06.2020 |               |
| IPP                | Adani U-5               | 660      | 04/06/2020   | 12.29        |            | Continued. | Zero Schedule.                          |               |
| IPP                | Adani U-4               | 660      | 12/06/2020   | 10.30        |            | Continued. | Zero Schedule                           |               |
| AEML               | AEML Unit 1             | 250      | 27/06/2020   | 23.55        |            | Continued. | Zero schedule.                          |               |
| MSPGCL             | Chandrapur Unit 7       | 500      | 06/08/2020   | 03.33        |            | Continued. | Sparkling in generator Rphase winding.  |               |
| MSPGCL             | Koradi Unit-8           | 660      | 11/08/2020   | 00.53        | 11/08/2020 | 06.43      | Condenser Vacuum Low.                   |               |
| MSPGCL             | Chandrapur Unit 3       | 210      | 11/08/2020   | 10.00        |            | Continued. | PA Fan problem                          |               |
| CPP                | SWPGL U-4               | 135      | 12/08/2020   | 00.45        |            | Continued. | Zero Schedule by MSEDCL                 |               |
| CPP                | SWPGL U-3               | 135      | 12/08/2020   | 00.45        |            | Continued. | Zero Schedule by MSEDCL                 |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 11/Aug/2020**

**Statement-VII**

Position as on 6.30 Hrs of 12/Aug/2020

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                       |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                        |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                               |
| Dhule Sar'Sarovar II                              | InterState                | 30/07/2020   | 12.45        |            | Continued. | HT          | Over Voltage                                                                                           |
| BABHALESHWAR - RPL(NASHIK) CKT - 1                | IntraState                | 11/06/2020   | 10.40        |            | Continued. | HT          | Over Voltage                                                                                           |
| Karad-Jaigad - I                                  | IntraState                | 29/07/2020   | 18.11        |            | Continued. | HT          | Over Voltage                                                                                           |
| Dhule- Bableshtar - I                             | IntraState                | 31/07/2020   | 19.27        |            | Continued. | HT          | Over Voltage                                                                                           |
| Bhusawal-Aurangabad                               | IntraState                | 07/08/2020   | 16.19        |            | Continued. | HT          | Over Voltage                                                                                           |
| Padghe - Nagothane - II                           | IntraState                | 07/08/2020   | 23.23        |            | Continued. | HT          | Over Voltage                                                                                           |
| karad -kolhapur-II                                | IntraState                | 08/08/2020   | 20.16        | 11/08/2020 | 11.00      | HT          | Over Voltage                                                                                           |
| Padghe - Kalwa- I                                 | IntraState                | 10/08/2020   | 20.56        | 11/08/2020 | 08.59      | HT          | Over Voltage                                                                                           |
| Lonikand I - Koyana stage-IV                      | IntraState                | 10/08/2020   | 22.12        | 11/08/2020 | 08.49      | HT          | Over Voltage                                                                                           |
| Chandrapur-II - Nanded ckt II                     | IntraState                | 10/08/2020   | 23.39        | 11/08/2020 | 08.35      | T           | Over Voltage                                                                                           |
| Akola II - Akola I Ckt-II                         | IntraState                | 11/08/2020   | 12.16        | 11/08/2020 | 12.40      | T           | Ckt tripped at Akola end only while availing Main Bus-II outage                                        |
| karad -kolhapur-I                                 | IntraState                | 11/08/2020   | 21.11        |            | Continued. | HT          | Over Voltage                                                                                           |
| Padghe - Kalwa- I                                 | IntraState                | 11/08/2020   | 21.15        |            | Continued. | HT          | Over Voltage                                                                                           |
| Lonikand I - Koyana stage-IV                      | IntraState                | 11/08/2020   | 21.28        |            | Continued. | HT          | Over Voltage                                                                                           |
| Akola II - RPL(Rattaniindia) Ckt I                | IntraState                | 12/08/2020   | 01.28        |            | Continued. | HT          | Over Voltage                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                                               |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement Of Existing 315 MVA ICT By 3*167 MVA ICT.                                                  |
| 400/220 Kv 500 MVA ICT II @Jejuri                 | IntraState                | 11/08/2020   | 00.17        | 11/08/2020 | 06.55      | HT          | Over Voltage                                                                                           |
| 400/220 Kv 600 MVA ICT-II @Kalwa                  | IntraState                | 11/08/2020   | 09.13        | 11/08/2020 | 17.40      | PO          | For B-ph IPS tube connection work between 29C isolator and 29D isolator and to take the ICT on own CB. |
| 400/220/33 Kv 500 Mva Ict-3 @Nagothane            | IntraState                | 11/08/2020   | 10.19        | 11/08/2020 | 14.49      | EO          | To attend Hot Spot                                                                                     |
| 400/220KV 315MVA ICT-II @Akola (M)                | IntraState                | 11/08/2020   | 14.19        | 11/08/2020 | 14.45      | T           | While testing Bus Bar scheme.Only LV CB tripped                                                        |
| 400/220KV 315MVA ICT-II @Akola (M)                | IntraState                | 11/08/2020   | 16.08        | 11/08/2020 | 16.41      | T           | Tripped while testing Bus Bar Scheme                                                                   |
| 400/220 kv 500 MVA ICT III @ Jejuri               | IntraState                | 12/08/2020   | 00.12        | 12/08/2020 | 06.47      | HT          | Over Voltage                                                                                           |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                        |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.                                                                                           |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                                                                |
| BOISAR BORIVALI                                   | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                                                           |
| Sawantwadi-Bidri                                  | IntraState                | 10/08/2020   | 22.45        | 11/08/2020 | 10.30      | HT          | Over Voltage                                                                                           |
| Kharghar-Borivali ckt II                          | IntraState                | 11/08/2020   | 08.45        |            | Continued. | T           | Cable Faulty                                                                                           |
| Talandge-Hamidwada                                | IntraState                | 11/08/2020   | 09.16        | 11/08/2020 | 19.22      | PO          | Relay Replacement                                                                                      |
| Yeotmal- Pusad                                    | IntraState                | 11/08/2020   | 18.07        | 11/08/2020 | 18.17      | T           | Distance Protection                                                                                    |
| <b>220 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                        |
| 220/132kv 100mva Ict 1 @Peth                      | IntraState                | 11/08/2020   | 12.01        | 11/08/2020 | 17.11      | PO          | Testing Work                                                                                           |
| 220/132 Kv 200 Mva Ict - 2 @Harangul              | IntraState                | 11/08/2020   | 14.40        | 11/08/2020 | 14.54      | EO          | To attend Hot Spot                                                                                     |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage