

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Aug/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	135.780	1399.964	1) Gujrat	12.684	124.841
2) Hydro	24.003	154.775	2) Madhya Pradesh	7.011	80.581
3) Gas	0.570	1.617	3) Chattisgarh	0.940	23.200
Total MSPGCL	160.353	1556.356	4) Maharashtra	165.136	1687.512
B) 1) APLM	76.245	584.875	5) Goa (Amona)	-1.563	-17.470
2) JSWEL	7.490	144.339	Total	184.208	1898.664
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.656	367.465
4) RPL(AMT)	24.817	275.734	b) Mumbai Drawl	33.611	408.347
5) SWPGPL	11.221	86.567	c) MSEDCL Bilateral *	76.064	995.358
6) Other IPP	7.292	68.959	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.656	367.465
C) 1) TPCL Thermal	13.572	120.244	Include PX	0.000	0.000
2) TPCL Hydro	7.157	56.762	Standby	0.000	0.000
3) TPCL Gas	3.783	30.066	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.242	100.299	1) MSEDCL	469.514	4770.474
D) STATE			2) Mumbai Discoms	68.365	715.718
1) Thermal	286.659	2780.981	3) Other Discoms	10.125	109.995
(A1+C1+C4+(B1-B6))			TOTAL STATE	548.004	5596.187
2) Hydro	31.160	211.537			
3) Gas	4.353	31.683			
4) Wind	27.510	552.039			
6) SOLAR	14.114	121.283			
TOTAL STATE	363.796	3697.523			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5522	5526	5750	5766
MSPGCL Hydro	821	837	1541	745
MSPGCL Gas	0	0	90	0
MSPGCL Total Generation	6343	6363	7381	6511
Central Sector Receipt	9607	9224	7347	6074
WIND	961	718	1218	1283
CPP / IPP Thermal	5188	5209	5369	5325
CPP / IPP Gas	0	0	0	0
SOLAR	1602	1681	0	0
Exchange with Mumbai	-2303	-2322	-1282	-786
MSEDCL DEMAND MET	20953	20427	19573	18045
Load Shedding	0	0	1569	0
MSEDCL DEMAND	20953	20427	21142	18045
TPCL GENERATION	754	737	1279	1116
AEML GENERATION	353	317	496	465
MUMBAI DEMAND	3410	3376	3057	2367
OTHER DISCOM DEMAND	446	446	460	362
STATE DEMAND MET	24808	24249	23090	20774
STATE DEMAND	24808	24249	24659	20774
Frequency (Hz)	49.99	50.02	49.97	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 13:02 Hrs	49.77 Hz at 19:14 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	1.74	33.62	140	0
Unit 8	13.88	142.67	610	525
Unit 9	12.16	133.29	551	467
Unit 10	0.00	0.00	0	0
Total	27.78	309.57		
Bhusawal				
Unit 3	3.22	32.41	138	130
Unit 4	0.00	87.88	0	0
Unit 5	10.86	99.94	470	420
Total	14.08	220.22		
Parli				
Unit 6	5.70	14.60	250	170
Unit 7	5.53	13.77	248	180
Unit 8	5.26	16.48	230	171
Total	16.49	44.85		
Chandrapur				
Unit 3	2.85	30.51	151	97
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	8.08	83.90	379	295
Unit 7	7.09	79.89	344	160
Unit 8	10.28	111.34	454	405
Unit 9	10.00	112.62	430	399
Total	38.31	418.25		
Paras				
Unit 3	4.98	50.15	227	184
Unit 4	4.64	48.09	221	176
Total	9.62	98.23		
Khaparkheda				
Unit 1	2.20	21.51	105	80
Unit 2	2.38	28.28	126	80
Unit 3	4.10	40.81	182	152
Unit 4	3.68	40.65	171	140
Unit 5	9.26	102.30	430	335
Total	21.62	233.56		
Nasik				
Unit 3	3.88	39.80	170	145
Unit 4	3.99	22.41	173	160
Unit 5	0.00	13.08	0	0
Total	7.87	75.29		
Uran				
All Units	0.57	1.62	91	0
Total	0.57	1.62		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.72	10.80	50	0
Total	0.72	10.80		
Koyna				
Stage 1-2	4.05	29.83	425	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	11.13	32.05	750	0
Stage 3	3.20	16.98	240	0
Total	18.37	78.86		
Hydro				
KDPH	0.00	7.15	0	0
VTRNA	0.12	0.61	56	0
TILLARI	0.46	1.62	60	0
BHIRA T.R.	0.46	4.83	80	0
SMLHY_PTN	3.88	47.45	166	154
GHATGHAR	0.00	3.45	0	0
Total	4.92	65.11		
Wind				
Total	27.51	552.04	0	0
Total	27.51	552.04		
CPP				
APML(Mus)	76.24	584.88	0	0
JSWEL(Mus)	7.49	144.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.82	275.73	0	0
SWPGPL-Mus	11.22	86.57	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.25	57.71	269	229
Other(Mus)	1.04	11.25	0	0
Total	127.06	1160.47		
SOLAR				
Total	14.11	121.28	0	0
Total	14.11	121.28		
Tata				
Trombay 5	8.72	79.64	453	262
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.34	17.62	108	37
Trombay 7B	1.44	12.44	64	35
TATA Hydro	7.16	56.76	433	180
Trombay 8	4.85	40.60	231	134
Total	24.51	207.07		
AEML				
DTPS U-1&2	10.24	100.30	497	297
Total	10.24	100.30		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	135.78	1399.96	MSPGCL Total	160.35	1556.36
			MSPGCL Thml+Gas	136.35	1401.58	Koyna 1,2 & 4 Total	15.18	61.88
			MSPGCL Hydro	24.00	154.78	State Total	363.80	3697.52

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5894	565	0	6459	1360	5345	0	0	6169	6087	-912	17966	0	0	17966	2508	373	20847	49.99
2	5766	745	0	6511	1283	5325	0	0	6074	6074	-786	18045	0	0	18045	2367	362	20774	50.02
3	5763	701	0	6464	1304	5300	0	0	6198	6210	-736	18197	0	0	18197	2236	344	20778	50.01
4	5675	591	3	6269	1358	5279	0	0	6751	6703	-906	18374	0	0	18374	2139	329	20842	50.01
5	5739	873	62	6674	1209	5301	0	0	6867	6793	-892	18737	80	0	18817	2141	348	21306	50.02
6	5641	1460	89	7190	1058	5311	0	1	7109	7073	-846	19397	652	0	20049	2264	390	22703	50.01
7	5731	1509	90	7330	993	5307	0	83	7709	7866	-934	20244	1246	0	21490	2414	401	24305	49.97
8	5695	1418	10	7123	900	5230	0	503	8295	7861	-1026	20161	106	0	20267	2577	430	23274	50.03
9	5555	1121	0	6676	842	5244	0	1031	8818	9000	-1532	20823	0	4	20823	2873	437	24134	50.04
10	5531	1025	0	6556	880	5252	0	1414	9297	9293	-1995	20943	0	0	20943	3175	457	24575	49.94
11	5537	944	0	6481	816	5217	0	1611	9585	9359	-2223	20808	0	5	20808	3364	453	24625	49.99
12	5522	821	0	6343	961	5188	0	1602	9559	9607	-2303	20953	0	2	20953	3410	446	24808	49.99
13	5526	837	0	6363	718	5209	0	1681	9254	9224	-2322	20427	0	0	20427	3376	446	24249	50.02
14	5508	550	0	6058	916	5208	0	1824	9056	8901	-2175	20293	0	0	20293	3213	439	23945	50.08
15	5501	713	0	6214	1032	5239	0	1566	8885	8893	-2056	20448	0	0	20448	3262	439	24150	50.04
16	5584	950	0	6534	1191	5282	0	1300	8554	8387	-1888	20366	0	1	20366	3301	439	24107	50.01
17	5643	935	0	6578	1304	5284	0	977	8126	7800	-1622	19861	0	0	19861	3272	461	23593	50.01
18	5661	1140	0	6801	1362	5316	0	459	7639	7569	-1506	19547	62	0	19609	3192	454	23255	50.03
19	5765	1100	37	6902	1249	5351	0	62	7477	7025	-1343	18773	963	0	19736	3094	473	23303	49.99
20	5750	1541	90	7381	1218	5369	0	0	7313	7347	-1282	19573	1569	0	21142	3057	460	24659	49.97
21	5725	1234	89	7048	1316	5369	0	0	7228	7050	-1176	19159	874	0	20033	2945	449	23426	50.01
22	5681	1071	91	6843	1400	5380	0	0	7085	7051	-1125	19103	49	0	19152	2812	445	22410	50.00
23	5716	1106	9	6831	1384	5385	0	0	6798	6801	-1029	18937	0	0	18937	2714	435	22086	50.00
24	5671	1053	0	6724	1456	5373	0	0	6415	6234	-996	18378	0	0	18378	2659	413	21450	50.00
MUs	135.78	24.00	0.57	160.35	27.51	127.06	0.00	14.11	186.26	184.21	-33.61	469.51	5.60	0.01	475.11	68.36	10.13	553.60	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

For load management.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Aug/2023

Position as on 6.30 Hrs of 12/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	07/07/2023	09:06	12/08/2023	06:46	Annual Overhaul	13/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	25/08/2023
MSPGCL	Uran Unit 6	108	12/08/2023	07:16	12/08/2023	17:50	NO SCHEDULE	
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	COH	16/08/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	20/08/2023
MSPGCL	Uran Unit 7	108	20/07/2023	20:00	12/08/2023	19:05	Boiler Inspection work	
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	19/08/2023
MSPGCL	Nasik Unit 5	210	05/08/2023	00:00		Continued.	ID Fan Problem(On Tolling since 18:23Hrs DT. 05-08-2023)	
IPP	RPL(AMT) U-3	270	05/08/2023	19:07	12/08/2023	00:15	Due to TG shaft vibration high.	
IPP	JSW (J) U4	300	10/08/2023	05:55		Continued.	CW system leakage	14/08/2023
MSPGCL	Koyna STG-IV Unit-4	250	10/08/2023	18:30	11/08/2023	00:20	Gov. Safety bolt rupture	
MSPGCL	Uran Unit 6	108	10/08/2023	22:14	11/08/2023	18:02	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Aug/2023

Position as on 6.30 Hrs of 12/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 4	500	10/08/2023	22:44		Continued.	Boiler Tube Leakage	14/08/2023
MSPGCL	Koradi Unit 6	210	11/08/2023	08:14	11/08/2023	16:19	Coal Bunkering Problem.	
MSPGCL	Uran Unit 6	108	11/08/2023	22:16	12/08/2023	03:35	Zero Schedule	
MSPGCL	Uran Unit 7	108	12/08/2023	21:59		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 6	108	12/08/2023	22:15		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 12/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Trippings							
Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC	IntraState	12/08/2023	16:32		Continued.	EO	For attending 1 no. of hotspot having temp.160 deg. cel
Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC	IntraState	12/08/2023	16:32	12/08/2023	18:20	EO	Attending Hotspot
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LONIKAND I - TALEGAON (PGCIL)	InterState	10/08/2023	23:04	11/08/2023	00:33	T	B-ph Line Reactor faulty at Talegaon PG
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of εYε phase Protection CT Of NTPP I (RPL 1)
PADGHE - PADGHE HVDC CKT- 1	IntraState	01/08/2023	17:03	11/08/2023	13:12	PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400kV HVDC-1 in service through TBC, Power restriction of 1300MW.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
KHADKA-AURANGABAD (WALUJ)	IntraState	10/08/2023	19:43	11/08/2023	08:33	HT	H/T FOR O/V
WARORA - WARORA (PG)	IntraState	11/08/2023	10:38	11/08/2023	17:53	PO	FOR LINE BAY 412 LINE SIDE EQUIPMENTS AMP WORK.
KORADI II - KORADI III CKT - 3	IntraState	11/08/2023	11:00	11/08/2023	17:20	PO	Annual Maintenance of Line equipment at Koradi III SS
AMRAPUR - TAPTITANDA CKT - 2	IntraState	11/08/2023	12:50	11/08/2023	18:06	HT	H/T At Taptitanda end only in view of outage on ICT 2 at TT.
PADGHE - KALWA CKT - 1	IntraState	11/08/2023	22:12	12/08/2023	04:28	EO	Fixing of repair sleeves at Loc.No. 1105
KORADI - KHADKA	IntraState	12/08/2023	10:30	12/08/2023	16:04	PO	For replacement of Y phase CT jump replacement work from PG Clamp to CT
KHADKA-AURANGABAD (WALUJ)	IntraState	12/08/2023	20:14		Continued.	HT	for load management
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
STATION TF-3 @ KORADI 2	IntraState	01/08/2023	10:44	11/08/2023	19:40	PO	1) Oil filtration & inspection work at PCR end 2) LV 1 & LV 2 Bus Duct inspection work at PCR end.
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	06/08/2023	09:44	11/08/2023	06:58	PO	Cooling System Renovation, commissioning, HV CB timing/DCRM,SFRA,REF,NDR relay & bay Maintenance work
400/220kv 500MVA ICT-2 @ TAPTITANDA	IntraState	11/08/2023	13:07	11/08/2023	17:52	PO	Oil filtration work of OLTC R phase Unit of ICT - 2 to be carried out as the given oil has low BDV value.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 12/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	12/08/2023	10:21			PO	1.Commissioning of High velocity water spray system for 315MVA ICT-1. 2. Routine maintenance of ICT 2. Maintenance and alignment of Isolators 3. Bay routine maintenance work
220 KV MAINBAY Outages/Trippings							
220 KV PT - I	IntraState	12/08/2023	12:25	12/08/2023	16:45	EO	Attending oil leakage of B ph PT-1
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21		Continued.	HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
KALMESHVAR-KALMESHVAR RLY TSS 2	IntraState	11/08/2023	08:25	11/08/2023	14:48	PO	Replacement of CTS Under Les Scheme
GHATGHAR - BAPGAON	IntraState	11/08/2023	10:12	11/08/2023	18:10	PO	For Flashover string Y&B Phase replacement at Loc. 207 and damage conductor work.
SAWANGI-BHOKARDAN CKT	IntraState	11/08/2023	10:42	11/08/2023	16:18	PO	Measurement of CT Tan delta and Routine maintenance work.
AKOLA-PARAS CKT NO-II	IntraState	11/08/2023	11:09	11/08/2023	13:51	PO	Air Compressor valve replacement of CB
220 KV KEKATNIBHORA - KHADKA (400 KV) CKT	IntraState	11/08/2023	15:32	11/08/2023	19:32	T	Distance Protection
MAIN BUS - 1 @ AAREY	IntraState	11/08/2023	23:48	12/08/2023	00:44	EO	For Shifting of 100 MVA Tr-4 form AIS Bay -8 to New GIS Bay no. 23 under MERC approved AIS to GIS conversion Project.
KOLSHET - ROMA	IntraState	12/08/2023	01:05	12/08/2023	05:52	EO	For launching of Pier cap at location No. P118 (Nr. Patlipada flyover) under 220Kv Kolshet Roma line of Mumbai Metro Rail Project of MMRDA package CA-12 ---for safety purpose
KALWA SALSETTE - 4	IntraState	12/08/2023	07:09	12/08/2023	08:43	PO	Bay Maintenance work
MALEGAON-SATANA	IntraState	12/08/2023	09:22	12/08/2023	15:20	PO	For jump replacement work.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	12/08/2023	09:30	12/08/2023	19:54	PO	1. Conversion of single jump into twin jump of tension tower at various locations. (As per current loading,frequent Red-Hot observed andalso with bypass jump done by Hot-Line. 2. Replacement of old disc insulator by new long-rod insulator at various location.
PEDHAMBE ONI LINE	IntraState	12/08/2023	09:45	12/08/2023	13:47	PO	For Bay R/M work
URAN - APTA 4	IntraState	12/08/2023	10:30	12/08/2023	19:45	PO	Replacement of damaged Jumper at loc no 7,26,25.
BOISAR - VERSOVA	IntraState	12/08/2023	10:50		Continued.	EO	To attend Air pressure low alarm on CB
220 KV DEEPNAGAR (400 KV) - CHALISGAON CKT	IntraState	12/08/2023	11:54	12/08/2023	15:38	PO	For Jump tightening and Maintenance work at tower LOC 309 & 398.
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	12/08/2023	12:20	12/08/2023	17:11	PO	Replacement of disc insulators LOC no.346 Y B ph and LOC no. 350 R ph.
BUS SECTION - 2 @ TROMBAY	IntraState	12/08/2023	13:18		Continued.	PO	For 1) Wave Trap replacement work of 220KV Sonkhar line 2) 220KV CC relocation/Shifting work & 3) Bus Section bay maintenance work.
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 12/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI	IntraState	11/08/2023	09:15		Continued.	PO	Oil filtration work to improve oil parameters.
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	11/08/2023	10:30	11/08/2023	14:04	PO	R ph & B ph lightening arrester of ICT 02 LV side replacement work to be carried out.
220/132 KV 200MVA ICT 1 @ JALNA	IntraState	11/08/2023	11:30	11/08/2023	17:40	PO	Work of Overhauling / Servicing of CB.
200 MVA 220/132 KV ICT 1 @ GIRWALI	IntraState	12/08/2023	06:06	12/08/2023	12:36	HT	Sparking on R-ph HV Bushing Jumper
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	12/08/2023	11:40	12/08/2023	18:14	PO	Testing work of ICT.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
MAIN BUS @ BELEWADI	IntraState	11/08/2023	10:20	11/08/2023	18:49	PO	For Diagnostic Testing of CT,CB & Maintenance work bus side isolators,metering CT,PT and bay equipments
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
110 KV BUSBAR Outages/Trippings							
ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI	IntraState	11/08/2023	01:36	11/08/2023	06:30	PO	Attending hot spot on B phase of Bus section 1-2 GOD

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage