

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Sep/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	116.056	1354.533	1) Gujrat	8.178	86.212
2) Hydro	9.400	149.881	2) Madhya Pradesh	-1.692	14.787
3) Gas	2.440	36.102	3) Chattisgarh	3.070	36.160
Total MSPGCL	127.896	1540.516	4) Maharashtra	156.795	1801.352
B) 1) APLM	64.042	732.791	5) Goa (Amona)	-0.668	-9.662
2) JSWEL	17.648	212.249	Total	165.683	1928.849
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.821	367.592
4) RPL(AMT)	18.334	173.165	b) Mumbai Drawl	35.085	399.525
5) SWPGPL	5.104	58.636	c) MSEDCL Bilateral *	44.415	482.614
6) Other IPP	5.306	64.945	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.821	367.461
C) 1) TPCL Thermal	10.963	131.990	Include PX	0.000	0.000
2) TPCL Hydro	2.448	53.810	Standby	0.000	0.132
3) TPCL Gas	0.000	10.030	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.089	108.296	1) MSEDCL	379.901	4383.538
D) STATE			2) Mumbai Discoms	57.585	703.652
1) Thermal	246.542	2836.605	3) Other Discoms	8.819	99.526
(A1+C1+C4+(B1-B6))			TOTAL STATE	446.305	5186.716
2) Hydro (A2+C2)	11.848	203.691			
3) Gas (A3+B7+C3)	2.440	46.132			
4) Wind	13.698	72.242			
6) SOLAR	6.094	99.196			
TOTAL STATE	280.622	3257.866			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4665	4407	5178	5055
MSPGCL Hydro	412	333	489	265
MSPGCL Gas	93	91	181	95
MSPGCL Total Generation	5170	4831	5848	5415
Central Sector Receipt	7893	7631	6728	5670
WIND	296	314	929	518
CPP / IPP Thermal	4561	4230	5190	4897
CPP / IPP Gas	0	0	0	0
SOLAR	640	924	0	0
Exchange with Mumbai	-1285	-1865	-1499	-1274
MSEDCL DEMAND MET	16884	15688	16809	14915
Load Shedding	0	0	0	0
MSEDCL DEMAND	16884	15688	16809	14915
TPCL GENERATION	668	428	696	441
AEML GENERATION	486	299	410	424
MUMBAI DEMAND	2439	2592	2605	2139
OTHER DISCOM DEMAND	391	377	387	311
STATE DEMAND MET	19714	18657	19801	17365
STATE DEMAND	19714	18657	19801	17365
Frequency (Hz)	50.06	50.00	50.03	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 1402 Hrs	49.61 Hz at 1222 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.36	35.48	160	120
Unit 7	0.00	0.00	0	0
Unit 8	9.48	117.24	416	362
Unit 9	0.00	0.00	0	0
Unit 10	9.82	114.87	435	370
Total	22.65	267.60		
Bhusawal				
Unit 3	2.10	30.13	115	0
Unit 4	8.54	101.00	425	295
Unit 5	0.21	0.21	66	0
Total	10.86	131.34		
Parli				
Unit 6	4.29	48.78	200	154
Unit 7	2.56	34.62	122	97
Unit 8	3.86	42.50	178	144
Total	10.72	125.90		
Chandrapur				
Unit 3	3.02	31.12	142	112
Unit 4	2.76	36.50	120	105
Unit 5	6.44	45.31	340	145
Unit 6	6.79	82.99	365	225
Unit 7	6.82	84.66	334	236
Unit 8	0.00	49.00	0	0
Unit 9	9.30	110.69	447	290
Total	35.12	440.27		
Paras				
Unit 3	4.05	49.68	234	112
Unit 4	4.84	49.84	228	143
Total	8.89	99.52		
Khaparkheda				
Unit 1	3.00	28.97	140	120
Unit 2	2.74	26.57	135	100
Unit 3	3.53	36.11	175	120
Unit 4	3.87	39.07	188	130
Unit 5	8.63	90.26	415	275
Total	21.77	220.98		
Nasik				
Unit 3	0.00	29.36	0	0
Unit 4	3.05	8.45	145	120
Unit 5	3.01	31.12	149	110
Total	6.06	68.93		
Uran				
All Units	2.44	36.10	181	90
Total	2.44	36.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.58	6.32	27	23
Total	0.58	6.32		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.72	27.73	255	35
Stage 4	0.51	28.02	320	0
Stage 3	0.33	12.64	80	0
Total	2.56	68.39		
Hydro				
KDPH	0.07	0.07	18	0
VTRNA	0.69	8.13	61	0
TILLARI	0.00	3.71	0	0
BHIRA T.R.	0.35	4.56	60	0
SMLHY_PTN	5.16	55.06	227	207
GHATGHAR	0.00	3.63	0	0
Total	6.26	75.17		
Wind				
Total	13.70	72.24	0	0
Total	13.70	72.24		
CPP				
APML(Mus)	64.04	732.79	0	0
JSWEL(Mus)	17.65	212.25	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.33	173.16	0	0
SWPGPL-Mus	5.10	58.64	0	0
Other(Mus)	5.31	64.94	0	0
Total	110.43	1241.79		
SOLAR				
Total	6.09	99.20	0	0
Total	6.09	99.20		
Tata				
Trombay 5	7.32	88.74	425	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	6.57	0	0
Trombay 7B	0.00	3.46	0	0
TATA Hydro	2.45	53.81	297	9
Trombay 8	3.65	43.25	233	132
Total	13.41	195.83		
AEMIL				
DTPS U-1&2	9.09	108.30	499	287
Total	9.09	108.30		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	116.06	1354.53	MSPGCL Total	127.90	1540.52
			MSPGCL Thml+Gas	118.50	1390.64	Koyna 1,2 & 4 Total	2.23	55.75
			MSPGCL Hydro	9.40	149.88	State Total	280.62	3257.87

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 11/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5020	270	94	5384	560	4893	0	0	5894	5764	-1230	15044	0	15044	2417	327	17788	49.90
2	5025	268	95	5388	451	4937	0	0	5713	5860	-1241	15074	0	15074	2260	321	17655	49.88
3	5055	265	95	5415	518	4897	0	0	5710	5670	-1274	14915	0	14915	2139	311	17365	49.98
4	5044	313	95	5452	405	4879	0	0	5804	5973	-1263	15137	0	15137	2041	309	17487	49.90
5	4986	306	95	5387	369	4814	0	0	6359	6443	-1245	15447	0	15447	2002	321	17770	49.99
6	4995	453	94	5542	481	4795	0	0	6904	6910	-1312	16058	0	16058	2047	358	18463	50.01
7	4847	771	95	5713	388	4922	0	18	7069	7309	-1334	16649	0	16649	2063	367	19079	50.01
8	4858	419	94	5371	246	4919	0	179	7420	7643	-1407	16573	0	16573	2126	378	19077	49.99
9	4900	429	94	5423	382	4860	0	400	7558	7571	-1432	16808	0	16808	2271	396	19475	50.04
10	4665	412	93	5170	296	4561	0	640	7680	7893	-1285	16884	0	16884	2439	391	19714	50.06
11	4346	535	92	4973	254	4289	0	803	8405	8395	-1704	16612	0	16612	2563	398	19573	50.00
12	4604	389	91	5084	318	4399	0	922	8304	7998	-1873	16463	0	16463	2628	385	19476	50.00
13	4407	333	91	4831	314	4230	0	924	8070	7631	-1865	15688	0	15688	2592	377	18657	50.00
14	4376	327	90	4793	608	3830	0	899	7914	7668	-1816	15611	0	15611	2540	371	18522	50.00
15	4524	335	90	4949	681	3903	0	651	7529	7378	-1775	15419	0	15419	2530	368	18317	50.00
16	4401	335	91	4827	802	3621	0	417	7681	7674	-1754	15201	0	15201	2503	386	18090	50.00
17	4540	374	90	5004	664	3830	0	172	7447	7743	-1695	15328	0	15328	2444	390	18162	50.00
18	4892	438	93	5423	751	4318	0	67	7009	7132	-1688	15598	0	15598	2426	405	18429	50.04
19	5132	597	130	5859	779	4926	0	2	6861	6844	-1545	16468	0	16468	2510	397	19375	49.99
20	5178	489	181	5848	929	5190	0	0	7225	6728	-1499	16809	0	16809	2605	387	19801	50.03
21	5090	407	178	5675	962	4825	0	0	7110	6604	-1265	16407	0	16407	2641	394	19442	50.01
22	5203	328	93	5624	793	4958	0	0	6273	5851	-1203	15660	0	15660	2614	363	18637	50.00
23	5171	303	93	5567	774	5154	0	0	5961	5498	-1207	15417	0	15417	2605	369	18391	50.01
24	4797	304	93	5194	973	4484	0	0	6146	5503	-1173	14632	0	14632	2579	349	17560	50.01
MUs	116.06	9.40	2.44	127.90	13.70	110.43	0.00	6.09	168.05	165.68	-35.09	379.90	0.00	379.90	57.58	8.82	446.30	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 11/Sep/2022

Position as on 6.30 Hrs of 12/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31	11/09/2022	02:52	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
IPP	SWPGPL U-4	135	16/08/2022	00:45	12/09/2022	12:26	Coal Shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
IPP	RPL(AMT) U-4	270	31/08/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
TPC-G	Trombay 7B	60	09/09/2022	03:36	12/09/2022	19:39	Gas shortage	
TPC-G	Trombay 7A	120	09/09/2022	03:52	12/09/2022	15:01	Gas shortage	
MSPGCL	Nasik Unit 3	210	10/09/2022	11:46		Continued.	Turbine Vibration	18/09/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Sep/2022

Position as on 6.30 Hrs of 12/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	10/09/2022	20:44	11/09/2022	17:52	Gas shortage	
MSPGCL	Bhusawal Unit 5	500	11/09/2022	05:48		Continued.	Turbine Vibration	13/09/2022
TPC-G	Bhira PSU	150	11/09/2022	06:32	11/09/2022	08:53	For slip ring cleaning	11/09/2022
MSPGCL	Bhusawal Unit 3	210	11/09/2022	17:07	11/09/2022	21:00	stator water flow reduced	
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
MSPGCL	Koradi Unit 6	210	12/09/2022	02:56		Continued.	AC Supply fail.	
MSPGCL	Chandrapur Unit 7	500	12/09/2022	10:33	12/09/2022	14:00	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	12/09/2022	21:13		Continued.	Zero schedule	
IPP	SWPGPL U-1	135	12/09/2022	23:28		Continued.	Turbine side drain valve steam leakage	13/09/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 11/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 12/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	11/09/2022	20:58	12/09/2022	06:24	EO	Pole 2 B-phase Converter transformer for OLTC Diverter switch overhauling and Oil flow relay replacement.
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (404) OF ICT - 2 @ JEJURI	IntraState	12/09/2022	16:27	12/09/2022	18:25	EO	To attend hotspot on 400kv 404 Bay R-ph CT
400 KV LINE Outages/Tripping							
CHAKAN - TALEGAON(PG)	InterState	10/09/2022	20:12	11/09/2022	02:33	PO	For AMP and Relay testing works.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38		Continued.	T	Y Phase Ground Fault
KARAD - LONIKAND I	IntraState	11/09/2022	11:26		Continued.	HT	For line loading control of 400 KV Karad Kolhapur
KHADKA-AURANGABAD (WALUJ)	IntraState	12/09/2022	00:13	12/09/2022	07:28	HT	H/T FOR O/V
KARAD - TALANDGE CKT - 1	IntraState	12/09/2022	06:03	12/09/2022	09:52	PO	Replacement of Y ph bottom side Jump & palm due to damages in outer side of Jump conductor.
PADGHE - NAGOTHANE CKT - 1	IntraState	12/09/2022	08:24	12/09/2022	18:25	PO	INSULATOR STRING REPLACEMENT WORK
KHADKA-AURANGABAD (WALUJ)	IntraState	12/09/2022	20:53		Continued.	HT	On Overvoltage
400 KV ICT Outages/Tripping							
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	11/09/2022	10:57	11/09/2022	17:07	EO	Replacement of tertiary PT of all 3 phases
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	11/09/2022	11:56	11/09/2022	16:21	T	R-ph OLTC Bucholz Protection
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	12/09/2022	09:43	12/09/2022	18:29	PO	Diagnostic testing & Relay testing work
400220kv 167MVA SPARE ICT @ DEEPNAGAR	IntraState	12/09/2022	09:58	12/09/2022	20:30	HT	HT for Main Bus-2 Outage
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	12/09/2022	10:39	12/09/2022	15:28	PO	1. Quarterly Maintenance Work 2. OLTC oil filtration work
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	12/09/2022	18:59	12/09/2022	20:29	EO	Attending hotspot (100 degree) observed on Y phase LV CT of ICT-1.
400 KV BUSBAR Outages/Tripping							
400KV MAIN BUS 2 @ 400KV DEEPNAGAR	IntraState	12/09/2022	09:58	12/09/2022	20:21	PO	For the work of Stringing between guide tower to 400 KV Main Bus & II & removal of Bus-II Earth Switch.
220 KV LINE Outages/Tripping							
220 KV HARANGUL - PARLY (PG) CKT	InterState	11/09/2022	00:54	11/09/2022	01:20	T	Tripped on Dist. Protection.
HINJAWADI I- CHINCHWAD	IntraState	10/09/2022	20:05	11/09/2022	03:24	HT	For load management of 400kv Talegaon-Chakan Line Outage
WAGHIVALI - DHARAVI 8	IntraState	11/09/2022	05:45	11/09/2022	08:53	PO	Project Work in vicinity for removing Khopoli Dharavi ling OPGW in Span 46-45
MULUND - GIS BHANDUP	IntraState	11/09/2022	10:28	11/09/2022	17:11	EO	For Cable Sheath Earthing and LA Earthing work at tower END
SALSETTE - SAHAR CKT	IntraState	11/09/2022	10:32	11/09/2022	13:53	PO	for LBBU relay testing, CR trials, Protection trials
CHAKAN PH II - VOLKSWAGEN	IntraState	11/09/2022	11:21	11/09/2022	19:22	PO	Stringing for tap arrangement at exiting Loc No. 42 (MCN+00) of 220kv Bridgestone - Chakan II line to Loc 1 of Proposed 220 kv Tetra Pak S/Sn with 21 Mtr span.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 12/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHAKAN -BRIDGESTONE	IntraState	11/09/2022	11:21	11/09/2022	19:22	PO	Stringing for tap arrangement at exiting Loc No. 42 (MCN+00) of 220kV Bridgestone - Chakan II line to Loc 1 of Proposed 220 kV Tetra Pak S/Sn with 21 Mtr span.
NAGOTHANE - POSCO	IntraState	11/09/2022	16:06	12/09/2022	01:18	T	Tripped on Dist Protection
CHAKAN-BHOSARI 1	IntraState	11/09/2022	18:01	11/09/2022	23:53	T	Tripped on Dist Protection Y-ph.
EKLAHARE (OCR) - PADGHE	IntraState	12/09/2022	08:49		Continued.	HT	HT for Load Management
URAN - KHARGHAR 1	IntraState	12/09/2022	10:02	12/09/2022	17:37	PO	Replacement of flashover polymer insulator at Loc no. 48 and sparked jumper at Loc no. 44
ADLABS - PEDAMBE	IntraState	12/09/2022	18:08		Continued.	T	Tripped on distance protection
ALEPHATA-PARGAON(KATHAPUR)	IntraState	12/09/2022	18:48	12/09/2022	20:47	HT	For load management
WARDHA - WARDHA (PG)	IntraState	12/09/2022	19:03	12/09/2022	22:15	HT	Autoreclosed successfully at both end, current does not appear on Y ph.
BUS SECTION-6 @ TROMBAY	IntraState	12/09/2022	23:40		Continued.	EO	for Trombay Carnac -6 Isolator Maintenance and Trombay Carnac-6 29 A busbar removal.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA ICT 1 @ KATHAPUR	IntraState	12/09/2022	10:38	12/09/2022	18:44	PO	Replacement of R & Y Phase LV Bushings due to High Tan Delta value.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage