

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Oct/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	128.857	1321.975	1) Gujrat	15.435	174.981
2) Hydro	11.826	67.486	2) Madhya Pradesh	8.474	93.997
3) Gas	7.781	93.056	3) Chattisgarh	3.230	31.100
Total MSPGCL	148.464	1482.517	4) Maharashtra	122.607	1451.496
B) 1) APML	39.386	278.119	5) Goa (Amona)	-0.770	-6.028
2) JSWEL	18.630	198.759	Total	148.976	1745.546
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.981	336.976
4) RPL(AMT)	19.705	229.899	b) Mumbai Drawl	39.776	376.360
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	15.813	284.714
6) Other IPP	8.683	93.198	Include PX	-1.255	81.330
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.981	336.976
C) 1) TPCL Thermal	12.270	143.570	Include PX	19.932	162.776
2) TPCL Hydro	4.935	40.628	Standby	0.000	0.000
3) TPCL Gas	3.020	36.364	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.810	89.037	1) MSEDCL	352.804	3777.744
D) STATE			2) Mumbai Discoms	64.810	685.955
1) Thermal	232.341	2354.557	TOTAL STATE	417.614	4463.699
(A1+C1+C4+(B1-B6))					
2) Hydro	16.761	108.114			
(A2+C2)					
3) Gas	10.801	129.420			
(A3+B7+C3)					
4) Wind	2.855	60.024			
6) SOLAR	5.881	66.042			
TOTAL STATE	268.639	2718.157			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5065	5231	5725	5402
MSPGCL Hydro	869	460	1007	62
MSPGCL Gas	278	345	401	287
MSPGCL Total Generation	6212	6036	7133	5751
Central Sector Receipt	6704	6701	6031	5493
WIND	136	89	61	178
CPP / IPP Thermal	3520	3695	4243	3029
CPP / IPP Gas	0	0	0	0
SOLAR	820	469	0	0
Exchange with Mumbai	-2107	-2060	-1483	-1189
MSEDCL DEMAND MET	15285	14930	15985	13262
Load Shedding	0	0	0	0
MSEDCL DEMAND	15285	14930	15985	13262
TPCL GENERATION	856	944	1255	603
AEML GENERATION	191	190	250	192
MUMBAI DEMAND	3154	3194	2988	1984
STATE DEMAND MET	18439	18124	18973	15246
STATE DEMAND	18439	18124	18973	15246
Frequency (Hz)	49.99	50.02	50.03	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 13.03 Hrs	49.8 Hz at 05.21 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	6.94	34.05	330	0
Unit 9	8.77	109.64	505	290
Unit 10	7.90	111.26	460	160
Total	23.61	254.95		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.07	107.26	455	355
Unit 5	9.50	30.48	495	350
Total	18.58	137.74		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.61	11.72	219	170
Unit 7	4.93	53.77	245	187
Unit 8	5.00	53.44	233	193
Total	14.54	118.93		
Chandrapur				
Unit 3	3.87	25.42	180	115
Unit 4	3.79	37.76	167	151
Unit 5	8.30	85.75	365	330
Unit 6	9.17	91.99	445	354
Unit 7	0.00	0.00	0	0
Unit 8	8.54	95.89	390	339
Unit 9	8.26	92.97	360	305
Total	41.94	429.78		
Paras				
Unit 3	4.50	36.82	237	158
Unit 4	0.00	0.00	0	0
Total	4.50	36.82		
Khaparkheda				
Unit 1	2.75	30.22	145	75
Unit 2	3.32	35.11	165	105
Unit 3	3.51	37.66	170	130
Unit 4	3.51	42.23	165	130
Unit 5	9.64	103.09	480	370
Total	22.73	248.30		
Nasik				
Unit 3	0.00	24.52	0	0
Unit 4	0.00	31.55	0	0
Unit 5	2.97	39.38	181	0
Total	2.97	95.45		
Uran				
All Units	7.78	93.06	411	268
Total	7.78	93.06		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.46	10.53	53	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.46	10.53		
Koyna				
Stage 1-2	4.49	30.45	540	40
Stage 4	3.32	13.22	415	0
Stage 3	1.67	10.32	160	0
Total	9.48	53.99		
Hydro				
KDPH	0.68	3.49	37	0
VTRNA	0.00	0.00	0	0
TILLARI	0.54	1.71	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.42	2.90	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	0.79	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.42	3.11	18	17
GHATGHAR	0.28	1.49	125	0
Total	2.35	13.49		
Wind				
Total	2.86	60.02	0	0
Total	2.86	60.02		
CPP				
APML(Mus)	39.39	278.12	0	0
JSWEL(Mus)	18.63	198.76	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	19.70	229.90	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.68	93.20	0	0
Total	86.40	799.98		
SOLAR				
Total	5.88	66.04	0	0
Total	5.88	66.04		
Tata				
Trombay 5	7.65	90.75	456	290
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.78	22.20	110	58
Trombay 7B	1.24	14.16	62	45
Trombay 8	4.62	52.82	209	179
TATA Hydro	4.94	40.63	459	0
Total	20.22	220.56		
AEML				
DTPS U-1&2	4.81	89.04	250	190
Total	4.81	89.04		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	128.86	1321.98	MSPGCL Total	148.46	1482.52
			MSPGCL Thml+Gas	136.64	1415.03	Koyna 1,2 & 4 Total	7.81	43.67
			MSPGCL Hydro	11.83	67.49	State Total	268.64	2718.16

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5623	135	295	6053	145	3025	0	0	6123	5962	-1558	13627	0	13627	2407	16034	49.98
2	5549	222	286	6057	184	2986	0	0	5653	5768	-1410	13585	0	13585	2207	15792	49.97
3	5449	58	286	5793	196	3112	0	0	5672	5405	-1269	13237	0	13237	2066	15303	50.02
4	5402	62	287	5751	178	3029	0	0	5586	5493	-1189	13262	0	13262	1984	15246	50.01
5	5432	85	288	5805	122	3034	0	0	5584	5676	-1158	13479	0	13479	1953	15432	49.93
6	5774	80	287	6141	100	3362	0	0	5839	5990	-1212	14381	0	14381	2007	16388	49.91
7	5843	375	299	6517	82	3846	0	22	6086	6185	-1214	15438	0	15438	2134	17572	49.96
8	5710	383	287	6380	86	3986	0	156	6298	6476	-1259	15825	0	15825	2306	18131	50.02
9	5362	306	285	5953	121	3793	0	402	6773	6617	-1632	15254	0	15254	2596	17850	50.02
10	5115	863	279	6257	116	3551	0	611	6451	6463	-1886	15112	0	15112	2929	18041	50.01
11	5065	869	278	6212	136	3520	0	820	6463	6704	-2107	15285	0	15285	3154	18439	49.99
12	5066	732	268	6066	133	3568	0	869	6651	6656	-2188	15104	0	15104	3246	18350	49.99
13	5102	360	298	5760	116	3543	0	838	6980	6764	-2195	14826	0	14826	3237	18063	50.04
14	5140	360	292	5792	111	3505	0	751	6440	6533	-2064	14628	0	14628	3106	17734	50.05
15	5268	330	325	5923	102	3533	0	646	6794	6797	-2136	14865	0	14865	3173	18038	49.97
16	5231	460	345	6036	89	3695	0	469	6865	6701	-2060	14930	0	14930	3194	18124	50.02
17	5296	614	357	6267	91	3600	0	242	6617	6615	-1992	14823	0	14823	3158	17981	50.01
18	5333	906	358	6597	54	3633	0	54	6349	6276	-1864	14750	0	14750	3078	17828	49.96
19	5605	1082	360	7047	68	4087	0	1	5834	6220	-1678	15745	0	15745	3044	18789	49.97
20	5725	1007	401	7133	61	4243	0	0	6078	6031	-1483	15985	0	15985	2988	18973	50.03
21	5657	634	411	6702	79	3921	0	0	6034	5752	-1515	14939	0	14939	2844	17783	50.03
22	5185	719	401	6305	160	3861	0	0	6080	6242	-1565	15003	0	15003	2715	17718	50.01
23	4968	618	404	5990	154	3942	0	0	6059	5930	-1530	14486	0	14486	2659	17145	50.01
24	4957	566	404	5927	171	4029	0	0	6023	5720	-1612	14235	0	14235	2626	16861	50.04
MUs	128.86	11.83	7.78	148.46	2.86	86.40	0.00	5.88	149.33	148.98	-39.78	352.80	0.00	352.80	64.81	417.62	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Oct/2019

Position as on 6.30 Hrs of 12/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Koyna STG- IV Unit - 1	250	18/07/2019	14.30	12/10/2019	00.15	Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019)	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn on shaft seal water leakage.Converted to AOH from 1 Nov 2019.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyna Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-1	660	19/09/2019	01.43		Continued.	Due to Low Coal Stock.	
IPP	Adani U-2	660	30/09/2019	05.37	11/10/2019	03.58	Coal Shortage	
IPP	Adani U-5	660	01/10/2019	23.10	11/10/2019	19.11	Coal Shortage	
MSPGCL	Koyna STG-IV Unit-2	250	02/10/2019	19.19	12/10/2019	20.40	Down Stream Seal Leakage Problem.	
AEML	AEML Unit 2	250	07/10/2019	21.18		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	09/10/2019	03.22	11/10/2019	11.48	Boiler Problem	
MSPGCL	Uran Unit B0	120	09/10/2019	03.23	11/10/2019	18.41	Boiler Problem	
IPP	JSW (J) U4	300	09/10/2019	12.49		Continued.	CW Duct Leakage.	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59		Continued.	Zero schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Oct/2019

Position as on 6.30 Hrs of 12/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 7	108	10/10/2019	10.15	12/10/2019	17.43	Balancing work of GT	
MSPGCL	Nasik Unit 5	210	11/10/2019	18.35	11/10/2019	23.55	UAT Bus DEAD	
IPP	Adani U-5	660	11/10/2019	19.21	11/10/2019	21.36	11KV Bus Transfer	
MSPGCL	Koradi Unit-8	660	11/10/2019	22.36		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 4	500	12/10/2019	09.42		Continued.	LP Bypass leakages	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	05/10/2019	00.29	11/10/2019	10.30	HT	Over Voltage
Chandrapur - Parli	IntraState	07/10/2019	13.57		Continued.	T	Distance Protection, Z-2, B-Ph, 1.3KA, 317KM.
Karad-Jaigad - I	IntraState	09/10/2019	21.08		Continued.	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	10/10/2019	08.36		Continued.	PO	CB Overhauling work
Bus Coupler @ Lonikand	IntraState	10/10/2019	17.56	11/10/2019	16.17	PO	Attending Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	10/10/2019	17.58	11/10/2019	07.38	HT	Over Voltage
Akola - Bhusawal	IntraState	11/10/2019	09.33	11/10/2019	15.31	PO	Restrining of conductor
Ektuni-Bableshwar ckt I	IntraState	11/10/2019	16.20	11/10/2019	19.04	PO	Replacement of Jumper Nut Bolt at Location no-14
Khadka-Aurangabad (Waluj)	IntraState	11/10/2019	17.15		Continued.	HT	Over Voltage
New Koyna -Koyna Stage IV-I	IntraState	11/10/2019	23.59	12/10/2019	00.19	PO	LBB Testing
Babhaleshwar - Padghe-II	IntraState	12/10/2019	09.04	12/10/2019	16.37	PO	PID Work
Girwali- Lonikand 2	IntraState	12/10/2019	10.11	12/10/2019	16.42	PO	Line Maintenance work
Nagothane - Dabhol I	IntraState	12/10/2019	10.35	12/10/2019	19.15	EO	Replacing Nut Bolt melt at BPI Clamp towards Line side
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220kv 315MVA ICT-III @ Kharghar	IntraState	11/10/2019	08.14	11/10/2019	20.19	PO	Diagnostic Testing & maintenance work
400/220/33 Kv 315 MVA ICT-I @Aurangabad (Waluj)	IntraState	11/10/2019	09.07	11/10/2019	19.15	PO	Routine Maintenance Work
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	11/10/2019	11.24	11/10/2019	13.04	EO	Attend fire CTR Alarm
400/220kv 315MVA ICT-III @ KHADKA	IntraState	12/10/2019	06.35		Continued.	PO	Replacement of Y Phase LV side bushing and oil filtration work.
400/220 KV 500MVA ICT-IV @ Babhaleshwar	IntraState	12/10/2019	09.33	12/10/2019	18.12	PO	Quarterly Maintenance Work
400/220/33 Kv 105 MVA Spare ICT @Kharghar	IntraState	12/10/2019	10.16	12/10/2019	17.19	PO	Attending mionr leakage from OLTC of Y-Ph
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Talegaon(PG)-Talegaon(Ambi)-II	InterState	10/10/2019	20.45	11/10/2019	07.26	T	LA Brust.
Talegaon(PG)-Talegaon(Ambi)-II	InterState	12/10/2019	23.14		Continued.	EO	LA Replacement work
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Lonand-Baramati	IntraState	17/09/2019	11.13		Continued.	HT	To Control Overloading of Lonand -Jejuri Line.
Kandalgaon - Koyna (Pophali)	IntraState	10/10/2019	15.16	11/10/2019	01.00	T	35.2 KM, A/R L,Y-E 4.15 KAMP EARTH WIRE BROKEN AT LOCATION NO. 271 & 272.
Sahara-Urse	IntraState	10/10/2019	22.48	11/10/2019	07.31	HT	TO CONTROL LOADING.
Dahanu Ghodbunder Line 2	IntraState	11/10/2019	07.25	11/10/2019	18.37	PO	Replacement of Isolator
Mahad - Pedambe	IntraState	11/10/2019	08.35	11/10/2019	17.35	PO	Replacement of insulator
khaparkheda-Khaparkheda(new)-I	IntraState	11/10/2019	10.48	11/10/2019	18.10	PO	Daigonistic testing work
Temghar - Kalwa	IntraState	11/10/2019	11.02	11/10/2019	18.08	PO	Annual Maintenance Work
Ghatghar - Bapgaon	IntraState	11/10/2019	11.36	11/10/2019	12.24	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ANANDNAGAR - PALAVA	IntraState	11/10/2019	11.39	11/10/2019	13.46	PO	Replacement work
Vita Alkud	IntraState	11/10/2019	11.43	11/10/2019	16.44	PO	Faulty String Replacement work
OSMANABAD BARSHI	IntraState	11/10/2019	15.58	11/10/2019	16.32	T	Tripped from barshi end only
PARANDA BARSHI	IntraState	11/10/2019	16.24	11/10/2019	17.01	T	Distance Protection
Nashik-Padgha	IntraState	11/10/2019	20.40	12/10/2019	00.50	HT	Hand Tripped For Load Management
MAHAPE - RELIANCE GIS	IntraState	12/10/2019	08.40	12/10/2019	13.40	PO	Attending Hot Spot
Pedambe-Nerle	IntraState	12/10/2019	09.00	12/10/2019	13.34	EO	Emergency outage
Goregaon Aarey Line 2	IntraState	12/10/2019	09.08	12/10/2019	21.29	PO	CT Replacement work
Theur-Phursungi	IntraState	12/10/2019	09.43	12/10/2019	13.27	PO	Tan Delta Work
Chinchwad-Hinjewadi I	IntraState	12/10/2019	09.56	12/10/2019	19.14	HT	HT For Load management for Urse-Talegaon outage
OSMANABAD PARANDA	IntraState	12/10/2019	10.07	12/10/2019	14.38	PO	Daigonistic Testing Work
Tilawani-Talandge-I	IntraState	12/10/2019	11.22	12/10/2019	13.00	PO	Annual Maintenance Work
Sahara-Urse	IntraState	12/10/2019	12.04	12/10/2019	19.10	HT	HT For Load management for Urse-Talegaon outage
Urse - Talegaon (Ambi) Ckt 2	IntraState	12/10/2019	12.18	12/10/2019	19.08	PO	Commissioning of B-ph LA
Theur-Phursungi ckt-2	IntraState	12/10/2019	13.31	12/10/2019	16.55	PO	Line Maintenance work
OSMANABAD BARSHI	IntraState	12/10/2019	14.54	12/10/2019	16.20	PO	Attending Hot Spot
Sahara-Urse	IntraState	12/10/2019	22.50		Continued.	HT	HT For Load Management
Chinchwad-Hinjewadi I	IntraState	12/10/2019	23.01		Continued.	HT	HT For Load Management
220 KV ICT Outages/Trippings							
220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-Ii (Mudshingi)	IntraState	11/10/2019	10.50	11/10/2019	13.17	PO	Annual Maintenance Work
220/132 kv 200 Mva ICT-II @Boisar-Ii	IntraState	11/10/2019	10.55	11/10/2019	19.20	PO	Diagnostic Testing work
220/22 Kv 50 Mva T&R Ptr 1 @Anandnagar	IntraState	11/10/2019	11.00	11/10/2019	12.23	PO	Attending Hot Spot
220/132kv 150MVA ICT-II @ Bhenda	IntraState	12/10/2019	11.20	12/10/2019	14.05	PO	Attending Oil Leakage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage