

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Oct/2020 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	112.291	1451.477	1) Gujrat	1.411	47.267
2) Hydro	3.339	81.261	2) Madhya Pradesh	5.377	66.222
3) Gas	6.640	65.253	3) Chattisgarh	6.110	63.200
Total MSPGCL	122.270	1597.991	4) Maharashtra	128.260	1363.743
B) 1) APMIL	51.520	681.266	5) Goa (Amona)	-0.828	-16.445
2) JSWEL	23.231	260.755	Total	140.330	1523.987
3) VIPL	0.000	0.000	a) Mumbai Schedule	20.576	235.933
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	22.239	275.255
5) WPCL	7.229	54.899	c) MSEDCL Bilateral *	37.027	379.484
6) Other IPP	8.298	100.933	Include PX	6.798	68.194
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	20.576	235.933
C) 1) TPCL Thermal	9.932	98.825	Include PX	8.575	87.770
2) TPCL Hydro	2.279	40.975	Standby	0.000	0.000
3) TPCL Gas	4.342	48.105	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.539	114.818	1) MSEDCL	346.890	4114.845
D) STATE			2) Mumbai Discoms	50.331	577.974
1) Thermal	224.040	2762.973	TOTAL STATE	397.221	4692.819
(A1+C1+C4+(B1-B6))					
2) Hydro	5.618	122.236			
(A2+C2)					
3) Gas	10.982	113.358			
(A3+B7+C3)					
4) Wind	13.051	106.686			
6) SOLAR	3.200	63.583			
TOTAL STATE	256.891	3168.836			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	4519	4552	4494	4245
MSPGCL Hydro	385	356	485	76
MSPGCL Gas	278	267	278	268
MSPGCL Total Generation	5182	5175	5257	4589
Central Sector Receipt	6814	6434	5767	5200
WIND	106	196	675	1137
CPP / IPP Thermal	3776	4023	3894	3406
CPP / IPP Gas	0	0	0	0
SOLAR	521	407	0	0
Exchange with Mumbai	-1026	-1055	-632	-1282
MSEDCL DEMAND MET	15373	15180	14961	13050
Load Shedding	0	0	0	0
MSEDCL DEMAND	15373	15180	14961	13050
TPCL GENERATION	692	696	1068	560
AEML GENERATION	501	500	501	501
MUMBAI DEMAND	2219	2251	2201	2343
STATE DEMAND MET	17592	17431	17162	15393
STATE DEMAND	17592	17431	17162	15393
Frequency (Hz)	50.02	50.02	50.02	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 22.01 Hrs	49.86 Hz at 18.10 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Oct/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	103.72	0	0
Unit 9	7.61	100.48	458	0
Unit 10	8.03	90.02	358	320
Total	15.64	294.22		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.80	112.84	435	360
Unit 5	8.83	113.53	470	348
Total	17.62	226.38		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.78	26.70	244	172
Unit 7	4.81	27.21	241	187
Unit 8	4.96	30.40	250	190
Total	14.56	84.31		
Chandrapur				
Unit 3	0.00	2.16	0	0
Unit 4	3.39	27.38	146	129
Unit 5	9.37	109.07	420	340
Unit 6	0.00	97.94	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.32	115.04	460	360
Unit 9	7.04	113.46	440	0
Total	30.13	465.04		
Paras				
Unit 3	4.85	46.36	250	116
Unit 4	5.32	55.76	255	189
Total	10.17	102.12		
Khaparkheda				
Unit 1	3.40	36.72	160	110
Unit 2	3.94	43.60	180	135
Unit 3	3.47	42.26	160	125
Unit 4	4.14	44.19	185	160
Unit 5	9.22	112.64	410	357
Total	24.18	279.41		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.64	65.25	290	258
Total	6.64	65.25		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.22	8.58	52	50

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.22	8.58		
Koyna				
Stage 1-2	1.88	33.51	325	40
Stage 4	0.23	18.49	122	0
Stage 3	0.44	11.84	80	0
Total	2.55	63.84		
Hydro				
KDPH	0.00	0.77	0	0
VTRNA	0.00	0.49	0	0
TILLARI	0.00	3.99	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.28	3.51	40	0
RNGR+BHTSA	0.00	0.14	0	0
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.50	5.83	22	21
SMLHY_PTN	0.00	0.35	1	0
GHATGHAR	0.00	2.34	0	0
Total	0.79	17.43		
Wind				
Total	13.05	106.69	0	0
Total	13.05	106.69		
CPP				
APML(Mus)	51.52	681.27	0	0
JSWEL(Mus)	23.23	260.76	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	7.23	54.90	0	0
Other(Mus)	8.30	100.93	0	0
Total	90.28	1097.85		
SOLAR				
Total	3.20	63.58	0	0
Total	3.20	63.58		
Tata				
Trombay 5	9.93	98.82	469	298
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	30.81	118	108
Trombay 7B	1.56	17.30	66	63
Trombay 8	0.00	0.00	0	0
TATA Hydro	2.28	40.98	435	2
Total	16.55	187.90		
AEML				
DTPS U-1&2	11.54	114.82	501	371
Total	11.54	114.82		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	112.29	1451.48	MSPGCL Total	122.27	1597.99
			MSPGCL Thml+Gas	118.93	1516.73	Koyna 1,2 & 4 Total	2.11	52.00
			MSPGCL Hydro	3.34	81.26	State Total	256.89	3168.84

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 11/Oct/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5094	62	290	5446	193	4196	0	0	5793	5601	-1093	14343	0	14343	2207	16550	50.02
2	4922	68	280	5270	219	3969	0	0	5739	5453	-971	13940	0	13940	2065	16005	49.99
3	4953	67	280	5300	304	3922	0	0	5385	5119	-871	13774	0	13774	1951	15725	50.03
4	4911	72	280	5263	570	3713	0	0	5385	5311	-794	14063	0	14063	1863	15926	50.02
5	4661	67	280	5008	480	3579	0	0	5496	5710	-769	14008	0	14008	1818	15826	50.01
6	4816	106	280	5202	326	3608	0	0	5890	6006	-885	14257	0	14257	1821	16078	50.02
7	4966	76	280	5322	283	3887	0	7	6430	6618	-917	15200	0	15200	1816	17016	50.01
8	4948	74	280	5302	381	3914	0	93	6885	6704	-960	15434	0	15434	1821	17255	50.05
9	4959	106	280	5345	233	3689	0	252	6658	6673	-938	15254	0	15254	1896	17150	50.03
10	4957	111	278	5346	146	3645	0	485	6516	6757	-927	15452	0	15452	2040	17492	50.03
11	4947	111	268	5326	100	3604	0	658	6524	6663	-1044	15307	0	15307	2155	17462	50.01
12	4519	385	278	5182	106	3776	0	521	6606	6814	-1026	15373	0	15373	2219	17592	50.02
13	4552	356	267	5175	196	4023	0	407	6354	6434	-1055	15180	0	15180	2251	17431	50.02
14	4559	151	278	4988	314	3947	0	294	6271	6130	-1047	14626	0	14626	2224	16850	50.05
15	4584	146	268	4998	516	3786	0	240	6237	5967	-1032	14475	0	14475	2193	16668	50.02
16	4621	141	287	5049	671	3668	0	132	6046	5480	-780	14220	0	14220	2120	16340	50.03
17	4431	151	258	4840	798	3609	0	83	5771	5533	-648	14215	0	14215	2063	16278	50.02
18	4453	82	278	4813	711	3611	0	28	5382	5438	-587	14014	0	14014	2057	16071	49.98
19	4494	485	278	5257	675	3894	0	0	5277	5767	-632	14961	0	14961	2201	17162	50.02
20	4686	223	278	5187	873	3979	0	0	5409	5602	-810	14831	0	14831	2289	17120	50.04
21	4406	96	278	4780	1129	3690	0	0	5445	5230	-998	13831	0	13831	2307	16138	49.99
22	4359	66	269	4694	1308	3655	0	0	5202	4961	-962	13656	0	13656	2287	15943	50.02
23	4248	61	279	4588	1382	3508	0	0	5558	5159	-1211	13426	0	13426	2324	15750	50.04
24	4245	76	268	4589	1137	3406	0	0	5431	5200	-1282	13050	0	13050	2343	15393	50.01
MUs	112.29	3.34	6.64	122.27	13.05	90.28	0.00	3.20	141.69	140.33	-22.24	346.89	0.00	346.89	50.33	397.22	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 11/Oct/2020

Position as on 6.30 Hrs of 12/Oct/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
TPC_G	Trombay 8	250	11/04/2020	16.55	12/10/2020	21.36	Zero Schedule.	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Ghatghar Unit-1	125	30/09/2020	18.05		Continued.	Turbine Guide Bearing problem	
MSPGCL	Chandrapur Unit 3	210	01/10/2020	16.00		Continued.	Main turbine bearing problem.	
IPP	Adani U-2	660	09/10/2020	12.16	12/10/2020	07.23	Genrator seal oil problem	
MSPGCL	Koradi Unit-8	660	10/10/2020	19.34		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	10/10/2020	22.16	12/10/2020	20.04	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	11/10/2020	11.05	11/10/2020	14.36	Tripped on jurk due to auto reclose of 400kv chandrapur switching to chandrapur ii ckt 1.	
MSPGCL	Koradi Unit 9	660	11/10/2020	18.16		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Oct/2020

Position as on 6.30 Hrs of 12/Oct/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 5	500	12/10/2020	10.00	12/10/2020	22.28	Under Frequency.	
MSPGCL	Uran Unit 5	108	12/10/2020	10.05		Continued.	Grid Failure	
MSPGCL	Uran Unit 6	108	12/10/2020	10.05	12/10/2020	14.00	Grid Failure	
TPC-G	Trombay 7B	60	12/10/2020	10.05		Continued.	Under Frequency	
MSPGCL	Uran Unit A0	120	12/10/2020	10.05		Continued.	Grid Failure	
TPC-G	Trombay 7A	120	12/10/2020	10.05	12/10/2020	12.59	Under frequency.	
AEML	AEML Unit 2	250	12/10/2020	11.12	12/10/2020	13.04	Tripped on jerk Due To tripping Of Godbunder line.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2020

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Waluj Aurangabad(PG)- I	InterState	07/10/2020	11.47		Continued.	PO	Breaker replacement works.
Dhule Sar'Sarovar II	InterState	09/10/2020	16.55	12/10/2020	09.04	HT	Over Voltage
Chandrapur Bhadravati III	InterState	12/10/2020	03.15		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	12/10/2020	09.17		Continued.	PO	Earth wire replacement work.(REC 18.22 Hrs).
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Kalwa - Talegaon(PG)	IntraState	10/10/2020	13.47		Continued.	T	Distance Protection
Girwali- Lonikand 2	IntraState	10/10/2020	14.34	11/10/2020	07.25	T	Distance Protection
Dhule- Bableshtar - I	IntraState	10/10/2020	18.06		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	10/10/2020	20.07	12/10/2020	11.18	HT	Over Voltage
Chandrapur II - Chandrapur SW Ckt I	IntraState	11/10/2020	15.21	12/10/2020	16.46	PO	Wave Trap Replacement work
Akola II - RPL(Rattanindia) Ckt I	IntraState	11/10/2020	21.08		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	12/10/2020	04.33	12/10/2020	10.41	T	As line was tripped on O/V,outage for same was requested from field & same was given @ 07.25 To Attend Decapping Of insulator String @ Loc.No. 1044.
Padghe - Kalwa-II	IntraState	12/10/2020	09.58	12/10/2020	18.48	T	R Phase Earth Fault.conductor snapped at loc.1007
Kalwa - Kharghar	IntraState	12/10/2020	10.02	12/10/2020	18.59	HT	Y ph CT Jumper Broken at Kharghar end
Kharghar-Talegaon(PG)	IntraState	12/10/2020	10.02	12/10/2020	10.27	HT	Heavy sparking on CT at kharghar end
Khadka-Aurangabad (Waluj)	IntraState	12/10/2020	21.12		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220kv 315MVA ICT-III @ Kharghar	IntraState	12/10/2020	10.05	12/10/2020	10.27	HT	Handtripped due to Zero load
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	12/10/2020	10.05	12/10/2020	19.05	HT	Handtripped due to Zero load
400/220/33 Kv 315 MVA ICT -I @Kharghar	IntraState	12/10/2020	10.05	12/10/2020	11.12	HT	Handtripped due to Zero load
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	12/10/2020	10.05	12/10/2020	11.18	HT	Handtripped due to Zero load
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	12/10/2020	10.05	12/10/2020	19.02	HT	Handtripped due to Zero load
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	12/10/2020	10.05	12/10/2020	10.45	HT	Handtripped due to Zero load
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	12/10/2020	10.05	12/10/2020	10.47	HT	Handtripped due to Zero load
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Mahalakshmi Amona	InterState	12/10/2020	04.30	12/10/2020	06.52	T	Over Voltage
Borivali(MS) Boisar(PG)	InterState	12/10/2020	10.05	12/10/2020	10.40	HT	Hand Tripped
Borivali - Tarapur	InterState	12/10/2020	10.05	12/10/2020	11.35	HT	Hand Tripped

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2020

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Borivali - Tarapur	InterState	12/10/2020	19.57		Continued.	T	Distance Protection
Kharghar-Borivali ckt II	IntraState	11/08/2020	01.45		Continued.	T	Speacial Repair Cable work
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Ghatghar - Jindal	IntraState	09/10/2020	09.45	11/10/2020	20.25	PO	CB Overhauling work at jindal end
Lonand-Baramati	IntraState	10/10/2020	12.25	11/10/2020	12.12	T	Overloading
Kandalgaon - Sona Alloys	IntraState	10/10/2020	12.25	11/10/2020	12.00	T	Distance Protection
Nerul-Trombay	IntraState	11/10/2020	06.35	11/10/2020	18.39	PO	Pile foundation work by MMRDA.
PAL DOMBIVALI - PALAVA	IntraState	11/10/2020	08.38	11/10/2020	17.28	PO	Fixing of Additional jumper at STN cut point location .
Pigasus-Hinjewadi-II	IntraState	11/10/2020	09.05	11/10/2020	12.23	PO	Attending Hot Spot
Chandrapur(MIDC)-Ballarshah II	IntraState	11/10/2020	09.48	11/10/2020	19.23	PO	Rectification work of 220 kv m/c line from 400kv chd-ii to 220 kv midc s/stn. between loc. no. 29/0 to 35/0.
Karad(400kv) - Wathar	IntraState	11/10/2020	12.58	11/10/2020	19.38	PO	Line Maintenance work
Nanded - Parli Ext. Ckt I	IntraState	11/10/2020	16.05		Continued.	T	Distance Protection
Talandage - Sawantwadi I	IntraState	12/10/2020	09.07	12/10/2020	18.46	PO	Line Maintenance work
Kharghar-Borivali ckt I	IntraState	12/10/2020	09.30		Continued.	HT	Over Voltage
Tilawani-Talandge-I	IntraState	12/10/2020	09.32	12/10/2020	16.28	PO	Testing Work
Apta - Bombay Dyeing	IntraState	12/10/2020	10.04	12/10/2020	11.35	T	Tripped due to grid Failure
Apta - Tambati	IntraState	12/10/2020	10.04	12/10/2020	10.40	T	Tripped due to grid Failure
ACCIL - Apta	IntraState	12/10/2020	10.04	12/10/2020	11.33	T	Tripped due to grid Failure
Kalwa - Siemens	IntraState	12/10/2020	10.05	12/10/2020	11.16	HT	Handtripped due to zero loading
Kalwa - Colourchem	IntraState	12/10/2020	10.05	12/10/2020	11.10	HT	Handtripped due to zero loading
Kalwa - Borivali	IntraState	12/10/2020	10.05	12/10/2020	11.42	HT	Handtripped due to zero loading
Kalwa - Mulund 1	IntraState	12/10/2020	10.05	12/10/2020	11.12	HT	Handtripped due to zero loading
Padgha - Temghar I	IntraState	12/10/2020	10.05	12/10/2020	11.12	T	Line Tripped on E/F Backup Protection
Kharghar - Nerul	IntraState	12/10/2020	10.05	12/10/2020	10.52	HT	Handtripped
Trombay - Kalwa	IntraState	12/10/2020	10.05	12/10/2020	11.05	HT	Handtripped due to zero loading
Colourchem - Temghar	IntraState	12/10/2020	10.05	12/10/2020	11.24	HT	Handtripped
Boisar(M) - Ghodbunder	IntraState	12/10/2020	10.05	12/10/2020	11.47	T	LTS Opeared
Temghar - Kalwa	IntraState	12/10/2020	10.05	12/10/2020	11.40	HT	Handtripped
GIS Bhandup - Borivali	IntraState	12/10/2020	10.05	12/10/2020	10.43	HT	Handtripped due to grid failure
Kalwa-TIFIL	IntraState	12/10/2020	10.05	12/10/2020	11.19	HT	Handtripped due to zero loading
Boisar Versova Line	IntraState	12/10/2020	10.05	12/10/2020	11.09	T	LTS Opearation
TPC Borivali Aarey Line 1	IntraState	12/10/2020	10.05		Continued.	T	Over Loading.
Gorai MSETCL Borivali Line-1	IntraState	12/10/2020	10.05	12/10/2020	13.57	HT	Over Loading.
Gorai MSETCL Borivali Line-2	IntraState	12/10/2020	10.05	12/10/2020	13.00	HT	Over Loading.
Kalwa-Salsette-IV	IntraState	12/10/2020	10.05	12/10/2020	10.55	HT	Handtripped due to zero loading
Kalwa 52B Interconnector CB	IntraState	12/10/2020	10.05	12/10/2020	11.01	HT	Handtripped due to zero loading

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2020

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kalwa Salsette III	IntraState	12/10/2020	10.05	12/10/2020	11.34	HT	Handtripped due to zero loading
Tata Borivli MSETCL Borivli 4	IntraState	12/10/2020	10.05	12/10/2020	13.53	HT	Over Loading.
Tata Borivli MSETCL Borivli 5	IntraState	12/10/2020	10.05	12/10/2020	13.53	HT	Over Loading.
Boisar-Viraj	IntraState	12/10/2020	10.05	12/10/2020	11.49	T	LTS Opearated
Dahanu-Viraj	IntraState	12/10/2020	10.05	12/10/2020	13.51	HT	Over Loading.
Padgha-Temghar-II	IntraState	12/10/2020	10.05	12/10/2020	10.58	T	Line Tripped on O/C Backup Protection
SAKI (REL) - SAKI (TATA) CKT - 1	IntraState	12/10/2020	10.05		Continued.	T	Over Loading.
SAKI (REL) - SAKI (TATA) CKT - 2	IntraState	12/10/2020	10.05		Continued.	T	Over Loading.
BOISAR BORIVALI	IntraState	12/10/2020	10.05	12/10/2020	10.38	T	Due to LTS Opearation
Chandrapur(MIDC)-Ballarshah I	IntraState	12/10/2020	10.05	12/10/2020	19.02	PO	Project balance work.
Kharghar-Sonkhar	IntraState	12/10/2020	10.05	12/10/2020	11.27	HT	Handtripped
Cable Borivli Aarey 2	IntraState	12/10/2020	10.15		Continued.	HT	Load Managment.
Cable Borivli Aarey 1	IntraState	12/10/2020	10.15		Continued.	HT	Load Managment.
Uran - Hoc 1	IntraState	12/10/2020	10.25	12/10/2020	12.01	HT	Handtripped due to grid failure
Uran - Apta II	IntraState	12/10/2020	10.25	12/10/2020	11.53	HT	Handtripped due to grid failure
Apta - Kalwa1	IntraState	12/10/2020	10.25	12/10/2020	11.45	HT	Handtripped due to grid failure
Apta - Taloja	IntraState	12/10/2020	10.25	12/10/2020	11.47	HT	Handtripped due to grid failure
Uran - Apta III	IntraState	12/10/2020	10.25	12/10/2020	11.54	HT	Handtripped due to grid failure
Uran - Apta IV	IntraState	12/10/2020	10.25	12/10/2020	11.55	HT	Handtripped due to grid failure
Chandrapur GCR - Warora - I	IntraState	12/10/2020	10.27	12/10/2020	14.12	PO	Line Maintenance work
Mulund - GIS Bhandup	IntraState	12/10/2020	10.32	12/10/2020	10.52	HT	Handtripped due to grid failure
Karad(400kv) - Wathar	IntraState	12/10/2020	11.36	12/10/2020	19.25	T	Distance Protection
Pusad - Hingoli	IntraState	12/10/2020	15.00	12/10/2020	17.35	PO	Line Maintenance work
220 KV ICT Outages/Trippings							
220/132 Kv 200 MVA ICT-III @Girwali	IntraState	12/10/2020	11.36	12/10/2020	17.51	PO	Testing Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage