

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Oct/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	171.138	1729.299	1) Gujrat	8.169	106.376
2) Hydro	29.441	161.387	2) Madhya Pradesh	2.541	65.749
3) Gas	6.822	58.404	3) Chattisgarh	2.720	42.620
Total MSPGCL	207.401	1949.090	4) Maharashtra	188.028	1956.619
B) 1) APML	76.223	617.450	5) Goa (Amona)	-1.813	-17.437
2) JSWEL	27.000	259.391	Total	199.645	2153.927
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.006	378.966
4) RPL(AMT)	31.496	292.148	b) Mumbai Drawl	36.853	425.851
5) SWPGPL	6.391	96.245			
6) Other IPP	9.362	34.991	c) MSEDCL Bilateral *	76.786	847.825
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	16.484	147.992	d) Mumbai Bilateral *	32.914	378.874
2) TPCL Hydro	6.659	49.812	Include PX	0.000	0.000
3) TPCL Gas	2.627	28.150	Standby	0.092	0.092
4) AEML Thermal	11.231	101.261			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	349.325	3278.777	1) MSEDCL	531.948	5153.246
2) Hydro (A2+C2)	36.100	211.199	2) Mumbai Discoms	73.854	753.066
3) Gas (A3+B7+C3)	9.449	86.554	3) Other Discoms	10.405	112.914
4) Wind	5.730	110.370			
6) SOLAR	15.958	178.399	TOTAL STATE	616.207	6019.226
TOTAL STATE	416.562	3865.299			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7028	7046	6926	7496
MSPGCL Hydro	1089	1305	1886	933
MSPGCL Gas	282	272	283	293
MSPGCL Total Generation	8399	8623	9095	8722
Central Sector Receipt	9329	9394	8769	6860
WIND	128	100	222	381
CPP / IPP Thermal	6271	6282	6272	6263
CPP / IPP Gas	0	0	0	0
SOLAR	2152	1653	0	0
Exchange with Mumbai	-2003	-2073	-1651	-898
MSEDCL DEMAND MET	23806	23514	22227	21018
Load Shedding	0	0	0	0
MSEDCL DEMAND	23806	23514	22227	21018
TPCL GENERATION	1074	1048	1269	949
AEML GENERATION	463	490	472	493
MUMBAI DEMAND	3540	3611	3392	2340
OTHER DISCOM DEMAND	470	465	480	310
STATE DEMAND MET	27816	27590	26099	23668
STATE DEMAND	27816	27590	26099	23668
Frequency (Hz)	50.00	49.93	49.90	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 20.43 Hrs	49.63 Hz at 06.39 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Oct/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.35	42.62	190	135
Unit 8	14.42	154.85	632	511
Unit 9	13.57	131.32	604	510
Unit 10	14.92	155.36	660	580
Total	47.25	484.15		
Bhusawal				
Unit 3	2.98	34.07	135	115
Unit 4	10.50	73.22	455	425
Unit 5	9.48	96.95	455	0
Total	22.96	204.24		
Parli				
Unit 6	5.21	48.41	240	188
Unit 7	5.01	48.95	220	180
Unit 8	4.59	43.46	209	158
Total	14.81	140.82		
Chandrapur				
Unit 3	2.51	26.80	127	84
Unit 4	3.37	25.18	148	133
Unit 5	3.16	34.06	450	0
Unit 6	7.45	70.37	350	270
Unit 7	6.73	70.80	318	260
Unit 8	10.97	110.22	490	415
Unit 9	11.34	112.36	485	458
Total	45.53	449.80		
Paras				
Unit 3	5.14	52.43	228	204
Unit 4	4.97	54.17	226	155
Total	10.11	106.60		
Khaparkheda				
Unit 1	3.90	39.75	185	140
Unit 2	2.12	24.09	118	53
Unit 3	3.78	30.18	179	136
Unit 4	3.22	37.57	161	115
Unit 5	10.80	115.75	470	415
Total	23.82	247.33		
Nasik				
Unit 3	0.00	31.99	0	0
Unit 4	3.70	31.80	162	139
Unit 5	2.96	32.58	135	110
Total	6.66	96.37		
Uran				
All Units	6.82	58.40	293	272
Total	6.82	58.40		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.72	10.81	47	0
Total	0.72	10.81		
Koyna				
Stage 1-2	6.74	37.20	450	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	14.62	54.53	1009	66
Stage 3	4.14	20.37	240	80
Total	25.49	112.09		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.65	0	0
TILLARI	0.18	1.20	60	0
BHIRA T.R.	0.44	3.32	80	0
SMLHY_PTN	2.39	29.47	102	94
GHATGHAR	0.22	3.85	125	0
Total	3.23	38.48		
Wind				
Total	5.73	110.37	0	0
Total	5.73	110.37		
CPP				
APML(Mus)	76.22	617.45	0	0
JSWEL(Mus)	27.00	259.39	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.50	292.15	0	0
SWPGPL-Mus	6.39	96.24	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.26	13.83	269	201
Other(Mus)	0.34	3.72	0	0
JPL	2.76	17.45	124	99
Total	150.47	1300.22		
SOLAR				
Total	15.96	178.40	0	0
Total	15.96	178.40		
Tata				
Trombay 5	10.97	97.64	467	441
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.50	16.21	108	38
Trombay 7B	1.13	11.94	65	35
TATA Hydro	6.66	49.81	401	136
Trombay 8	5.51	50.36	239	220
Total	25.77	225.95		
AEML				
DTPS U-1&2	11.23	101.26	495	343
Total	11.23	101.26		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	171.14	1729.30	MSPGCL Total	207.40	1949.09
			MSPGCL Thml+Gas	177.96	1787.70	Koyna 1,2 & 4 Total	21.35	91.72
			MSPGCL Hydro	29.44	161.39	State Total	416.56	3865.30

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Oct/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7512	903	290	8705	266	6263	0	0	7130	7451	-1304	21011	0	0	21011	2840	370	24221	49.96
2	7466	865	292	8623	323	6263	0	0	6875	7205	-1140	20931	0	0	20931	2599	343	23873	49.93
3	7467	909	293	8669	364	6257	0	0	6702	6945	-970	20935	0	0	20935	2439	330	23704	49.96
4	7496	933	293	8722	381	6263	0	0	6608	6860	-898	21018	0	0	21018	2340	310	23668	49.99
5	7481	1055	289	8825	475	6254	0	0	7042	7052	-896	21379	0	0	21379	2308	331	24018	49.98
6	7515	1230	290	9035	480	6290	0	0	7728	7774	-939	22271	0	0	22271	2386	369	25026	49.92
7	7469	1769	290	9528	508	6196	0	72	8109	7911	-1024	22794	0	7	22794	2503	397	25694	49.85
8	7521	1580	290	9391	358	6250	0	539	7858	8065	-1207	22939	0	2	22939	2669	457	26065	50.04
9	7149	944	282	8375	198	6251	0	1229	8211	8438	-1564	22464	0	0	22464	2975	463	25902	50.04
10	7122	730	287	8139	132	6258	0	1776	8973	9115	-1818	23129	0	3	23129	3305	473	26907	49.98
11	7028	1089	282	8399	128	6271	0	2152	9252	9329	-2003	23806	0	58	23806	3540	470	27816	50.00
12	6982	695	278	7955	149	6276	0	2267	9461	9345	-2080	23434	0	33	23434	3630	478	27542	49.97
13	6986	409	278	7673	118	6254	0	2246	9510	9422	-2069	23191	0	0	23191	3604	453	27248	49.95
14	6993	526	275	7794	104	6211	0	2078	9478	9546	-2049	23221	0	4	23221	3533	463	27217	49.99
15	7046	1305	272	8623	100	6282	0	1653	9423	9394	-2073	23514	0	15	23514	3611	465	27590	49.93
16	7045	1666	276	8987	126	6281	0	1142	9580	9281	-2031	23304	0	18	23304	3646	482	27432	49.91
17	6994	1662	273	8929	149	6277	0	635	9077	9026	-1952	22591	0	2	22591	3580	473	26644	49.91
18	6877	1697	278	8852	185	6275	0	169	8731	8600	-1741	21839	0	3	21839	3459	501	25799	49.85
19	6926	1886	283	9095	222	6272	0	0	8847	8769	-1651	22227	0	0	22227	3392	480	26099	49.90
20	6943	1756	283	8982	186	6267	0	0	9073	8854	-1597	22211	0	0	22211	3308	481	26000	50.02
21	6911	1299	284	8494	207	6294	0	0	8164	8156	-1540	21121	0	0	21121	3185	490	24796	50.03
22	7013	1224	290	8527	194	6298	0	0	7803	7756	-1447	20862	0	0	20862	3052	466	24380	49.97
23	6615	1543	286	8444	190	6338	0	0	7642	7653	-1430	20742	0	0	20742	3000	453	24195	49.99
24	6581	1768	288	8637	187	6331	0	0	7634	7696	-1430	21015	0	0	21015	2950	406	24371	49.99
MUs	171.14	29.44	6.82	207.40	5.73	150.47	0.00	15.96	198.91	199.65	-36.85	531.95	0.00	0.14	531.95	73.85	10.40	616.21	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)22kV Lonikand1as per 400kV Lonikand-1 instructions due to undervoltage issue & ICT Overloading issue.2)132 KV BBLR - Sangamner Line Overload 482A/88.15MW

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Oct/2023

Position as on 6.30 Hrs of 12/Oct/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	12/10/2023
MSPGCL	Koyana Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
IPP	SWPGPL U-4	135	29/09/2023	00:03		Continued.	Turbine Bearing no.4 temperature high	20/10/2023
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
MSPGCL	Koyana Unit 4	70	10/10/2023	09:05	11/10/2023	16:50	Turbine guide bearing oil leakage attending work	11/10/2023
MSPGCL	Nasik Unit 3	210	10/10/2023	23:55		Continued.	ESP Hoppers & restoration of ESP Filters	14/10/2023
IPP	SWPGPL U-3	135	10/10/2023	23:56		Continued.	Electrostatic precipitator problem	19/10/2023
MSPGCL	Chandrapur Unit 5	500	11/10/2023	08:12		Continued.	Turbine Vibration High.	27/10/2023
MSPGCL	Bhusawal Unit 5	500	11/10/2023	22:01	12/10/2023	00:42	PA FAN 5B UNLOADED Resulted in Low furnance Pressure due to that Boiler Tripped	
MSPGCL	Khaparkheda Unit 4	210	12/10/2023	06:58		Continued.	Reheater Problem	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	IntraState	11/10/2023	10:01	11/10/2023	20:41	PO	Annual Maintenance of CB at Koradi-III SS
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
MAIN BAY (406) OF WARORA CKT - 1 @ TIRORA	IntraState	09/10/2023	09:48	11/10/2023	18:18	PO	For line main bay breaker arcing contact inspection and testing work
Main bay (406) of Deepnagar line @ Taptitanda	IntraState	09/10/2023	12:56	11/10/2023	17:47	PO	Circuit Breaker Mechanism overhauling work to be carried out by M/s CGL through M/s Ajaydeep
Main Bay (418) of Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	IntraState	11/10/2023	10:19	11/10/2023	17:18	PO	Diagnostic testing & allied bay maintenance work
MAIN BAY (407) OF BUS REACTOR @ LONIKAND 2	IntraState	12/10/2023	08:27			PO	Diagnostic testing and Maintenance
Main bay (409) of Tirora - Warora ckt- 2 @ TIRORA	IntraState	12/10/2023	09:00			PO	For line main bay breaker arcing contact inspection and testing work
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ɛYɛ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/10/2023	08:04			HT	H/T for load management.
CHANDRAPUR GCR - CHANDRAPUR HVDC - 2	IntraState	11/10/2023	07:12	11/10/2023	18:35	EO	To attend the hotspot on R & Y-ph PG-1 Isolator (R & Y-ph Main Bus-1 Isolator) and providing binding to bus conductor by hot line tehcnique. emergency outage on PG-1 Isolator (Main Bus-1 Isolator R & Y-ph) of 400KV Chandrapur- HVDC Ckt. No.-II by shifting on 400KV TBC-2 bay and permission to work on 400KV Main Bus-1 by hot line technique at 400kv S/st. GCR-1, MSETCL, Chandrapur
NEW KOYNA-KARAD CKT - 1	IntraState	11/10/2023	10:11	11/10/2023	19:01	PO	PID Faulty disc insulator replacement work & Cold line washing work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	11/10/2023	07:30			EO	TRIP TRAILS OF 220KV BUS BAR/ICT HV & LV BY STU NOMINATED TEAM AS PER CE AC& I DIRECTIONS DATED 09.10.2023
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	11/10/2023	08:32			EO	TRIP TRAILS OF 220KV BUS BAR/ICT HV & LV BY STU NOMINATED TEAM AS PER CE AC& I DIRECTIONS DATED 09.10.2023
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	11/10/2023	08:40			EO	TRIP TRAILS OF 220KV BUS BAR/ICT HV & LV BY STU NOMINATED TEAM AS PER CE AC& I DIRECTIONS DATED 09.10.2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	11/10/2023	09:21	11/10/2023	19:19	PO	Post Monsoon Maintenance Work
220 KV TIEBAY Outages/Trippings							
220 KV BUS COUPLER	IntraState	11/10/2023	10:02	11/10/2023	14:09	PO	FOR ATTENDING GAS LEAKAGE PROBLEM FROM B-PH. POLE AND YEARLY DIAGNOSTIC TESTING WORK
220 KV TBC Outages/Trippings							
BUS COUPLER @ MULUND	IntraState	11/10/2023	10:22	11/10/2023	15:53	PO	1. CT tan delta & IR testing 2. Bay maintenance work.
220 KV LINE Outages/Trippings							
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
AAREY - MSETCL BORIVALI CKT - 1	IntraState	25/09/2023	09:06	11/10/2023	20:46	T	Tripped on distance protection.
AAREY - MSETCL BORIVALI CKT - 2	IntraState	05/10/2023	19:29			T	Tripped on Differential protection.
EKLAHARE (OCR) - PADGHE	IntraState	06/10/2023	07:37			HT	Kept Handtripped from padghe end for load managment
FLAGSHIP-CHINCHWAD	IntraState	11/10/2023	08:05	11/10/2023	20:07	PO	Dismantelling of old tower
CHINCHWAD- PARVATI	IntraState	11/10/2023	08:05	11/10/2023	19:59	PO	Dismantelling of old tower
PIRANGUT - HINJAWADI 2	IntraState	11/10/2023	08:36			PO	C.B. operating mechanism overhauling
NEW KOYNA - POPHALI	IntraState	11/10/2023	09:16			PO	CT Replacement work
MALINAGAR - TEMBHURNI	IntraState	11/10/2023	09:31	11/10/2023	19:23	PO	Cold line washing of strings LILO Loc 1 to 40.
PARLI NEW TPS - BEED CKT 1	IntraState	11/10/2023	11:02	11/10/2023	14:02	PO	TAN DELTA OF CTS AND BAY ROUTINE MAINTENANCE WORK
AMBAZARI - KARANJA CKT	IntraState	11/10/2023	12:06	11/10/2023	16:23	PO	1. CT TAN DELTA,CAP. MEASUREMENT. 2.CB CRM, TIMING & ROUTINE BAY MAINTENANCE WORK. 3. ROUTINE LINE MAINTENANCE WORK
OSMANABAD - PARLY (PG)	IntraState	11/10/2023	12:19	11/10/2023	17:33	PO	LINE/ s/s maintenance
OSMANABAD - PARLY (PG)	IntraState	11/10/2023	12:19	11/10/2023	17:33	PO	CT TAN DELTA WORK AT USMANABAD END
EKLAHARE (GCR) - GHATGHAR	IntraState	11/10/2023	12:34	11/10/2023	13:13	HT	Emergency Outage for CT wire found loose at Nasik GCR
NAGOTHANE - POSCO	IntraState	11/10/2023	13:26	11/10/2023	18:41	PO	DAIGNOSTIC TESTING AND MAINTENANCE WORK
132 KV NAGEWADI (220 KV) - JALNA (220 KV) CKT 2	IntraState	11/10/2023	14:20	11/10/2023	15:20	T	AT J E= R PH, IF=3.8KA, D=6.7KM
ACCIL - APTA	IntraState	11/10/2023	14:48	11/10/2023	18:03	PO	Providing of twin jumpering from Loc no. 523 to 584 on all cut point towers
KANDALGAON - KOYNA (POPHALI)	IntraState	11/10/2023	15:09	11/10/2023	17:00	T	Tripped on distance protection
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	12/10/2023	06:52	12/10/2023	08:55	T	Tripped on distance protection
HINJAWADI I- CHINCHWAD	IntraState	12/10/2023	07:25			PO	Dismatelling of old tower no.160, 161,162.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 12/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 200MVA ICT 2 @ DHULE	IntraState	11/10/2023	09:10	11/10/2023	16:40	PO	FOR SFRA, DIAGNOSTIC TESTING & ROUTINE MAINTENANCE WORK
220/132KV 100MVA ICT 2 @ JEUR	IntraState	11/10/2023	10:22	11/10/2023	12:32	PO	Outage is required for Quarterly Maintenance
220/132KV 150MVA ICT - 1 @ MALINAGAR	IntraState	11/10/2023	10:46	11/10/2023	15:02	PO	Outage is required for Quarterly Maintenance
220/132KV 200MVA ICT 2 @ PANDHARPUR	IntraState	11/10/2023	11:07	11/10/2023	15:30	PO	Outage is required for CTR FIRE FIGHTING SYSTEM MAINT WORK.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
LBB PROTECTION @ EKLAHARE (GCR)	IntraState	11/10/2023	11:38	11/10/2023	17:01	PO	Retrieving data. Wait a few seconds and try to cut or copy again.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
KURUNDA - VASMAT	IntraState	11/10/2023	05:25	11/10/2023	14:05	T	WAVE TRAP JUMPER BROKEN
132 KV UJANI - KORAL CKT	IntraState	11/10/2023	12:52	11/10/2023	14:05	T	D/P PROT. Y-PH, 4.6 KA, 3.9 KM
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage