

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Nov/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	139.765	1589.957	1) Gujrat	-6.739	-98.868
2) Hydro	5.367	86.996	2) Madhya Pradesh	-1.244	-23.558
3) Gas	2.179	18.295	3) Chattisgarh	6.250	64.980
Total MSPGCL	147.311	1695.248	4) Maharashtra	161.353	1807.070
B) 1) APLM	63.348	692.827	5) Goa (Amona)	-1.672	-15.932
2) JSWEL	12.444	141.436	Total	157.948	1733.692
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.097	353.063
4) RPL(AMT)	25.483	280.841	b) Mumbai Drawl	37.908	393.153
5) SWPGPL	8.074	69.951	c) MSEDCL Bilateral *	85.553	747.953
6) Other IPP	34.987	320.746	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.097	353.063
C) 1) TPCL Thermal	10.762	119.219	Include PX	0.000	0.000
2) TPCL Hydro	3.871	43.902	Standby	0.000	0.000
3) TPCL Gas	0.000	6.990	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.036	96.427	1) MSEDCL	448.708	4736.288
D) STATE			2) Mumbai Discoms	61.577	659.691
1) Thermal	303.899	3311.404	3) Other Discoms	9.548	102.554
(A1+C1+C4+(B1-B6))			TOTAL STATE	519.833	5498.533
2) Hydro	9.238	130.898			
(A2+C2)					
3) Gas	2.179	25.285			
(A3+B7+C3)					
4) Wind	35.183	163.673			
6) SOLAR	11.386	133.581			
TOTAL STATE	361.885	3764.841			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6104	5504	6439	5206
MSPGCL Hydro	251	260	304	142
MSPGCL Gas	91	90	86	91
MSPGCL Total Generation	6446	5854	6829	5439
Central Sector Receipt	7639	7244	7062	5920
WIND	1633	1770	1287	1750
CPP / IPP Thermal	5855	5699	6580	5314
CPP / IPP Gas	0	0	0	0
SOLAR	1542	1685	0	0
Exchange with Mumbai	-1876	-1877	-1756	-1549
MSEDCL DEMAND MET	20802	19969	19550	16504
Load Shedding	0	0	0	0
MSEDCL DEMAND	20802	19969	19550	16504
TPCL GENERATION	667	690	800	526
AEML GENERATION	498	487	384	297
MUMBAI DEMAND	3041	3054	2940	2372
OTHER DISCOM DEMAND	437	406	453	370
STATE DEMAND MET	24280	23429	22942	19246
STATE DEMAND	24280	23429	22942	19246
Frequency (Hz)	50.02	50.00	50.00	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 18.01 Hrs	49.76 Hz at 08.06 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.91	50.47	215	175
Unit 7	0.00	0.00	0	0
Unit 8	14.17	134.87	607	571
Unit 9	12.64	135.43	574	410
Unit 10	0.00	91.74	0	0
Total	31.72	412.52		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.90	98.64	435	275
Unit 5	8.85	100.11	460	275
Total	17.75	198.74		
Parli				
Unit 6	3.78	41.17	222	147
Unit 7	3.91	40.04	238	144
Unit 8	3.61	32.33	183	142
Total	11.30	113.54		
Chandrapur				
Unit 3	3.16	35.48	150	124
Unit 4	3.00	31.96	140	118
Unit 5	6.90	71.70	315	275
Unit 6	7.07	72.32	325	280
Unit 7	7.38	79.41	357	275
Unit 8	8.94	106.10	445	277
Unit 9	8.61	101.03	422	299
Total	45.06	498.00		
Paras				
Unit 3	4.26	53.51	202	163
Unit 4	4.11	7.67	189	111
Total	8.37	61.19		
Khaparkheda				
Unit 1	2.66	29.33	130	90
Unit 2	2.85	29.05	125	110
Unit 3	3.44	37.61	167	86
Unit 4	3.46	36.61	162	130
Unit 5	9.78	109.99	495	280
Total	22.19	242.58		
Nasik				
Unit 3	0.23	1.31	76	0
Unit 4	0.00	28.41	0	0
Unit 5	3.15	33.67	150	109
Total	3.38	63.38		
Uran				
All Units	2.18	18.30	95	86
Total	2.18	18.30		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.37	10.26	45	0
Total	0.37	10.26		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.34	25.41	210	40
Stage 4	0.00	16.11	0	0
Stage 3	0.43	9.24	80	0
Total	1.76	50.76		
Hydro				
KDPH	0.63	1.80	36	18
VTRNA	0.00	0.00	0	0
TILLARI	0.58	0.58	58	0
BHIRA T.R.	0.28	2.06	80	0
SMLHY_PTN	1.56	18.12	66	63
GHATGHAR	0.19	3.41	125	0
Total	3.24	25.98		
Wind				
Total	35.18	163.67	0	0
Total	35.18	163.67		
CPP				
APML(Mus)	63.35	692.83	0	0
JSWEL(Mus)	12.44	141.44	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.48	280.84	0	0
SWPGPL-Mus	8.07	69.95	0	0
Other(Mus)	34.99	320.75	0	0
Total	144.34	1505.80		
SOLAR				
Total	11.39	133.58	0	0
Total	11.39	133.58		
Tata				
Trombay 5	7.27	80.85	370	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	3.87	43.90	401	2
Trombay 8	3.49	38.37	175	131
Total	14.63	170.11		
AEML				
DTPS U-1&2	9.04	96.43	499	297
Total	9.04	96.43		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	139.76	1589.96	MSPGCL Total	147.31	1695.25
			MSPGCL Thml+Gas	141.94	1608.25	Koyna 1,2 & 4 Total	1.34	41.52
			MSPGCL Hydro	5.37	87.00	State Total	361.88	3764.84

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 11/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5359	184	92	5635	1656	5702	0	0	5601	5501	-1449	16689	0	16689	2245	357	19290	50.01
2	5274	279	93	5646	1563	5679	0	0	5575	5688	-1365	16882	0	16882	2086	329	19297	49.99
3	5541	189	94	5824	1376	5711	0	0	5423	5721	-1263	17055	0	17055	1968	314	19337	50.00
4	5596	356	95	6047	1326	5761	0	0	5388	5736	-1181	17376	0	17376	1900	313	19589	50.01
5	5928	214	94	6236	1312	6227	0	0	5539	5680	-1147	17994	0	17994	1872	314	20180	50.01
6	6151	185	94	6430	1327	6546	0	0	6459	6109	-1254	18798	0	18798	1981	360	21139	50.00
7	6052	184	94	6330	1382	6532	0	27	7553	7242	-1353	19785	0	19785	2104	375	22264	49.99
8	6102	178	94	6374	1267	6448	0	320	7339	7587	-1409	20178	0	20178	2254	409	22841	50.00
9	6122	206	92	6420	1174	6523	0	790	7208	6948	-1585	19842	0	19842	2535	428	22805	49.95
10	5978	226	92	6296	1362	5986	0	1250	7288	7628	-1653	20433	0	20433	2819	436	23688	49.93
11	6104	251	91	6446	1633	5855	0	1542	7560	7639	-1876	20802	0	20802	3041	437	24280	50.02
12	5952	266	92	6310	1769	5872	0	1691	7414	7320	-1937	20603	0	20603	3101	422	24126	50.01
13	5504	260	90	5854	1770	5699	0	1685	7390	7244	-1877	19969	0	19969	3054	406	23429	50.00
14	5381	261	90	5732	1533	5685	0	1528	7197	7159	-1720	19519	0	19519	2921	399	22838	50.04
15	5782	259	90	6131	1405	5753	0	1273	7220	7611	-1744	19993	0	19993	2972	436	23401	50.01
16	6101	255	89	6445	1292	6156	0	829	7370	7258	-1804	19749	0	19749	3012	427	23188	50.00
17	6195	180	87	6462	1087	6447	0	395	7151	6790	-1679	19077	0	19077	2988	425	22490	49.97
18	6171	223	86	6480	970	6541	0	56	7049	6794	-1750	18650	0	18650	2932	442	22023	49.96
19	6439	304	86	6829	1287	6580	0	0	7048	7062	-1756	19550	0	19550	2940	453	22942	50.00
20	6225	289	86	6600	1516	6407	0	0	7203	6046	-1750	18365	0	18365	2829	454	21648	50.03
21	5870	200	86	6156	1727	5912	0	0	6091	5655	-1626	17398	0	17398	2682	426	20506	50.02
22	5468	124	90	5682	1859	5610	0	0	6001	5701	-1636	16794	0	16794	2545	422	19761	50.06
23	5264	152	91	5507	1840	5390	0	0	5936	5909	-1545	16703	0	16703	2424	398	19525	50.02
24	5206	142	91	5439	1750	5314	0	0	5824	5920	-1549	16504	0	16504	2372	370	19246	50.00
MUs	139.77	5.37	2.18	147.31	35.18	144.34	0.00	11.39	159.83	157.95	-37.91	448.71	0.00	448.71	61.58	9.55	519.83	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Nov/2022

Position as on 6.30 Hrs of 12/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	14/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	14/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-3	135	21/10/2022	01:33	11/11/2022	14:07	Coal Shortage	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	
IPP	JSW (J) U3	300	09/11/2022	08:08		Continued.	Generator Elect. Fault	12/11/2022
MSPGCL	Nasik Unit 4	210	09/11/2022	22:00		Continued.	Boiler validity work	12/11/2022
MSPGCL	Uran Unit 6	108	10/11/2022	10:44		Continued.	Gas shortage	
MSPGCL	Koradi Unit-10	660	10/11/2022	22:13		Continued.	Boiler Tube Leakage	13/11/2022
MSPGCL	Nasik Unit 3	210	11/11/2022	03:16		Continued.	Boiler Tube Leakage	13/11/2022
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scraper Conveyor Scraper bar problem.	13/11/2022
IPP	Adani U-3	660	12/11/2022	15:00		Continued.	Hot PA Bellow Leakage.	15/11/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 12/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (708) of KORADI - 3 CKT - 2 & EKTUNI CKT - 2 @ AKOLA 2	IntraState	11/11/2022	09:32	11/11/2022	18:24	PO	Annual Maintenance of Bay Equipment
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21	12/11/2022	20:42	PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21	12/11/2022	20:42	PO	Annual Maintenance work AC & DC yard Equipment, Valve Hall,Diagnostic testing, Line Maintenance, etc.
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF ICT -2 @ WARORA	IntraState	11/11/2022	11:00	11/11/2022	12:53	PO	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
PADGHE - PADGHE HVDC CKT- 2	IntraState	05/11/2022	12:21	12/11/2022	20:42	PO	1. Bay maint. work 2. Diagnostic testing work 3. Bhel CB Pole Overhauling work 4. A bus PG Isolator Replacement work under LES 5. If pole Overhauling work not completed due to any reason line will be charge on TBC. 6. Hot line work for Replacement of Hanger assembly of A bus PG Isolator 7. Outage Should be Reschedule with annual outage of HVDC Pole if any date change .
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
BUS - 1 @ NEW KOYNA	IntraState	09/11/2022	13:07			PO	1) 09/11/2022 to 10/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 11/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 and damage conductor replacement work 3) 12/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 13/11/2022 Bus Insulator replacement work at section Koyana -I & II 5) 14/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 15/11/2022 to 16/11/2022 Bus Insulator replacement work at section Jaigad - I & II
KARAD - TALANDGE CKT - 2	IntraState	10/11/2022	12:39			PO	Overhauling of A bus, B Bus PG isolators.
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	11/11/2022	06:37	11/11/2022	18:35	PO	Replacement of faulty Disc Insulator strings by LRP strings
JAIGAD - NEW KOYNA CKT - 2	IntraState	11/11/2022	09:55	11/11/2022	18:15	PO	Bay equipment maintenance/washing

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 12/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KHADKA-AURANGABAD (WALUJ)	IntraState	11/11/2022	20:52	12/11/2022	05:43	HT	H/T DUE TO O/V
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	12/11/2022	06:02	12/11/2022	18:05	PO	Replacement of faulty Disc Insulator strings by LRP strings
GT-10 @ KORADI-2	IntraState	12/11/2022	11:44				1) Routine maintenance of isolator. 2) Health check up of CB 402-Q52 by M/S Siemens(OEM) 3) Routine Bay maintenance work. 4) Erection, testing and commissioning of dedicated metering CT and IVT for the metering arrangement for GT-10 bay at 400 kV Koradi II S/s.
KHADKA-AURANGABAD (WALUJ)	IntraState	12/11/2022	21:03		Continued.	HT	H/T DUE TO O/V
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	07/11/2022	10:17			PO	Overhauling of 400kV Circuit Breaker (CGL Make) of 400/220kV, 315 MVA ICT-2 @ Girwali. 400/220kV, 315 MVA ICT-2 @ Girwali will remain charged through TBC
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	09/11/2022	09:12	12/11/2022	16:17	PO	For HV CB Mechanism overhauling work
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	11/11/2022	10:13	11/11/2022	18:09	PO	Differential, HV MV Back Up, REF, NDR Bushing Tan D, LV CT Tan D, SFRA and bay maintenance work
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	12/11/2022	12:05	12/11/2022	22:02	PO	For Overhauling of Bus C 89C Rph, Yph and Bph PG Isolators and Routine Testing and Maintenance Work.
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	11/11/2022	05:17	11/11/2022	09:38	EO	Attending hot spot work at loc. No.82 (B-Ph PGCIL Side Temp-75 °C) & (Y-Ph Nalasopara side Temp-94 °C), Loc No.110 (B-Ph PGCIL Side Temp-119 °C & B-Ph Nalasopara side Temp-124 °C), Loc No.136 (Y-PhTemp96 °C & B-PhTemp-128 °C Both Nalasopara side.
EKLAHARE (OCR) - PADGHE	IntraState	07/11/2022	07:42		Continued.	HT	For Overloading of 220kV Nashik-BBLR Line
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/11/2022	08:24			HT	For Load Management
LAMBOTI - PANDHARPUR	IntraState	09/11/2022	06:34	12/11/2022	21:14	PO	Outage is required for Replacement of old Tower of Loc no. 506 by B+9 mtr due to low ground clearance alongwith allied work.
LAMBOTI - KARKAMB	IntraState	09/11/2022	06:47	12/11/2022	21:28	PO	Replacement of old Tower of Loc no. 506 by B+9 mtr due to low ground clearance alongwith allied work.
HINJEWADI 2 - PEGASUS	IntraState	10/11/2022	10:08	11/11/2022	19:10	PO	CB overhauling work
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/11/2022	07:20	11/11/2022	23:44	HT	For load management
MAHAPE - RELIANCE GIS	IntraState	11/11/2022	08:15	11/11/2022	18:07	PO	Diagnostic testing and bay equipment maintenance work at both end substations.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 12/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
INFOSYS - HINJAWADI 1	IntraState	11/11/2022	08:26	11/11/2022	19:02	PO	Dtd:10.11.2022 1.Cable termination work at MCTT tower- ckt 2 2.Structure erection of LA / BPI at 220kV Infosys S/s ckt 1 Dtd:11.11.2022 1.Cable termination work at MCTT tower- ckt 1 2.Structure erection of LA / BPI at 220kV Infosys S/s ckt 1 3. Stringing from MCTT to Tower no 1 Dtd:12.11.2022 1.Temp Stringing from MDN to GT 2.Removal of conductor from 158 A to 15B 3.Stringing of MCTT to 158 4.Jumper work at MCTT & tower loc no 1
KHAREPATAN -PAWAS LINE	IntraState	11/11/2022	08:49	11/11/2022	16:56	PO	For carrying out tan delta test on line CTs & CRM, CB timing test on CB & bay equipments washing work.
URAN - SEZ JNPT	IntraState	11/11/2022	10:22	11/11/2022	17:53	PO	For Disc Insulator String Replcement work
TALANDGE - BIDRI	IntraState	11/11/2022	10:48	11/11/2022	16:17	PO	Point to point testing of data to SLDC
KOLSHET - KHARBAO	IntraState	11/11/2022	11:09	11/11/2022	14:52	PO	Diagnostic testing work, Isolator maintenance work, Bay maintenance work, Annual relay testing work, CT painting & RMW
LONAND-BARAMATI	IntraState	11/11/2022	11:27	11/11/2022	13:20	PO	Relay testing Work
BUS SECTION - 3 @ TROMBAY	IntraState	11/11/2022	22:06	12/11/2022	07:15	PO	(1) 220 kV BUS PT Diagnostic Testing work. (2) 220KV Mulund line Bus-Isolator spring replacement. (3) TATA Tie-1 line Bus-Isolator clamp replacement by TATA at MSETCL end. (4) BUS SEC -3 TATA CVT (1-Phase) disconnection work by TATA.
KHADKI- CENTURY ENKA	IntraState	12/11/2022	00:38	12/11/2022	01:23	T	EHV metering check CT R Ph burst at Century Enka end
KALWA - SIEMENS	IntraState	12/11/2022	01:19	12/11/2022	04:45	T	Distance Protection
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	12/11/2022	08:15	12/11/2022	23:22	HT	For load management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 12/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
INFOSYS - HINJAWADI 1	IntraState	12/11/2022	08:18	12/11/2022	21:03	PO	Dtd:10.11.2022 1.Cable termination work at MCTT tower- ckt 2 2.Structure erection of LA / BPI at 220kV Infosys S/s ckt 1 Dtd:11.11.2022 1.Cable termination work at MCTT tower- ckt 1 2.Structure erection of LA / BPI at 220kV Infosys S/s ckt 1 3. Stringing from MCTT to Tower no 1 Dtd:12.11.2022 1.Temp Stringing from MDN to GT 2.Removal of conductor from 158 A to 15B 3.Stringing of MCTT to 158 4.Jumper work at MCTT & tower loc no 1
BIDRI - SAWANTWADI	IntraState	12/11/2022	09:01	12/11/2022	12:24	PO	C & Tan-delta testing of Bay HVCT & CRM of CB along with Quarterly maintenance of Bay equipment at Sawantwadi end.
AAREY - AEML BORIVALI	IntraState	12/11/2022	10:19	12/11/2022	16:10	PO	Annul maintenance of CB
TALANDGE - SAWANTWADI	IntraState	12/11/2022	12:30	12/11/2022	14:47	PO	C & Tan-delta testing of Bay HVCT & CRM of CB along with Quarterly maintenance of Bay equipment at Sawantwadi end.
DASTURI-KANDALGAON LINE	IntraState	12/11/2022	12:45	12/11/2022	19:25	PO	Diagnostic testing, Bay maintenance works at 220 kV Kandalgaon SS & Outage tree cutting and other line maintenance work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	11/11/2022	09:20	11/11/2022	16:41	PO	Faulty Insulator String replacement work, found in PID Testing.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 12/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NERAL - AMBERNATH	IntraState	12/11/2022	11:05	12/11/2022	18:15	PO	To Replace Line Circuit Breaker . (Breaker Required to be replaced on Urgent Basis , As SF 6 Gas of own CB Found contaminated.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage