

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Dec/2019 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.575	1378.079	1) Gujrat	4.046	51.677
2) Hydro	15.227	184.598	2) Madhya Pradesh	8.077	108.036
3) Gas	5.845	88.341	3) Chattisgarh	6.230	76.780
Total MSPGCL	172.647	1651.018	4) Maharashtra	119.650	1274.542
B) 1) APLM	74.818	818.134	5) Goa (Amona)	-0.792	-7.788
2) JSWEL	23.132	258.242	Total	137.211	1503.247
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.080	306.615
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	31.670	330.356
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	32.003	333.977
6) Other IPP	13.953	151.908	Include PX	9.817	84.031
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.080	306.615
C) 1) TPCL Thermal	9.567	108.345	Include PX	8.517	110.313
2) TPCL Hydro	6.568	58.192	Standby	0.000	0.000
3) TPCL Gas	2.219	35.066	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.761	118.997	1) MSEDCL	399.217	4245.545
D) STATE			2) Mumbai Discoms	60.785	650.955
1) Thermal	283.806	2833.705	TOTAL STATE	460.002	4896.500
(A1+C1+C4+(B1-B6))					
2) Hydro	21.795	242.790			
(A2+C2)					
3) Gas	8.064	123.407			
(A3+B7+C3)					
4) Wind	3.424	137.527			
6) SOLAR	5.702	55.825			
TOTAL STATE	322.791	3393.254			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6461	6573	6760	5679
MSPGCL Hydro	1246	925	887	143
MSPGCL Gas	277	230	239	238
MSPGCL Total Generation	7984	7728	7886	6060
Central Sector Receipt	6638	6729	5207	4913
WIND	152	164	174	77
CPP / IPP Thermal	4907	4896	4896	4443
CPP / IPP Gas	0	0	0	0
SOLAR	899	845	0	0
Exchange with Mumbai	-1577	-1534	-1458	-1039
MSEDCL DEMAND MET	19003	18828	16705	14454
Load Shedding	0	0	0	0
MSEDCL DEMAND	19003	18828	16705	14454
TPCL GENERATION	1028	1013	994	399
AEML GENERATION	500	500	501	373
MUMBAI DEMAND	3105	3047	2953	1811
STATE DEMAND MET	22108	21875	19658	16265
STATE DEMAND	22108	21875	19658	16265
Frequency (Hz)	49.98	49.95	50.02	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.19 Hz at 06:01 Hrs	49.65 Hz at 16:17 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 11/Dec/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.32	131.51	539	400
Unit 9	12.63	131.18	565	480
Unit 10	12.64	58.98	580	470
Total	36.58	321.67		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.62	75.08	455	355
Unit 5	10.18	86.77	500	355
Total	19.80	161.85		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.54	61.56	250	191
Unit 7	5.46	38.84	249	194
Unit 8	5.49	45.52	250	190
Total	16.49	145.92		
Chandrapur				
Unit 3	4.17	45.93	186	163
Unit 4	3.92	37.10	168	139
Unit 5	8.79	97.00	375	344
Unit 6	10.50	115.94	480	355
Unit 7	0.00	0.00	0	0
Unit 8	10.56	115.19	480	360
Unit 9	10.12	114.62	460	360
Total	48.06	525.78		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	3.76	6.52	170	140
Unit 2	4.18	7.45	190	155
Unit 3	4.22	7.83	200	158
Unit 4	4.37	42.84	200	162
Unit 5	10.11	112.03	495	365
Total	26.63	176.67		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	4.00	46.19	195	73
Total	4.00	46.19		
Uran				
All Units	5.84	88.34	284	227
Total	5.84	88.34		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.09	1.28	36	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.09	1.28		
Koyna				
Stage 1-2	3.96	52.71	380	35
Stage 4	7.28	88.49	753	0
Stage 3	2.48	29.87	240	0
Total	13.72	171.07		
Hydro				
KDPH	0.15	0.15	19	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.40	3.42	80	0
RNGR+BHTSA	0.39	4.06	17	16
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.25	2.78	11	10
GHATGHAR	0.32	3.12	125	0
Total	1.50	13.53		
Wind				
Total	3.42	137.53	0	0
Total	3.42	137.53		
CPP				
APML(Mus)	74.82	818.13	0	0
JSWEL(Mus)	23.13	258.24	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	13.95	151.91	0	0
Total	111.90	1228.28		
SOLAR				
Total	5.70	55.82	0	0
Total	5.70	55.82		
Tata				
Trombay 5	9.57	108.25	477	294
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.22	20.97	65	45
Trombay 7B	1.00	14.09	51	38
Trombay 8	0.00	0.10	0	0
TATA Hydro	6.57	58.19	459	0
Total	18.35	201.60		
AEML				
DTPS U-1&2	10.76	119.00	501	372
Total	10.76	119.00		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	151.58	1378.08	MSPGCL Total	172.65	1651.02
			MSPGCL Thml+Gas	157.42	1466.42	Koyna 1,2 & 4 Total	11.24	141.20
			MSPGCL Hydro	15.23	184.60	State Total	322.79	3393.25

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 11/Dec/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5706	173	227	6106	119	4362	0	0	5243	5177	-1378	14386	0	14386	2160	16546	49.95
2	5660	123	238	6021	128	4389	0	0	5132	5222	-1221	14539	0	14539	1994	16533	49.96
3	5648	68	238	5954	83	4462	0	0	5010	5028	-1111	14416	0	14416	1886	16302	50.00
4	5679	143	238	6060	77	4443	0	0	4954	4913	-1039	14454	0	14454	1811	16265	49.99
5	6088	68	229	6385	82	4477	0	0	5211	5093	-1028	15009	0	15009	1793	16802	50.05
6	6575	217	237	7029	65	4460	0	0	5572	5511	-864	16201	0	16201	1901	18102	50.01
7	6636	879	238	7753	103	4625	0	8	6021	5827	-751	17565	0	17565	2070	19635	49.96
8	6583	1448	228	8259	94	4738	0	100	6019	5830	-760	18261	0	18261	2231	20492	49.95
9	6525	1471	238	8234	102	4773	0	339	6062	6109	-990	18567	0	18567	2516	21083	49.95
10	6472	1282	279	8033	120	4807	0	624	6273	6283	-1281	18586	0	18586	2807	21393	49.92
11	6446	1414	280	8140	103	4818	0	777	6639	6521	-1493	18866	0	18866	3020	21886	49.96
12	6461	1246	277	7984	152	4907	0	899	6951	6638	-1577	19003	0	19003	3105	22108	49.98
13	6573	925	230	7728	164	4896	0	845	6921	6729	-1534	18828	0	18828	3047	21875	49.95
14	6653	574	239	7466	126	4854	0	819	6713	6380	-1605	18040	0	18040	2932	20972	49.94
15	6755	943	238	7936	151	4886	0	638	6760	6815	-1610	18816	0	18816	2961	21777	49.92
16	6725	1036	227	7988	103	4844	0	405	6664	6271	-1484	18127	0	18127	2989	21116	49.85
17	6744	772	239	7755	118	4854	0	220	6431	6207	-1475	17679	0	17679	2970	20649	49.86
18	6754	736	238	7728	119	4871	0	28	5631	5640	-1425	16961	0	16961	2922	19883	50.00
19	6760	887	239	7886	174	4896	0	0	5299	5207	-1458	16705	0	16705	2953	19658	50.02
20	6644	395	227	7266	248	4820	0	0	5208	4995	-1473	15856	0	15856	2840	18696	50.03
21	6215	122	239	6576	244	4723	0	0	5130	5179	-1515	15207	0	15207	2680	17887	49.99
22	5891	80	238	6209	221	4520	0	0	5370	5274	-1534	14690	0	14690	2517	17207	50.08
23	5829	80	260	6169	259	4393	0	0	5335	5209	-1594	14436	0	14436	2404	16840	49.99
24	5553	145	284	5982	269	4085	0	0	5233	5153	-1470	14019	0	14019	2276	16295	49.98
MUs	151.58	15.23	5.84	172.65	3.42	111.90	0.00	5.70	139.78	137.21	-31.67	399.22	0.00	399.22	60.78	460.00	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Dec/2019

Position as on 6.30 Hrs of 12/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
MSPGCL	Nasik Unit 4	210	20/11/2019	04.15		Continued.	ID Fan Problem(Converted for Zero Schedule from 05.00hrs DT. 21-11-2019 and Continued for Annual Overhaul From 01.12.2019	
TPC_G	Trombay 8	250	01/12/2019	00.50		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-4	250	06/12/2019	12.00		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45	12/12/2019	02.38	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00	12/12/2019	00.05	Zero Schedule	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Dec/2019

Position as on 6.30 Hrs of 12/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	30/11/2019	19.14		Continued.	Over Speed Bolt Trip.	
MSPGCL	Uran Unit B0	120	07/12/2019	07:14		Continued.	Gas shortage	
MSPGCL	Uran Unit 7	108	07/12/2019	07:14		Continued.	Gas shortage	
IPP	JSW (J) U1	300	11/12/2019	23.58		Continued.	Governing Valve Rectification Work	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 04.25Hrs DT. 13-12-2019)	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Dec/2019

Statement-VII

Position as on 6.30 Hrs of 12/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 500MVA SPARE ICT UNIT @ AURANGABAD (EKTUNI)	IntraState	12/12/2019	11.36	12/12/2019	23.21	PO	To Remove The bearing Casting Holding of 400KV Isolator of Spare Ict Unit, TO Be Used as Replacement For Damaged For Bearing Casting Holding of Y Ph Isolator Pole of 400KV Taptitanda Ckt 1.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	09/12/2019	19.24	11/12/2019	07.12	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	11/12/2019	19.07	12/12/2019	07.03	HT	Over Voltage
Parli(MS)-Parli (PG) I	InterState	12/12/2019	10.25	12/12/2019	23.29	EO	CT Testing Work.
Dabhol Nagothane I	InterState	12/12/2019	10.43		Continued.	PO	RPH CT Leakage Attend Work. (Replacement of faulty string dt:13/12/2019 at 09:40 hrs.)
Padgha - Boisar (PG)	InterState	12/12/2019	15.37	12/12/2019	20.38	PO	Hot Spot Isolator Attending Work.
Dhule Sar'Sarovar I	InterState	12/12/2019	18.07		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/12/2019	09.54		Continued.	PO	Construction Work
Koradi-Bhusawal	IntraState	04/12/2019	08.41		Continued.	PO	Restranging of Conductor
New Koyna - Dabhol - II	IntraState	11/12/2019	09.14	11/12/2019	20.14	PO	Earth Wire Replacement.
Deepnagar Taptitanda	IntraState	11/12/2019	11.49	11/12/2019	16.13	PO	Replacement of Faulty String & AMC Work.
Deepnagar - Aurangabad	IntraState	12/12/2019	09.21	12/12/2019	15.58	PO	Replacement of Faulty String & AMC Work.
Lonikand2-Lonikand1 (Intrconector)	IntraState	12/12/2019	12.38	12/12/2019	19.10	PO	Half yearly maintenance work
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	10/12/2019	10.27		Continued.	PO	For Replacment Of Y-PH UNIT By Overhauled Unit.
400/220/33kv, 500 Mva Ict-2 @Khaparkheda	IntraState	11/12/2019	09.28	11/12/2019	17.56	PO	Diagnostic Testing and Routine Maintenance Work.
400/132 Kv 200 Mva Ict 2 @Khadka	IntraState	11/12/2019	10.12	11/12/2019	14.32	PO	Online Nitrogen Filling.
400/132 KV 200MVA ICT II @Bhusawal	IntraState	11/12/2019	14.10	11/12/2019	14.35	PO	Refilling of Nitrogen Gas In CTR By Online.
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	11/12/2019	16.15	11/12/2019	23.45	PO	To Attend R Phase CT Oil Leakage.
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	12/12/2019	11.31	12/12/2019	17.42	PO	Diagnostic Testing & Maintenance Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
A'bad(PG)-Shendra Ckt II	InterState	11/12/2019	11.48	11/12/2019	18.10	T	Replacement of U Bolts of Suspension Clamps.
EKLAHARE (OCR) Nasik Navsari II	InterState	12/12/2019	08.48	12/12/2019	18.41	PO	Insulator Replacement Work
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	11/12/2019	09.01	11/12/2019	18.23	T	Replacement of Old Disc Insulators By Procprocelain Long Rod Insulator.
SIEMENS - RELIANCE GIS	IntraState	11/12/2019	09.32	11/12/2019	19.50	PO	Stringing of OPGW Cable.
Mahad - Pedambe	IntraState	11/12/2019	09.35	11/12/2019	19.20	EO	Tree Cutting.
Raymond - TKES	IntraState	11/12/2019	09.42	11/12/2019	19.26	PO	Breaker Work.
Lamboti - Pandharpur li	IntraState	11/12/2019	10.20	11/12/2019	15.55	PO	Replacement of Flash Over Insulator.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 11/Dec/2019

Statement-VII

Position as on 6.30 Hrs of 12/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kharghar-Borivali ckt II	IntraState	11/12/2019	10.39	11/12/2019	19.14	PO	Stringing of OPGW Cable.
K'Kheda- Suryalakshmi	IntraState	11/12/2019	11.42	11/12/2019	15.28	PO	CT, CVT Capacitance & Tan Delta Measurement & Routine Bay Maintenance Work.
Kandalgaon - Sona Alloys	IntraState	11/12/2019	12.35	11/12/2019	13.00	T	Distance Protection
Lonikand-II- Kathapur	IntraState	11/12/2019	12.50	11/12/2019	19.01	T	Distance Protection
Bapgaon - Kalwa	IntraState	11/12/2019	15.56	11/12/2019	19.29	PO	Replacement of Earthwire With OPGW Wire.
Pophali - Pedambe II	IntraState	11/12/2019	22.25	12/12/2019	01.55	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Pophali - Nerale	IntraState	11/12/2019	22.40	12/12/2019	02.35	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Pophali - New Koyna	IntraState	11/12/2019	22.45	12/12/2019	02.27	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Bus Section II @ Pophali	IntraState	11/12/2019	23.00	12/12/2019	02.00	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Siemens - Mahape	IntraState	12/12/2019	08.30	12/12/2019	12.39	PO	As The Clipping of OPGW Cable at LOC No. Lilo 1 Get Slips.
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	12/12/2019	08.48	12/12/2019	18.41	PO	Replacement of Old Disc Insulator By Procprocelain Long Rod Insulator.
Chandrapur GCR - Warora - I	IntraState	12/12/2019	09.27	12/12/2019	09.35	PO	In View of Ict 2 Outage.
Miraj - Mhaishal	IntraState	12/12/2019	09.30	12/12/2019	14.15	PO	String Replacement Work at Loc No. 35 of TPH.
Phursungi-Parvati	IntraState	12/12/2019	09.36	12/12/2019	16.38	PO	Half yearly maintenance work
Talandge(400)- Mudshingi 2 Line	IntraState	12/12/2019	10.01	12/12/2019	13.08	PO	Relay Testing Work & Annual Maintenance Work.
Jamde-Dondaicha 2	IntraState	12/12/2019	11.05	12/12/2019	13.34	PO	Replacement of Autoreclose Relay Work.
Nanded-Parbhani	IntraState	12/12/2019	11.44	12/12/2019	17.26	HT	Outage On Nanded - Nanded Ckt 2.
Nagothane - ACCIL	IntraState	12/12/2019	11.55	12/12/2019	17.20	PO	Tree Cutting.
Nanded-Nanded(Waghale) II	IntraState	12/12/2019	12.25	12/12/2019	15.12	PO	Diagnostic Testing Work.
Trombay - Mulund	IntraState	12/12/2019	14.44	12/12/2019	16.46	EO	Attending Hot Spot
Nanded-Nanded(Waghale) I	IntraState	12/12/2019	15.23	12/12/2019	17.18	PO	Diagnostic Testing Work.
Kandalgaon - ONGC Panvel	IntraState	12/12/2019	16.20	12/12/2019	18.55	PO	Distance Protection
220 KV ICT Outages/Trippings							
220/22 Kv 50mva Telk Ptr No 2 @Chinchwad	IntraState	11/12/2019	05.52	11/12/2019	10.20	T	Differential protection
220/132 kV 200MVA ICT II @ Girwali	IntraState	11/12/2019	10.02	11/12/2019	11.24	PO	HV CT Hot Spot Attending Work And Bay Maintenance Work.
220/132 Kv 200 Mva Emco Ict 2 @Ambazari	IntraState	11/12/2019	10.12	11/12/2019	17.19	PO	CTR Trail.
220/132 Kv 200 Mva Bbl Ict 1 @Kalmeshwar	IntraState	11/12/2019	10.33	11/12/2019	17.02	PO	Tan Delta Measurment of CTs
220/132 Kv 200 Mva Vijai Ict 1 @Ranjangaon	IntraState	12/12/2019	00.43	12/12/2019	19.45	PO	Repare of OLTC Tap Changer.
220/132 Kv 200 MVA ICT III @Ambazari	IntraState	12/12/2019	10.08	12/12/2019	17.48	PO	CTR Trial.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage