

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 11/Dec/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	142.753	1603.956	1) Gujrat	-5.546	-62.566
2) Hydro	5.577	118.544	2) Madhya Pradesh	0.541	11.075
3) Gas	3.354	57.408	3) Chattisgarh	5.570	60.000
Total MSPGCL	151.684	1779.908	4) Maharashtra	167.348	1802.122
B) 1) APLM	58.444	787.688	5) Goa (Amona)	-0.873	-14.550
2) JSWEL	13.698	136.153	Total	167.040	1796.081
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.755	297.227
4) RPL(AMT)	25.440	303.237	b) Mumbai Drawl	27.150	347.619
5) SWPGPL	8.454	84.676	c) MSEDCL Bilateral *	83.017	765.236
6) Other IPP	42.126	488.265	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.755	297.227
C) 1) TPCL Thermal	9.902	122.516	Include PX	0.000	0.000
2) TPCL Hydro	1.488	36.822	Standby	0.000	0.000
3) TPCL Gas	1.906	19.554	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.132	107.201	1) MSEDCL	456.002	5159.618
D) STATE			2) Mumbai Discoms	48.578	633.710
1) Thermal	308.949	3633.692	3) Other Discoms	8.775	102.590
(A1+C1+C4+(B1-B6))			TOTAL STATE	513.355	5895.918
2) Hydro	7.065	155.366			
(A2+C2)					
3) Gas	5.260	76.962			
(A3+B7+C3)					
4) Wind	15.587	114.937			
6) SOLAR	9.454	118.882			
TOTAL STATE	346.315	4099.839			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6380	6281	6375	5383
MSPGCL Hydro	700	260	255	79
MSPGCL Gas	139	136	137	140
MSPGCL Total Generation	7219	6677	6767	5602
Central Sector Receipt	8584	8399	7274	5523
WIND	834	576	280	630
CPP / IPP Thermal	6386	6331	6320	5760
CPP / IPP Gas	0	0	0	0
SOLAR	1460	1483	2	0
Exchange with Mumbai	-1168	-1246	-1321	-1174
MSEDCL DEMAND MET	22930	21860	18905	15978
Load Shedding	0	0	0	0
MSEDCL DEMAND	22930	21860	18905	15978
TPCL GENERATION	533	541	652	555
AEML GENERATION	493	480	300	297
MUMBAI DEMAND	2194	2267	2273	2026
OTHER DISCOM DEMAND	385	360	417	363
STATE DEMAND MET	25509	24487	21595	18367
STATE DEMAND	25509	24487	21595	18367
Frequency (Hz)	50.07	50.03	50.08	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 11.24 Hrs	49.51 Hz at 07.35 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 11/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.87	55.40	215	190
Unit 7	0.00	0.00	0	0
Unit 8	9.91	139.44	468	372
Unit 9	12.16	144.82	570	450
Unit 10	11.90	142.75	562	438
Total	38.84	482.40		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.73	106.34	475	275
Unit 5	9.92	109.58	480	280
Total	19.65	215.91		
Parli				
Unit 6	4.08	46.04	220	145
Unit 7	4.13	47.68	234	140
Unit 8	3.66	32.08	167	144
Total	11.88	125.80		
Chandrapur				
Unit 3	3.44	37.75	165	122
Unit 4	2.98	34.41	145	115
Unit 5	7.05	74.93	310	280
Unit 6	7.26	74.60	365	280
Unit 7	0.00	0.00	0	0
Unit 8	9.51	68.14	477	284
Unit 9	9.85	108.97	500	283
Total	40.10	398.81		
Paras				
Unit 3	0.00	44.26	0	0
Unit 4	5.12	56.08	236	190
Total	5.12	100.34		
Khaparkheda				
Unit 1	2.28	30.35	110	80
Unit 2	2.32	30.26	110	75
Unit 3	3.74	40.20	180	127
Unit 4	2.99	36.16	132	117
Unit 5	9.47	76.28	450	280
Total	20.82	213.26		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.28	34.17	167	116
Unit 5	3.06	9.95	153	111
Total	6.34	67.43		
Uran				
All Units	3.35	57.41	146	135
Total	3.35	57.41		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.08	1.34	22	0
Total	0.08	1.34		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.65	33.60	395	40
Stage 4	1.41	33.44	411	0
Stage 3	0.67	14.41	160	0
Total	3.73	81.46		
Hydro				
KDPH	0.00	4.07	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.52	5.63	58	0
BHIRA T.R.	0.12	2.22	40	0
SMLHY_PTN	0.97	19.26	43	37
GHATGHAR	0.15	4.57	77	0
Total	1.76	35.74		
Wind				
Total	15.59	114.94	0	0
Total	15.59	114.94		
CPP				
APML(Mus)	58.44	787.69	0	0
JSWEL(Mus)	13.70	136.15	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.44	303.24	0	0
SWPGPL-Mus	8.45	84.68	0	0
Other(Mus)	42.13	488.26	0	0
Total	148.16	1800.02		
SOLAR				
Total	9.45	118.88	0	0
Total	9.45	118.88		
Tata				
Trombay 5	6.73	82.74	378	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.02	10.61	49	39
Trombay 7B	0.88	8.94	41	34
TATA Hydro	1.49	36.82	167	9
Trombay 8	3.18	39.77	137	131
Total	13.30	178.89		
AEML				
DTPS U-1&2	8.13	107.20	497	291
Total	8.13	107.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	142.75	1603.96	MSPGCL Total	151.68	1779.91
			MSPGCL Thml+Gas	146.11	1661.36	Koyna 1,2 & 4 Total	3.06	67.04
			MSPGCL Hydro	5.58	118.54	State Total	346.32	4099.84

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 11/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5128	77	144	5349	1027	5806	0	0	5977	5637	-1089	16376	0	16376	1919	354	18649	49.99
2	5167	81	145	5393	1007	5802	0	0	6068	5797	-997	16681	0	16681	1801	321	18803	49.98
3	5253	80	145	5478	1045	5739	0	0	6024	5725	-918	16770	0	16770	1704	299	18773	50.00
4	5268	82	146	5496	1073	5775	0	0	5961	5833	-857	17023	0	17023	1652	297	18972	49.98
5	5423	83	144	5650	1032	6078	0	0	5880	6020	-843	17629	0	17629	1639	308	19576	49.95
6	5874	82	144	6100	975	6325	0	0	5911	6012	-881	18200	0	18200	1709	331	20240	49.99
7	6226	87	142	6455	839	6364	0	8	6644	6380	-922	18771	0	18771	1755	353	20879	50.05
8	6004	354	143	6501	810	6432	0	141	7127	6899	-940	19456	0	19456	1815	387	21658	49.76
9	6212	884	142	7238	742	6455	0	531	6978	7078	-1003	20655	0	20655	1971	386	23012	49.86
10	6371	720	141	7232	765	6403	0	1040	7522	7657	-1022	21697	0	21697	2134	378	24209	49.93
11	6380	700	139	7219	834	6386	0	1460	8513	8584	-1168	22930	0	22930	2194	385	25509	50.07
12	6290	490	136	6916	709	6320	0	1510	8612	8700	-1252	22522	0	22522	2277	381	25180	50.10
13	6281	260	136	6677	576	6331	0	1483	8296	8399	-1246	21860	0	21860	2267	360	24487	50.03
14	6298	225	137	6660	404	6274	0	1357	8145	8474	-1334	21502	0	21502	2185	333	24020	50.07
15	6397	147	136	6680	274	6314	0	949	8529	8955	-1331	21473	0	21473	2150	368	23991	50.12
16	6505	139	135	6779	261	6332	0	667	8668	8690	-1253	21098	0	21098	2112	378	23588	50.06
17	6493	139	135	6767	239	6300	0	246	8211	7960	-1169	19956	0	19956	2093	387	22436	49.94
18	6359	157	137	6653	273	6355	0	60	7383	7463	-1255	19152	0	19152	2109	397	21658	49.98
19	6375	255	137	6767	280	6320	0	2	7246	7274	-1321	18905	0	18905	2273	417	21595	50.08
20	6418	218	138	6774	364	6307	0	0	6603	6265	-1315	17983	0	17983	2271	412	20666	50.01
21	5816	79	137	6032	391	6277	0	0	6064	5865	-1347	16820	0	16820	2239	398	19457	49.96
22	5485	80	136	5701	483	5938	0	0	5797	5916	-1281	16354	0	16354	2183	403	18940	49.99
23	5347	79	139	5565	554	5769	0	0	6046	5934	-1232	16209	0	16209	2100	381	18690	50.06
24	5383	79	140	5602	630	5760	0	0	5877	5523	-1174	15978	0	15978	2026	363	18367	50.03
MUs	142.75	5.58	3.35	151.68	15.59	148.16	0.00	9.45	168.08	167.04	-27.15	456.00	0.00	456.00	48.58	8.77	513.36	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 11/Dec/2022

Position as on 6.30 Hrs of 12/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	JSW (J) U2	300	10/12/2022	15:51		Continued.	NO SCHEDULE	
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	13/12/2022
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
IPP	RPL(AMT) U-3	270	05/12/2022	12:00		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage	12/12/2022
MSPGCL	Paras Unit 3	250	09/12/2022	18:28	12/12/2022	15:03	Boiler Tube Leakage	13/12/2022
MSPGCL	Uran Unit 6	108	10/12/2022	18:00		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 12/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	11/12/2022	22:01	12/12/2022	15:57	T	Tripped on distance protection
DHULE - SSNNL CKT - 1	InterState	12/12/2022	09:31	12/12/2022	18:52	PO	Maintenance work. Auto reclose of 400 kv SSP - Dhule 2 will remain out
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/12/2022	08:48			PO	For attending SF6 gas leakage
NAGOTHANE - DABHOL CKT - 1	IntraState	10/12/2022	11:32	11/12/2022	08:55	PO	Cold washing work
KHADKA-AURANGABAD (WALUJ)	IntraState	10/12/2022	22:06	11/12/2022	08:08	HT	For voltage management
JAIGAD - KARAD CKT - 2	IntraState	12/12/2022	01:17	12/12/2022	09:19	HT	Overvoltage
NAGOTHANE - DABHOL CKT - 1	IntraState	12/12/2022	13:30			PO	Dignostic testing work and Earthwire restringing work
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	03/12/2022	09:20			PO	FOR CB replacemnt work
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	10/12/2022	11:02			EO	Due to LV 220 kv CB problem bay needs to be shifted into TBC
400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	IntraState	12/12/2022	09:25	12/12/2022	19:59	PO	Replacement of faulty disc observed in PID
400/11.5kv STATION TRANSFORMER - 4 @ TIRORA	IntraState	12/12/2022	09:53			PO	For bay equipment maintenance and testing work
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	12/12/2022	10:50	12/12/2022	17:15	PO	(1) IV breaker & CTs testing work. (2) Bay maintenance work.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	12/12/2022	12:33			PO	1) 29A & 29B Isolator Bus Jumpers removing and reconnecting work by Hot Line Team.2) 29A & 29B Isolator Overhauling & alignment work. 3)440/220/33kv 501 MVA ICT-III IV Bay will be charged through TBC.
220 KV TBC Outages/Trippings							
TBC @ NAGOTHANE	IntraState	12/12/2022	09:50			PO	POST MANSOON MAINTENANCE WORK
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ RANJANGAON	IntraState	10/12/2022	11:18	11/12/2022	16:10	PO	220kv CB Mechanism Overhauling work & other General Bay Maintenance work.
TBC @ RANJANGAON	IntraState	12/12/2022	10:03		Continued.	PO	220kv CB Mechanism Overhauling work & Repairs & maintenance of Isolators & Dignostic testing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 12/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS @ EKLAHARE OCR	IntraState	12/12/2022	13:12	12/12/2022	18:22	PO	220KV Busbar Relay Testing work in view of the occurrence on dtd.05.12.2022 outage on main bus is not required, Bus bar protection will be out of service
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	10/12/2022	23:02	11/12/2022	04:39	EO	Attending hot spot work at loc. No.108 (Y-Ph Nalasopara Side Temp-77 ºC), & Loc No.132 (B-Ph Nalasopara side Temp-74 ºC), 156(R-Ph PGCIL Side Temp-101 ºC), 102 (Y-Ph PGCIL Side Temp-74 ºC, R-Ph Nalasopara Side Temp-72 ºC & B-Ph Nalasopara Side Temp-78 ºC)
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KALWA SALSETTE - 3	IntraState	01/12/2022	22:23			EO	Interchanging of BUS of 220KV Kalwa-Salshette-3 & 220KV Kalwa-Salshette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.
KALWA SALSETTE - 4	IntraState	01/12/2022	22:42			EO	Interchanging of BUS of 220 kV Kalwa-Salsette-3 & 220 kV Kalwa-Salsette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.
PADGHE - NALASOPARA - VASAI (T)	IntraState	10/12/2022	05:21			PO	Work of bunching, removing jumper & changing oreintation of lines for backup supply to Vasai Ss & Nalasopara S/stn:1) 220kV Kamba-Vasai line jumper will be open at loc. No. 51 for 7 days continuous i.e. 159 Hrs.2) 220kV Padgha-Nalasopara º Vasai Tap line-Jumper will open at loc. 54 for 7 days continuous & 220kV Vasai-Nalasopara link line will be in service for 7 days.3) 220kV Padghe º Nalasopara-Vasai Tap line bunching work will be done to 220kV Kamba-Vasai line between loc. No. 51 & 52 after that line orientation will be change i.e. 220kV Padghe-Vasai line and after that load of 220kV Vasai will be feed from 400/220 Padghe s/stn.4) After bunching 220kV Padghe-Vasai line will be charged at 9:00 Hrs. on same day dtd. 10.12.2022. The line will be in service for 07 days continuous i.e. 159 Hrs.5) Erection of MDN+9 Tower (2 nos.)6) Stringing of conductor of one side ckt.
POPHALI - KDPH	IntraState	10/12/2022	10:20			PO	For erection & stringing of In-line Multi circuit tower (Loc No.1to7) of new 220KV Karad-Koyana line and restringing of existing 220KV D/C KDPH LILO line.
VANKUSWADE - KDPH	IntraState	10/12/2022	11:00			PO	For erection & Stringing of In line multi circuit tower (Loc no.01 to 07) of new 220kV Karad-Koyana line and re stringing of existing 220kV D/C KDPH LILO line.
BORIVALI - BOISAR II LINE	IntraState	10/12/2022	15:26	11/12/2022	01:19	T	Tripped on Phase to Phase fault

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 11/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 12/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NEW KOYNA - NIWALI	IntraState	10/12/2022	17:48	11/12/2022	01:05	T	Tripped on distance protection
PHURSUNGI-PARVATI	IntraState	11/12/2022	04:57	11/12/2022	06:40	T	BUSBAR operated due to bursting of R ph 220KV PT of 220KV Main Bus-2 at Phursungi s/s
THEUR-PHURSUNGI CKT II	IntraState	11/12/2022	04:57	11/12/2022	05:13	T	BUSBAR operated due to bursting of R ph 220KV PT of 220KV Main Bus-2 at Phursungi s/s
JEJURI-PHURSUNGI 1	IntraState	11/12/2022	04:57	11/12/2022	06:10	T	BUSBAR operated due to bursting of R ph 220KV PT of 220KV Main Bus-2 at Phursungi s/s
JEJURI-PHURSUNGI 2	IntraState	11/12/2022	04:57	11/12/2022	07:25	T	BUSBAR operated due to bursting of R ph 220KV PT of 220KV Main Bus-2 at Phursungi s/s
THEUR-PHURSUNGI CKT I	IntraState	11/12/2022	04:57	11/12/2022	05:14	T	BUSBAR operated due to bursting of R ph 220KV PT of 220KV Main Bus-2 at Phursungi s/s
PHURSUNGI-SERUM	IntraState	11/12/2022	04:57	11/12/2022	05:11	T	BUSBAR operated due to bursting of R ph 220KV PT of 220KV Main Bus-2 at Phursungi s/s
KAMBA - VASAI	IntraState	11/12/2022	05:19			PO	Work of bunching, removing jumper & changing orientation of lines for backup supply to Vasai Ss & Nalasopara S/stn:1) 220kV Kamba-Vasai line jumper will be open at loc. No. 51 for 7 days continuous i.e. 159 Hrs. From Loc no. 52 to 220KV Vasai S/sstn will be converted to 220KV Padgha-Vasai after bunching and same will be charged at 08:00 Hrs on 11.12.2022 (Temporary arrangement till 17.12.2022. 2) 220kV Padgha-Nalasopara & Vasai Tap line-Jumper is already opened at loc. 54 for 7 days continuous & 220kV Vasai-Nalasopara link line is established 7 days. 3) 220kV Padghe - Nalasopara-Vasai Tap line bunching work will be done to 220kV Kamba-Vasai line between loc. No. 51 & 52 after that line orientation will be change i.e. 220kV Padghe-Vasai line and after that load of 220kV Vasai will be feed from 400/220 Padghe s/stn. 4) After bunching 220kV Padghe-Vasai line will be charged at 8:00 Hrs. on same day dtd. 11.12.2022. The line will be in service for 07 days continuous i.e. 159 Hrs. 5) Erection of MDN+9 Tower (2 nos.) 6) Stringing of conductor of one side ckt.
WAGHIVALI - DHARAVI 7	IntraState	11/12/2022	09:30	11/12/2022	17:33	PO	Mero Project Work-Work in vicinity for removal of old OPGW in span 38A to 40 at Kurla Metro 2B site.
CHAKAN (400KV) - VOLKSWAGEN	IntraState	11/12/2022	10:11	11/12/2022	20:19	HT	Emergency outage availed for SCADA trial and commissioning work.
SALSETTE - SAKI -7	IntraState	11/12/2022	10:58	11/12/2022	13:30	PO	LBBU relay testing, Protection trials and CR trials
WARDHA (PG) - BADNERA	IntraState	12/12/2022	08:44			PO	For Replacement of Flashover Disc
TALANDGE - MUDSHINGI CKT - 1	IntraState	12/12/2022	09:10	12/12/2022	17:19	HT	H/T For load Management.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 11/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 12/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - MUDSHINGI CKT - 2	IntraState	12/12/2022	09:10			HT	H/T for Load management.
KALWA - MULUND 1	IntraState	12/12/2022	09:18			PO	For Main CB pole Overhauling work after shifting the line on TBC.
NERLE- POPHALI	IntraState	12/12/2022	09:51	12/12/2022	15:22	T	Distance Protection
TALANDGE - BIDRI	IntraState	12/12/2022	10:40	12/12/2022	17:04	PO	QMW
HALKARNI - TILARI LINE	IntraState	12/12/2022	12:22	12/12/2022	16:35		Attending SF6 Gas leakage
EKLAHARE (OCR) - PADGHE	IntraState	12/12/2022	14:22	12/12/2022	21:23	HT	HT for Load Management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	12/12/2022	16:10	12/12/2022	19:40	HT	HT for Load Management
220 KV ICT Outages/Tripping							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 25 MVA PTR 1 @ WASHALA	IntraState	12/12/2022	09:25	12/12/2022	15:50	PO	Oil leakage attending work
220/33 KV 50 MVA PTR - 7 @ WATHAR	IntraState	12/12/2022	09:30	12/12/2022	16:55	PO	Diagonstic testing work& Quarterly maint work.
220/33 kv 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	12/12/2022	10:05	12/12/2022	16:35	PO	1) For Atttneding oil lekage in LV Bph Bushing 2) Quarterly maintenance work.
220 KV BUSBAR Outages/Tripping							
MAIN BUS - 1 @ VILEBHAGAD	IntraState	12/12/2022	11:50	12/12/2022	17:10	PO	Main bus isolator maintenance work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage