

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Jan/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	153.590	1696.867	1) Gujrat	-4.946	-60.164
2) Hydro	11.929	180.819	2) Madhya Pradesh	2.665	46.822
3) Gas	5.324	53.264	3) Chattisgarh	5.460	72.690
Total MSPGCL	170.843	1930.950	4) Maharashtra	170.952	2151.532
B) 1) APLM	57.100	618.207	5) Goa (Amona)	-1.194	-20.103
2) JSWEL	19.255	235.917	Total	172.937	2190.777
3) VIPL	0.000	0.000	a) Mumbai Schedule	21.477	269.412
4) RPL(AMT)	27.762	247.518	b) Mumbai Drawl	26.465	317.343
5) SWPGPL	6.899	93.185	c) MSEDCL Bilateral *	58.883	889.135
6) Other IPP	48.306	559.461	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	21.477	269.412
C) 1) TPCL Thermal	12.285	138.254	Include PX	0.000	0.000
2) TPCL Hydro	3.777	42.851	Standby	0.000	0.000
3) TPCL Gas	2.646	30.947	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.093	106.855	1) MSEDCL	485.714	5688.646
D) STATE			2) Mumbai Discoms	54.265	636.249
1) Thermal	334.290	3696.264	3) Other Discoms	9.611	115.547
(A1+C1+C4+(B1-B6))			TOTAL STATE	549.590	6440.442
2) Hydro	15.706	223.670			
(A2+C2)					
3) Gas	7.970	84.211			
(A3+B7+C3)					
4) Wind	4.786	100.423			
6) SOLAR	13.902	145.098			
TOTAL STATE	376.654	4249.666			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6719	6830	6773	5520
MSPGCL Hydro	1622	126	1035	90
MSPGCL Gas	144	139	235	248
MSPGCL Total Generation	8485	7095	8043	5858
Central Sector Receipt	8381	8513	6356	6553
WIND	98	99	267	252
CPP / IPP Thermal	7236	6812	6932	5773
CPP / IPP Gas	0	0	0	0
SOLAR	1793	2059	0	0
Exchange with Mumbai	-1264	-1437	-1101	-945
MSEDCL DEMAND MET	24298	22690	20061	17122
Load Shedding	0	0	0	0
MSEDCL DEMAND	24298	22690	20061	17122
TPCL GENERATION	959	770	1222	504
AEML GENERATION	499	490	469	318
MUMBAI DEMAND	2722	2697	2792	1767
OTHER DISCOM DEMAND	431	451	436	369
STATE DEMAND MET	27451	25838	23289	19258
STATE DEMAND	27451	25838	23289	19258
Frequency (Hz)	50.00	50.05	50.02	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.36 Hz at 17:04 Hrs	49.69 Hz at 09:15 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.14	57.96	195	95
Unit 7	0.00	0.00	0	0
Unit 8	13.26	159.52	620	502
Unit 9	12.43	58.18	585	465
Unit 10	12.51	152.31	600	392
Total	42.34	427.97		
Bhusawal				
Unit 3	3.42	13.04	165	105
Unit 4	10.62	123.28	495	290
Unit 5	5.24	79.82	495	0
Total	19.29	216.14		
Parli				
Unit 6	4.65	52.48	239	152
Unit 7	0.00	13.70	0	0
Unit 8	4.18	46.82	205	139
Total	8.83	113.00		
Chandrapur				
Unit 3	3.51	40.32	157	125
Unit 4	3.23	25.48	144	120
Unit 5	7.14	74.01	320	284
Unit 6	8.15	103.14	405	286
Unit 7	0.00	0.00	0	0
Unit 8	11.01	129.19	496	337
Unit 9	11.10	130.50	500	331
Total	44.14	502.63		
Paras				
Unit 3	5.26	58.54	236	187
Unit 4	5.36	42.77	237	202
Total	10.62	101.32		
Khaparkheda				
Unit 1	3.07	31.67	140	115
Unit 2	3.14	31.42	144	116
Unit 3	3.89	40.37	180	130
Unit 4	3.05	33.80	149	115
Unit 5	8.36	119.10	445	280
Total	21.51	256.36		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.42	40.41	164	120
Unit 5	3.44	39.05	170	110
Total	6.86	79.46		
Uran				
All Units	5.32	53.26	252	137
Total	5.32	53.26		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.25	4.88	46	0
Total	0.25	4.88		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.64	54.80	475	40
Stage 4	4.17	61.74	751	0
Stage 3	1.53	25.00	262	0
Total	9.34	141.53		
Hydro				
KDPH	0.00	3.13	0	0
VTRNA	0.00	0.04	0	0
TILLARI	0.00	4.41	0	0
BHIRA T.R.	0.24	2.56	80	0
SMLHY_PTN	1.24	16.54	53	49
GHATGHAR	0.86	7.73	125	0
Total	2.34	34.41		
Wind				
Total	4.79	100.42	0	0
Total	4.79	100.42		
CPP				
APML(Mus)	57.10	618.21	0	0
JSWEL(Mus)	19.26	235.92	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	27.76	247.52	0	0
SWPGPL-Mus	6.90	93.18	0	0
Other(Mus)	48.31	559.46	0	0
Total	159.32	1754.29		
SOLAR				
Total	13.90	145.10	0	0
Total	13.90	145.10		
Tata				
Trombay 5	8.06	91.52	469	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.52	17.71	108	44
Trombay 7B	1.13	13.24	65	38
TATA Hydro	3.78	42.85	388	7
Trombay 8	4.22	46.74	241	129
Total	18.71	212.05		
AEML				
DTPS U-1&2	9.09	106.86	499	288
Total	9.09	106.86		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	153.59	1696.87	MSPGCL Total	170.84	1930.95
			MSPGCL Thml+Gas	158.91	1750.13	Koyna 1,2 & 4 Total	7.81	116.53
			MSPGCL Hydro	11.93	180.82	State Total	376.65	4249.67

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 12/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5520	90	248	5858	252	5773	0	0	6533	6553	-945	17122	0	17122	1767	369	19258	49.98
2	5569	95	248	5912	231	5758	0	0	6647	6839	-813	17583	0	17583	1629	344	19556	50.01
3	5596	89	248	5933	206	5837	0	0	6714	6712	-727	17639	0	17639	1547	322	19508	50.00
4	5567	90	249	5906	168	5822	0	0	6809	7023	-678	17928	0	17928	1499	313	19740	49.99
5	5796	90	248	6134	196	5867	0	0	7018	7273	-698	18443	0	18443	1520	329	20292	50.02
6	6377	97	250	6724	179	6451	0	0	6940	7044	-832	19218	0	19218	1656	348	21222	49.97
7	6586	472	249	7307	192	7390	0	1	6229	6668	-872	20292	0	20292	1886	394	22572	49.90
8	6512	1522	252	8286	175	7470	0	168	6202	6999	-874	21812	0	21812	2137	412	24361	49.94
9	6573	1515	246	8334	121	7470	0	742	6521	7347	-948	22630	0	22630	2383	436	25449	50.02
10	6620	1424	237	8281	74	7476	0	1338	7364	7707	-1149	23295	0	23295	2570	432	26297	49.91
11	6719	1622	144	8485	98	7236	0	1793	7974	8381	-1264	24298	0	24298	2722	431	27451	50.00
12	6795	924	137	7856	95	6876	0	1964	8395	8698	-1344	23713	0	23713	2740	432	26885	49.98
13	6830	126	139	7095	99	6812	0	2059	8648	8513	-1437	22690	0	22690	2697	451	25838	50.05
14	6701	93	139	6933	168	6660	0	1956	8544	8538	-1587	22253	0	22253	2548	415	25216	50.14
15	6660	102	176	6938	225	6380	0	1745	8750	8968	-1649	22200	0	22200	2572	407	25179	50.05
16	6873	238	233	7344	279	6803	0	1294	8162	8215	-1526	21988	0	21988	2590	421	24999	50.01
17	6837	356	226	7419	247	7115	0	702	7269	7065	-1235	20878	0	20878	2597	435	23910	49.96
18	6774	362	233	7369	313	7041	0	140	6417	6641	-1096	19963	0	19963	2759	445	23167	50.06
19	6773	1035	235	8043	267	6932	0	0	6157	6356	-1101	20061	0	20061	2792	436	23289	50.02
20	6720	1118	229	8067	273	7041	0	0	6038	6121	-1086	19975	0	19975	2783	441	23199	50.03
21	6659	136	232	7027	243	6952	0	0	5830	5962	-1027	18731	0	18731	2645	426	21802	50.02
22	6374	92	242	6708	194	6412	0	0	6349	6213	-1181	17937	0	17937	2230	409	20576	50.03
23	6178	120	241	6539	227	5998	0	0	6621	6606	-1278	17701	0	17701	2067	391	20159	50.04
24	5981	121	243	6345	264	5750	0	0	6603	6495	-1118	17363	0	17363	1930	373	19666	50.02
MUs	153.59	11.93	5.32	170.84	4.79	159.32	0.00	13.90	168.73	172.94	-26.47	485.71	0.00	485.71	54.27	9.61	549.59	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jan/2023

Position as on 6.30 Hrs of 13/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
IPP	JSW (J) U4	300	04/01/2023	23:45		Continued.	NO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	13/01/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	13/01/2023
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
IPP	RPL(AMT) U-3	270	25/12/2022	17:45	12/01/2023	12:07	Bottom Ash evacuation problem	13/01/2023
IPP	SWPGPL U-4	135	28/12/2022	00:00	13/01/2023	03:22	BOTTOM ASH EVACUATION PROBLEM	13/01/2023
MSPGCL	Bhusawal Unit 5	500	08/01/2023	19:14	12/01/2023	09:44	Boiler Tube Leakage	13/01/2023
MSPGCL	Uran Unit 6	108	12/01/2023	09:55	12/01/2023	14:00	Due To I & C Problem.	
IPP	Adani U-1	660	12/01/2023	11:02		Continued.	APH-B Hot PA below leakage.	
MSPGCL	Nasik Unit 5	210	13/01/2023	05:55		Continued.	Low Vacuum	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	IntraState	12/01/2023	10:16	12/01/2023	18:22	PO	OEM Inspection of CB
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	11/01/2023	22:58	12/01/2023	06:26	EO	Cold line washing of insulator strings at tower Loc.No. 1095, 1096, 1097,1106, 1107, 1111, 1248, 1270,1307, 1315, 1316, 1317 under Aurangabad Subdivision and at tower Loc.No. 796, 759, 842, 863, 903, 993, 961, 985, 990, 1023, 1022 under Jintur Subdivision
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BUS - 2 @ CHANDRAPUR SWITCHING SS	IntraState	12/01/2023	10:39	12/01/2023	15:03	PO	Diagnostic testing and allied bay maintenance work
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHADKA - BABLESHWAR	IntraState	12/01/2023	08:06	12/01/2023	19:52	PO	Chemical Cleaning of Insulator string and Routine Line maintenance work
DABHOL - NEW KOYNA CKT - 1	IntraState	12/01/2023	09:36	12/01/2023	22:52	PO	Replacement of Surge Arrestor for all the three poles
BUS COUPLER @ KALWA	IntraState	12/01/2023	12:18	12/01/2023	23:03	EO	Heavy Sparking observed in B ph B bus isolator and hence its scissor replacement work. Hanger assembly replacement work by hotline unit
KHADKA - BABLESHWAR	IntraState	13/01/2023	08:01			PO	Chemical Cleaning of Insulator string and Routine Line maintenance work
400 KV ICT Outages/Trippings							
400/220/33KV SPARE ICT @ KORADI 2	IntraState	27/12/2022	09:20		Continued.	PO	SFRA , DFRA test & tan delta measurement - spare ICT.
400kv Stn. TF No 3 @ C'pur GCR	IntraState	12/01/2023	14:10			EO	To attend the closing problem of Y-ph PG-3 Isolator (Aux. Bus Isolator)On dt.- 12/01/2023 at 10:00Hrs, during Isolator operation closing problem of Y-ph PG-3 isolator (Aux. Bus Isolator) is observed and hence, not closing properly. It is very necessary to attend the same on top priority.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	12/01/2023	14:21	12/01/2023	21:47	PO	Annual testing & maintenance work
220 KV TIEBAY Outages/Trippings							
MAIN BUS SECTIONALIZER -2 @ GHODBUNDER (GIS)	IntraState	12/01/2023	09:02	12/01/2023	17:17	EO	Facilitating outage of 220kV GIS Main Bus 2 for attending abnormal Sound from CT Chamber of 220kV GIS Switchgear
220 KV TBC Outages/Trippings							
GIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	12/01/2023	09:02	12/01/2023	17:17	EO	Attending abnormal sound from CT chamber of 220kV GIS Switchgear
TBC @ AAREY	IntraState	12/01/2023	09:27	12/01/2023	16:29	PO	Annual Maintenance of Bay Equipments.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
POPHALI - KDPH	IntraState	07/01/2023	10:32			PO	For Erection & stringing of In-line Multi circuit towers (Loc. No. 1 to 7) of new 220 KV Karad & Koyana line and restringing of existing 220 KV D/C KDPH LILO line.
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.
RANJANGAON - U TECH SUGAR CKT	IntraState	11/01/2023	11:45	12/01/2023	14:31	PO	220kV A& B- Bus Isolator Maintenance work
THEUR-PHURSUNGI CKT I	IntraState	12/01/2023	06:44	12/01/2023	14:13	PO	Replacement of PID faulty string
URAN - APTA 4	IntraState	12/01/2023	08:50	12/01/2023	19:05	PO	For disc insulator string replacement work
MAIN BUS - 2 @ GHODBUNDER (GIS)	IntraState	12/01/2023	09:02	12/01/2023	17:17	EO	Facilitating outage of 220kV GIS Main Bus 2 for attending abnormal Sound from Bus Coupler CT Chamber of 220kV GIS Switchgear
SHEDYAL-JATH	IntraState	12/01/2023	09:03	12/01/2023	17:15	PO	Cold line washing Work
FLAGSHIP-CHINCHWAD	IntraState	12/01/2023	09:05	12/01/2023	16:28	PO	Half yearly maintenance work
LONAND-BARAMATI	IntraState	12/01/2023	09:08	12/01/2023	16:36	HT	H/T TO CONTROL JEJURI LINE LOADING
TALANDGE - HAMIDWADA	IntraState	12/01/2023	09:30	12/01/2023	15:02	PO	Quarterly Maintainance Work.Diagnostic testing work
NEW KOYNA - PEDAMBE	IntraState	12/01/2023	09:33	12/01/2023	15:02	PO	Circuit breaker Overhauling work and hotsopt attending work
MALEGAON-SATANA	IntraState	12/01/2023	10:20	12/01/2023	17:30	HT	H/T TO CONTROL DHULE LINE LOADING
HINJAWADI I- CHINCHWAD	IntraState	12/01/2023	11:56	12/01/2023	18:49	HT	H/T TO AVAILED OUTAGE ON TALEGAON AMBI-1 CKT
KANHAN-BHANDARA 1	IntraState	12/01/2023	12:08	12/01/2023	21:21	T	Tripped on distance protection
SAHARA-URSE	IntraState	12/01/2023	12:18	12/01/2023	18:46	HT	H/T TO AVAILED OUTAGE ON TALEGAON AMBI-1 CKT
BARAMATI - KURKUMBH	IntraState	12/01/2023	12:25	12/01/2023	18:40	PO	DIAGNOSTIC & RELAY TESTING WORK .Also Hybrid pass bushing erection work (main bus RPh jump will be removed)
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	12/01/2023	12:47	12/01/2023	18:32	PO	IPS Tube Clamp replacment work
KALWA - COLOURCHEM	IntraState	12/01/2023	14:37	12/01/2023	16:27	T	Distance Protection
TROMBAY SALSETTE LINE-2	IntraState	12/01/2023	23:06	13/01/2023	03:50	PO	Shifting to TDS bay 400KVPTL work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA SALSETTE - 3	IntraState	13/01/2023	02:24			T	Tripped on distance protection
BORIVALI - BOISAR II LINE	IntraState	13/01/2023	02:24			T	Tripped on distance protection
BELEWADI - MUMEWADI LINE	IntraState	13/01/2023	08:41			PO	For Testing and Commissioning of new Control & Relay Panel at 220 KV SubStation,Mumewadi
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	23/12/2022	09:30		Continued.	PO	For TF Diagnostic Testing work , HV CT Tandelta , HV & LV Breaker CRM, Timing and R&M work
220/33kV 100 MVA TF 2 @ VERSOVA (AEML)	IntraState	12/01/2023	09:55	12/01/2023	18:34	PO	Annual Maintenance of Circuit Breaker.
STATION TRANSFORMER - 3 @ EKLAHARE (GCR)	IntraState	12/01/2023	10:22	12/01/2023	18:24	PO	Diagnostic testing work
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	12/01/2023	10:09	12/01/2023	19:05	PO	For MAIN BUS 2 insulator string replacement work.
MAIN BUS SECTION - 1 @ PIRANGUT	IntraState	12/01/2023	19:00	13/01/2023	03:54	EO	1)Bus strengthning work of existing 220 kV single conductor Bus by twin conductor. 2)TF Bushing and Winding Tan delta measurement. 3) Attending emergency hot spot on CB of Hinjewadi-II line bay at 220kV Pirangut SS.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage