

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 12/Feb/2019 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 135.992        | 1602.319        | 1) Gujrat                      | 2.424          | 30.430          |
| 2) Hydro            | 7.410          | 91.855          | 2) Madhya Pradesh              | 12.280         | 165.314         |
| 3) Gas              | 6.778          | 81.783          | 3) Chattisgarh                 | 6.080          | 73.330          |
| <b>Total MSPGCL</b> | <b>150.180</b> | <b>1775.957</b> | 4) Maharashtra                 | 102.624        | 1149.254        |
| B) 1) APML          | 65.914         | 709.611         | 5) Goa (Amona)                 | -0.396         | -5.764          |
| 2) JSWEL            | 21.879         | 257.057         | <b>Total</b>                   | <b>123.012</b> | <b>1412.564</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 15.739         | 186.177         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 17.651         | 200.673         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 13.698         | 180.642         |
| 6) Other IPP        | 12.486         | 154.325         | Include PX                     | -1.386         | 1.430           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 15.739         | 186.177         |
| C) 1) TPCL Thermal  | 15.004         | 162.451         | Include PX                     | 4.877          | 54.752          |
| 2) TPCL Hydro       | 2.797          | 34.734          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.249          | 47.846          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.549         | 116.172         | 1) MSEDCL                      | 369.950        | 4296.202        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 50.248         | 561.873         |
| 1) Thermal          | 261.824        | 3001.935        | <b>TOTAL STATE</b>             | <b>420.198</b> | <b>4858.075</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 10.207         | 126.589         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.027         | 129.629         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 8.906          | 115.232         |                                |                |                 |
| 6) SOLAR            | 5.224          | 72.129          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>297.188</b> | <b>3445.514</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5973                      | 5942                  | 6029                      | 5042                      |
| MSPGCL Hydro             | 434                       | 448                   | 133                       | 205                       |
| MSPGCL Gas               | 303                       | 283                   | 293                       | 315                       |
| MSPGCL Total Generation  | 6710                      | 6673                  | 6455                      | 5562                      |
| Central Sector Receipt   | 6090                      | 5746                  | 5171                      | 3842                      |
| WIND                     | 569                       | 300                   | 311                       | 435                       |
| CPP / IPP Thermal        | 4684                      | 4393                  | 4600                      | 3498                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 674                       | 737                   | 0                         | 0                         |
| Exchange with Mumbai     | -1053                     | -1021                 | -946                      | -282                      |
| <b>MSEDCL DEMAND MET</b> | <b>17674</b>              | <b>16828</b>          | <b>15591</b>              | <b>13055</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 17674                     | 16828                 | 15591                     | 13055                     |
| TPCL GENERATION          | 1070                      | 1111                  | 1034                      | 659                       |
| AEML GENERATION          | 487                       | 454                   | 500                       | 374                       |
| <b>MUMBAI DEMAND</b>     | <b>2610</b>               | <b>2586</b>           | <b>2480</b>               | <b>1315</b>               |
| STATE DEMAND MET         | 20284                     | 19414                 | 18071                     | 14370                     |
| <b>STATE DEMAND</b>      | <b>20284</b>              | <b>19414</b>          | <b>18071</b>              | <b>14370</b>              |
| Frequency (Hz)           | 50.05                     | 49.98                 | 50.01                     | 49.96                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 10:01 Hrs | 49.81 Hz at 14:17 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 12/Feb/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 9.42          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.84        | 128.18        | 528      | 450      |
| Unit 9             | 12.51        | 137.15        | 600      | 460      |
| Unit 10            | 12.03        | 129.95        | 550      | 460      |
| <b>Total</b>       | <b>36.38</b> | <b>404.70</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 10.50        | 115.78        | 500      | 350      |
| Unit 5             | 10.14        | 85.45         | 475      | 350      |
| <b>Total</b>       | <b>20.64</b> | <b>201.24</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.37         | 51.18         | 193      | 163      |
| Unit 4             | 4.25         | 26.98         | 187      | 157      |
| Unit 5             | 0.00         | 77.89         | 0        | 0        |
| Unit 6             | 10.05        | 93.30         | 460      | 365      |
| Unit 7             | 9.63         | 115.66        | 443      | 365      |
| Unit 8             | 10.84        | 127.28        | 498      | 370      |
| Unit 9             | 10.78        | 126.23        | 490      | 365      |
| <b>Total</b>       | <b>49.92</b> | <b>618.50</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 39.42         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>39.42</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.86         | 42.72         | 165      | 155      |
| Unit 2             | 3.86         | 43.94         | 165      | 160      |
| Unit 3             | 3.81         | 44.83         | 160      | 149      |
| Unit 4             | 3.68         | 44.76         | 160      | 145      |
| Unit 5             | 9.69         | 112.82        | 450      | 375      |
| <b>Total</b>       | <b>24.89</b> | <b>289.08</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 30.01         | 0        | 0        |
| Unit 5             | 4.16         | 19.36         | 191      | 150      |
| <b>Total</b>       | <b>4.16</b>  | <b>49.37</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.78         | 81.78         | 317      | 145      |
| <b>Total</b>       | <b>6.78</b>  | <b>81.78</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.00         | 0.18          | 0        | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>   | <b>0.18</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 2.24          | 26.86          | 220      | 40       |
| Stage 4         | 0.61          | 12.16          | 250      | 0        |
| Stage 3         | 0.80          | 8.68           | 160      | 0        |
| <b>Total</b>    | <b>3.64</b>   | <b>47.69</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.41          | 4.18           | 37       | 0        |
| VTRNA           | 0.68          | 8.00           | 61       | 0        |
| TILLARI         | 0.00          | 3.06           | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.12          | 1.63           | 80       | 0        |
| RNGR+BHTSA      | 0.30          | 3.72           | 13       | 12       |
| BHANDARDRA      | 0.00          | 0.00           | 0        | 0        |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.51          | 6.89           | 26       | 15       |
| GHATGHAR        | 1.74          | 16.70          | 250      | 0        |
| <b>Total</b>    | <b>3.77</b>   | <b>44.16</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 8.91          | 115.23         | 0        | 0        |
| <b>Total</b>    | <b>8.91</b>   | <b>115.23</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 65.91         | 709.61         | 0        | 0        |
| JSWEL(Mus)      | 21.88         | 257.06         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 0.00          | 0.00           | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 12.49         | 154.32         | 0        | 0        |
| <b>Total</b>    | <b>100.28</b> | <b>1120.99</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 5.22          | 72.13          | 0        | 0        |
| <b>Total</b>    | <b>5.22</b>   | <b>72.13</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.76          | 100.05         | 484      | 310      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.68          | 29.84          | 117      | 83       |
| Trombay 7B      | 1.57          | 18.01          | 68       | 56       |
| Trombay 8       | 5.25          | 62.40          | 235      | 198      |
| TATA Hydro      | 2.80          | 34.73          | 274      | 0        |
| <b>Total</b>    | <b>22.05</b>  | <b>245.03</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 10.55         | 116.17         | 502      | 372      |
| <b>Total</b>    | <b>10.55</b>  | <b>116.17</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 135.99      | 1602.32       | MSPGCL Total        | 150.18      | 1775.96       |
|                |             |         | MSPGCL Thml+Gas | 142.77      | 1684.10       | Koyna 1,2 & 4 Total | 2.85        | 39.02         |
|                |             |         | MSPGCL Hydro    | 7.41        | 91.86         | State Total         | 297.19      | 3445.51       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 12/Feb/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5080        | 241  | 306  | 5627   | 390  | 3568      | 0    | 0     | 4011        | 4044        | -462                 | 13167                 | 0                    | 13167                     | 1534             | 14701           | 50.01         |
| 2                  | 5065        | 175  | 314  | 5554   | 395  | 3524      | 0    | 0     | 3984        | 3909        | -354                 | 13028                 | 0                    | 13028                     | 1417             | 14445           | 49.99         |
| 3                  | 5063        | 190  | 314  | 5567   | 449  | 3536      | 0    | 0     | 3540        | 3895        | -298                 | 13149                 | 0                    | 13149                     | 1348             | 14497           | 50.02         |
| 4                  | 5042        | 205  | 315  | 5562   | 435  | 3498      | 0    | 0     | 3713        | 3842        | -282                 | 13055                 | 0                    | 13055                     | 1315             | 14370           | 49.96         |
| 5                  | 5081        | 120  | 306  | 5507   | 486  | 3493      | 0    | 0     | 4297        | 4501        | -301                 | 13686                 | 0                    | 13686                     | 1336             | 15022           | 49.98         |
| 6                  | 5284        | 215  | 316  | 5815   | 404  | 3605      | 0    | 0     | 4793        | 5253        | -438                 | 14639                 | 0                    | 14639                     | 1483             | 16122           | 49.98         |
| 7                  | 5804        | 634  | 315  | 6753   | 418  | 4199      | 0    | 5     | 5177        | 5218        | -531                 | 16062                 | 0                    | 16062                     | 1716             | 17778           | 50.00         |
| 8                  | 5840        | 830  | 317  | 6987   | 471  | 4597      | 0    | 73    | 5746        | 5816        | -519                 | 17425                 | 0                    | 17425                     | 1918             | 19343           | 49.97         |
| 9                  | 5914        | 555  | 314  | 6783   | 514  | 4703      | 0    | 289   | 5884        | 5928        | -692                 | 17525                 | 0                    | 17525                     | 2202             | 19727           | 50.01         |
| 10                 | 5932        | 548  | 298  | 6778   | 629  | 4709      | 0    | 497   | 5858        | 5797        | -925                 | 17485                 | 0                    | 17485                     | 2450             | 19935           | 50.02         |
| 11                 | 5973        | 434  | 303  | 6710   | 569  | 4684      | 0    | 674   | 5934        | 6090        | -1053                | 17674                 | 0                    | 17674                     | 2610             | 20284           | 50.05         |
| 12                 | 6000        | 309  | 277  | 6586   | 442  | 4538      | 0    | 788   | 5991        | 5905        | -1038                | 17221                 | 0                    | 17221                     | 2645             | 19866           | 50.03         |
| 13                 | 5942        | 448  | 283  | 6673   | 300  | 4393      | 0    | 737   | 5750        | 5746        | -1021                | 16828                 | 0                    | 16828                     | 2586             | 19414           | 49.98         |
| 14                 | 5956        | 287  | 224  | 6467   | 207  | 4330      | 0    | 739   | 5563        | 5746        | -918                 | 16571                 | 0                    | 16571                     | 2467             | 19038           | 49.96         |
| 15                 | 5996        | 428  | 145  | 6569   | 193  | 4349      | 0    | 677   | 5572        | 5558        | -882                 | 16464                 | 0                    | 16464                     | 2500             | 18964           | 49.93         |
| 16                 | 6036        | 292  | 167  | 6495   | 145  | 4348      | 0    | 464   | 5612        | 5723        | -901                 | 16274                 | 0                    | 16274                     | 2507             | 18781           | 50.00         |
| 17                 | 6111        | 277  | 202  | 6590   | 160  | 4365      | 0    | 178   | 5457        | 5334        | -915                 | 15712                 | 0                    | 15712                     | 2497             | 18209           | 49.96         |
| 18                 | 6111        | 311  | 286  | 6708   | 172  | 4526      | 0    | 98    | 4940        | 5198        | -902                 | 15800                 | 0                    | 15800                     | 2475             | 18275           | 50.00         |
| 19                 | 6037        | 178  | 290  | 6505   | 266  | 4590      | 0    | 5     | 5056        | 4990        | -933                 | 15423                 | 0                    | 15423                     | 2470             | 17893           | 49.99         |
| 20                 | 6029        | 133  | 293  | 6455   | 311  | 4600      | 0    | 0     | 5127        | 5171        | -946                 | 15591                 | 0                    | 15591                     | 2480             | 18071           | 50.01         |
| 21                 | 5745        | 132  | 294  | 6171   | 350  | 4295      | 0    | 0     | 5124        | 5045        | -999                 | 14862                 | 0                    | 14862                     | 2330             | 17192           | 49.98         |
| 22                 | 5446        | 127  | 306  | 5879   | 387  | 3953      | 0    | 0     | 5070        | 4987        | -890                 | 14316                 | 0                    | 14316                     | 2167             | 16483           | 49.97         |
| 23                 | 5319        | 132  | 295  | 5746   | 369  | 3965      | 0    | 0     | 4917        | 4768        | -770                 | 14078                 | 0                    | 14078                     | 1988             | 16066           | 49.95         |
| 24                 | 5186        | 209  | 298  | 5693   | 444  | 3911      | 0    | 0     | 4320        | 4548        | -681                 | 13915                 | 0                    | 13915                     | 1809             | 15724           | 49.99         |
| MUs                | 135.99      | 7.41 | 6.78 | 150.18 | 8.91 | 100.28    | 0.00 | 5.22  | 121.44      | 123.01      | -17.65               | 369.95                | 0.00                 | 369.95                    | 50.25            | 420.20          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 12/Feb/2019**

**Position as on 6.30 Hrs of 13/Feb/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                    | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|-------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                     |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |           | Continued. | Annual Overhaul                     |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                     |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |           | Continued. | Economic shutdown                   |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                             |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                   |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                   |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                         |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |           | Continued. | Compressor & Turbine Blade Failure. |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | Poor Coal Receipt                   |               |
| MSPGCL                | Uran Unit B0            | 120      | 08/09/2018   | 12.19        |           | Continued. | T/F Shifting Work.                  |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |           | Continued. | Withdrawn Due To B0 & U-7           |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |           | Continued. | Stator Earth Fault                  |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |           | Continued. | Zero Schedule.                      |               |
| MSPGCL                | Koyana Unit 1           | 70       | 26/11/2018   | 00.00        |           | Continued. | Oil Cooler Leakage.                 |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |           | Continued. | No Schedule.                        |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |           | Continued. | Zero Schedule.                      |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/12/2018   | 00.00        |           | Continued. | Zero Schedule.                      |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 14/12/2018   | 03.00        |           | Continued. | Zero Schedule.                      |               |
| IPP                   | RPL(AMT) U-3            | 270      | 14/12/2018   | 16.30        |           | Continued. | Zero Schedule.                      |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                         |               |
| IPP                   | RPL(AMT) U-2            | 270      | 27/12/2018   | 19.30        |           | Continued. | Zero Schedule.                      |               |
| IPP                   | RPL(AMT) U-5            | 270      | 28/12/2018   | 19.30        |           | Continued. | Zero Schedule.                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                       |               |
| MSPGCL                | Nasik Unit 3            | 210      | 09/01/2019   | 19.30        |           | Continued. | Zero Schedule                       |               |
| IPP                   | Dhariwal                | 300      | 12/01/2019   | 10.15        |           | Continued. | Coal Shortage                       |               |
| MSPGCL                | Parli Unit 8            | 250      | 12/01/2019   | 12.00        |           | Continued. | Zero Schedule by MSEDCL             |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                       |               |
| MSPGCL                | Koradi Unit 7           | 210      | 19/01/2019   | 18.21        |           | Continued. | Poor Coal Receipt                   |               |
| IPP                   | RPL(AMT) U-1            | 270      | 27/01/2019   | 02.17        |           | Continued. | Withdrawn On RSD.                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 03/02/2019   | 22.09        |           | Continued. | Boiler Tube Leakage                 |               |
| MSPGCL                | Nasik Unit 4            | 210      | 08/02/2019   | 05.18        |           | Continued. | Zero schedule                       |               |
| MSPGCL                | Chandrapur Unit 5       | 500      | 09/02/2019   | 12.33        |           | Continued. | Air Heater Basket Replacement Work. |               |
| MSPGCL                | Paras Unit 4            | 250      | 10/02/2019   | 04.55        |           | Continued. | Air heater problem                  |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 12/Feb/2019**

**Position as on 6.30 Hrs of 13/Feb/2019**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage              | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------|---------------|
| MSPGCL             | Uran Unit 5             | 108      | 12/02/2019   | 13.36        | 12/02/2019 | 15.17      | Electronic card failure.      |               |
| MSPGCL             | Uran Unit 5             | 108      | 13/02/2019   | 08.26        | 13/02/2019 | 09.55      | Generator Protection operated |               |
| IPP                | Adani U-5               | 660      | 13/02/2019   | 14.52        |            | Continued. | Due To APH-B Gearbox Problem. |               |
| MSPGCL             | Uran Unit 5             | 108      | 13/02/2019   | 18.58        | 13/02/2019 | 21.30      | Generator Protection operated |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Feb/2019**

**Statement-VII**

Position as on 6.30 Hrs of 13/Feb/2019

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                     | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                               |
| Dhule Sar'Sarovar I                    | InterState                | 07/02/2019   | 08.55        |            | Continued. | PO          | Relay Testing Work(RFC 19.48Hrs)                                                                                                       |
| Dabhol Nagothane I                     | InterState                | 11/02/2019   | 10.20        | 13/02/2019 | 20.14      | PO          | Cold Welding & String Replacement Work.During Opening R-Phase Pole Burst                                                               |
| Karad-Jaigad - I                       | IntraState                | 10/02/2019   | 18.07        | 13/02/2019 | 09.30      | HT          | Over Voltage                                                                                                                           |
| Khadka-Aurangabad (Waluj)              | IntraState                | 11/02/2019   | 16.24        | 12/02/2019 | 07.38      | HT          | Over Voltage                                                                                                                           |
| Kala Kudus Ckt-II                      | IntraState                | 12/02/2019   | 07.55        | 12/02/2019 | 19.29      | PO          | Line Maintenance work at kala end.                                                                                                     |
| Deepnagar Waluj 1                      | IntraState                | 12/02/2019   | 10.34        | 12/02/2019 | 17.58      | PO          | Replacement of dead end and mid span joint.                                                                                            |
| Khadka-Aurangabad (Waluj)              | IntraState                | 12/02/2019   | 18.16        | 13/02/2019 | 07.04      | HT          | Over Voltage                                                                                                                           |
| Deepnagar - Aurangabad                 | IntraState                | 13/02/2019   | 07.06        | 13/02/2019 | 17.54      | PO          | Replacement Of Dead End And MID Span Joint And Replacement Of Faulty Insulator String.                                                 |
| Girwali- Lonikand 2                    | IntraState                | 13/02/2019   | 10.47        | 13/02/2019 | 11.46      | PO          | Work At Lonikand 2 End.                                                                                                                |
| Girwali- Lonikand 2                    | IntraState                | 13/02/2019   | 16.41        | 13/02/2019 | 17.12      | HT          | To Take L/R In Service At Lonikand End.                                                                                                |
| Bhusawal-Aurangabad                    | IntraState                | 13/02/2019   | 18.00        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe    | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                                                                                              |
| 400/220 KV 300 MVA ICT- I @Koradi      | IntraState                | 12/02/2019   | 08.59        | 12/02/2019 | 19.34      | PO          | Painting work.                                                                                                                         |
| 400/220/33 Kv 500 MVA ICT-III @Girwali | IntraState                | 12/02/2019   | 10:14        | 12/02/2019 | 21:50      | PO          | For erection of support structure of RRS scheme                                                                                        |
| 400/220/33 Kv 315 Mva Ict 2 @Koradi    | IntraState                | 13/02/2019   | 09.06        | 13/02/2019 | 20.32      | PO          | RELAY TESTING WORK                                                                                                                     |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                    | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                    | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| PARLY (PG) - OLD GCR PARLI             | InterState                | 13/02/2019   | 10.17        | 13/02/2019 | 19.28      | PO          | CT Replacement Work.                                                                                                                   |
| Chandrapur GCR - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.                   |
| Chandrapur GCR - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107. |
| Gadchandur-Ultratech I                 | IntraState                | 03/04/2018   | 22.12        | 13/02/2019 | 18.50      | HT          | Replacement Of Metering CT AT UTCL End (Form 100/1 To 50/1) Request By Discom.                                                         |
| BOISAR BORIVALI                        | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading.                                                                                                               |
| 220KV Sawangi- Bhokardan               | IntraState                | 12/02/2019   | 08.43        | 12/02/2019 | 17.55      | PO          | In view of outage on sawangi padegaon CKT.                                                                                             |
| Padegaon-Sawangi                       | IntraState                | 12/02/2019   | 08.56        | 12/02/2019 | 17.52      | PO          | Insulator string replacement work.                                                                                                     |
| satara MIDC- Malharpeth                | IntraState                | 12/02/2019   | 10.15        | 12/02/2019 | 13.22      | PO          | Quarterly Maintainance Work                                                                                                            |
| Alkud Miraj                            | IntraState                | 12/02/2019   | 10.58        | 12/02/2019 | 15.30      | EO          | Y PH CT oil leakage.                                                                                                                   |
| Yeotmal- Pusad                         | IntraState                | 12/02/2019   | 12.06        | 12/02/2019 | 15.00      | PO          | Jumper removal work.                                                                                                                   |
| Nagothane - ACCIL                      | IntraState                | 12/02/2019   | 12.22        | 12/02/2019 | 17.55      | PO          | Diagnostic testing.                                                                                                                    |
| Paranda-Barshi                         | IntraState                | 12/02/2019   | 14.15        | 12/02/2019 | 17.00      | PO          | Line Maintenance work                                                                                                                  |
| Apta - Tambati                         | IntraState                | 13/02/2019   | 07.08        | 13/02/2019 | 17.07      | PO          | Routine Maintenance Work &Diagnostic Testing Work.                                                                                     |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Feb/2019**

**Statement-VII**

Position as on 6.30 Hrs of 13/Feb/2019

| Name of Line                                       | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                           |
|----------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------|
| Boisar-Viraj                                       | IntraState                | 13/02/2019   | 08.05        | 13/02/2019 | 13.30      | PO          | Diagnostic Testing Work.                   |
| Karad(400kv) -Mudshingi Ckt 2-Tak                  | IntraState                | 13/02/2019   | 10.02        | 13/02/2019 | 12.51      | PO          | Quarterly Maintainance Work                |
| Bhugaon-WardhaPG (Deoli)                           | IntraState                | 13/02/2019   | 10.04        | 13/02/2019 | 17.29      | PO          | Testing Work                               |
| Beed-Manjarsumba                                   | IntraState                | 13/02/2019   | 10.25        | 13/02/2019 | 14.05      | PO          | Quarterly Maintainance Work                |
| khaparkheda-Khaparkheda(new)-I                     | IntraState                | 13/02/2019   | 10.58        | 13/02/2019 | 15.43      | PO          | Testing Work                               |
| Dhamangaon New- Tss -I                             | IntraState                | 13/02/2019   | 11.34        | 13/02/2019 | 18.17      | PO          | R PH Metering PT Replacement Work.         |
| Trombay - Kalwa                                    | IntraState                | 13/02/2019   | 12.08        | 13/02/2019 | 12.28      | EO          | Bird Nest Removal.                         |
| Pophali - Kdph                                     | IntraState                | 13/02/2019   | 13.05        | 13/02/2019 | 13.45      | T           | R PH E/F 1.32KA.                           |
| Beed-Patoda Ckt 1                                  | IntraState                | 13/02/2019   | 14.12        | 13/02/2019 | 16.30      | PO          | Diagnostic Testing Work.                   |
| ACCIL - Apta                                       | IntraState                | 13/02/2019   | 17.33        | 13/02/2019 | 19.26      | PO          | Diagnostic Testing Work.                   |
| Gadchandur-Ultratech II                            | IntraState                | 13/02/2019   | 18.00        |            | Continued. | PO          | Metering C.T.Replacement Work.             |
| <b>220 KV ICT Outages/Trippings</b>                |                           |              |              |            |            |             |                                            |
| 220/132-110kv 200mva Ptr 1 @Oglewadi               | IntraState                | 12/02/2019   | 10.40        | 12/02/2019 | 16.17      | PO          | C.B timing CRM testing work.               |
| 220/132kv 100MVA ICT II @Satara Midc               | IntraState                | 12/02/2019   | 14.20        | 12/02/2019 | 16.55      | PO          | Quarterly Maintainance Work                |
| 220/33 Kv 100 Mva Areva Ptr 1 @Jamde               | IntraState                | 13/02/2019   | 08.48        | 13/02/2019 | 14.25      | EO          | HV BPH CT Oil Leakage.                     |
| 220/100 Kv 200 Mva Cgl Ict @Pal-Dombivali          | IntraState                | 13/02/2019   | 09.30        | 13/02/2019 | 21.30      | PO          | Diagnostic Testing Work.                   |
| 220/132KV 200MVA ICT-II @ Miraj                    | IntraState                | 13/02/2019   | 10.20        | 13/02/2019 | 17.20      | PO          | Diagnostic Testing Work.                   |
| 220/132 Kv 200 Mva Vijai Ict 2 @Bale (Solapur 2)   | IntraState                | 13/02/2019   | 10:36        | 13/02/2019 | 12:41      | PO          | Quarterly Maintainance Work                |
| 220/66 Kv 150 Mva Emco Ict 2 @Gadchandur           | IntraState                | 13/02/2019   | 11.35        |            | Continued. | PO          | LV Bushing Replacement,Work For 10 Days    |
| 220/132 Kv 100 Mva Ict 1 @South Solapur (Kumbhari) | IntraState                | 13/02/2019   | 12.00        | 13/02/2019 | 15.45      | PO          | Quarterly Maintainance Work                |
| 220/132 Kv 200 Mva Bbl Ict 1 @Kalmeshwar           | IntraState                | 13/02/2019   | 14.28        | 13/02/2019 | 16.22      | PO          | Attending Oil Leakage                      |
| 220/132 Kv 100 Mva Emco Ict @Shahada               | IntraState                | 13/02/2019   | 17.40        | 13/02/2019 | 21.08      | PO          | For Cold Welding To Attending Oil Leakage. |
| <b>132 KV LINE Outages/Trippings</b>               |                           |              |              |            |            |             |                                            |
| Mansar Pench                                       | InterState                | 22/01/2019   | 18.40        |            | Continued. | HT          | After Completion of Outage.                |
| Kanhan-Pench                                       | IntraState                | 22/01/2019   | 18.44        |            | Continued. | HT          | After Completion of Outage.                |
| Harangul-Latur(Koyana) Ckt-I                       | IntraState                | 13/02/2019   | 11.06        | 13/02/2019 | 15.43      | PO          | Diagnostic Testing Work.                   |
| Ujani - Ausa                                       | IntraState                | 13/02/2019   | 13.35        | 13/02/2019 | 16.07      | T           | Distance Protection                        |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage