

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Feb/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.244	1803.166	1) Gujrat	-9.862	-101.728
2) Hydro	16.337	158.468	2) Madhya Pradesh	4.325	67.700
3) Gas	6.533	84.517	3) Chattisgarh	7.470	81.410
Total MSPGCL	182.114	2046.151	4) Maharashtra	138.093	1673.790
B) 1) APMIL	70.204	826.339	5) Goa (Amona)	-1.414	-18.384
2) JSWEL	14.823	173.814	Total	138.612	1702.788
3) VIPL	0.000	0.000	a) Mumbai Schedule	20.735	218.084
4) RPL(AMT)	28.959	331.897	b) Mumbai Drawl	22.933	254.332
5) SWPGPL	8.180	96.841	c) MSEDCL Bilateral *	64.719	810.680
6) Other IPP	41.509	481.498	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	20.735	217.864
C) 1) TPCL Thermal	10.971	110.746	Include PX	0.000	0.000
2) TPCL Hydro	2.477	43.586	Standby	0.000	0.220
3) TPCL Gas	4.195	41.499	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.793	114.117	1) MSEDCL	472.556	5541.572
D) STATE			2) Mumbai Discoms	47.369	564.283
1) Thermal	340.683	3938.418	3) Other Discoms	8.318	99.477
(A1+C1+C4+(B1-B6))			TOTAL STATE	528.243	6205.332
2) Hydro (A2+C2)	18.814	202.054			
3) Gas (A3+B7+C3)	10.728	126.016			
4) Wind	10.420	132.219			
6) SOLAR	8.986	103.834			
TOTAL STATE	389.631	4502.541			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	7065	7028	6777	5803
MSPGCL Hydro	1596	562	1006	371
MSPGCL Gas	264	278	282	291
MSPGCL Total Generation	8925	7868	8065	6465
Central Sector Receipt	7286	7390	5229	5214
WIND	328	151	210	931
CPP / IPP Thermal	7079	6998	7093	5692
CPP / IPP Gas	0	0	0	0
SOLAR	1088	1290	0	0
Exchange with Mumbai	-1300	-1309	-981	-675
MSEDCL DEMAND MET	23163	22160	19361	17420
Load Shedding	0	0	0	0
MSEDCL DEMAND	23163	22160	19361	17420
TPCL GENERATION	801	777	1044	547
AEML GENERATION	282	283	283	284
MUMBAI DEMAND	2383	2369	2308	1506
OTHER DISCOM DEMAND	373	348	383	284
STATE DEMAND MET	25919	24878	22052	19210
STATE DEMAND	25919	24878	22052	19210
Frequency (Hz)	50.04	49.95	50.00	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 18.03 Hrs	49.82 Hz at 21.05 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Feb/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.71	42.83	170	115
Unit 7	0.00	0.00	0	0
Unit 8	13.59	166.20	602	504
Unit 9	13.01	158.45	575	520
Unit 10	12.75	151.05	565	500
Total	43.06	518.53		
Bhusawal				
Unit 3	3.22	38.28	150	120
Unit 4	0.00	0.00	0	0
Unit 5	10.32	114.93	475	290
Total	13.54	153.20		
Parli				
Unit 6	4.06	46.83	195	61
Unit 7	4.03	47.26	202	144
Unit 8	3.96	45.11	181	146
Total	12.05	139.19		
Chandrapur				
Unit 3	3.48	17.66	176	107
Unit 4	3.46	10.89	166	121
Unit 5	8.02	96.06	395	290
Unit 6	7.62	92.61	340	275
Unit 7	9.02	98.44	440	286
Unit 8	10.16	123.72	470	330
Unit 9	9.97	120.45	440	364
Total	51.72	559.83		
Paras				
Unit 3	4.92	54.51	250	144
Unit 4	4.48	51.96	228	142
Total	9.40	106.47		
Khaparkheda				
Unit 1	2.83	38.14	150	70
Unit 2	3.06	8.34	155	100
Unit 3	3.36	45.09	160	125
Unit 4	3.25	36.20	150	122
Unit 5	9.90	125.21	460	320
Total	22.40	252.99		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.57	39.60	180	118
Unit 5	3.50	33.36	177	115
Total	7.08	72.96		
Uran				
All Units	6.53	84.52	311	160
Total	6.53	84.52		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.37	2.31	42	0
Total	0.37	2.31		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.05	29.12	440	35
Stage 4	2.46	25.51	505	0
Stage 3	1.32	11.87	160	0
Total	6.83	66.49		
Hydro				
KDPH	0.86	8.18	36	35
VTRNA	0.84	8.86	60	0
TILLARI	0.52	6.21	58	0
BHIRA T.R.	0.12	2.48	77	0
SMLHY_PTN	6.32	60.03	270	251
GHATGHAR	0.84	6.23	160	0
Total	9.51	91.98		
Wind				
Total	10.42	132.22	0	0
Total	10.42	132.22		
CPP				
APML(Mus)	70.20	826.34	0	0
JSWEL(Mus)	14.82	173.81	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	28.96	331.90	0	0
SWPGPL-Mus	8.18	96.84	0	0
Other(Mus)	41.51	481.50	0	0
Total	163.68	1910.39		
SOLAR				
Total	8.99	103.83	0	0
Total	8.99	103.83		
Tata				
Trombay 5	7.12	66.36	456	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.62	25.11	115	95
Trombay 7B	1.57	16.38	68	60
TATA Hydro	2.48	43.59	323	0
Trombay 8	3.85	44.38	222	130
Total	17.64	195.83		
AEML				
DTPS U-1&2	6.79	114.12	284	282
Total	6.79	114.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.24	1803.17	MSPGCL Total	182.11	2046.15
			MSPGCL Thml+Gas	165.78	1887.68	Koyna 1,2 & 4 Total	5.52	54.62
			MSPGCL Hydro	16.34	158.47	State Total	389.63	4502.54

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 12/Feb/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5723	333	311	6367	878	5730	0	0	5175	5345	-590	17424	0	17424	1633	306	19363	49.91
2	5803	371	291	6465	931	5769	0	0	5130	5214	-675	17420	0	17420	1506	284	19210	49.98
3	6109	351	301	6761	967	6084	0	0	5077	4592	-618	17509	0	17509	1449	277	19235	50.02
4	6131	346	303	6780	960	6073	0	0	5048	4728	-568	17702	0	17702	1400	271	19373	49.99
5	6153	333	301	6787	958	6207	0	0	5021	4765	-569	17862	0	17862	1413	286	19561	49.96
6	6506	368	303	7177	887	6631	0	0	5154	5042	-662	18769	0	18769	1508	306	20583	49.96
7	6869	513	231	7613	854	7134	0	12	5132	5121	-679	19710	0	19710	1628	345	21683	49.94
8	7013	1177	160	8350	674	7189	0	111	5361	5106	-638	20429	0	20429	1780	363	22572	49.96
9	6960	1334	186	8480	549	7131	0	476	5836	5881	-886	21254	0	21254	1996	377	23627	50.03
10	6910	1518	217	8645	504	7118	0	847	6402	6598	-1147	22205	0	22205	2211	360	24776	50.02
11	7065	1596	264	8925	328	7209	0	1088	7287	7286	-1300	23163	0	23163	2383	373	25919	50.04
12	7088	1223	270	8581	160	7204	0	1260	7391	7177	-1250	22773	0	22773	2445	358	25577	49.98
13	7028	562	278	7868	151	7119	0	1290	7670	7390	-1309	22160	0	22160	2369	348	24878	49.95
14	7026	524	268	7818	131	7115	0	1231	7061	7031	-1238	21729	0	21729	2240	359	24328	50.00
15	6899	478	267	7644	108	7120	0	1140	7472	7411	-1233	21813	0	21813	2240	376	24430	49.92
16	6949	484	279	7712	89	7178	0	849	7419	7341	-1230	21559	0	21559	2236	380	24175	49.97
17	6868	723	279	7870	95	7253	0	525	6463	6270	-1209	20426	0	20426	2229	378	23033	49.99
18	6782	759	271	7812	97	7265	0	154	5716	5811	-1031	19727	0	19727	2210	381	22318	50.00
19	6775	691	293	7759	154	7226	0	3	5460	5438	-1005	19186	0	19186	2274	389	21849	49.97
20	6777	1006	282	8065	210	7221	0	0	5381	5229	-981	19361	0	19361	2308	383	22052	50.00
21	6841	436	294	7571	214	7185	0	0	4895	4663	-1088	18161	0	18161	2191	384	20736	50.00
22	6380	410	294	7084	191	6811	0	0	5177	5053	-1100	17671	0	17671	2057	368	20096	49.99
23	6284	397	294	6975	171	6394	0	0	5218	4991	-1007	17184	0	17184	1894	339	19418	49.95
24	6305	404	296	7005	159	6309	0	0	5127	5130	-920	17358	0	17358	1769	326	19452	49.96
MUs	159.24	16.34	6.53	182.11	10.42	163.68	0.00	8.99	141.07	138.61	-22.93	472.56	0.00	472.56	47.37	8.32	528.24	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Feb/2022

Position as on 6.30 Hrs of 13/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55	12/02/2022	19:35	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U3	300	15/01/2022	07:46		Continued.	non availability of load schedule.	
MSPGCL	Uran Unit 5	108	03/02/2022	16:54	12/02/2022	07:50	Gas shortage	
MSPGCL	Parli Unit 6	250	11/02/2022	19:24	12/02/2022	00:19	Furnace Pressure High	
MSPGCL	Uran Unit B0	120	12/02/2022	06:37		Continued.	Controller Fault	
MSPGCL	Uran Unit 8	108	12/02/2022	06:37		Continued.	Controller Fault.	
IPP	Adani U-3	660	13/02/2022	15:16		Continued.	Due to APH-B hot PA below leakage.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 13/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
BUS - I @ KORADI - 3	IntraState	13/02/2022	09:39	13/02/2022	19:41	PO	Annual Maintenance of Bus Equipments
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	12/02/2022	01:15	13/02/2022	16:43	PO	1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3)During Bus 2 outage 400 KV Kalwa -Padghe ckt-1 H/T for safety purpose. 6 hrs 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole -1 out durion BUS-2 outage .6) HVDC-pole 2 out for safety purpose .Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	12/02/2022	01:37	12/02/2022	06:25	PO	safety purpose. Removing of Jumper of B Bus Section-4 .HVDC- pole 2 out for 5 hrs for safety purpose.1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3)During Bus 2 outage 400 KV Kalwa -Padghe ckt-1 H/T for safety purpose. 6 hrs 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole -1 out durion BUS-2 outage .6) HVDC-pole 2 out for safety purpose .Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV Nagaothane ckt-2
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	13/02/2022	01:43	13/02/2022	04:00	PO	Restoration of 400kv Padgha bus-2 for safety purpose.
400 KV TIEBAY Outages/Trippings							
TIE BAY (429) OF ICT - 1 @ KORADI - 2	IntraState	13/02/2022	08:12	13/02/2022	19:11	PO	33kv BPI excavation work associated with rapid restoration scheme near 33KV Side of ICT1.
400 KV MAINBAY Outages/Trippings							
MAIN BAY (430) OF ICT - 1 @ KORADI - 2	IntraState	13/02/2022	08:12	13/02/2022	19:07	PO	33kv BPI excavation work associated with rapid restoration scheme near 33KV Side of ICT1.
400 KV LINE Outages/Trippings							
KALWA - TALEGAON (PG)	InterState	11/02/2022	23:09	12/02/2022	00:50	EO	Hot spot attending work of R phase Line side CT conductor near the clamp (Temp. 115 deg. C)
THAPTI TANDA - WALUJ	IntraState	01/02/2022	13:01			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 12/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 13/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DEEPNAGAR - THAPTI TANDA	IntraState	01/02/2022	13:11			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	04/02/2022	14:43			HT	H/T TO CONTROL 400KV TALEGAON PG -CHAKAN LINE LOADING.
PADGHE - KALWA CKT - 2	IntraState	11/02/2022	13:58	13/02/2022	15:27	PO	Line will be in service through TBC 1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3)During Bus 2 outag 400 KV Kalwa -Padghe ckt-1 H/T for safety purpose. 6 hrs 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole -1 out durion BUS-2 outage .6) HVDC-pole 2 out for safety purpose .Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	11/02/2022	23:06	12/02/2022	00:46	T	Distance Protection.
THAPTI TANDA - WALUJ	IntraState	12/02/2022	09:27	12/02/2022	20:09		line routine maint. work is to be carried out
DEEPNAGAR - THAPTI TANDA	IntraState	12/02/2022	09:42	12/02/2022	20:09		Line routine maint. work is to be carried out
AKOLA - KHADKA (BHUSAWAL)	IntraState	12/02/2022	22:24	13/02/2022	01:53	EO	Permission for Emergency outage on 400 KV Khadka- Akola line for replacement of R phase faulty suspension string at location no 867.
PADGHE - KALWA CKT - 1	IntraState	13/02/2022	09:49	13/02/2022	14:51	PO	Restoration of Padghe BUS 2 .Line Hand tripped for Safety purpose
400 KV ICT Outages/Trippings							
400/11KV STN-4B @ DEEPNAGAR	IntraState	03/02/2022	12:57			PO	Oil Filtration and other allied works of STN - 4B at 2 x 500MW , BTPS, Deepnagar, MSPGCL
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	12/02/2022	12:15	12/02/2022	20:51	PO	33KV BPI excavation work associated with rapid restoration scheme near 33KV side of ICT2
400/220/33 KV 315MVA ICT - 1 @ CHAKAN	IntraState	12/02/2022	12:42	12/02/2022	18:31	EO	R Ph ICT No1 Conservator tank Oil Level Low
220 KV LV BAY 205 OF 400/220 KV ICT - I	IntraState	13/02/2022	08:12	13/02/2022	19:15	PO	33KV BPI excavation work associated with rapid restoration scheme near 33KV Side of ICT1.
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
GHODBUNDER - MSETCL BOISAR	IntraState	04/02/2022	13:40			T	TRIPPED ON DIST.PROTN.
KARAD - VITA CKT- 1	IntraState	07/02/2022	08:36			PO	For tower erection of Loc.no.23-24 and stringing work between Loc.no.22-23-24-25 in respect of modification of EHV lines crossing Pune � Miraj Railway electrification work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 13/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KARAD - VITA CKT- 2	IntraState	07/02/2022	08:40			PO	For tower erection of Loc.no.23-24 and stringing work between Loc.no.22-23-24-25 in respect of modification of EHV lines crossing Pune � Miraj Railway electrification work
INFOSYS - HINJAWADI 1	IntraState	12/02/2022	09:17	12/02/2022	20:33	PO	Yearly Maintenance work, CB CRM & timing test & CT Tan Delta
TROMBAY CARNAC - 6	IntraState	12/02/2022	09:39	12/02/2022	21:43		For 29C GOD R/M
MAHAD-KALAMBANI(TSS)	IntraState	12/02/2022	09:50	12/02/2022	19:15	PO	Tree cutting work and other line maintenance work
MUMEWADI -HALKARNI 1 LINE	IntraState	12/02/2022	10:06	12/02/2022	17:01	PO	Dignostic testing and meggering of CB,CT and QM of the bay.
MAHINDRA VEHICLE-BRIDGESTONE	IntraState	13/02/2022	09:16	13/02/2022	18:46	PO	M/S MVML Consumer for jumper connection work from Isolator to PT, Metering connections, CT-PT testing and charging of new CT-PT for 40MVA for Consumer bay-1 & Opportunity outage for Bay Maintenance and Relay Testing work.
CHAKAN-MAHINDRA VEHICLE	IntraState	13/02/2022	09:18	13/02/2022	18:28	PO	M/S MVML Consumer for jumper connection work from Isolator to PT, Metering connections, CT-PT testing and charging of new CT-PT for 40MVA for Consumer bay-1 & Opportunity outage for Bay Maintenance and Relay Testing work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	28/01/2022	12:10			PO	Dismantling of bus post insulator jump of 220kV Main bus by hot line unit for erection of new bus post isolator
220/132/11KV 200 MVA ICT 2 @ MALINAGAR	IntraState	08/02/2022	22:32	12/02/2022	11:40	PO	220/132 kV 200MVA Aditya ICT Main Tank Oil filtration work
220/22 KV 50 MVA PTR 2 @ PADGHE	IntraState	11/02/2022	09:58	12/02/2022	21:29	PO	1. Retrofitting of REF relay for MTAMC work 2. Diagnostic testing work 3. Anticorrosive Painting work
220/100 KV 200 MVA ICT 1 @ KALWA	IntraState	12/02/2022	15:02	12/02/2022	17:27	EO	4 Nature of work to be carried out For attending fire extinguisher problem in ICT-1 (Indication "Fire detector trip")
220/22 KV 50 MVA PTR 1 @ BHANDUP GIS	IntraState	13/02/2022	08:02	13/02/2022	14:38	PO	HV testing work of 220kV Bus, using Tata Power testing Kit at 220kV GIS Bhandup.
220 / 110 / 33kV 315 MVA ICT 5	IntraState	13/02/2022	10:06	13/02/2022	17:21	PO	FOR CHECKING DIMENSIONS FOR 110 KV GIS PROJECT WORK
220/132 KV 200 MVA ICT 2 @ BABHLESHWAR	IntraState	13/02/2022	14:57	13/02/2022	15:05	T	Overcurrent Protection
220/132 KV 100 MVA ICT 1	IntraState	13/02/2022	14:57	13/02/2022	15:05	T	Overcurrent Protection
220 KV BUSBAR Outages/Trippings							
GIS BUS - 2 @ KARANJADE	IntraState	13/02/2022	08:41		Continued.		For new Reactor Bay installation work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage