

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 12/Feb/2025 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 147.382        | 1728.406        | 1) Gujrat                      | 1.767          | 3.604           |
| 2) Hydro            | 18.457         | 170.438         | 2) Madhya Pradesh              | 11.726         | 83.801          |
| 3) Gas              | 7.180          | 85.235          | 3) Chattisgarh                 | 4.710          | 56.580          |
| <b>Total MSPGCL</b> | <b>173.019</b> | <b>1984.079</b> | 4) Maharashtra                 | 226.896        | 2636.418        |
| B) 1) APLM          | 65.050         | 819.633         | 5) Goa (Amona)                 | -2.714         | -30.975         |
| 2) JSWEL            | 25.512         | 307.858         | <b>Total</b>                   | <b>242.385</b> | <b>2749.428</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 37.113         | 436.264         |
| 4) RPL(AMT)         | 31.199         | 366.812         | b) Mumbai Drawl                | 39.720         | 470.712         |
| 5) SWPGPL           | 9.221          | 140.873         | c) MSEDCL Bilateral *          | 108.063        | 1227.469        |
| 6) Other IPP        | 36.630         | 502.147         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 37.113         | 435.722         |
| C) 1) TPCL Thermal  | 9.481          | 81.884          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 2.953          | 34.893          | Standby                        | 0.000          | 0.541           |
| 3) TPCL Gas         | 2.875          | 39.320          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 5.480          | 70.311          | 1) MSEDCL                      | 561.052        | 6587.021        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 60.509         | 697.119         |
| 1) Thermal          | 329.955        | 4017.924        | 3) Other Discoms               | 12.555         | 147.662         |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>634.116</b> | <b>7431.802</b> |
| 2) Hydro            | 21.410         | 205.331         |                                |                |                 |
| 3) Gas              | 10.055         | 124.555         |                                |                |                 |
| 4) Wind             | 6.019          | 67.395          |                                |                |                 |
| 6) SOLAR            | 24.292         | 267.170         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>391.731</b> | <b>4682.375</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 5977                      | 5800                  | 6474                      | 5733                      |
| MSPGCL Hydro               | 1477                      | 966                   | 1793                      | 240                       |
| MSPGCL Gas                 | 291                       | 281                   | 290                       | 301                       |
| MSPGCL Total Generation    | 7745                      | 7047                  | 8557                      | 6274                      |
| Central Sector Receipt     | 11117                     | 10815                 | 9902                      | 9642                      |
| WIND                       | 105                       | 113                   | 254                       | 505                       |
| CPP / IPP Thermal          | 6783                      | 6017                  | 7607                      | 6946                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2982                      | 3445                  | 0                         | 0                         |
| Exchange with Mumbai       | -2234                     | -2319                 | -1676                     | -991                      |
| <b>MSEDCL DEMAND MET</b>   | <b>25934</b>              | <b>24559</b>          | <b>24082</b>              | <b>21956</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 25934                     | 24559                 | 24082                     | 21956                     |
| TPCL GENERATION            | 551                       | 531                   | 984                       | 541                       |
| AEML GENERATION            | 212                       | 191                   | 235                       | 247                       |
| <b>MUMBAI DEMAND</b>       | <b>2997</b>               | <b>3041</b>           | <b>2895</b>               | <b>1779</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>564</b>                | <b>559</b>            | <b>562</b>                | <b>420</b>                |
| STATE DEMAND MET           | 29495                     | 28159                 | 27539                     | 24155                     |
| <b>STATE DEMAND</b>        | <b>29495</b>              | <b>28159</b>          | <b>27539</b>              | <b>24155</b>              |
| Frequency (Hz)             | 49.91                     | 50.05                 | 49.94                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.22 Hz at 18.02 Hrs | 49.77 Hz at 10.11 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 12/Feb/2025

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.02         | 48.28         | 176      | 134      |
| Unit 8             | 14.14        | 169.52        | 634      | 534      |
| Unit 9             | 13.48        | 167.55        | 595      | 484      |
| Unit 10            | 12.93        | 103.17        | 570      | 520      |
| <b>Total</b>       | <b>44.58</b> | <b>488.53</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.42         | 43.13         | 170      | 125      |
| Unit 4             | 0.00         | 85.00         | 0        | 0        |
| Unit 5             | 9.50         | 115.91        | 470      | 290      |
| <b>Total</b>       | <b>12.92</b> | <b>244.04</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.20         | 51.15         | 250      | 138      |
| Unit 7             | 3.80         | 50.56         | 205      | 137      |
| Unit 8             | 4.17         | 42.80         | 211      | 148      |
| <b>Total</b>       | <b>12.18</b> | <b>144.51</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.15         | 37.98         | 192      | 126      |
| Unit 4             | 3.50         | 33.87         | 158      | 126      |
| Unit 5             | 9.01         | 106.03        | 400      | 300      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 5.88         | 69.21         | 328      | 0        |
| Unit 8             | 10.88        | 123.01        | 475      | 354      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>33.42</b> | <b>370.10</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.34         | 60.04         | 240      | 175      |
| Unit 4             | 5.56         | 61.15         | 245      | 162      |
| <b>Total</b>       | <b>10.90</b> | <b>121.18</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.62         | 43.88         | 165      | 125      |
| Unit 2             | 3.98         | 36.97         | 181      | 123      |
| Unit 3             | 4.08         | 44.62         | 187      | 141      |
| Unit 4             | 3.74         | 47.30         | 171      | 137      |
| Unit 5             | 10.94        | 95.90         | 470      | 430      |
| <b>Total</b>       | <b>26.35</b> | <b>268.67</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.45         | 37.08         | 164      | 120      |
| Unit 4             | 0.00         | 13.05         | 0        | 0        |
| Unit 5             | 3.58         | 41.26         | 174      | 115      |
| <b>Total</b>       | <b>7.02</b>  | <b>91.38</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.18         | 85.24         | 395      | 274      |
| <b>Total</b>       | <b>7.18</b>  | <b>85.24</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.13         | 5.45          | 20       | 0        |
| <b>Total</b>       | <b>0.13</b>  | <b>5.45</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 2.78         | 26.78         | 470      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 8.14          | 58.83          | 995      | 0        |
| Stage 3         | 2.19          | 18.23          | 234      | 0        |
| <b>Total</b>    | <b>13.12</b>  | <b>103.83</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.82          | 9.79           | 34       | 34       |
| VTRNA           | 0.21          | 1.16           | 59       | 0        |
| TILLARI         | 0.19          | 5.14           | 62       | 0        |
| BHIRA T.R.      | 0.14          | 1.58           | 40       | 0        |
| SMLHY_PTN       | 3.61          | 41.82          | 158      | 146      |
| GHATGHAR        | 0.38          | 7.12           | 125      | 0        |
| <b>Total</b>    | <b>5.34</b>   | <b>66.61</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 6.02          | 67.40          | 0        | 0        |
| <b>Total</b>    | <b>6.02</b>   | <b>67.40</b>   |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 65.05         | 819.63         | 0        | 0        |
| JSWEL(Mus)      | 25.51         | 307.86         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 31.20         | 366.81         | 0        | 0        |
| SWPGPL-Mus      | 9.22          | 140.87         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 0.00          | 40.66          | 0        | 0        |
| Other(Mus)      | 34.46         | 436.14         | 0        | 0        |
| JPL             | 2.17          | 25.35          | 139      | 75       |
| <b>Total</b>    | <b>167.61</b> | <b>2137.32</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 24.29         | 267.17         | 0        | 0        |
| <b>Total</b>    | <b>24.29</b>  | <b>267.17</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 5.99          | 36.63          | 250      | 244      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.63          | 23.24          | 109      | 60       |
| Trombay 7B      | 1.25          | 16.08          | 64       | 49       |
| TATA Hydro      | 2.95          | 34.89          | 411      | 31       |
| Trombay 8       | 3.49          | 45.26          | 212      | 126      |
| <b>Total</b>    | <b>15.31</b>  | <b>156.10</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 5.48          | 70.31          | 249      | 143      |
| <b>Total</b>    | <b>5.48</b>   | <b>70.31</b>   |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 147.38      | 1728.41       | MSPGCL Total        | 173.02      | 1984.08       |
|                |             |         | MSPGCL Thml+Gas | 154.56      | 1813.64       | Koyna 1,2 & 4 Total | 10.92       | 85.60         |
|                |             |         | MSPGCL Hydro    | 18.46       | 170.44        | State Total         | 391.73      | 4682.38       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 12/Feb/2025

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |      | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 5817        | 224   | 300  | 6341   | 516  | 7234      | 0    | 0     | 9804     | 9546     | -1322          | 21843            | 0             | 0                        | 21843                | 2077          | 471                 | 24392        | 49.96      |
| 2            | 5814        | 230   | 300  | 6344   | 486  | 7087      | 0    | 0     | 9606     | 9598     | -1124          | 21969            | 0             | 0                        | 21969                | 1889          | 422                 | 24280        | 49.98      |
| 3            | 5733        | 240   | 301  | 6274   | 505  | 6946      | 0    | 0     | 9581     | 9642     | -991           | 21956            | 0             | 0                        | 21956                | 1779          | 420                 | 24155        | 50.00      |
| 4            | 5918        | 225   | 303  | 6446   | 515  | 6823      | 0    | 0     | 9535     | 9591     | -923           | 22053            | 0             | 0                        | 22053                | 1706          | 399                 | 24158        | 49.99      |
| 5            | 6153        | 234   | 304  | 6691   | 506  | 6995      | 0    | 0     | 9503     | 9670     | -956           | 22485            | 0             | 0                        | 22485                | 1715          | 421                 | 24621        | 49.97      |
| 6            | 6228        | 232   | 304  | 6764   | 452  | 7360      | 0    | 0     | 9982     | 9897     | -1085          | 22920            | 0             | 0                        | 22920                | 1835          | 468                 | 25223        | 49.96      |
| 7            | 6413        | 1143  | 307  | 7863   | 396  | 7671      | 0    | 20    | 9383     | 9154     | -1074          | 23537            | 0             | 0                        | 23537                | 2041          | 493                 | 26071        | 50.00      |
| 8            | 6537        | 1877  | 395  | 8809   | 297  | 7749      | 0    | 315   | 9006     | 9311     | -1162          | 24811            | 0             | 0                        | 24811                | 2301          | 508                 | 27620        | 49.98      |
| 9            | 6469        | 1325  | 370  | 8164   | 208  | 7633      | 0    | 1222  | 9675     | 9578     | -1470          | 24790            | 0             | 0                        | 24790                | 2550          | 544                 | 27885        | 50.05      |
| 10           | 6223        | 1230  | 292  | 7745   | 152  | 7396      | 0    | 2211  | 10246    | 10287    | -1950          | 25287            | 0             | 28                       | 25287                | 2797          | 554                 | 28638        | 49.96      |
| 11           | 5977        | 1477  | 291  | 7745   | 105  | 6783      | 0    | 2982  | 10952    | 11117    | -2234          | 25934            | 0             | 63                       | 25934                | 2997          | 564                 | 29495        | 49.91      |
| 12           | 5498        | 1563  | 282  | 7343   | 95   | 5989      | 0    | 3287  | 11192    | 11438    | -2386          | 25204            | 0             | 78                       | 25204                | 3067          | 562                 | 28833        | 50.01      |
| 13           | 5800        | 966   | 281  | 7047   | 113  | 6017      | 0    | 3445  | 10949    | 10815    | -2319          | 24559            | 0             | 77                       | 24559                | 3041          | 559                 | 28159        | 50.05      |
| 14           | 5811        | 565   | 274  | 6650   | 81   | 5909      | 0    | 3319  | 10615    | 10639    | -2239          | 23798            | 0             | 47                       | 23798                | 2941          | 562                 | 27300        | 50.01      |
| 15           | 5877        | 548   | 274  | 6699   | 87   | 6147      | 0    | 3064  | 10930    | 10788    | -2174          | 24069            | 0             | 37                       | 24069                | 2951          | 541                 | 27562        | 49.96      |
| 16           | 6018        | 633   | 276  | 6927   | 107  | 6628      | 0    | 2416  | 11035    | 11084    | -2198          | 24378            | 0             | 17                       | 24378                | 2996          | 585                 | 27960        | 49.95      |
| 17           | 6216        | 633   | 280  | 7129   | 97   | 6935      | 0    | 1524  | 10891    | 10990    | -2177          | 23912            | 0             | 10                       | 23912                | 2989          | 586                 | 27487        | 49.94      |
| 18           | 6424        | 638   | 285  | 7347   | 148  | 7386      | 0    | 483   | 10485    | 10124    | -2026          | 22879            | 0             | 4                        | 22879                | 2964          | 583                 | 26426        | 49.98      |
| 19           | 6422        | 1405  | 288  | 8115   | 188  | 7627      | 0    | 4     | 9541     | 9737     | -1750          | 23342            | 0             | 0                        | 23342                | 2968          | 580                 | 26889        | 49.94      |
| 20           | 6474        | 1793  | 290  | 8557   | 254  | 7607      | 0    | 0     | 9628     | 9902     | -1676          | 24082            | 0             | 0                        | 24082                | 2895          | 562                 | 27539        | 49.94      |
| 21           | 6458        | 538   | 292  | 7288   | 194  | 6998      | 0    | 0     | 9859     | 10064    | -1712          | 22275            | 0             | 0                        | 22275                | 2730          | 557                 | 25562        | 50.02      |
| 22           | 6386        | 276   | 295  | 6957   | 170  | 6926      | 0    | 0     | 9919     | 9736     | -1643          | 21590            | 0             | 0                        | 21590                | 2575          | 555                 | 24721        | 49.99      |
| 23           | 6259        | 232   | 297  | 6788   | 171  | 6881      | 0    | 0     | 9957     | 9971     | -1612          | 21653            | 0             | 0                        | 21653                | 2415          | 546                 | 24614        | 49.95      |
| 24           | 6457        | 230   | 299  | 6986   | 176  | 6886      | 0    | 0     | 9819     | 9706     | -1517          | 21724            | 0             | 0                        | 21724                | 2290          | 513                 | 24527        | 50.00      |
| MUs          | 147.38      | 18.46 | 7.18 | 173.02 | 6.02 | 167.61    | 0.00 | 24.29 | 242.09   | 242.38   | -39.72         | 561.05           | 0.00          | 0.36                     | 561.05               | 60.51         | 12.55               | 634.12       | 49.98      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

1) ELR carried out due to overloading of 132kv chordiya solar line at 220Kv Manmad s/s, 2) ELR carried out due to overloading of 132 KV BBLR-Rahuri line.

| Maximum Demand scenario for the date 12/Feb/2025 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 29495 MW                                         | 25934 MW                         | 3067 MW                           |
| 11 Hrs                                           | 11 Hrs                           | 12 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

# State Load Despatch Center, Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 12/Feb/2025

Position as on 6.30 Hrs of 13/Feb/2025

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        | Chandrapur Unit 6       | 500      | 14/12/2024   | 19:45        |            | Continued. | Capital overhaul                                                                                                | 15/02/2025    |
| MSPGCL                        | Koyna Unit 9            | 80       | 24/01/2025   | 08:00        |            | Continued. | for upgradation of existing protection system to numerical protection system and H.S. Lubrication system work.  | 23/02/2025    |
| Total Capacity MSPGCL         |                         | 580      |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   | Tarapur 4               | 540      | 21/12/2024   | 21:50        |            | Continued. | Annual Overhaul                                                                                                 | 17/02/2025    |
| Total Capacity CENT.SECTOR    |                         | 540      |              |              |            |            |                                                                                                                 |               |
| Total Capacity PLANNED OUTAGE |                         | 1120     |              |              |            |            |                                                                                                                 |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | Turbine Tripped on High Vibrations                                                                              | 15/02/2025    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                              | 31/03/2025    |
| MSPGCL                        | Chandrapur Unit 9       | 500      | 11/01/2025   | 18:55        |            | Continued. | Generator Protection operated                                                                                   | 06/03/2025    |
| MSPGCL                        | Koyna Unit 8            | 80       | 31/01/2025   | 12:00        |            | Continued. | Due to Shaft vibrations problem                                                                                 | 19/02/2025    |
| MSPGCL                        | Nasik Unit 4            | 210      | 05/02/2025   | 01:36        |            | Continued. | For Boiler work                                                                                                 | 15/02/2025    |
| MSPGCL                        | Bhusawal Unit 4         | 500      | 09/02/2025   | 09:46        | 13/02/2025 | 03:03      | Boiler Tube Leakage                                                                                             | 13/02/2025    |
| MSPGCL                        | Chandrapur Unit 7       | 500      | 09/02/2025   | 23:15        | 12/02/2025 | 02:19      | Suspected BTL                                                                                                   | 14/02/2025    |
| MSPGCL                        | Parli Unit 7            | 250      | 12/02/2025   | 23:30        |            | Continued. | Boiler Tube Leakage                                                                                             | 14/02/2025    |
| Total Capacity MSPGCL         |                         | 2285     |              |              |            |            |                                                                                                                 |               |
| AEML                          |                         |          |              |              |            |            |                                                                                                                 |               |
| AEML                          | AEML Unit 1             | 250      | 01/02/2025   | 18:52        |            | Continued. | APH -1A Problem                                                                                                 | 15/02/2025    |
| Total Capacity AEML           |                         | 250      |              |              |            |            |                                                                                                                 |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                 |               |
| IPP                           | IEPL Unit 1             | 270      | 11/02/2025   | 12:07        | 13/02/2025 | 09:32      | Bottom ash evacuation & BTL problem                                                                             | 13/02/2025    |
| IPP                           | SWPGPL U-4              | 135      | 11/02/2025   | 19:57        |            | Continued. | Boiler Tube Leakage                                                                                             | 14/02/2025    |
| IPP                           | Adani U-2               | 660      | 12/02/2025   | 20:04        |            | Continued. | APH-A, PA hot air bellow leakage.                                                                               | 15/02/2025    |
| Total Capacity IPP            |                         | 1065     |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling. | 31/03/2025    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water                                                        | 05/04/2025    |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 12/Feb/2025**

Position as on 6.30 Hrs of 13/Feb/2025

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                               | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------------------------------------------------|---------------|
|                                               |                         |          |              |              |            |            | system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. |               |
| Total Capacity CENT.SECTOR                    |                         | 320      |              |              |            |            |                                                                                                |               |
| Total Capacity FORCED OUTAGE                  |                         | 3920     |              |              |            |            |                                                                                                |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |            |            |                                                                                                |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                                                                |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 06/02/2025   | 08:52        |            | Continued. | Zero Schedule Given By MSEDCL (not available due to boiler A2 work).                           |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 11/02/2025   | 20:00        | 12/02/2025 | 07:04      | No schedule from MSEDCL                                                                        |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 12/02/2025   | 08:45        | 13/02/2025 | 06:22      | No schedule from MSEDCL                                                                        |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 13/02/2025   | 09:10        |            | Continued. | No schedule from MSEDCL                                                                        |               |
| Total Capacity MSPGCL                         |                         | 432      |              |              |            |            |                                                                                                |               |
| IPP                                           |                         |          |              |              |            |            |                                                                                                |               |
| IPP                                           | JPL Unit 2              | 150      | 21/11/2024   | 01:30        |            | Continued. | Unit Out due to Non-avaialbility of Schedule.                                                  |               |
| Total Capacity IPP                            |                         | 150      |              |              |            |            |                                                                                                |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 582      |              |              |            |            |                                                                                                |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                                                                                |               |
| IPP                                           |                         |          |              |              |            |            |                                                                                                |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                           |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                           |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                        |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                         |               |
| Total Capacity IPP                            |                         | 988      |              |              |            |            |                                                                                                |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |            |            |                                                                                                |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Feb/2025**

**Statement-VII**

Position as on 6.30 Hrs of 13/Feb/2025

| Name of Line                                                   | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                             |
|----------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV TIEBAY Outages/Trippings</b>                         |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| TIE BAY (708) of KORADI - 3 CKT - 2 & EKTUNI CKT - 2 @ AKOLA 2 | IntraState                | 12/02/2025   | 1005         | 12/02/2025 | 19:08      | PO          | Annual Maintenance of Bay Equipment at Akola-II SS.                                                                                                                                                                                          |
| <b>765 KV MAINBAY Outages/Trippings</b>                        |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| MAIN BAY (709) OF KORADI 3 CKT- 2 @ AKOLA 2                    | IntraState                | 13/02/2025   | 09:39        |            |            | PO          | Annual Maintenance of Bay Equipment at Akola-II SS.                                                                                                                                                                                          |
| MAIN BAY (710) OF 1500MVA ICT 1@ 765KV EKTUNI                  | IntraState                | 13/02/2025   | 12:04        |            |            | PO          | Diagnostic Testing and Routine Maintenance Works                                                                                                                                                                                             |
| <b>400 KV TIEBAY Outages/Trippings</b>                         |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| 408 TIE BAY OF EKTUNI CKT 1 AND BUS REACTOR                    | InterState                | 09/02/2025   | 10:54        |            |            | PO          | Cable termination and testing work and IPS tube connection work                                                                                                                                                                              |
| Tie bay (408) of Ektuni line 1 @ Taptitanda                    | IntraState                | 09/02/2025   | 10:54        |            |            | HT          | Cable termination and testing work and ips tube connection work.                                                                                                                                                                             |
| <b>400 KV MAINBAY Outages/Trippings</b>                        |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| MAIN BAY (401) OF GT 9 @ 400KV CHANDRAPUR SWITCHING S/S        | InterState                | 10/02/2025   | 11:59        |            |            |             | Opportunity Outage for Overhauling and Testing work of 400KV Main CB of 401 Bay.                                                                                                                                                             |
| <b>400 KV LINE Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| DHULE - SSNNL CKT - 2                                          | InterState                | 04/12/2024   | 12:04        |            |            | EO          | 400kv Dhule SSNNL-2 line CB as hydraulic operated CB mechanism oil pressure is 310bar & not building up so it is requested to give permission for shifting of 400KV Dhule SSNNL-2 line load shifting to 400KV TBC urgently & attending same. |
| CHANDRAPUR - BHADRAVATI CKT - 2                                | InterState                | 12/02/2025   | 11:23        | 12/02/2025 | 20:44      | PO          | LBB ABB/RAICA Model relay will be upgraded to Numerical relay under under technology upgradation AT MSETCL END                                                                                                                               |
| 400 KV KORADI SARNI CKT                                        | InterState                | 12/02/2025   | 11:34        | 12/02/2025 | 23:26      | PO          | For AMP of Line Bay                                                                                                                                                                                                                          |
| TALANDGE - KOLHAPUR (PG) CKT - 1                               | InterState                | 12/02/2025   | 17:15        | 13/02/2025 | 06:42      | HT          | For LBB protection relay retrofitting works                                                                                                                                                                                                  |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I                      | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                                      |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                            | IntraState                | 14/01/2025   | 10:30        |            |            | HT          | For load management                                                                                                                                                                                                                          |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                            | IntraState                | 25/01/2025   | 09:38        |            |            | HT          | Control loading of Talegaon-chakan ckt.                                                                                                                                                                                                      |
| DABHOL - NAGOTHANE CKT - 2                                     | IntraState                | 10/02/2025   | 13:31        | 12/02/2025 | 19:34      | PO          | Chemical Washing work & Cold washing work                                                                                                                                                                                                    |
| CHANDRAPUR 2 - DHARIWAL CKT - 2                                | IntraState                | 12/02/2025   | 11:34        | 12/02/2025 | 15:46      | PO          | Line maintenance & Bay equipment testing work                                                                                                                                                                                                |
| PARLI-SOLAPUR (LAMBOTI)                                        | IntraState                | 12/02/2025   | 15:18        | 12/02/2025 | 19:57      | PO          | Hardware tightening and cold line washing                                                                                                                                                                                                    |
| <b>400 KV ICT Outages/Trippings</b>                            |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| STATION TF No 3 @ CHANDRAPUR GCR                               | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                               |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA                            | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                      |
| 400 /7.6KV Station T/F-5 A @ KHAPERKHEDA                       | IntraState                | 01/02/2025   | 10:56        |            |            | EO          | STN-5A due to Acetylene gas concentration crosses the safe limit of 7                                                                                                                                                                        |
| 400/220/33 KV 315MVA ICT - 1 @ CHAKAN                          | IntraState                | 13/02/2025   | 10:25        |            |            | PO          | Replacement of scissor Assembly of 89 B PG isolator R,Y,B phase of 315 MVA 400/220kv ICT-1                                                                                                                                                   |
| 400/220/33 KV 500 MVA ICT - 3 @ JEJURI                         | IntraState                | 13/02/2025   | 10:51        |            |            | PO          | For Maintenance & Testing work                                                                                                                                                                                                               |
| <b>400 KV BUSBAR Outages/Trippings</b>                         |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| PUNE-GIS - 400KV - BUS 2                                       | InterState                | 10/02/2025   | 14:14        |            |            | PO          | For Bus extension                                                                                                                                                                                                                            |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Feb/2025**

**Statement-VII**

Position as on 6.30 Hrs of 13/Feb/2025

| Name of Line                                                                                    | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                       |
|-------------------------------------------------------------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV BR Outages/Trippings</b>                                                              |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| BUS REACTOR (80 MVar) - 1 @<br>BABHALESHWAR                                                     | IntraState                   | 07/10/2024      | 09:40           |            |               | PO             | The work of Dismantling of<br>existing 80 MVAR replacement by<br>125 MVAR bus reactor along with<br>allied requirement at 400KV<br>Bableshtar has been entrusted to<br>M/s RK Electrical vide Zone office<br>order no. 1258 dtd 12.08.2022.<br>Following work are proposed on<br>reactor 1 1) Dismantling of reactor<br>1 2) Erection of new 125 MVAR<br>reactor 3) Commissioning work 4)<br>Replacement work as per the<br>work order |
| <b>220 KV TIEBAY Outages/Trippings</b>                                                          |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| BUS SECTIONALISER @<br>BELWANDI                                                                 | IntraState                   | 13/02/2025      | 12:04           |            |               | PO             | ANNUAL MAINTENANCE &<br>DIAGNOSTIC TESTING WORK                                                                                                                                                                                                                                                                                                                                                                                        |
| <b>220 KV MAINBAY Outages/Trippings</b>                                                         |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Main Bay-220 kV Boisar(PG)-Tarapur<br>-3,4 And 220 kV Boisar(PG)- BUS 1<br>at 220 kV Boisar(PG) | InterState                   | 12/02/2025      | 23:48           | 12/02/2025 | 07:38         | HT             | For busbar testing work                                                                                                                                                                                                                                                                                                                                                                                                                |
| 220KV BUS SECTION BAY @<br>PEDAMBE                                                              | IntraState                   | 03/04/2024      | 15:55           |            |               | T              | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                                                                                                                                                                           |
| TBC @ BHOSARI-1                                                                                 | IntraState                   | 12/02/2025      | 11:22           | 12/02/2025 | 12:40         | PO             | 220kV TBC Bay CT Tan Delta<br>Measurment work                                                                                                                                                                                                                                                                                                                                                                                          |
| <b>220 KV LINE Outages/Trippings</b>                                                            |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| BALE - SOLAPUR (PG)                                                                             | InterState                   | 19/06/2024      | 08:56           |            |               | PO             | 1) Outage is required for Project<br>work for Balance foundation,<br>erection & stringing work of 220<br>kV Bale-PGCIL M/C portion (From<br>Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL<br>arrangement will be changed from<br>220 kV PG-Dharashiv<br>(Osmanabad). (Bunching<br>arrangement at Loc. No. 37)                                                                                                                               |
| PRINT HOUSE - NAVI MUMBAI (PG)                                                                  | InterState                   | 05/12/2024      | 23:09           |            |               | EO             | 1) For bunching at TL no 678/1<br>with 220kV Kalwa-Panchanand<br>line to provide 2nd source to<br>Panchanand & Talaja s/stn.<br>2)For opening jumpers at TL no<br>678/1.                                                                                                                                                                                                                                                               |
| BUS - 1 @ BOISAR (PG)                                                                           | InterState                   | 06/02/2025      | 18:51           | 12/02/2025 | 17:54         | PO             | Continuous outage of 220kV Bus-<br>1 for Bus-bar relay retrofitting &<br>testing                                                                                                                                                                                                                                                                                                                                                       |
| PANCHALI TSS - BOISAR (PG)                                                                      | InterState                   | 11/02/2025      | 23:31           | 12/02/2025 | 07:18         | PO             | Simultaneous outage of 220KV<br>Bus-2 and line for busbar relay<br>retrofitting and testing                                                                                                                                                                                                                                                                                                                                            |
| OSMANABAD - SOLAPUR (BALE)                                                                      | IntraState                   | 19/06/2024      | 09:15           |            |               | PO             | 1) Outage is required for Project<br>work for Balance foundation,<br>erection & stringing work of 220<br>kV Bale-PGCIL M/C portion (From<br>Loc No 17A-37 A) 2) 220 kV Bale-<br>PGCIL arrangement will be<br>changed from 220 kV PG-<br>Dharashiv (Osmanabad).<br>(Bunching arrangement at Loc.<br>No. 37)                                                                                                                             |
| WAGHIVALI (MSETCL) - ULWE GIS<br>CKT - 2                                                        | IntraState                   | 25/06/2024      | 08:05           |            |               | T              | Tripped on differential protection.                                                                                                                                                                                                                                                                                                                                                                                                    |
| 220KV KORADI II(400KV) -<br>BUTIBORI 3 CKT II                                                   | IntraState                   | 01/10/2024      | 13:11           |            |               | HT             | H/T From Koradi 2 end                                                                                                                                                                                                                                                                                                                                                                                                                  |
| KALWA - PANCHANAND                                                                              | IntraState                   | 17/10/2024      | 12:10           |            |               | EO             | For providing bunching at Loc. No.<br>691 by fixing T clamps & jumper<br>connections to provide 2nd source<br>to 220kV Talaja.                                                                                                                                                                                                                                                                                                         |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Feb/2025**

**Statement-VII**

Position as on 6.30 Hrs of 13/Feb/2025

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                           |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                                                                                                                       |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                                                                                                                       |
| TROMBAY - DHARAVI 9                           | IntraState                | 19/01/2025   | 18:38        |            |            | EO          | Attending hotspot on BS-3                                                                                                                                                                                                                                  |
| SAKI (AEML) - SAKI (TATA) CKT - 2             | IntraState                | 21/01/2025   | 15:26        |            |            | HT          | Fire Caught near Marve Bridge                                                                                                                                                                                                                              |
| SAKI (AEML) - SAKI (TATA) CKT - 1             | IntraState                | 21/01/2025   | 15:26        |            |            | HT          | fire caught near Marve bridge                                                                                                                                                                                                                              |
| TALANDGE - MUDSHINGI CKT - 1                  | IntraState                | 10/02/2025   | 12:04        |            |            | PO          | 220kV Circuit breaker overhauling work will be done by agency                                                                                                                                                                                              |
| VANKUSWADE - KDPH                             | IntraState                | 11/02/2025   | 15:30        | 12/02/2025 | 17:11      | PO          | Diagnostic Testing Work & Quarterly Maintenance Work                                                                                                                                                                                                       |
| BORIVALI - TARAPUR                            | IntraState                | 11/02/2025   | 16:34        |            |            | PO          | 1) TAPS 1&2, 220kV Zone-II main bus outages to carry out annual maintenance of main bus and bay's equipments. 2) Remarks: During outage period BS#1between 220 KV Zone-1 & Zone-II will remain open from 0800 hrs of 10/02/2025 to 1800 hrs of 15/02/2025. |
| EKLAHARE (OCR) - NAVASARI CKT - 1             | IntraState                | 11/02/2025   | 18:08        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                   |
| EKLAHARE (OCR) - NAVASARI CKT - 2             | IntraState                | 11/02/2025   | 18:09        | 12/02/2025 | 14:08      | HT          | H/T for load management.                                                                                                                                                                                                                                   |
| EKLAHARE (OCR) - PADGHE                       | IntraState                | 11/02/2025   | 18:35        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                   |
| MALEGAON-SATANA                               | IntraState                | 12/02/2025   | 05:28        | 12/02/2025 | 18:11      | HT          | Load management                                                                                                                                                                                                                                            |
| HINJAWADI I- CHINCHWAD                        | IntraState                | 12/02/2025   | 07:20        | 12/02/2025 | 23:21      | HT          | Load management                                                                                                                                                                                                                                            |
| ALEPHATA-PARGAON(KATHAPUR)                    | IntraState                | 12/02/2025   | 07:47        | 12/02/2025 | 20:38      | HT          | Load management                                                                                                                                                                                                                                            |
| 132 KV GHATODI (220 KV ) - PUSAD CKT          | IntraState                | 12/02/2025   | 08:27        | 12/02/2025 | 22:58      | HT          | 220kV Yeotmal-Pusad Ckt U/Outage. Ckt H/T For Load management                                                                                                                                                                                              |
| PUSAD-GHATODI                                 | IntraState                | 12/02/2025   | 08:38        | 12/02/2025 | 22:57      | HT          | 220kV Yeotmal-Pusad Ckt U/Outage. Ckt H/T For Load management                                                                                                                                                                                              |
| YEOTMAL- PUSAD                                | IntraState                | 12/02/2025   | 08:43        | 12/02/2025 | 22:50      | PO          | For Shifting of line from ERS to new inline towers at Loc no.181 under ORC work for the work of Diversion of 220kV Deoli-Pusad line for Wardha-Yavatmal-Nanded railway line crossing                                                                       |
| VSNL- KHADKI                                  | IntraState                | 12/02/2025   | 11:13        | 12/02/2025 | 17:20      | PO          | Half yearly maint. work                                                                                                                                                                                                                                    |
| HALKARNI-MAHALAXMI LINE                       | IntraState                | 12/02/2025   | 11:21        | 12/02/2025 | 17:12      | PO          | Insulator cleaning work                                                                                                                                                                                                                                    |
| GADCHANDUR - VIRUR-I                          | IntraState                | 12/02/2025   | 11:40        | 12/02/2025 | 13:48      | PO          | Diagnostic testing work                                                                                                                                                                                                                                    |
| PHURSUNGI-PARVATI                             | IntraState                | 12/02/2025   | 11:57        | 12/02/2025 | 13:32      | PO          | CB CRM and Timing                                                                                                                                                                                                                                          |
| 132 KV AMBAZARI (220KV) - MANKAPUR CKT II     | IntraState                | 12/02/2025   | 12:24        | 12/02/2025 | 13:39      | T           | Distance protection operated                                                                                                                                                                                                                               |
| 220 KV DEEPNAGAR - VIRODA                     | IntraState                | 12/02/2025   | 13:32        | 12/02/2025 | 16:31      | PO          | Replacement of faulty 195B TCS relays and to attend low SF6 pressure false indication issue of circuit breaker.                                                                                                                                            |
| 220 KV KAULEWADA-KORADI 2 CKT - II            | IntraState                | 12/02/2025   | 14:14        | 12/02/2025 | 19:31      | EO          | Problem in Distance Relay                                                                                                                                                                                                                                  |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Feb/2025**

**Statement-VII**

Position as on 6.30 Hrs of 13/Feb/2025

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                          |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| NERLE - PEDAMBE                          | IntraState                | 12/02/2025   | 15:25        | 12/02/2025 | 18:47      | PO          | For replacement of damaged conductor at loc no 2 Loc no - 16B,Rph (top),Pedhambe side, 9B,Bph (bottom), Nerale side, loc.no - 22B,R phase (Top), Pedhambe side, loc no - 43B,Rph,(top), Pedhambe side, Loc no - 34B, Top ph Nerale side, Loc no- 34B, middle ph Pedhambe side, Loc no - 34B, bottom ph Nerale side, Loc no - 35B, Top ph Pedhambe side ,Loc no - 37B, bottom ph Pedhambe side, Loc no - 82B, Nerale side. |
| EKLAHARE (GCR) - AIROLI KNOW PARK        | IntraState                | 12/02/2025   | 16:30        | 12/02/2025 | 23:19      | HT          | Load management                                                                                                                                                                                                                                                                                                                                                                                                           |
| FLAGSHIP-CHINCHWAD                       | IntraState                | 12/02/2025   | 23:01        | 13/02/2025 | 01:58      | HT          | Load management                                                                                                                                                                                                                                                                                                                                                                                                           |
| HINJAWADI I- CHINCHWAD                   | IntraState                | 13/02/2025   | 01:45        | 13/02/2025 | 02:03      | HT          | Load management                                                                                                                                                                                                                                                                                                                                                                                                           |
| NANDED CITY-FLAGSHIP                     | IntraState                | 13/02/2025   | 01:58        |            |            | HT          | Emergency outage on dated 13.02.2025.                                                                                                                                                                                                                                                                                                                                                                                     |
| MUMEWADI -HALKARNI 1 LINE                | IntraState                | 13/02/2025   | 11:12        |            |            | PO          | Insulator cleaning work                                                                                                                                                                                                                                                                                                                                                                                                   |
| LONIKAND 2 - BHOSARI                     | IntraState                | 13/02/2025   | 11:46        |            |            | PO          | Cleaning of Disc Insulators (Cold line washing) work.                                                                                                                                                                                                                                                                                                                                                                     |
| NERLE- POPHALI                           | IntraState                | 13/02/2025   | 11:56        |            |            | PO          | For replacement of conductor at Loc no 16B, Rph(top), Pophali side, loc no - 37B Phase Pophali side and other line related maintenance work.                                                                                                                                                                                                                                                                              |
| THEUR - SERUM                            | IntraState                | 13/02/2025   | 12:58        |            |            | PO          | Annual testing of all the CT and PT                                                                                                                                                                                                                                                                                                                                                                                       |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                           |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2         | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                                                                                                                                                                                                                                                                                                                               |
| 220/132 KV 150 MVA PTR NO 7 @ CHINCHWAD  | IntraState                | 11/11/2024   | 03:05        |            |            | T           | Bucholz Protection                                                                                                                                                                                                                                                                                                                                                                                                        |
| 220/100 KV 200 MVA ICT 4 @ PADGHE        | IntraState                | 12/02/2025   | 12:06        | 12/02/2025 | 21:40      | PO          | HV / LV Back up relay replacement under scheme                                                                                                                                                                                                                                                                                                                                                                            |
| 220/132KV 100MVA ICT 2 @ SHENDRA         | IntraState                | 12/02/2025   | 12:09        | 12/02/2025 | 18:17      | PO          | Diagnostic testing work (Tandelta, CRM Timing of CB ETC.)                                                                                                                                                                                                                                                                                                                                                                 |
| 220/132-110 KV 200MVA ICT - 3 @ OGLEWADI | IntraState                | 12/02/2025   | 12:40        | 12/02/2025 | 16:15      | EO          | Tightening of all earthing connections                                                                                                                                                                                                                                                                                                                                                                                    |
| 220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR  | IntraState                | 12/02/2025   | 14:37        | 12/02/2025 | 17:07      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                                                                                                                                                                                                              |
| 220 KV /33 KV 50 MVA PTR 1 @ CHITEGAON   | IntraState                | 12/02/2025   | 20:50        | 12/02/2025 | 21:07      | T           | Tripped on Differential protection                                                                                                                                                                                                                                                                                                                                                                                        |
| 220/33 KV 50 MVA PTR 2 @ HAMIDWADA       | IntraState                | 13/02/2025   | 05:35        |            |            | PO          | Overhauling of OLTC along with inspection of selector switch.                                                                                                                                                                                                                                                                                                                                                             |
| 220/33KV 25MVA PTR 1 @ NIWALI            | IntraState                | 13/02/2025   | 10:30        |            |            | PO          | OLTC overhauling work.                                                                                                                                                                                                                                                                                                                                                                                                    |
| PT - 2 @ PHURSUNGI                       | IntraState                | 13/02/2025   | 10:52        |            |            | PO          | Half Yearly Maint. work                                                                                                                                                                                                                                                                                                                                                                                                   |
| 220/33KV 50MVA PTR 1 @ JEJURI            | IntraState                | 13/02/2025   | 11:16        |            |            | PO          | T/F OLTC overhauling work and relay testing work                                                                                                                                                                                                                                                                                                                                                                          |
| 220/132KV 100MVA ICT 2 @ KATHAPUR        | IntraState                | 13/02/2025   | 12:30        |            |            | PO          | Diagnostic Testing and routine Maintenance.                                                                                                                                                                                                                                                                                                                                                                               |
| 220/132 KV 100 MVA ICT - 2 @ ALEPHATA    | IntraState                | 13/02/2025   | 12:55        |            |            | PO          | LV CT Tan delta measurement due to higher Tan delta results                                                                                                                                                                                                                                                                                                                                                               |
| <b>220 KV BUSBAR Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                           |
| MAIN BUS - 2 @ PHURSUNGI                 | IntraState                | 13/02/2025   | 12:05        |            |            | PO          | Half yearly manit. work                                                                                                                                                                                                                                                                                                                                                                                                   |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                           |
| MANSAR-PENCH                             | InterState                | 26/09/2024   | 14:40        | 12/02/2025 | 13:20      | HT          | H/T at 132KV Pench end                                                                                                                                                                                                                                                                                                                                                                                                    |
| 132 KV KANHAN (220 KV) - PENCH CKT       | InterState                | 29/01/2025   | 10:56        | 12/02/2025 | 13:20      | HT          | H/T AT PENCH END AFTER BLACK START                                                                                                                                                                                                                                                                                                                                                                                        |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Feb/2025**

**Statement-VII**

Position as on 6.30 Hrs of 13/Feb/2025

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                              |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| MANSAR-PENCH                             | InterState                | 12/02/2025   | 19:12        |            |            | HT          | System Constraints H/T at Pench End.                                                                                                                                                                                                                                                                                                                                          |
| CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP | IntraState                | 16/10/2024   | 07:02        |            |            | HT          | For Load Management                                                                                                                                                                                                                                                                                                                                                           |
| 132 KV PATHRI-MAJALGAON CKT              | IntraState                | 06/01/2025   | 13:05        |            |            | HT          | After completion of outage on 132kv patri parbhani ckt                                                                                                                                                                                                                                                                                                                        |
| PARBHANI-GANGAKHED                       | IntraState                | 11/02/2025   | 18:37        |            |            | HT          | Due to overloading of parly 100MVA IBT                                                                                                                                                                                                                                                                                                                                        |
| 132 KV KANHAN (220 KV) - PARDI CKT       | IntraState                | 12/02/2025   | 11:15        |            |            | T           | Tripped on LMS (275 AMP)                                                                                                                                                                                                                                                                                                                                                      |
| KANHAN-MANSAR                            | IntraState                | 12/02/2025   | 13:20        | 12/02/2025 | 19:12      | PO          | For routine maintenance work                                                                                                                                                                                                                                                                                                                                                  |
| MANMAD - CHORDIYA SOLAR LINE             | IntraState                | 12/02/2025   | 16:50        | 12/02/2025 | 23:53      | EO          | 132kv Manmad Chordiya ckt will be kept of and LILO                                                                                                                                                                                                                                                                                                                            |
| MEHKAR - MALEGAON                        | IntraState                | 12/02/2025   | 17:05        | 12/02/2025 | 19:44      | T           | Distance protection                                                                                                                                                                                                                                                                                                                                                           |
| MANMAD-PIMPERKHED                        | IntraState                | 12/02/2025   | 18:36        | 13/02/2025 | 00:54      | EO          | 1st manmad chordiya ckt krpt off and LILO jumper will be removed. 2nd 132kv Manmad Pimperkhed krpt off and chordiya solar tap jumper execute and solar will be restore on existing Man-Pimperkhed ckt 3rd 132kv chordiya chalisgaon kept and through jumper will be fixed at loc 96 of 132kv man-chalisgaon then supply will be restord                                       |
| 132KV CHALISGAON-1 - CHORDIYA SOLAR LINE | IntraState                | 12/02/2025   | 21:00        | 12/02/2025 | 23:53      | EO          | 1. Ist 132kv Man-Choridya Ckt kept off and LILO jumper will be removed.<br>2. 2nd 132k Manmad-Pimperkhed kept off and Chordiya Solar Tap jumper executed and chordiya solar will be restored on existing Man-Pimperkhed Ckt.<br>3. 3rd 132kv Chordia 2 Chalisgaon kept off and Through jumper will be fixed at loc 96 of 132kv Manmad-Chalisgaon then supply will be restored |
| <b>132 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                               |
| 132/33 KV 50 MVA PTR 2 @ DONDAICHA       | IntraState                | 15/11/2024   | 11:40        |            |            | T           | Tripped on Buchholz alarm                                                                                                                                                                                                                                                                                                                                                     |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage