

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Mar/2025 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	166.502	2042.834	1) Gujrat	1.366	24.027
2) Hydro	31.879	246.775	2) Madhya Pradesh	13.735	138.988
3) Gas	5.844	65.598	3) Chattisgarh	4.800	54.160
Total MSPGCL	204.225	2355.207	4) Maharashtra	226.410	2628.542
B) 1) APLM	75.183	737.654	5) Goa (Amona)	-2.649	-32.365
2) JSWEL	24.238	311.900	Total	243.662	2813.352
3) VIPL	0.000	0.000	a) Mumbai Schedule	42.421	447.898
4) RPL(AMT)	25.602	371.130	b) Mumbai Drawl	43.829	485.136
5) SWPGPL	12.417	148.756	c) MSEDCL Bilateral *	123.938	1440.470
6) Other IPP	23.402	328.238	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	42.421	447.898
C) 1) TPCL Thermal	11.994	128.923	Include PX	0.000	0.000
2) TPCL Hydro	5.109	36.298	Standby	0.000	0.000
3) TPCL Gas	4.265	49.066	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.985	122.153	1) MSEDCL	583.199	6845.904
D) STATE			2) Mumbai Discoms	76.183	821.577
1) Thermal	350.323	4191.588	3) Other Discoms	13.626	156.681
(A1+C1+C4+(B1-B6))			TOTAL STATE	673.008	7824.162
2) Hydro	36.988	283.073			
(A2+C2)					
3) Gas	10.109	114.664			
(A3+B7+C3)					
4) Wind	6.491	108.633			
6) SOLAR	25.434	312.851			
TOTAL STATE	429.345	5010.809			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6542	6263	7273	7143
MSPGCL Hydro	1698	1298	2300	425
MSPGCL Gas	214	210	305	227
MSPGCL Total Generation	8454	7771	9878	7795
Central Sector Receipt	10549	10957	10637	10222
WIND	217	426	250	329
CPP / IPP Thermal	6711	5762	6755	6999
CPP / IPP Gas	0	0	0	0
SOLAR	3124	3582	0	0
Exchange with Mumbai	-2377	-2659	-1677	-1292
MSEDCL DEMAND MET	26083	25257	25234	23632
Load Shedding	0	0	0	0
MSEDCL DEMAND	26083	25257	25234	23632
TPCL GENERATION	686	703	1239	655
AEML GENERATION	490	302	499	491
MUMBAI DEMAND	3553	3664	3415	2438
OTHER DISCOM DEMAND	595	582	609	421
STATE DEMAND MET	30231	29503	29258	26491
STATE DEMAND	30231	29503	29258	26491
Frequency (Hz)	49.95	50.04	50.01	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 13:01 Hrs	49.64 Hz at 16:57 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Mar/2025

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.55	46.33	171	120
Unit 8	14.37	167.03	631	568
Unit 9	14.16	162.30	612	565
Unit 10	8.18	159.08	590	0
Total	40.27	534.73		
Bhusawal				
Unit 3	3.22	38.78	150	120
Unit 4	10.02	118.02	490	275
Unit 5	7.66	80.68	460	0
Unit 6	0.00	44.43	0	0
Total	20.90	281.90		
Parli				
Unit 6	4.80	55.96	250	140
Unit 7	4.06	53.24	230	115
Unit 8	4.58	50.75	218	144
Total	13.44	159.95		
Chandrapur				
Unit 3	4.34	50.30	198	124
Unit 4	1.52	23.67	155	0
Unit 5	8.66	102.83	405	285
Unit 6	9.88	102.85	485	280
Unit 7	8.84	108.26	426	283
Unit 8	10.88	129.47	475	400
Unit 9	0.00	0.00	0	0
Total	44.11	517.38		
Paras				
Unit 3	4.59	59.60	222	144
Unit 4	5.30	58.48	239	182
Total	9.88	118.08		
Khaparkheda				
Unit 1	4.04	45.62	180	160
Unit 2	4.12	47.68	191	131
Unit 3	4.04	46.74	190	141
Unit 4	3.84	43.52	180	143
Unit 5	10.95	128.86	475	430
Total	26.98	312.42		
Nasik				
Unit 3	3.44	40.01	157	124
Unit 4	3.92	43.20	174	122
Unit 5	3.57	35.15	163	113
Total	10.92	118.36		
Uran				
All Units	5.84	65.60	320	206
Total	5.84	65.60		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.19	2.78	23	0
Total	0.19	2.78		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.03	31.90	575	40
Stage 4	16.30	111.53	1005	200
Stage 3	4.61	30.92	300	0
Total	25.94	174.35		
Hydro				
KDPH	0.84	9.95	35	35
VTRNA	0.44	4.82	60	0
TILLARI	0.44	4.98	62	0
BHIRA T.R.	0.22	1.37	40	0
SMLHY_PTN	3.72	47.36	178	137
GHATGHAR	0.29	3.94	100	0
Total	5.94	72.42		
Wind				
Total	6.49	108.63	0	0
Total	6.49	108.63		
CPP				
APML(Mus)	75.18	737.65	0	0
JSWEL(Mus)	24.24	311.90	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.60	371.13	0	0
SWPGPL-Mus	12.42	148.76	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.97	70.72	269	198
Other(Mus)	12.65	203.79	0	0
JPL	4.78	53.72	273	155
Total	160.84	1897.68		
SOLAR				
Total	25.43	312.85	0	0
Total	25.43	312.85		
Tata				
Trombay 5	7.95	85.59	456	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.70	30.65	115	109
Trombay 7B	1.57	18.42	66	65
TATA Hydro	5.11	36.30	430	83
Trombay 8	4.04	43.33	225	124
Total	21.37	214.29		
AEML				
DTPS U-1&2	10.98	122.15	500	286
Total	10.98	122.15		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	166.50	2042.83	MSPGCL Total	204.22	2355.21
			MSPGCL Thml+Gas	172.35	2108.43	Koyna 1,2 & 4 Total	21.33	143.43
			MSPGCL Hydro	31.88	246.78	State Total	429.34	5010.81

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Mar/2025

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7105	628	225	7958	289	6886	0	0	10518	10681	-1763	23533	0	0	23533	3000	518	27051	50.01
2	7035	449	226	7710	309	6933	0	0	10654	10659	-1627	23515	0	0	23515	2756	469	26740	49.99
3	7097	426	227	7750	356	6959	0	0	10190	10324	-1401	23530	0	0	23530	2571	458	26559	49.97
4	7143	425	227	7795	329	6999	0	0	10115	10222	-1292	23621	0	0	23621	2438	432	26491	49.99
5	7211	735	226	8172	349	7018	0	0	9924	10179	-1185	24097	0	0	24097	2383	436	26916	49.99
6	7375	1029	235	8639	391	7030	0	0	9970	10099	-1153	24531	0	0	24531	2470	475	27476	49.98
7	7572	1685	320	9577	391	7134	0	46	9320	9465	-1041	25039	0	8	25039	2612	533	28184	50.01
8	7549	1841	317	9707	288	7135	0	522	8909	8966	-1133	24924	0	5	24924	2748	561	28233	50.05
9	7190	1515	237	8942	160	6869	0	1538	9822	9511	-1734	24684	0	0	24684	3031	602	28317	50.04
10	6511	1364	223	8098	170	6881	0	2413	10132	10405	-2063	25293	0	0	25293	3324	611	29228	49.93
11	6542	1698	214	8454	217	6711	0	3124	10610	10549	-2377	26069	0	101	26069	3553	609	30231	49.95
12	6565	1494	211	8270	312	6679	0	3438	10966	10507	-2649	25955	0	200	25955	3665	602	30222	50.02
13	6263	1298	210	7771	426	5762	0	3582	10977	10957	-2659	25242	0	16	25242	3664	597	29503	50.04
14	5932	791	209	6932	344	5747	0	3427	11082	11371	-2592	24633	0	0	24633	3582	596	28811	50.09
15	6025	841	206	7072	274	6412	0	3008	11251	10460	-2747	23875	0	5	23875	3708	604	28187	49.97
16	6142	1524	219	7885	196	6424	0	2297	11563	7912	-2110	21978	0	3075	21978	3708	626	26312	50.06
17	6525	1767	299	8591	179	6385	0	1508	9774	8956	-1871	23115	0	2182	23115	3651	633	27399	49.96
18	7088	1811	301	9200	151	6522	0	512	9579	9584	-1809	23513	0	1452	23513	3589	647	27749	50.01
19	7085	1563	303	8951	193	6563	0	19	10679	10636	-1760	23962	0	0	23962	3464	640	28066	50.00
20	7273	2300	305	9878	250	6755	0	0	10106	10637	-1677	25220	0	0	25220	3415	623	29258	50.01
21	7204	2035	250	9489	216	6781	0	0	10112	10056	-1672	24254	0	0	24254	3288	616	28158	50.01
22	7290	1767	216	9273	259	6746	0	0	10259	10200	-1810	24074	0	0	24074	3203	594	27871	50.00
23	7443	1592	219	9254	248	6763	0	0	10341	10401	-1789	24287	0	0	24287	3166	590	28043	49.95
24	7337	1301	219	8857	194	6748	0	0	10854	10925	-1915	24257	0	0	24257	3193	552	28002	49.97
MUs	166.50	31.88	5.84	204.23	6.49	160.84	0.00	25.43	247.71	243.66	-43.83	583.20	0.00	7.04	583.20	76.18	13.63	673.01	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)LTS operated due to under voltages of multiple 400kV S/Stn.2)ELR carried out due to overload of 132kV BBLR-Rahuri line at 132kV Rahuri s/s.3)Due to overload of 25MVA 132/33kV T/F-1 & T/F-2 are parallel & HV overload at 132kV Wadzire s/stn.

Maximum Demand scenario for the date 12/Mar/2025		
State Demand	MSEDC L Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
30231 MW	26069 MW	3708 MW
11 Hrs	11 Hrs	15 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Mar/2025

Position as on 6.30 Hrs of 13/Mar/2025

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	31/03/2025
MSPGCL	Chandrapur Unit 9	500	11/01/2025	18:55		Continued.	Generator Protection operated	30/04/2025
MSPGCL	Uran Unit 7	108	04/03/2025	14:15		Continued.	Turbine bearing vibration high	20/03/2025
MSPGCL	Bhusawal Unit 6	660	05/03/2025	00:04		Continued.	PG TEST preparation	15/03/2025
MSPGCL	Chandrapur Unit 4	210	08/03/2025	09:55	12/03/2025	11:50	Boiler Tube Leakage	12/03/2025
MSPGCL	Uran Unit A0	120	10/03/2025	03:09		Continued.	Turbine Vibration	20/03/2025
MSPGCL	Koyna STG-IV Unit-4	250	11/03/2025	17:00	12/03/2025	00:40	Spherical valve control fault	
MSPGCL	Koyna Unit 11	80	11/03/2025	18:30	12/03/2025	00:00	Excitation voltage not buildup	
MSPGCL	Bhusawal Unit 5	500	11/03/2025	22:57	12/03/2025	02.03	Flame Failure	
MSPGCL	Koradi Unit-10	660	12/03/2025	13:21	12/03/2025	20:48	Governing Valve Oil Leakage of Main Turbine.	
Total Capacity MSPGCL		3213						
IPP								
IPP	RPL(AMT) U-4	270	11/03/2025	21:00	13/03/2025	21:13	Bottom Ash evacuation problem	14/03/2025
IPP	JSW (J) U1	300	12/03/2025	14:30		Continued.	Turbine Vibration	30/03/2025
Total Capacity IPP		570						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2025
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	05/04/2025
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		4103						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	11/03/2025	20:00	12/03/2025	15:49	Emergency Pick Up Given due to grid occurence	
MSPGCL	Uran Unit 5	108	12/03/2025	20:30	13/03/2025	16:26	Zero Schedule	
MSPGCL	Uran Unit 5	108	13/03/2025	19:30		Continued.	Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		324						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		324						
FORCED OUTAGE DUE TO NO PPA								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Mar/2025

Position as on 6.30 Hrs of 13/Mar/2025

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Mar/2025

Statement-VII

Position as on 6.30 Hrs of 13/Mar/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400/11.5 KV 110MVA STN T/F 6A @ DEEPNAGAR	InterState	08/03/2025	10:44			T	WINDING TEMP TRIPPED, MTR OPTD.
MAIN BAY (410) OF ICT-2 @ KUDUS	IntraState	12/03/2025	14:24	12/03/2025	17:12	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
400 KV LR Outages/Trippings							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	04/12/2024	12:04			EO	400kv Dhule SSNNL-2 line CB as hydraulic operated CB mechanism oil pressure is 310bar & not building up so it is requested to give permission for shifting of 400KV Dhule SSNNL-2 line load shifting to 400KV TBC urgently & attending same.
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/03/2025	10:00	12/03/2025	15:15	HT	For load management
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	10/03/2025	06:46	12/03/2025	15:15	HT	H/T AT WALUJ END ONLY.
CHANDRAPUR 2 - DHARIWAL CKT - 2	IntraState	12/03/2025	06:02	12/03/2025	17:08	PO	Line & its Bay Equipment PM & Testing work
DEEPNAGAR - THAPTI TANDA	IntraState	12/03/2025	07:16	12/03/2025	16:59	PO	To increase the ground clearance at span 202-203 and other maintenance work like disc replacment and nut-bolt tightning work
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	12/03/2025	13:09	12/03/2025	13:43	T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	12/03/2025	18:02			HT	for load management
PARLI-SOLAPUR (LAMBOTI)	IntraState	12/03/2025	19:50	13/03/2025	02:01	PO	Hardware tightening, string replacement and cold line washing
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	13/03/2025	01:15			HT	load management
CHANDRAPUR 2 - DHARIWAL CKT - 2	IntraState	13/03/2025	06:06	13/03/2025	13:48	PO	Line & its Bay Equipment PM & Testing work
RPL(AMT) NANDGAON PETH - AKOLA 2 CKT - 1	IntraState	13/03/2025	12:58	13/03/2025	16:36	EO	Outage required for Corona ring on the top of insulator is broken and hang on the insulator. Ring create chartering and noise and shows glow during night hours at loc-15/15 in B phase suspension insulator
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	13/03/2025	13:26	13/03/2025	20:02	T	Tripped on distance protection.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	IntraState	01/02/2025	10:56		Continued.	EO	STN-5A due to Acetylene gas concentration crosses the safe limit of 7
105 MVA SPARE ICT @ CHAKAN	IntraState	26/02/2025	10:59			PO	Long Duration outage required for Rapid restoration scheme work of ICT at 400kv Chakan s/sn

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 12/Mar/2025

Statement-VII

Position as on 6.30 Hrs of 13/Mar/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	12/03/2025	18:41	12/03/2025	22:44	PO	1. Quarterly Maintenance Work 2. Replacement Work of LV R Ph conductor 3. Replacement work of mid span joint LV side conductor in diff zone
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	13/03/2025	11:28	13/03/2025	14:48	T	Tripped due to Yph. Tertiary LA burst.
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	13/03/2025	12:40	13/03/2025	18:35	PO	1) Diagnostic Testing of CB (Timing, DCRM & IR) and Routine Maintenance. 2) Outage on 400/220/33 KV 315 MVA ICT - 1 @ WALUJ through TBC Bay
400 KV BR Outages/Tripping							
400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2	InterState	12/03/2025	09:36	13/03/2025	00:16	PO	Diagnostic testing and allied bay maintenance work
BUS REACTOR (80 MVar) - 1 @ TIRORA	IntraState	10/03/2025	09:38			PO	Dia Equipment Maintenance
BUS REACTOR (80 MVar) - 2 @ TIRORA	IntraState	13/03/2025	10:20	13/03/2025	12:55	PO	Dia Equipment Maintenance
220 KV TIEBAY Outages/Tripping							
BUS COUPLER @ PHURSUNGI	IntraState	11/03/2025	07:36		Continued.	HT	Load management
220 KV MAINBAY Outages/Tripping							
220KV YAWATMAL- WARDHA(DEOLI) PG CKT 1	InterState	12/03/2025	14:31	12/03/2025	18:49	EO	For attending Hot glow on Line Isolator Rph Pad towards CB (Temp -180°C) Nut Bolt
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Tripping							
PRINT HOUSE - NAVI MUMBAI (PG)	InterState	05/12/2024	23:09			EO	1) For bunching at TL no 678/1 with 220kV Kalwa-Panchanand line to provide 2nd source to Panchanand & Talaja s/stn. 2)For opening jumpers at TL no 678/1.
220 kV-Wardha(PG)-Yawatmal Ckt-1	InterState	12/03/2025	14:31	12/03/2025	18:49	EO	Attending Hot glow on line isolator R-ph pad towards CB temp-180 deg nut bolt.
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Talaja.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
TROMBAY - DHARAVI 9	IntraState	19/01/2025	18:38			EO	Attending hotspot on BS-3
SAKI (AEML) - SAKI (TATA) CKT - 2	IntraState	21/01/2025	15:26			HT	Fire Caught near Marve Bridge
SAKI (AEML) - SAKI (TATA) CKT - 1	IntraState	21/01/2025	15:26			HT	fire caught near Marve bridge
EKLAHARE (OCR) - PADGHE	IntraState	11/02/2025	18:35		Continued.	HT	H/T for load management.
220KV TULJAPUR-BALE CKT	IntraState	03/03/2025	00:45			T	TULJAPUR: D/P,Z1,B PH,33KM, CB CLOSED AT BALE END.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	06/03/2025	19:27	12/03/2025	11:18	HT	H/T for load management.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Mar/2025

Statement-VII

Position as on 6.30 Hrs of 13/Mar/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PUSAD - WARDHA (PG)	IntraState	08/03/2025	20:26			PO	1)Shifting of Line on ERS for Erection & Conductor Stringing of Inline Towers under ORC work for the work of Diversion of 220kV Deoli - Pusad Line at Loc. No. 181 -182 by considering Monopole Tower for Wardha - Yavatmal - Nanded Railway Line Crossing. 2) ORC WORK -Diversion of 220KV Deoli PG-Pusad line at loc 250-251 due to four lanning of NH -361 (Butibori-Tuljapur)- shifting of line on ERS thereof. 3)ORC WORK -Diversion of 220KV Deoli PG-Pusad line at loc 250-251 due to four lanning of NH-361 (Butibori -Tuljapur)- shifting of line from ERS to newly erected tower thereof.
PUSAD-GHATODI	IntraState	10/03/2025	19:47			HT	IN VIEW OF OUTAGE ON PUSAD-WARDHA PG-CKT.
HINJAWADI I- CHINCHWAD	IntraState	11/03/2025	06:11	12/03/2025	00:42	HT	Load management
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	11/03/2025	11:43	12/03/2025	01:48	PO	Retrofitting of Distance Relay
MALEGAON-SATANA	IntraState	12/03/2025	00:56	13/03/2025	00:35	HT	Load management
132KV PARTUR RLY TSS	IntraState	12/03/2025	01:10	12/03/2025	01:45	T	Distance protection
MALEGAON-SATANA	IntraState	12/03/2025	01:18	12/03/2025	18:30	HT	Load management
NIWALI - PAWAS LINE	IntraState	12/03/2025	07:09	12/03/2025	12:00	PO	For Line gantry & CT gantry insulator string cold washing.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	12/03/2025	07:29	12/03/2025	22:34	HT	Load management
CHINCHWAD 2-CHINCHWAD (INTERCONNECTOR)	IntraState	12/03/2025	08:33	12/03/2025	12:48	HT	Load management
KHAPARKHEDA- BUTIBORI	IntraState	12/03/2025	09:38	12/03/2025	16:25	PO	Replacement of Y-ph CT due to ageing and CB timing
GOREGAON - VERSOVA CKT - 1	IntraState	12/03/2025	09:45	12/03/2025	17:13	PO	Annual Maintenance of Circuit Breaker
DAHANU - VIRAJ	IntraState	12/03/2025	09:55	12/03/2025	19:34	HT	MVAR Management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	12/03/2025	10:57	13/03/2025	01:03	HT	Load management
220KV KURUNDA -GIRWALI CKT	IntraState	12/03/2025	12:01	12/03/2025	13:31	EO	Attend Hotspot at R-ph CT P1 side.
THEUR-PHURSUNGI CKT II	IntraState	12/03/2025	12:29	12/03/2025	18:57	EO	Replacement of flashover SSN string Rph at loc. no. 37 and chemical washing of disc insulator
LAMBOTI - TULJAPUR CKT - 2	IntraState	12/03/2025	12:49	12/03/2025	20:35	PO	Outage is required for Replacement of string at Loc. No. 28, 41, & cold washing of Insulator String.
MALINAGAR - TEMBHURNI	IntraState	12/03/2025	12:53	12/03/2025	19:50	PO	Outage is required for Quarterly Maintenance
MALINAGAR - TEMBHURNI	IntraState	12/03/2025	12:53	12/03/2025	19:50	PO	Outage is required for Quarterly Maintenance
PEDHAMBE ONI LINE	IntraState	12/03/2025	13:02	12/03/2025	18:42	PO	For replacement of damaged rusted jump nut bolt at loc no-202, 223, 227.
OSMANABAD - BARSHI	IntraState	12/03/2025	14:38	12/03/2025	17:37	PO	Outage is required for Quarterly Maintenance
CHINCHWAD 2-CHINCHWAD (INTERCONNECTOR)	IntraState	12/03/2025	18:40	12/03/2025	22:54	HT	Load management
HAMIDWADA - MUMEWADI	IntraState	13/03/2025	06:28	13/03/2025	07:22	PO	Quarterly maintenance work & to attend hot spot
HINJAWADI I- CHINCHWAD	IntraState	13/03/2025	06:49	13/03/2025	23:58	HT	Load management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Mar/2025

Statement-VII

Position as on 6.30 Hrs of 13/Mar/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ALEPHATA-PARGAON(KATHAPUR)	IntraState	13/03/2025	07:29	13/03/2025	21:55	HT	Load management
220kV REL Life Science (GIS) - NASIK-1	IntraState	13/03/2025	09:38			HT	H/T for load management.
LOTEPARSHURAM- DASTURI LINE	IntraState	13/03/2025	12:28	13/03/2025	15:01	PO	C- Tan delta testing of R, Y, B ph CTs of 220KV Dasturi Lote line at 220KV Dasturi S/s.
NAGAR BELWANDI CKT 1	IntraState	13/03/2025	12:50	13/03/2025	17:27	T	Tripped on distance protection.
BHUGAON - WARDHA (PG)	IntraState	13/03/2025	13:15	13/03/2025	15:48	T	Tripped on distance protection.
NANDED 2 (WAGHALA) - PARBHANI	IntraState	13/03/2025	13:30	13/03/2025	14:45	EO	Replacement of flashover disc at Loc no 06
JEJURI - KONDHWA	IntraState	13/03/2025	13:58	13/03/2025	17:18	EO	For attending hot spot of 117 deg cel on Y-ph 29D isolator jaw. The hot spot can be attended by shifting 220kV Kondhwa bay on TBC.
220 KV KALMESHWAR WARUD CKT II	IntraState	13/03/2025	14:35	13/03/2025	19:00	EO	Relay testing work
WARDHA-D-GAON NEW	IntraState	13/03/2025	15:45	13/03/2025	15:48	EO	Tree cutting work
DASTURI-KANDALGAON LINE	IntraState	13/03/2025	16:44	13/03/2025	18:35	PO	C- Tan delta testing of R, Y, B ph CTs of 220KV Dasturi Kandalgaon line at 220KV Dasturi S/s.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	13/03/2025	18:02	13/03/2025	20:02	EO	For attending Hot Spot in Middle ph jumper cone at TL no. 401.
220 KV ICT Outages/Trippings							
220/22KV 50MVA PTR 3 @ BHOSARI 2	IntraState	24/07/2024	23:02			T	Tripped due to caught fire.
220/132 KV 150 MVA PTR NO 7 @ CHINCHWAD	IntraState	11/11/2024	03:05			T	Bucholz Protection
220/132 KV 80 MVA ICT 1 @ HINGANGHAT	IntraState	19/02/2025	12:45			HT	H/T Due to end of expected life of paper insulation of ICT
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	10/03/2025	11:02	13/03/2025	19:57	PO	ABB make HV CB pole overhauling work & HV CB testing by agency
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	12/03/2025	08:23	12/03/2025	23:16	PO	Shifting of LA & CT of ICT 4 LV side from RCC structure to Lattice structure
220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR)	IntraState	12/03/2025	08:51	12/03/2025	15:55	PO	Outage is required for Tandelta Testing of Bushing & Winding & SFRA Test By MTU, Pune
220/132 KV 100MVA ICT - 1 @ MANMAD	IntraState	12/03/2025	14:07	12/03/2025	17:25	PO	SFRA & DFR measurement & Quarterly Bay maintenance work.
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	12/03/2025	17:01	12/03/2025	19:57	PO	Outage is required for Tandelta Testing of Bushing & Winding By MTU, Pune
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	IntraState	13/03/2025	12:31	13/03/2025	14:52	PO	Outage is required for Tan delta and SFRA testing by MTU, Pune
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	12/02/2025	19:12			HT	System Constraints H/T at Pench End.
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management
132 KV PATHRI-MAJALGAON CKT	IntraState	06/01/2025	13:05			HT	After completion of outage on 132kv patri parbhani ckt
132 KV BADNAPUR - HYOSUNG (STERLIGHT) CKT	IntraState	14/02/2025	17:01			T	B - R PH, Z2, 2.56 KA, 26 KM. H - R PH, 3 KA, 700 MTR.
NANDURBAR - RAILWAY TSS	IntraState	11/03/2025	17:00	12/03/2025	19:50	T	Distance protection
132 KV ICT Outages/Trippings							
132/33 KV 50 MVA PTR 2 @ DONDAICHA	IntraState	15/11/2024	11:40			T	Tripped on Buchholz alarm
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Mar/2025

Statement-VII

Position as on 6.30 Hrs of 13/Mar/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KOLSHET - BMC - BORIVALI (T) - BORIVALI (M)	IntraState	13/03/2025	13:33	13/03/2025	18:00	EO	Replacement of Lightning Arrester

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage