

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Apr/2017 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	169.586	1846.472	1) Gujrat	1.131	17.360
2) Hydro	14.484	176.832	2) Madhya Pradesh	9.246	123.801
3) Gas	10.551	118.428	3) Chattisgarh	5.360	52.390
Total MSPGCL	194.621	2141.732	4) Maharashtra Net	131.480	1563.733
B) 1) APML	45.884	550.097	5) Goa (Amona)	-0.594	-7.478
2) JSWEL	23.781	251.347	Total	146.623	1749.806
3) VIPL	7.184	161.211	a) Mumbai Schedule	28.105	298.991
4) RPL(AMT)	25.961	314.905	b) Mumbai Drawl	31.852	329.419
5) WPCL	4.369	51.228	c) MSEDCL Bilateral *	34.904	415.125
6) PGPL	0.000	0.000	Include PX	-0.757	29.224
7) Other IPP	3.500	45.700	d) Mumbai Bilateral *	28.105	298.991
C) 1) TPCL Thermal	16.135	184.838	Include PX	4.697	35.000
2) TPCL Hydro	4.928	44.075	Include Standby	0.000	0.000
3) TPCL Gas	4.504	54.252	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	11.647	135.280	1) MSEDCL	429.175	5106.949
D) STATE			2) Mumbai Discoms	69.066	747.877
1) Thermal	308.047	3541.078	TOTAL STATE	498.241	5854.826
(A1+C1+C4+(B1-B6))					
2) Hydro	19.412	220.907			
(A2+C2)					
3) Gas	15.055	172.680			
(A3+B6+C3)					
4) Wind	7.541	152.621			
6) SOLAR	1.563	17.721			
TOTAL STATE	351.618	4105.007			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6730	7322	7003	7001
MSPGCL Hydro	829	1345	438	208
MSPGCL Gas	434	422	433	451
MSPGCL Total Generation	7993	9089	7874	7660
Central Sector Receipt	6684	7071	6428	5197
WIND	285	191	296	470
CPP / IPP Thermal	4558	4400	4624	4789
CPP / IPP Gas	0	0	0	0
SOLAR	241	164	0	0
Exchange with Mumbai	-1590	-1627	-1352	-915
MSEDCL DEMAND MET	18171	19288	17870	17201
Load Shedding	11	0	0	0
MSEDCL DEMAND	18182	19288	17870	17201
TPCL GENERATION	1357	1350	1255	734
R-INFRA GENERATION	499	494	502	507
MUMBAI DEMAND	3446	3471	3109	2156
STATE DEMAND MET	21617	22759	20979	19357
STATE DEMAND	21628	22759	20979	19357
Frequency (Hz)	49.92	49.90	49.91	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 06.01 Hrs	49.73 Hz at 22.27 Hrs	49.94	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 12/Apr/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	3.80	45.71	165	140
Unit 8	12.58	151.25	619	325
Unit 9	14.37	157.83	625	503
Unit 10	4.81	6.42	333	0
Total	35.55	361.21		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	3.82	50.21	180	135
Unit 4	8.65	118.26	365	355
Unit 5	8.63	118.70	370	350
Total	21.10	287.17		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.81	69.59	254	210
Unit 7	5.71	45.42	257	194
Unit 8	2.75	3.41	232	0
Total	14.26	118.42		
Chandrapur				
Unit 3	4.81	56.98	202	194
Unit 4	4.70	56.18	198	187
Unit 5	10.72	91.01	455	430
Unit 6	10.06	123.20	435	384
Unit 7	0.00	0.00	0	0
Unit 8	8.92	98.99	409	318
Unit 9	11.12	110.31	500	402
Total	50.32	536.68		
Paras				
Unit 3	5.89	70.91	256	212
Unit 4	5.85	55.32	255	212
Total	11.74	126.23		
Khaparkheda				
Unit 1	4.10	47.66	185	150
Unit 2	4.22	48.25	185	150
Unit 3	4.28	49.35	194	160
Unit 4	4.22	47.72	183	161
Unit 5	10.72	126.18	504	380
Total	27.55	319.17		
Nasik				
Unit 3	0.00	36.00	0	0
Unit 4	4.55	12.05	203	165
Unit 5	4.50	49.55	198	167
Total	9.06	97.60		
Uran				
All Units	10.55	118.43	462	418
Total	10.55	118.43		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.08	1.01	33	0
Total	0.08	1.01		
Koyna				
Stage 1-2	4.06	52.62	515	40
Stage 4	4.95	55.49	516	0
Stage 3	1.95	24.29	160	0
Total	10.96	132.39		
Hydro				
KDPH	0.74	6.72	31	31
VTRNA	0.00	9.07	0	0
TILLARI	0.00	1.70	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.29	2.30	80	0
RNGR+BHTSA	0.32	3.39	14	13
BHANDARDRA	0.49	6.04	21	20
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.48	6.70	28	17
GHATGHAR	1.20	8.52	250	0
Total	3.53	44.44		
Wind				
Total	7.54	152.62	0	0
Total	7.54	152.62		
CPP				
APML(Mus)	45.88	550.10	0	0
JSWEL(Mus)	23.78	251.35	0	0
VIPL(Mus)	7.18	161.21	0	0
RPLAMT(Mus)	25.96	314.90	0	0
WPCL(Mus)	4.37	51.23	0	0
Other(Mus)	3.50	45.70	0	0
Total	110.68	1374.49		
SOLAR				
Total	1.56	17.72	0	0
Total	1.56	17.72		
Tata				
Trombay 5	10.67	120.80	493	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.90	34.89	122	118
Trombay 7B	1.60	19.36	68	66
Trombay 8	5.46	64.04	243	200
TATA Hydro	4.93	44.08	439	64
Total	25.57	283.16		
R-INFRA				
DTPS U-1&2	11.65	135.28	507	388
Total	11.65	135.28		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	169.59	1846.47	MSPGCL Total	194.62	2141.73
			MSPGCL Thml+Gas	180.14	1964.90	Koyna 1,2 & 4 Total	9.01	108.11
			MSPGCL Hydro	14.48	176.83	State Total	351.62	4105.01

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 12/Apr/2017

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6996	879	439	8314	434	4842	0	0	5707	5606	-1248	17948	0	17948	2669	20617	49.96
2	6998	379	450	7827	520	4760	0	0	5811	5692	-1033	17766	0	17766	2457	20223	49.96
3	6993	204	462	7659	453	4769	0	0	5650	5538	-890	17529	0	17529	2283	19812	49.98
4	7001	208	451	7660	470	4789	0	0	5644	5197	-915	17201	0	17201	2156	19357	49.98
5	7061	208	449	7718	423	4815	0	0	5644	5374	-893	17437	0	17437	2104	19541	49.96
6	7096	486	459	8041	351	4789	0	0	5684	5845	-896	18130	0	18130	2164	20294	49.99
7	7146	761	453	8360	302	4773	0	10	5732	4780	-830	17395	44	17439	2218	19657	50.00
8	6943	493	453	7889	235	4540	0	46	5983	6632	-1076	18266	81	18347	2344	20691	50.02
9	6767	437	446	7650	239	4393	0	108	6458	6806	-1383	17813	43	17856	2599	20455	49.99
10	6994	358	434	7786	331	4502	0	165	6573	6277	-1701	17360	30	17390	3088	20478	49.98
11	7152	508	438	8098	355	4612	0	205	6650	6093	-1600	17763	13	17776	3247	21023	49.96
12	6730	829	434	7993	285	4558	0	241	6694	6684	-1590	18171	11	18182	3446	21628	49.92
13	6817	1281	418	8516	152	4444	0	238	6723	6930	-1611	18669	9	18678	3456	22134	49.93
14	7105	970	421	8496	116	4593	0	232	6682	6756	-1575	18618	4	18622	3398	22020	49.95
15	7262	1131	430	8823	119	4426	0	199	6694	6772	-1613	18726	0	18726	3463	22189	49.89
16	7322	1345	422	9089	191	4400	0	164	6712	7071	-1627	19288	0	19288	3471	22759	49.90
17	7232	1157	423	8812	182	4434	0	108	6732	7154	-1587	19103	0	19103	3439	22542	49.94
18	7054	573	424	8051	226	4517	0	37	6624	6807	-1637	18001	0	18001	3269	21270	49.95
19	6833	179	442	7454	228	4523	0	3	6377	6222	-1599	16831	0	16831	3108	19939	49.93
20	7003	438	433	7874	296	4624	0	0	6117	6428	-1352	17870	0	17870	3109	20979	49.91
21	7077	434	431	7942	392	4656	0	0	5775	5701	-1323	17368	0	17368	2973	20341	49.90
22	7250	295	448	7993	425	4648	0	0	5536	5402	-1348	17120	0	17120	2875	19995	49.87
23	7442	236	443	8121	429	4646	0	0	5751	5743	-1266	17673	0	17673	2867	20540	49.83
24	7312	695	448	8455	387	4626	0	0	5732	5880	-1259	18089	0	18089	2863	20952	49.88
MUs	169.59	14.48	10.55	194.62	7.54	110.68	0.00	1.76	147.69	147.39	-31.85	430.13	0.23	430.37	69.07	499.44	49.94

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Apr/2017

Position as on 6.30 Hrs of 13/Apr/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Chandrapur Unit 7	500	25/01/2017	19.32		Continued.	Turbine Problem, continued under COH	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Koyna STG- IV Unit - 1	250	17/03/2017	10.45		Continued.	Turbine bearing Vabration high	
IPP	Adani U-3	660	03/04/2017	01.22	13/04/2017	20.06	Reduction in Hydrogen Pressure.	
IPP	Adani U-1	660	04/04/2017	12.52	13/04/2017	07.16	Bearing vibration high	
MSPGCL	Nasik Unit 3	210	09/04/2017	15.50		Continued.	tripped on boiler feed pump problem.	
MSPGCL	Koradi Unit 10	660	11/04/2017	17.55	12/04/2017	03.58	BFP Problem.	
IPP	VIPL U-2	300	11/04/2017	22.36		Continued.	Boiler Tube Leakage	
MSPGCL	Parli Unit 8	250	12/04/2017	11.15	12/04/2017	13.23	B.F.P. PROBLEM.	
MSPGCL	Parli Unit 8	250	13/04/2017	00.53	13/04/2017	04.20	Drum level low	
IPP	VIPL U-1	300	13/04/2017	03.34		Continued.	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 3	210	13/04/2017	07.17	13/04/2017	09.17	Furnace draft very low.	
MSPGCL	Parli Unit 8	250	13/04/2017	08.03	13/04/2017	10.44	Vacumme pressure low.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Apr/2017

Position as on 6.30 Hrs of 13/Apr/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 3	210	13/04/2017	15.45		Continued.	turbine protection operated.	
MSPGCL	Chandrapur Unit-8	500	13/04/2017	22.03		Continued.	Drum level high.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Apr/2017

Statement-VII

Position as on 6.30 Hrs of 13/Apr/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi III - Akola II- ckt-II	IntraState	13/04/2017	15.34	13/04/2017	16.26	T	Distance Protection
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	13/04/2017	01.14	13/04/2017	03.58	PO	TRANSFORMER MCB REPLACEMENT WORK.
400 KV LINE Outages/Trippings							
Kolhapur Solapur (PG) II	InterState	11/04/2017	10.30		Continued.	EO	Taken on TBC to Attend Hot Spot.
Kolhapur Solapur (PG) II	InterState	12/04/2017	03.48	12/04/2017	08.52	T	Dist Prot. B Ph to Earth.
Chakan Talegaon(Pg)	InterState	12/04/2017	10.28	12/04/2017	11.56	HT	DUE TO HEAVY SPARK ON BUS ISOLATOR.
karad -kolhapur-I	IntraState	12/04/2017	03.48	12/04/2017	17.42	T	Dist Prot. B Ph to Earth Z-1.
karad -kolhapur-II	IntraState	12/04/2017	04.12	12/04/2017	05.19	T	Dist Prot. Y Ph to Earth Z-1.
N.Koyna-Karad -Ckt I	IntraState	12/04/2017	04.25	12/04/2017	14.29	T	Dist Prot. Z-1,R-E Trip.
Jejuri- Koynastage-IV	IntraState	12/04/2017	04.27	12/04/2017	05.25	T	Dist Prot. Z-1,Y-E Trip.
karad -kolhapur-II	IntraState	12/04/2017	05.19	12/04/2017	14.36	T	Tripped Again.Dist.Prot. Y Ph to Earth Zone-1.
Jejuri- Koynastage-IV	IntraState	12/04/2017	05.25	12/04/2017	14.09	T	Dist.Prot. Z-1,Y-E Trip.
Lonikand I - Koyna stage-IV	IntraState	12/04/2017	05.28	12/04/2017	16.48	T	Dist Prot Z-1 B-E Trip, Trial Taken Again Tripped @ 06.15 Hrs.
N.Koyna-Karad -Ckt II	IntraState	12/04/2017	05.41	12/04/2017	16.18	T	Dist Prot.Z-1 Y-E Trip.
Alkud-Kolhapur(Talandage)	IntraState	12/04/2017	06.50	12/04/2017	07.04	T	TRIPPED AT KOLHSPUR END ONLY.
Akola-Nandgaonpeth (RPL)	IntraState	12/04/2017	09.34	12/04/2017	10.13	T	Distance Protection
Chandrapur - Parli	IntraState	12/04/2017	18.21	12/04/2017	19.22	T	Distance Protection
Ektuni-Bableshwar ckt I	IntraState	12/04/2017	19.02	13/04/2017	00.54	HT	TO AVAIL 400KV KALWA-PADGHA-2 OUTAGE.
Padghe - Kalwa-II	IntraState	12/04/2017	19.16	13/04/2017	00.45	T	Decapped Insulator String Replacement.
Chandrapur II - Chandrapur ckt I	IntraState	13/04/2017	09.46	13/04/2017	20.41	PO	Attending Hot Spot
400 KV ICT Outages/Trippings							
400/220 KV 500 MVA ICT- II @Warora	IntraState	27/03/2017	12.58		Continued.	PO	Dismantling Work And Will Be Transport At Padgha.
765/400KV 1500MVA ICT-II @ Koradi-III	IntraState	12/04/2017	21.32	12/04/2017	22.58	PO	Diagnostic Testing Work.
400/220 Kv 315 Mva ICT -I @Padghe	IntraState	13/04/2017	02.34	13/04/2017	09.29	T	B-PHASE 220KV SIDE CT BURST.
400/220 Kv 600 MVA ICT-IV @Padghe	IntraState	13/04/2017	04.33	13/04/2017	04.51	T	OVER LOADING.
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	13/04/2017	09.37	13/04/2017	10.07	T	Backup o/c optd.
400/220kv 315 Mva ICT III @Karad	IntraState	13/04/2017	09.37	13/04/2017	10.23	T	Backup o/c optd
400/220kv 315 Mva ICT II @Karad	IntraState	13/04/2017	09.37	13/04/2017	10.20	T	Backup o/c optd
400/220kv 315 Mva ICT I @Karad	IntraState	13/04/2017	09.37	13/04/2017	11.58	T	Backup o/c optd
400/220 Kv 500 MVA ICT 3 @Kolhapur	IntraState	13/04/2017	09.37	13/04/2017	10.15	T	Backup o/c optd.
400/220kv 315 MVA ICT I @ Kolhapur	IntraState	13/04/2017	09.37	13/04/2017	10.03	T	Overload trip.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	12/04/2017	06.50	12/04/2017	10.46	T	PDR PROBLEM.
Talandge Chikodi	InterState	13/04/2017	09.37	13/04/2017	11.16	T	Load thrown off due to tripping of ICTs at Kolhapur.
Talandage - Chikodi	InterState	13/04/2017	09.59	13/04/2017	11.16	HT	Hand tripped as all three ict tripped at talangade.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Apr/2017

Statement-VII

Position as on 6.30 Hrs of 13/Apr/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Trombay MSETCL Tie 1	IntraState	05/04/2017	12.33		Continued.	PO	Relay and scada panel replacement
Adlabs - Pedambe	IntraState	07/04/2017	07.20	12/04/2017	14.57	PO	R.M & C T Replacement Work.
Talandge(400kv)- Ichalkaranji 2	IntraState	12/04/2017	06.09	12/04/2017	18.46	T	Dist Prot.Z-1, B-E Trip.
Talandge-Mudshingi Ckt-I	IntraState	12/04/2017	06.11	12/04/2017	06.58	T	Dist Prot.Z-1, B-E Trip.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	12/04/2017	06.12	12/04/2017	15.32	T	Dp Zone 1,Y-E TRIP, CURRENT -3.27KAMP,DISTANCE-48.6KM
Uran - Kharghar 2	IntraState	12/04/2017	06.20	12/04/2017	06.53	T	Distance Protection
Talandge(400kv)- Ichalkaranji 1	IntraState	12/04/2017	06.21	12/04/2017	08.46	T	Dp Zone 1,B-E TRIP, CURRENT -11 KAMP,DISTANCE-6.46KM
Karad -Mudshingi Ckt- IV	IntraState	12/04/2017	06.51	12/04/2017	17.58	T	Dp Zone 1,R-Y TRIP, CURRENT -3.45KAMP,DISTANCE-57.46KM TRIL TAKEN.
Eklahare (Gcr) - Airoli Know Park	IntraState	12/04/2017	14.37	12/04/2017	15.14	T	TRIPPED ONLY FROM NASIK END.
Lamboti-Vita	IntraState	12/04/2017	17.25	12/04/2017	19.07	EO	Jumpering Work.
Kandalgaon - Koyna	IntraState	13/04/2017	04.57	13/04/2017	10.25	T	Distance Protection
Mahad - Pedambe	IntraState	13/04/2017	05.05	13/04/2017	09.01	T	Distance Protection
Pedhambe - Oni	IntraState	13/04/2017	09.04	13/04/2017	15.30	PO	Attending Hot Spot
Phursungi-Parvati	IntraState	13/04/2017	09.10	13/04/2017	13.27	PO	Routine Maintenance Work
Halkarni - Tillari II	IntraState	13/04/2017	09.27	13/04/2017	16.28	T	Tripped due to overloading.
Karad - Kadegaon	IntraState	13/04/2017	09.37	13/04/2017	10.31	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Karad-Nerle	IntraState	13/04/2017	09.37	13/04/2017	10.47	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	13/04/2017	09.37	13/04/2017	12.13	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Karad(400kv) -Nigade	IntraState	13/04/2017	09.37	13/04/2017	12.09	T	Due to tripping of ICTs at karad all 220KV load thrown off.
karad - Dasgaon	IntraState	13/04/2017	09.37	13/04/2017	10.53	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Karad - Vita Ckt- II	IntraState	13/04/2017	09.37	13/04/2017	10.35	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Karad - Vita Ckt- I	IntraState	13/04/2017	09.37	13/04/2017	10.41	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Karad(400kv) - Wathar	IntraState	13/04/2017	09.37	13/04/2017	12.04	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Karad -Mudshingi Ckt- IV	IntraState	13/04/2017	09.37	13/04/2017	12.03	T	Due to tripping of ICTs at karad all 220KV load thrown off.
Talandge(400)- Mudshingi 2 Line	IntraState	13/04/2017	09.55	13/04/2017	10.21	HT	Hand tripped as all three ict tripped at talangade.
Kolhapur-Bidri	IntraState	13/04/2017	09.56	13/04/2017	10.27	HT	Hand tripped as all three ict tripped at talangade.
Talandge(400kv)- Ichalkaranji 1	IntraState	13/04/2017	09.57	13/04/2017	10.23	HT	Hand tripped as all three ict tripped at talangade.
Talandge-Hamidwada	IntraState	13/04/2017	09.57	13/04/2017	10.17	HT	Hand tripped as all three ict tripped at talangade.
Talandge(400kv)- Ichalkaranji 2	IntraState	13/04/2017	09.58	13/04/2017	10.32	HT	Hand tripped as all three ict tripped at talangade.
Talandage(kolh'r)- Sawantwadi II	IntraState	13/04/2017	09.58	13/04/2017	10.30	HT	Hand tripped as all three ict tripped at talangade.
Talandge-Mudshingi Ckt-I	IntraState	13/04/2017	10.00	13/04/2017	10.09	HT	Hand tripped as all three ict tripped at talangade.
Talandage(400kv) - Five Star Midc	IntraState	13/04/2017	10.00	13/04/2017	10.12	HT	Hand tripped as all three ict tripped at talangade.
Uran - Kharghar 2	IntraState	13/04/2017	10.05	13/04/2017	15.55	PO	replacement of insulator string
Vsnl-512 Khadki	IntraState	13/04/2017	10.11	13/04/2017	16.22	PO	Routine Maintenance Work
Trombay - Kalwa	IntraState	13/04/2017	11.51	13/04/2017	12.05	PO	To remove metallic wire at loc 19.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Apr/2017

Statement-VII

Position as on 6.30 Hrs of 13/Apr/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Karad - Vita Ckt- I	IntraState	13/04/2017	17.29	13/04/2017	18.57	PO	Routine Maintenance Work
Karad(400kv) - Wathar	IntraState	13/04/2017	21.00	13/04/2017	22.10	T	Tripped only from wather end.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
200MVA ICT VI @ Nasik GCR	IntraState	12/04/2017	14.37	12/04/2017	15.09	T	TRIPPED ON JERK.
220/132 KV 200MVA ict 1@Nasik GCR	IntraState	12/04/2017	14.37	12/04/2017	15.22	T	TRIPPED ON JERK.
132 KV LINE Outages/Trippings							
Eklhara(Gcr)-Jindal	IntraState	12/04/2017	14.37	12/04/2017	15.14	T	BUS BAR PROTECTION OPERATED.
Eklhara(Gcr)-Pachpatta	IntraState	12/04/2017	14.37	12/04/2017	15.04	T	BUS BAR PROTECTION OPERATED.
Ekl(Gcr)-Sinnar	IntraState	12/04/2017	14.37	12/04/2017	15.09	T	BUS BAR PROTECTION OPERATED
Ekl(Gcr)-Ranwad	IntraState	12/04/2017	14.37	12/04/2017	15.15	T	BUS BAR PROTECTION OPERATED
Ekl(Gcr)-Ozar I	IntraState	12/04/2017	14.37	12/04/2017	15.17	T	BUS BAR PROTECTION OPERATED
Eklhara(Gcr)-Ambad	IntraState	12/04/2017	14.37	12/04/2017	15.08	T	BUS BAR PROTECTION OPERATED.
Ekl(Gcr)-Ozar li	IntraState	12/04/2017	14.37	12/04/2017	15.10	T	BUS BAR PROTECTION OPERATED.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage