

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 12/Jun/2017 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 147.101        | 1806.395        | 1) Gujrat                      | -5.870         | -28.660         |
| 2) Hydro            | 4.351          | 61.885          | 2) Madhya Pradesh              | 8.682          | 130.806         |
| 3) Gas              | 10.195         | 119.028         | 3) Chattisgarh                 | 6.820          | 78.270          |
| <b>Total MSPGCL</b> | <b>161.647</b> | <b>1987.308</b> | 4) Maharashtra Net             | 94.228         | 1213.416        |
| B) 1) APML          | 44.824         | 534.665         | 5) Goa (Amona)                 | -0.418         | -4.950          |
| 2) JSWEL            | 15.449         | 185.859         | <b>Total</b>                   | <b>103.442</b> | <b>1388.882</b> |
| 3) VIPL             | 8.704          | 71.732          | a) Mumbai Schedule             | 25.926         | 336.017         |
| 4) RPL(AMT)         | 0.000          | 115.123         | b) Mumbai Drawl                | 31.811         | 392.593         |
| 5) WPCL             | 4.086          | 40.481          | c) MSEDCL Bilateral *          | 13.401         | 257.455         |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -2.034         | 44.231          |
| 7) Other IPP        | 2.836          | 37.968          | d) Mumbai Bilateral *          | 25.926         | 335.889         |
| C) 1) TPCL Thermal  | 12.355         | 170.058         | Include PX                     | 3.099          | 91.174          |
| 2) TPCL Hydro       | 4.261          | 45.864          | Include Standby                | 0.000          | 0.128           |
| 3) TPCL Gas         | 4.504          | 52.711          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) R-INFRA Thermal  | 9.335          | 120.119         | 1) MSEDCL                      | 326.669        | 4240.164        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 62.266         | 781.345         |
| 1) Thermal          | 244.690        | 3082.400        | <b>TOTAL STATE</b>             | <b>388.935</b> | <b>5021.509</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 8.612          | 107.749         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 14.699         | 171.739         |                                |                |                 |
| (A3+B6+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 16.159         | 254.185         |                                |                |                 |
| 6) SOLAR            | 1.333          | 16.554          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>285.493</b> | <b>3632.627</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6139                      | 6084                  | 6251                      | 6011                      |
| MSPGCL Hydro             | 228                       | 206                   | 397                       | 61                        |
| MSPGCL Gas               | 431                       | 416                   | 419                       | 437                       |
| MSPGCL Total Generation  | 6798                      | 6706                  | 7067                      | 6509                      |
| Central Sector Receipt   | 5173                      | 5434                  | 4210                      | 3672                      |
| WIND                     | 421                       | 445                   | 1030                      | 448                       |
| CPP / IPP Thermal        | 3566                      | 3545                  | 3234                      | 2979                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 182                       | 189                   | 0                         | 0                         |
| Exchange with Mumbai     | -1643                     | -1671                 | -1490                     | -812                      |
| <b>MSEDCL DEMAND MET</b> | <b>14497</b>              | <b>14648</b>          | <b>14051</b>              | <b>12796</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14497                     | 14648                 | 14051                     | 12796                     |
| TPCL GENERATION          | 1115                      | 1081                  | 982                       | 688                       |
| R-INFRA GENERATION       | 389                       | 387                   | 389                       | 389                       |
| <b>MUMBAI DEMAND</b>     | <b>3147</b>               | <b>3139</b>           | <b>2861</b>               | <b>1889</b>               |
| STATE DEMAND MET         | 17644                     | 17787                 | 16912                     | 14685                     |
| <b>STATE DEMAND</b>      | <b>17644</b>              | <b>17787</b>          | <b>16912</b>              | <b>14685</b>              |
| Frequency (Hz)           | 49.94                     | 49.95                 | 49.96                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.15 Hz at 14.01 Hrs | 49.77 Hz at 21.36 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 12/Jun/2017

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.30         | 32.95         | 150      | 120      |
| Unit 8             | 0.00         | 76.43         | 0        | 0        |
| Unit 9             | 10.82        | 108.04        | 533      | 360      |
| Unit 10            | 10.63        | 97.94         | 480      | 400      |
| <b>Total</b>       | <b>24.75</b> | <b>315.36</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.00         | 47.67         | 170      | 165      |
| Unit 4             | 8.83         | 113.03        | 375      | 345      |
| Unit 5             | 9.10         | 112.44        | 380      | 370      |
| <b>Total</b>       | <b>21.92</b> | <b>273.14</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 4.86         | 61.11         | 215      | 198      |
| Unit 7             | 4.75         | 59.86         | 209      | 187      |
| Unit 8             | 1.63         | 1.63          | 178      | 0        |
| <b>Total</b>       | <b>11.25</b> | <b>122.60</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 19.72         | 0        | 0        |
| Unit 4             | 4.17         | 52.08         | 186      | 169      |
| Unit 5             | 8.52         | 106.46        | 370      | 330      |
| Unit 6             | 8.94         | 111.92        | 410      | 350      |
| Unit 7             | 8.69         | 105.32        | 417      | 305      |
| Unit 8             | 8.60         | 102.75        | 390      | 330      |
| Unit 9             | 8.61         | 106.97        | 434      | 343      |
| <b>Total</b>       | <b>47.54</b> | <b>605.23</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.51         | 56.13         | 199      | 169      |
| Unit 4             | 4.41         | 56.01         | 197      | 166      |
| <b>Total</b>       | <b>8.91</b>  | <b>112.14</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.70         | 40.46         | 165      | 140      |
| Unit 2             | 3.74         | 43.12         | 165      | 145      |
| Unit 3             | 3.73         | 42.79         | 164      | 131      |
| Unit 4             | 3.75         | 35.18         | 162      | 145      |
| Unit 5             | 9.34         | 115.50        | 410      | 380      |
| <b>Total</b>       | <b>24.26</b> | <b>277.06</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.23         | 50.49         | 199      | 162      |
| Unit 5             | 4.25         | 50.38         | 199      | 163      |
| <b>Total</b>       | <b>8.48</b>  | <b>100.86</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.20        | 119.03        | 440      | 385      |
| <b>Total</b>       | <b>10.20</b> | <b>119.03</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |

| Generating unit   | Generation   |               |          |          |
|-------------------|--------------|---------------|----------|----------|
|                   | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |              |               |          |          |
| Pench (MS)        | 0.06         | 0.59          | 23       | 0        |
| <b>Total</b>      | <b>0.06</b>  | <b>0.59</b>   |          |          |
| <b>Koyna</b>      |              |               |          |          |
| Stage 1-2         | 1.73         | 26.09         | 355      | 40       |
| Stage 4           | 0.00         | 3.65          | 0        | 0        |
| Stage 3           | 0.74         | 7.68          | 80       | 0        |
| <b>Total</b>      | <b>2.47</b>  | <b>37.42</b>  |          |          |
| <b>Hydro</b>      |              |               |          |          |
| KDPH              | 0.25         | 2.70          | 11       | 10       |
| VTRNA             | 0.96         | 10.21         | 61       | 0        |
| TILLARI           | 0.00         | 0.38          | 0        | 0        |
| BHTGR/VEER        | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.        | 0.18         | 2.85          | 40       | 0        |
| RNGR+BHTSA        | 0.25         | 2.23          | 11       | 10       |
| BHANDARDRA        | 0.00         | 1.36          | 0        | 0        |
| ELDARY            | 0.00         | 0.00          | 0        | 0        |
| SMLHY_PTN         | 0.00         | 0.36          | 0        | 0        |
| GHATGHAR          | 0.24         | 4.38          | 125      | 0        |
| <b>Total</b>      | <b>1.88</b>  | <b>24.46</b>  |          |          |
| <b>Wind</b>       |              |               |          |          |
| Total             | 16.16        | 254.18        | 0        | 0        |
| <b>Total</b>      | <b>16.16</b> | <b>254.18</b> |          |          |
| <b>CPP</b>        |              |               |          |          |
| APML(Mus)         | 44.82        | 534.66        | 0        | 0        |
| JSWEL(Mus)        | 15.45        | 185.86        | 0        | 0        |
| VIPL(Mus)         | 8.70         | 71.73         | 0        | 0        |
| RPLAMT(Mus)       | 0.00         | 115.12        | 0        | 0        |
| WPCL(Mus)         | 4.09         | 40.48         | 0        | 0        |
| Other(Mus)        | 2.84         | 37.97         | 0        | 0        |
| <b>Total</b>      | <b>75.90</b> | <b>985.83</b> |          |          |
| <b>SOLAR</b>      |              |               |          |          |
| Total             | 1.33         | 16.55         | 0        | 0        |
| <b>Total</b>      | <b>1.33</b>  | <b>16.55</b>  |          |          |
| <b>Tata</b>       |              |               |          |          |
| Trombay 5         | 7.47         | 107.77        | 396      | 295      |
| Trombay 6         | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A        | 2.92         | 34.10         | 122      | 120      |
| Trombay 7B        | 1.59         | 18.61         | 67       | 66       |
| Trombay 8         | 4.89         | 62.29         | 207      | 201      |
| TATA Hydro        | 4.26         | 45.86         | 421      | 0        |
| <b>Total</b>      | <b>21.12</b> | <b>268.63</b> |          |          |
| <b>R-INFRA</b>    |              |               |          |          |
| DTPS U-1&2        | 9.34         | 120.12        | 390      | 387      |
| <b>Total</b>      | <b>9.34</b>  | <b>120.12</b> |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 147.10      | 1806.40       | MSPGCL Total        | 161.65      | 1987.31       |
|                |             |         | MSPGCL Thml+Gas | 157.30      | 1925.42       | Koyna 1,2 & 4 Total | 1.73        | 29.74         |
|                |             |         | MSPGCL Hydro    | 4.35        | 61.88         | State Total         | 285.49      | 3632.63       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 12/Jun/2017

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |       | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|-------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS   |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6040        | 122  | 426   | 6588   | 918   | 3126      | 0    | 0     | 3950        | 4092        | -1225                | 13499                 | 0                    | 13499                     | 2302             | 15801           | 50.00         |
| 2                  | 6054        | 67   | 425   | 6546   | 731   | 2953      | 0    | 0     | 3820        | 3970        | -1055                | 13145                 | 0                    | 13145                     | 2131             | 15276           | 49.99         |
| 3                  | 6035        | 106  | 435   | 6576   | 568   | 2953      | 0    | 0     | 3793        | 3881        | -890                 | 13088                 | 0                    | 13088                     | 1970             | 15058           | 49.95         |
| 4                  | 6011        | 61   | 437   | 6509   | 448   | 2979      | 0    | 0     | 3804        | 3672        | -812                 | 12796                 | 0                    | 12796                     | 1889             | 14685           | 49.98         |
| 5                  | 6022        | 66   | 438   | 6526   | 362   | 2975      | 0    | 0     | 3827        | 3747        | -802                 | 12808                 | 0                    | 12808                     | 1881             | 14689           | 49.96         |
| 6                  | 6130        | 61   | 430   | 6621   | 335   | 2977      | 0    | 0     | 4292        | 4358        | -859                 | 13432                 | 0                    | 13432                     | 1938             | 15370           | 49.98         |
| 7                  | 6127        | 71   | 440   | 6638   | 372   | 3023      | 0    | 6     | 4444        | 4718        | -891                 | 13866                 | 0                    | 13866                     | 1971             | 15837           | 49.97         |
| 8                  | 6135        | 145  | 439   | 6719   | 421   | 3112      | 0    | 36    | 4388        | 4636        | -1037                | 13887                 | 0                    | 13887                     | 2114             | 16001           | 50.00         |
| 9                  | 6151        | 227  | 440   | 6818   | 379   | 3177      | 0    | 80    | 4490        | 4659        | -1250                | 13863                 | 0                    | 13863                     | 2443             | 16306           | 50.00         |
| 10                 | 6197        | 404  | 426   | 7027   | 318   | 3334      | 0    | 114   | 4474        | 4777        | -1425                | 14145                 | 0                    | 14145                     | 2922             | 17067           | 49.99         |
| 11                 | 6301        | 246  | 424   | 6971   | 345   | 3605      | 0    | 154   | 4901        | 4857        | -1670                | 14262                 | 0                    | 14262                     | 3063             | 17325           | 49.99         |
| 12                 | 6139        | 228  | 431   | 6798   | 421   | 3566      | 0    | 182   | 5059        | 5173        | -1643                | 14497                 | 0                    | 14497                     | 3147             | 17644           | 49.94         |
| 13                 | 6084        | 206  | 416   | 6706   | 445   | 3545      | 0    | 189   | 5004        | 5434        | -1671                | 14648                 | 0                    | 14648                     | 3139             | 17787           | 49.95         |
| 14                 | 6052        | 201  | 415   | 6668   | 587   | 3566      | 0    | 178   | 4941        | 4557        | -1678                | 13878                 | 0                    | 13878                     | 3080             | 16958           | 49.98         |
| 15                 | 6155        | 178  | 414   | 6747   | 903   | 3343      | 0    | 159   | 4883        | 4437        | -1665                | 13924                 | 0                    | 13924                     | 3135             | 17059           | 50.00         |
| 16                 | 6101        | 122  | 425   | 6648   | 909   | 3150      | 0    | 135   | 4506        | 4573        | -1668                | 13747                 | 0                    | 13747                     | 3132             | 16879           | 49.99         |
| 17                 | 6062        | 113  | 421   | 6596   | 943   | 3131      | 0    | 70    | 4144        | 4745        | -1610                | 13875                 | 0                    | 13875                     | 3113             | 16988           | 49.98         |
| 18                 | 6080        | 394  | 418   | 6892   | 924   | 3148      | 0    | 26    | 3602        | 3789        | -1532                | 13247                 | 0                    | 13247                     | 3007             | 16254           | 49.97         |
| 19                 | 6140        | 376  | 420   | 6936   | 1043  | 3230      | 0    | 4     | 3875        | 4007        | -1463                | 13757                 | 0                    | 13757                     | 2900             | 16657           | 49.98         |
| 20                 | 6251        | 397  | 419   | 7067   | 1030  | 3234      | 0    | 0     | 4200        | 4210        | -1490                | 14051                 | 0                    | 14051                     | 2861             | 16912           | 49.96         |
| 21                 | 6234        | 190  | 431   | 6855   | 1040  | 3233      | 0    | 0     | 4612        | 4198        | -1518                | 13808                 | 0                    | 13808                     | 2811             | 16619           | 49.99         |
| 22                 | 6210        | 161  | 435   | 6806   | 932   | 2993      | 0    | 0     | 3934        | 3701        | -1463                | 12969                 | 0                    | 12969                     | 2651             | 15620           | 49.94         |
| 23                 | 6223        | 138  | 405   | 6766   | 956   | 2795      | 0    | 0     | 3799        | 3501        | -1291                | 12727                 | 0                    | 12727                     | 2379             | 15106           | 49.95         |
| 24                 | 6167        | 71   | 385   | 6623   | 829   | 2750      | 0    | 0     | 3665        | 3750        | -1203                | 12749                 | 0                    | 12749                     | 2287             | 15036           | 49.97         |
| MUs                | 147.10      | 4.35 | 10.19 | 161.65 | 16.16 | 75.90     | 0.00 | 1.33  | 102.41      | 103.44      | -31.81               | 326.67                | 0.00                 | 326.67                    | 62.27            | 388.93          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 12/Jun/2017**

**Position as on 6.30 Hrs of 13/Jun/2017**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul                                                |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 05/06/2017   | 23.24        |            | Continued. | AOH.                                                                                                                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                                  |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                                                                                                                    |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                                                                                                                     |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |            | Continued. | EE R&M LE Work                                                                                                                                                   |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                                                          |               |
| IPP                   | SWPGL U-2               | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                                                                                                                                           |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 14/06/2016   | 19.35        |            | Continued. | Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)                                                                               |               |
| MSPGCL                | Uran Unit 8             | 108      | 14/08/2016   | 07.56        |            | Continued. | Maintenance work                                                                                                                                                 |               |
| RGPL                  | Dabhol 2A               | 230      | 24/08/2016   | 13.31        |            | Continued. | Change Over.                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 5           | 200      | 05/09/2016   | 00.21        |            | Continued. | ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                                                      |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                                                      |               |
| IPP                   | RPL(AMT) U-1            | 270      | 24/05/2017   | 03.27        |            | Continued. | Flame Failure                                                                                                                                                    |               |
| IPP                   | Adani U-5               | 660      | 28/05/2017   | 18.09        |            | Continued. | EARTH FAULT PROTECTION STAGE 1 OPERATED.                                                                                                                         |               |
| MSPGCL                | Nasik Unit 3            | 210      | 29/05/2017   | 11.30        |            | Continued. | BTL( Converted to Zero schedule by MSEDCL. from 19.02 Hrs Dt.01.062017.                                                                                          |               |
| IPP                   | VIPL U-2                | 300      | 29/05/2017   | 23.51        | 12/06/2017 | 05.52      | GT Problem                                                                                                                                                       |               |
| MSPGCL                | Parli Unit 8            | 250      | 31/05/2017   | 21.56        | 12/06/2017 | 07.34      | Coal Shortage                                                                                                                                                    |               |
| IPP                   | JSW (J) U2              | 300      | 31/05/2017   | 23.58        |            | Continued. | NO SCHEDULE.                                                                                                                                                     |               |
| IPP                   | Dhariwal                | 300      | 01/06/2017   | 00.01        |            | Continued. | NO SCHEDULE.                                                                                                                                                     |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 04/06/2017   | 19.09        |            | Continued. | 3 months outage for refuelling.                                                                                                                                  |               |
| IPP                   | RPL(AMT) U-3            | 270      | 05/06/2017   | 14.31        |            | Continued. | swaping with unit-5.                                                                                                                                             |               |
| IPP                   | RPL(AMT) U-4            | 270      | 09/06/2017   | 00.20        |            | Continued. | Zero Schedule.                                                                                                                                                   |               |
| IPP                   | RPL(AMT) U-5            | 270      | 09/06/2017   | 01.39        |            | Continued. | Zero Schedule.                                                                                                                                                   |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 12/Jun/2017**

**Position as on 6.30 Hrs of 13/Jun/2017**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage           | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------|---------------|
| IPP                | RPL(AMT) U-2            | 270      | 09/06/2017   | 04.24        |            | Continued. | Zero Schedule.             |               |
| MSPGCL             | Koradi Unit-8           | 660      | 11/06/2017   | 00.20        |            | Continued. | Air duct Leakage           |               |
| MSPGCL             | Parli Unit 8            | 250      | 12/06/2017   | 10.20        | 12/06/2017 | 13.53      | Flame Failure              |               |
| IPP                | Adani U-2               | 660      | 12/06/2017   | 21.43        |            | Continued. | PA Duct Bellow leakage     |               |
| MSPGCL             | Parli Unit 7            | 250      | 13/06/2017   | 00.04        |            | Continued. | Zero Schedule By<br>MSEDCL |               |
| MSPGCL             | Bhusawal Unit 3         | 210      | 13/06/2017   | 06.01        |            | Continued. | Zero Schedule By<br>MSEDCL |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Jun/2017**

**Statement-VII**

**Position as on 6.30 Hrs of 13/Jun/2017**

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                     |
| Karad Solapur (PG)                        | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kv Solapur (PG)- Jeur from LOC 403                                                            |
| Dhule Sar'Sarovar II                      | InterState                | 08/06/2017   | 19.25        | 12/06/2017 | 07.46      | HT          | Over Voltage                                                                                                        |
| Lamboti - Solapur (PG)                    | InterState                | 12/06/2017   | 00.11        | 12/06/2017 | 00.44      | T           | Distance Protection                                                                                                 |
| Dhule Sar'Sarovar I                       | InterState                | 12/06/2017   | 08.51        |            | Continued. | PO          | Preventive maint.work at SSP end(RFC 17.22Hrs)                                                                      |
| Talegaon PG-Aurangabad-I                  | InterState                | 12/06/2017   | 10.01        | 12/06/2017 | 12.58      | EO          | Breaker work                                                                                                        |
| Lamboti - Solapur (PG)                    | InterState                | 12/06/2017   | 14.16        |            | Continued. | T           | Distance Protection                                                                                                 |
| Talegaon PG - Aurangabad - II             | InterState                | 12/06/2017   | 15.41        | 12/06/2017 | 18.11      | PO          | Pre Monsoon maint.work                                                                                              |
| Ektuni-Bableshtar ckt II                  | IntraState                | 06/06/2017   | 20.53        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Khadka-Aurangabad (Waluj)                 | IntraState                | 09/06/2017   | 20.01        | 12/06/2017 | 08.30      | HT          | Over Voltage                                                                                                        |
| karad -kolhapur-I                         | IntraState                | 11/06/2017   | 17.29        | 12/06/2017 | 09.27      | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                       | IntraState                | 11/06/2017   | 18.05        | 12/06/2017 | 09.53      | HT          | Over Voltage                                                                                                        |
| Chandrapur - Parli                        | IntraState                | 12/06/2017   | 11.29        |            | Continued. | T           | Over Voltage                                                                                                        |
| karad -kolhapur-II                        | IntraState                | 12/06/2017   | 17.37        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Bhusawal-Aurangabad                       | IntraState                | 12/06/2017   | 18.06        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Deepnagar - Aurangabad                    | IntraState                | 12/06/2017   | 21.21        | 12/06/2017 | 22.59      | T           | Distance Protection                                                                                                 |
| Karad-Jaigad - I                          | IntraState                | 12/06/2017   | 23.56        |            | Continued. | HT          | Over Voltage                                                                                                        |
| <b>400 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                     |
| 400/220 Kv 500 MVA ICT-I @Kalwa           | IntraState                | 12/06/2017   | 06.09        | 12/06/2017 | 09.28      | EO          | Attending Hot Spot                                                                                                  |
| 400/132 Kv 200 Mva Ict 1 @Khadka          | IntraState                | 12/06/2017   | 08.53        | 12/06/2017 | 11.38      | PO          | Pre Monsoon maint.work                                                                                              |
| 400/132 Kv 200 Mva Ict 2 @Khadka          | IntraState                | 12/06/2017   | 12.13        | 12/06/2017 | 14.03      | PO          | Pre Monsoon maint.work                                                                                              |
| 400/220kv, 500 Mva ICT-1 @Deepnagar       | IntraState                | 12/06/2017   | 21.21        | 12/06/2017 | 23.11      | T           | NDR Operated                                                                                                        |
| <b>220 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                     |
| Talandage - Chikodi                       | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | NO SCHEDULE.                                                                                                        |
| Mudshingi - Chikodi                       | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | NO SCHEDULE.                                                                                                        |
| Chandrapur GCR - Warora - I               | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                     | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Walchandnagar-Bhigwan                     | IntraState                | 04/06/2017   | 17.29        |            | Continued. | T           | Distance Protection                                                                                                 |
| Nanded-Ghatodi                            | IntraState                | 06/06/2017   | 16.28        |            | Continued. | HT          | to control line loading.                                                                                            |
| Kharghar-Borivali ckt II                  | IntraState                | 07/06/2017   | 12.23        |            | Continued. | T           | Distance Protection                                                                                                 |
| Ambazari-Amravati                         | IntraState                | 12/06/2017   | 07.39        | 12/06/2017 | 15.04      | PO          | Testing Work                                                                                                        |
| Mahad - Pedambe                           | IntraState                | 12/06/2017   | 09.33        | 12/06/2017 | 19.28      | PO          | Insulator Replacement Work                                                                                          |
| Mumewadi-Belewadi                         | IntraState                | 12/06/2017   | 10.01        | 12/06/2017 | 16.13      | PO          | Quarterly Maintainance Work                                                                                         |
| Butibori - VIPL Ckt I                     | IntraState                | 12/06/2017   | 14.21        | 12/06/2017 | 17.42      | PO          | Testing Work                                                                                                        |
| Kalwa - Airoli Knowledge Park             | IntraState                | 12/06/2017   | 17.55        | 12/06/2017 | 18.19      | T           | Distance Protection                                                                                                 |
| Nashik-Airoli Knowledge Park              | IntraState                | 12/06/2017   | 17.55        | 12/06/2017 | 22.21      | T           | Distance Protection                                                                                                 |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali      | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |
| 220/132 Kv 100 Mva Ibt Ptr @Old Gcr Parli | IntraState                | 12/06/2017   | 12.45        | 12/06/2017 | 15.00      | PO          | For protection Trials                                                                                               |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Jun/2017**

**Statement-VII**

Position as on 6.30 Hrs of 13/Jun/2017

| Name of Line                          | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage         |
|---------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|--------------------------|
| 220/132 Kv lct 2 200 Mva<br>@Parbhani | IntraState                   | 12/06/2017      | 13.46           | 12/06/2017 | 16.50         | T              | Bucchohz Protection Optd |
| <b>132 KV LINE Outages/Trippings</b>  |                              |                 |                 |            |               |                |                          |
| Hingoli 2- Akhada Balapur             | IntraState                   | 12/06/2017      | 16.14           | 12/06/2017 | 16.34         | T              | Distance Protection      |