

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Jun/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	163.487	1861.241	1) Gujrat	0.216	-36.930
2) Hydro	6.333	203.830	2) Madhya Pradesh	5.577	70.910
3) Gas	4.526	59.412	3) Chattisgarh	3.470	36.360
Total MSPGCL	174.346	2124.483	4) Maharashtra	202.510	2576.852
B) 1) APLM	67.237	789.489	5) Goa (Amona)	-1.219	-17.176
2) JSWEL	22.254	291.731	Total	210.554	2630.016
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.146	519.071
4) RPL(AMT)	30.400	370.282	b) Mumbai Drawl	49.304	572.737
5) SWPGPL	10.722	124.638	c) MSEDCL Bilateral *	114.299	1312.269
6) Other IPP	7.214	51.208	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	45.146	518.884
C) 1) TPCL Thermal	12.114	151.990	Include PX	0.000	0.000
2) TPCL Hydro	5.390	64.792	Standby	0.000	0.187
3) TPCL Gas	1.787	24.247	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.864	107.262	1) MSEDCL	521.789	6233.408
D) STATE			2) Mumbai Discoms	77.459	921.028
1) Thermal	322.292	3747.841	3) Other Discoms	10.702	128.214
(A1+C1+C4+(B1-B6))			TOTAL STATE	609.950	7282.650
2) Hydro (A2+C2)	11.723	268.622			
3) Gas (A3+B7+C3)	6.313	83.659			
4) Wind	42.186	359.790			
6) SOLAR	16.882	192.722			
TOTAL STATE	399.396	4652.634			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6628	6815	6979	6885
MSPGCL Hydro	234	126	418	192
MSPGCL Gas	174	169	191	210
MSPGCL Total Generation	7036	7110	7588	7288
Central Sector Receipt	9484	9498	8234	8673
WIND	2025	2113	2111	1235
CPP / IPP Thermal	4734	5465	6438	5920
CPP / IPP Gas	0	0	0	0
SOLAR	2211	1361	0	0
Exchange with Mumbai	-2552	-2514	-2028	-1572
MSEDCL DEMAND MET	22441	22537	21862	21207
Load Shedding	0	0	0	0
MSEDCL DEMAND	22441	22537	21862	21207
TPCL GENERATION	681	939	899	668
AEML GENERATION	482	490	323	295
MUMBAI DEMAND	3715	3943	3250	2535
OTHER DISCOM DEMAND	497	496	481	337
STATE DEMAND MET	26654	26976	25594	24078
STATE DEMAND	26654	26976	25594	24078
Frequency (Hz)	49.96	50.06	50.00	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 08.00 Hrs	49.83 Hz at 13.16 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.55	56.13	195	180
Unit 8	13.80	88.41	607	555
Unit 9	14.38	74.69	604	590
Unit 10	12.76	155.71	541	505
Total	45.48	374.93		
Bhusawal				
Unit 3	3.44	28.72	150	135
Unit 4	10.19	118.58	450	355
Unit 5	10.86	127.98	480	340
Total	24.49	275.28		
Parli				
Unit 6	4.66	55.80	250	144
Unit 7	4.51	57.10	241	144
Unit 8	3.47	50.61	156	135
Total	12.64	163.52		
Chandrapur				
Unit 3	3.54	33.97	160	125
Unit 4	0.00	39.36	0	0
Unit 5	0.00	0.00	0	0
Unit 6	9.27	89.07	400	295
Unit 7	9.13	112.55	416	291
Unit 8	10.50	129.69	469	320
Unit 9	10.86	134.23	479	335
Total	43.31	538.89		
Paras				
Unit 3	4.89	59.60	226	171
Unit 4	0.00	54.79	0	0
Total	4.89	114.38		
Khaparkheda				
Unit 1	2.82	35.22	125	95
Unit 2	2.94	35.25	129	116
Unit 3	3.91	38.92	180	135
Unit 4	3.80	48.60	173	127
Unit 5	11.15	129.96	470	450
Total	24.62	287.95		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	4.03	48.63	180	151
Unit 5	4.03	47.57	178	151
Total	8.06	106.29		
Uran				
All Units	4.53	59.41	211	169
Total	4.53	59.41		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.05	1.08	21	0
Total	0.05	1.08		
Koyna				
Stage 1-2	2.16	48.08	380	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.48	29.59	160	0
Total	2.64	158.88		
Hydro				
KDPH	0.20	4.23	9	9
VTRNA	1.15	13.48	60	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.20	4.27	40	0
SMLHY_PTN	2.08	20.65	108	62
GHATGHAR	0.00	0.19	0	0
Total	3.64	43.87		
Wind				
Total	42.19	359.79	0	0
Total	42.19	359.79		
CPP				
APML(Mus)	67.24	789.49	0	0
JSWEL(Mus)	22.25	291.73	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.40	370.28	0	0
SWPGPL-Mus	10.72	124.64	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.28	23.48	271	153
Other(Mus)	1.94	27.72	0	0
Total	137.83	1627.35		
SOLAR				
Total	16.88	192.72	0	0
Total	16.88	192.72		
Tata				
Trombay 5	7.92	99.52	429	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.95	13.17	52	36
Trombay 7B	0.83	11.08	41	32
TATA Hydro	5.39	64.79	400	69
Trombay 8	4.19	52.47	231	127
Total	19.29	241.03		
AEML				
DTPS U-1&2	8.86	107.26	496	290
Total	8.86	107.26		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	163.49	1861.24	MSPGCL Total	174.35	2124.48
			MSPGCL Thml+Gas	168.01	1920.65	Koyna 1,2 & 4 Total	2.16	129.29
			MSPGCL Hydro	6.33	203.83	State Total	399.40	4652.63

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6899	174	210	7282	1355	6506	0	0	8102	8258	-1592	21417	0	0	21417	2921	392	24730	50.00
2	7019	176	210	7404	1300	6372	0	0	8510	8495	-1642	21559	0	0	21559	2824	370	24754	49.98
3	7034	176	210	7420	1303	6196	0	0	8208	8295	-1583	21279	0	0	21279	2713	353	24344	49.99
4	6936	176	211	7324	1434	6069	0	0	8578	8442	-1613	21321	0	0	21321	2602	335	24258	49.98
5	6885	192	210	7288	1235	5920	0	0	8811	8673	-1572	21207	0	0	21207	2535	337	24078	49.98
6	6895	428	211	7534	1224	5972	0	3	8875	9021	-1581	21780	0	0	21780	2547	394	24720	49.98
7	6945	314	206	7466	1113	6117	0	170	8809	8739	-1654	21521	0	0	21521	2533	430	24484	50.00
8	6783	284	205	7272	1416	5764	0	638	8615	8539	-1807	21381	0	0	21381	2656	440	24478	50.09
9	6603	228	183	7014	1975	5235	0	1210	9020	8924	-2099	21766	0	0	21766	2971	494	25230	50.14
10	5991	228	177	6396	2090	4671	0	1824	9324	9380	-2352	21514	0	4	21514	3321	495	25330	50.01
11	6390	182	175	6748	2043	4615	0	2082	9212	9248	-2535	21701	0	0	21701	3603	499	25804	50.01
12	6628	234	174	7036	2025	4734	0	2211	9185	9484	-2552	22441	0	0	22441	3715	497	26654	49.96
13	6718	122	169	7008	1941	5016	0	2133	9436	9196	-2573	22242	0	0	22242	3716	480	26438	50.00
14	6745	120	171	7036	1874	5266	0	2003	9131	8726	-2493	21930	0	0	21930	3685	482	26098	49.99
15	6665	126	170	6960	1984	5146	0	1796	9904	9626	-2620	22411	0	0	22411	3824	482	26716	50.02
16	6815	126	169	7110	2113	5465	0	1361	9289	9498	-2514	22537	0	0	22537	3943	496	26976	50.06
17	6782	324	169	7276	2122	5323	0	931	8712	9186	-2411	21928	0	0	21928	3876	498	26302	50.04
18	6913	320	169	7402	2137	5766	0	458	8088	8200	-2168	21402	0	0	21402	3667	392	25462	50.07
19	6855	256	175	7286	2216	5958	0	62	7798	8064	-2284	20796	0	0	20796	3402	506	24704	50.06
20	6838	420	173	7430	2202	6231	0	0	7894	8143	-2096	21428	0	0	21428	3314	483	25224	50.03
21	6979	418	191	7588	2111	6438	0	0	7625	8234	-2028	21862	0	0	21862	3250	481	25594	50.00
22	7059	280	197	7536	1842	6398	0	0	7693	8056	-1926	21431	0	0	21431	3222	475	25128	50.01
23	7047	460	196	7704	1585	6362	0	0	7926	8877	-1839	22227	0	0	22227	3276	461	25964	50.03
24	7063	566	195	7824	1546	6287	0	0	8086	9250	-1770	22707	0	0	22707	3343	430	26480	50.04
MUs	163.49	6.33	4.53	174.35	42.19	137.83	0.00	16.88	206.83	210.55	-49.30	521.79	0.00	0.00	521.79	77.46	10.70	609.95	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

At 132KV Shirwal s/stn, LTS command received from 132KV Kamthadi s/stn due to overloading of 132KV Kamthadi Phursungi line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jun/2023

Position as on 6.30 Hrs of 13/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	09/07/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Paras Unit 4	250	11/06/2023	13:46		Continued.	Boiler Tube Leakage	14/06/2023
MSPGCL	Chandrapur Unit 4	210	11/06/2023	18:51		Continued.	SUSPECTED BTL AT AB-4 ELEVATION	
MSPGCL	Bhusawal Unit 3	210	13/06/2023	03:15		Continued.	ID Fan Problem	15/06/2023
TPC-G	Trombay 7B	60	13/06/2023	23:10		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	13/06/2023	23:24		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	13/06/2023	00:30		Continued.	EO	Emergency Shutdown of HVDC Pole 1 for premonsoon maintenance work.
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58		Continued.	PO	Overhauling of 400 kV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LONIKAND I - TALEGAON (PGCIL)	InterState	12/06/2023	09:54		Continued.	PO	400kV CB O/H work by shifting on TBC and 29-A PG Isolator mechanimc box replacement and trials
DHULE - KHANDWA CKT - 1	InterState	13/06/2023	09:08		Continued.	PO	MTAMC Project work Main-I Dist Protn, REF & Master trip relay Gr-A &B replacement work
PADGHE - NAGOTHANE CKT - 2	IntraState	08/06/2023	13:08	13/06/2023	18:37	PO	Work of shifting/height raising of various EHV (220/110KV) transmission lines infringing in Samruddhi crossing . 1) Erection of 5 no. of Monopple 2) Stringing of 6.nos. of spans between location nos. 310-313
TBC 2 @ CHANDRAPUR	IntraState	12/06/2023	08:48		Continued.	PO	Replacement of problematic old BHEL make 400kV quad break CB of TBC-2 bay with new siemens ltd make 400kV Quad CB.
220 KV CHANDRAPUR GCR (400 KV) - GRACE CKT	IntraState	12/06/2023	14:07	12/06/2023	18:56	PO	Routine Maintenance Work.
JEJURI - KARAD	IntraState	12/06/2023	20:10		Continued.	PO	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
220KV CHANDRAPUR MIDC-CHANDRAPUR 2(400KV) CKT	IntraState	13/06/2023	07:29	13/06/2023	14:11	PO	Replacement of Broken Disc Insulator
220 KV CHANDRAPUR 2 - TADALI CKT	IntraState	13/06/2023	07:39	13/06/2023	13:53	PO	To attend damaged/ broken strand of conductor
JAIGAD - KARAD CKT - 1	IntraState	13/06/2023	09:08	13/06/2023	13:35	PO	BAY EQUIPMENT WASHING
PADGHE - NAGOTHANE CKT - 1	IntraState	13/06/2023	09:45	13/06/2023	10:13	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
NAGOTHANE - DABHOL CKT - 1	IntraState	13/06/2023	09:45	13/06/2023	11:47	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
NAGOTHANE - DABHOL CKT - 2	IntraState	13/06/2023	09:45		Continued.	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
NAGOTHANE - DABHOL CKT - 1	IntraState	13/06/2023	11:49		Continued.	HT	LINE H/T DUE TO HEAVY SPARKING ON Y PHASE CT AT NAGOTHANE END
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	12/06/2023	08:34	12/06/2023	18:05	PO	For alignment of 220 kV Bus-I Isolator by opening jumps from Bus-I with the help of Hot Line Unit,Ogalewadi as there is hotspot in Y ph Isolator jaw towards Bus side. Temp-160 degree.
400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	IntraState	12/06/2023	21:28	13/06/2023	23:59	EO	To attend hotspot of 400 kV Bushing -B ph (Temp 160 °C)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	13/06/2023	09:45	13/06/2023	18:45	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	13/06/2023	09:45	13/06/2023	10:20	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	13/06/2023	09:45	13/06/2023	10:36	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
400/220/33 KV 167 MVA SPARE ICT @ WALUJ	IntraState	13/06/2023	11:50	13/06/2023	18:14	PO	Installation of SCADA interfacing control box of CTR fire fighting system panel.
400 KV BR Outages/Trippings							
BUS REACTOR (50 MVar) @ KORADI	IntraState	12/06/2023	09:22	12/06/2023	19:25	PO	Bushings TAN Delta
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
MAIN BUS @ DASTURI	IntraState	12/06/2023	14:00	12/06/2023	18:30	PO	Replacement of damaged jumpers of Bus isolator towards 220KV Bus of Lote line & Kandalgaon line (Bph) at Dasturi S/s. Annual Maintenance of 220kV Bus & 220KV PT at 220/33kV Dasturi S/S.
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	13/06/2023	11:40	13/06/2023	13:05	T	220kv Bale Pgcil(solapur) line tripped due to the DT send, LBB operated.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23	13/06/2023	14:36	T	Tripped on Differential protection.
MAHAD-KALAMBANI(TSS)	IntraState	10/06/2023	19:32	12/06/2023	13:08	PO	1) Erection of 06 nos cross-arm on 02 nos monopole. 2) Stringing of 03 nos conductor on new erected monopole. 3) Stringing of 03 nos conductor both sides of 02 nos erected monopole. 4) Dismantling of old conductor and tower (02 nos)
BORIVALI - TARAPUR	IntraState	11/06/2023	14:47	12/06/2023	03:17	T	Bus fault at Borivali s/s due to bad whether
GADCHANDUR - GRACE	IntraState	12/06/2023	07:52	12/06/2023	13:50	PO	Routine Maintenance Work.
TALANDAGE - FIVE STAR MIDC 1	IntraState	12/06/2023	10:06	12/06/2023	13:29	PO	For hotspot attending work (220KV Bus isolator)
BARAMATI - KURKUMBH	IntraState	12/06/2023	10:10	12/06/2023	10:35	PO	To remove bird nest from gantry in switchyard.
MALEGAON - KALWAN CKT-2	IntraState	12/06/2023	10:37	12/06/2023	13:25	PO	An outage required for urgent tree cutting falling under Ckt-II under the vicinity of line for the preventive maintenance purpose
220 KV AMRAVATI - KARANJA CKT	IntraState	12/06/2023	11:05	12/06/2023	15:27	PO	Distance & Back Up Protection Work.
TOPWORTH - Vile - bhagad	IntraState	12/06/2023	12:15	12/06/2023	16:00	PO	1.For replacement of 89 C isolator gear box 2. Dignostic testig work at Vilebhagad S/s end 3. Line maintenance work
TPC BORIVALI - AAREY	IntraState	12/06/2023	12:16	12/06/2023	12:48	T	Through fault
PALGHAR - NALASOPARA	IntraState	12/06/2023	12:22	12/06/2023	18:28	T	Distance Protection

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
132 KV KANHAN-KANHAN RLY TSS 1	IntraState	12/06/2023	12:30	12/06/2023	14:07	PO	For Attending Overload Relay And Contactor Problem In CB.
BORIVALI - TARAPUR	IntraState	12/06/2023	13:03	12/06/2023	23:50	T	Distance Protection
ABHIJEET-WARDHA-1	IntraState	13/06/2023	08:14	13/06/2023	12:14	PO	Testing work
PEDHAMBE ONI LINE	IntraState	13/06/2023	08:20	13/06/2023	13:20	PO	Pre-monsoon maintenance activities to be done.
PEDHAMBE ONI LINE	IntraState	13/06/2023	08:20	13/06/2023	13:20	PO	For cold washing of insulator strings & other maintenance work.
PARANDA - OSMANABAD	IntraState	13/06/2023	08:29	13/06/2023	15:41	PO	Quarterly Maintenance work
KALMESHWAR-PANDHURNA	IntraState	13/06/2023	08:45	13/06/2023	19:11	PO	FOR LINE MAINTENANCE WORK
LOTEPARSHURAM- DASTURI LINE	IntraState	13/06/2023	11:06	13/06/2023	16:45	T	Tripped on Distance Protection.
PUSAD - WARDHA (PG)	IntraState	13/06/2023	12:24		Continued.	EO	Urgent CB mechanism overhauling-- 1. Low SF6 Pressure alarm 2. Change Aux. Contact of CB
PANDHARPUR - MALINAGAR	IntraState	13/06/2023	16:36	13/06/2023	20:40	PO	Outage is required for Date:- 12.06.2023; Cold line cleaning loc no. 1 to 30 Date:- 13.06.2023; Cold line cleaning loc no. 31 to 61 Date:- 14.06.2023; Cold line cleaning loc no. 62 to 118 For changing /replacement of faulty string at loc no LILo portion 60, 64, 67. Date:- 15.06.2023; Cold line cleaning LILo loc no. 1 to 30 Date:- 16.06.2023; Cold line cleaning LILo loc no. 31 to 60 Date:- 17.06.2023; Cold line cleaning LILo loc no. 61 to 62
BORIVALI - TARAPUR	IntraState	13/06/2023	17:27		Continued.	T	Tripped on Distance Protection.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	12/06/2023	10:38	12/06/2023	10:50	PO	To remove bird nest from gantry in switchyard.
100 MVA 220/132 KV ICT - II @ NARANGWADI	IntraState	12/06/2023	10:50	12/06/2023	17:47	PO	Pre-Monsoon Maintenance Work.
220/132 KV 200MVA ICT 2 @ KURKUMBH	IntraState	12/06/2023	11:00	12/06/2023	11:17	PO	To remove bird nest on gantry in switchyard.
220/132-110/11KV 200MVA ICT 3 @ MIRAJ	IntraState	12/06/2023	12:05	12/06/2023	17:01	PO	Diagnostic testing & Quarterly maintenance work
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	13/06/2023	09:03	13/06/2023	16:41	PO	Replacement work of LV CTs & testing of LTS scheme on HV Back up relay of 100MVA ICT-1
220/33KV 50MVA PTR 1 @ MIRAJ	IntraState	13/06/2023	11:45	13/06/2023	17:19	PO	For replacing chipped support insulator stack of TF HV side isolator
220/33 KV 50 MVA PTR 1 @ VIRAJ	IntraState	13/06/2023	17:54	13/06/2023	20:03	T	Tripped due to R-ph LA Burst LV
220 KV BUSBAR Outages/Trippings							
220KV PT-1 of BUS-1@ MULUND	IntraState	13/06/2023	08:15	13/06/2023	16:04	PO	PRE MANSOON ACTIVITY work & PAINTING WORK.
220KV PT-2 of BUS-1@ MULUND	IntraState	13/06/2023	16:10	13/06/2023	19:08	PO	PRE MANSOON ACTIVITY work & PAINTING WORK.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	11/06/2023	21:56	12/06/2023	05:17	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)
KALWA KALYAN	IntraState	11/06/2023	21:56	12/06/2023	05:12	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)
BHIRA (T) - DAVDI	IntraState	12/06/2023	07:02	12/06/2023	18:18	PO	FOR WORK IN VICINITY AT BHIRA
KALYAN KALWA SALSETTE 1	IntraState	12/06/2023	21:17	13/06/2023	00:05	EO	Removal of hanging object at loc.48
KALWA KALYAN	IntraState	13/06/2023	00:13	13/06/2023	06:23	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)
KALWA KALYAN	IntraState	13/06/2023	22:15		Continued.	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage