

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Jun/2024 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	152.751	1878.404	1) Gujrat	1.020	8.158
2) Hydro	6.972	111.867	2) Madhya Pradesh	-2.384	15.492
3) Gas	6.874	83.163	3) Chattisgarh	1.430	28.350
Total MSPGCL	166.597	2073.434	4) Maharashtra	179.169	2360.686
B) 1) APML	40.631	698.440	5) Goa (Amona)	-1.972	-25.407
2) JSWEL	22.474	314.062	Total	177.263	2387.279
3) VIPL	0.000	0.000	a) Mumbai Schedule	41.303	535.288
4) RPL(AMT)	31.486	355.605	b) Mumbai Drawl	45.246	563.307
5) SWPGPL	12.072	146.169	c) MSEDCL Bilateral *	75.134	1043.651
6) Other IPP	15.706	179.468	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	41.303	535.235
C) 1) TPCL Thermal	11.894	154.730	Include PX	0.000	0.000
2) TPCL Hydro	6.202	68.252	Standby	0.000	0.053
3) TPCL Gas	4.128	49.098	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.544	113.452	1) MSEDCL	447.520	5854.625
D) STATE			2) Mumbai Discoms	77.014	948.836
1) Thermal	296.558	3840.330	3) Other Discoms	11.741	139.494
(A1+C1+C4+(B1-B6))			TOTAL STATE	536.275	6942.955
2) Hydro	13.174	180.119			
(A2+C2)					
3) Gas	11.002	132.261			
(A3+B7+C3)					
4) Wind	26.092	224.247			
6) SOLAR	12.186	178.722			
TOTAL STATE	359.012	4555.679			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6136	6402	6954	6520
MSPGCL Hydro	124	267	573	174
MSPGCL Gas	287	282	285	291
MSPGCL Total Generation	6547	6951	7812	6985
Central Sector Receipt	8123	8178	7905	6057
WIND	954	1349	1077	1365
CPP / IPP Thermal	4745	4731	5822	4875
CPP / IPP Gas	0	0	0	0
SOLAR	1093	733	0	0
Exchange with Mumbai	-2265	-2273	-1832	-1320
MSEDCL DEMAND MET	18677	19135	20236	17574
Load Shedding	0	0	0	0
MSEDCL DEMAND	18677	19135	20236	17574
TPCL GENERATION	726	993	1104	728
AEML GENERATION	304	471	471	375
MUMBAI DEMAND	3295	3737	3407	2423
OTHER DISCOM DEMAND	520	534	548	388
STATE DEMAND MET	22492	23406	24191	20385
STATE DEMAND	22492	23406	24191	20385
Frequency (Hz)	50.05	50.00	49.98	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 09.54 Hrs	49.86 Hz at 15.28 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.15	49.26	188	135
Unit 8	13.37	163.98	610	385
Unit 9	12.79	135.50	580	375
Unit 10	12.80	153.41	575	442
Total	43.11	502.15		
Bhusawal				
Unit 3	2.01	20.50	145	0
Unit 4	9.94	123.08	490	300
Unit 5	9.48	113.14	485	285
Total	21.43	256.72		
Parli				
Unit 6	0.00	34.93	0	0
Unit 7	0.00	26.47	0	0
Unit 8	0.00	38.18	0	0
Total	0.00	99.58		
Chandrapur				
Unit 3	3.42	43.26	162	124
Unit 4	3.42	43.79	160	123
Unit 5	7.93	74.29	435	275
Unit 6	7.90	57.76	420	280
Unit 7	8.64	107.90	460	290
Unit 8	9.46	118.79	443	270
Unit 9	10.88	98.35	500	294
Total	51.66	544.14		
Paras				
Unit 3	4.82	54.63	232	147
Unit 4	0.00	7.43	0	0
Total	4.82	62.06		
Khaparkheda				
Unit 1	3.35	43.10	160	115
Unit 2	3.75	50.62	190	116
Unit 3	3.74	36.93	174	129
Unit 4	4.18	51.28	187	132
Unit 5	10.42	131.96	465	295
Total	25.44	313.88		
Nasik				
Unit 3	3.16	40.71	146	109
Unit 4	0.00	19.19	0	0
Unit 5	3.14	39.97	161	119
Total	6.30	99.88		
Uran				
All Units	6.87	83.16	293	278
Total	6.87	83.16		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.46	1.42	25	0
Total	0.46	1.42		
Koyna				
Stage 1-2	2.34	35.10	505	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.55	28.88	500	0
Stage 3	0.53	15.30	234	0
Total	4.42	79.29		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.79	7.83	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.76	20.02	79	66
GHATGHAR	0.00	1.77	0	0
Total	2.55	32.58		
Wind				
Total	26.09	224.25	0	0
Total	26.09	224.25		
CPP				
APML(Mus)	40.63	698.44	0	0
JSWEL(Mus)	22.47	314.06	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.49	355.60	0	0
SWPGPL-Mus	12.07	146.17	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.86	68.99	269	194
Other(Mus)	3.85	52.86	0	0
JPL	6.00	57.63	271	233
Total	122.37	1693.74		
SOLAR				
Total	12.19	178.72	0	0
Total	12.19	178.72		
Tata				
Trombay 5	7.90	102.79	424	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	30.77	108	108
Trombay 7B	1.54	18.32	64	64
TATA Hydro	6.20	68.25	408	71
Trombay 8	4.00	51.94	227	130
Total	22.22	272.08		
AEML				
DTPS U-1&2	9.54	113.45	501	295
Total	9.54	113.45		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	152.75	1878.40	MSPGCL Total	166.60	2073.43
			MSPGCL Thml+Gas	159.62	1961.57	Koyna 1,2 & 4 Total	3.89	63.99
			MSPGCL Hydro	6.97	111.87	State Total	359.01	4555.68

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6863	175	290	7328	1420	5524	0	0	6590	6000	-1658	18176	0	0	18176	3050	438	21664	50.03
2	6332	195	290	6817	1287	5168	0	0	6771	6510	-1496	17873	0	0	17873	2809	413	21095	50.01
3	6416	172	290	6878	1344	5091	0	0	6374	6382	-1367	17938	0	0	17938	2631	390	20959	49.99
4	6459	187	291	6937	1364	4929	0	0	6512	6164	-1381	17624	0	0	17624	2512	389	20525	50.03
5	6520	174	291	6985	1365	4875	0	0	6488	6057	-1320	17574	0	0	17574	2423	388	20385	49.99
6	6481	142	293	6916	1167	4769	0	2	6974	6881	-1453	17862	0	0	17862	2457	420	20739	50.00
7	6955	121	293	7369	1025	5158	0	57	7187	6863	-1452	18544	0	0	18544	2510	476	21530	50.00
8	6971	120	293	7384	911	4961	0	313	7505	7270	-1622	18732	0	0	18732	2682	485	21899	49.99
9	6310	118	282	6710	942	4781	0	734	8243	7980	-2023	18622	0	0	18622	2979	502	22103	50.00
10	6136	124	287	6547	954	4745	0	1093	8581	8123	-2265	18677	0	5	18677	3295	520	22492	50.05
11	5450	118	286	5854	917	4677	0	1431	8651	8251	-2288	18324	0	14	18324	3573	518	22415	50.01
12	5006	213	284	5503	825	4597	0	1672	8734	8441	-2422	18085	0	20	18085	3705	531	22321	49.98
13	5031	117	280	5428	779	4628	0	1756	8633	8174	-2447	17799	0	0	17799	3694	519	22012	49.98
14	5030	177	278	5485	872	4491	0	1584	8583	8245	-2343	17839	0	0	17839	3623	495	21957	49.97
15	5573	133	279	5985	1065	4596	0	1315	8519	8528	-2319	18672	0	0	18672	3725	498	22895	50.00
16	6266	205	282	6753	981	4749	0	1036	8467	8057	-2267	18780	0	0	18780	3792	529	23101	49.96
17	6402	267	282	6951	1349	4731	0	733	8381	8178	-2273	19135	0	0	19135	3737	534	23406	50.00
18	6779	192	284	7255	1437	4795	0	384	8236	7926	-2278	18955	0	0	18955	3620	564	23139	50.03
19	6917	186	285	7388	1362	5267	0	76	7913	7810	-2128	19221	0	0	19221	3422	554	23197	50.06
20	6954	573	285	7812	1077	5822	0	0	7774	7905	-1832	20236	0	0	20236	3407	548	24191	49.98
21	6997	1015	285	8297	721	5913	0	0	7164	7317	-1682	20027	0	0	20027	3383	539	23949	49.97
22	7010	1033	287	8330	765	5887	0	0	7158	6905	-1643	19721	0	0	19721	3314	523	23558	49.99
23	6948	810	287	8045	993	6050	0	0	7042	6840	-1632	19807	0	0	19807	3319	489	23615	50.00
24	6945	405	290	7640	1170	6165	0	0	7113	6456	-1655	19298	0	0	19298	3352	478	23128	50.03
MUs	152.75	6.97	6.87	166.60	26.09	122.37	0.00	12.19	183.59	177.26	-45.25	447.52	0.00	0.04	447.52	77.01	11.74	536.28	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

- 1) 220kv Satana to Dindori line overload.
- 2) As Satana Dindori line was overloaded due to export to GCR, ELR was carried out for load management

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jun/2024

Position as on 6.30 Hrs of 13/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	16/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Uran Unit 8	108	13/06/2024	02:58		Continued.	attending B2 Boiler Super Heater vent leakage	13/06/2024
Total Capacity MSPGCL		813						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1133						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	12/06/2024	16:15		Continued.	Zero schedule given by LM Cell Discom due to drop in demand	
Total Capacity MSPGCL		1176						
IPP								
IPP	Adani U-4	660	10/06/2024	16:16		Continued.	ZERO SCHEDULE BY MSEDCL	
Total Capacity IPP		660						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		1836						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jun/2024

Position as on 6.30 Hrs of 13/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11	12/06/2024	20:44	T	Tripped on distance protection.(Due to tower
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) OF 400/21KV GT-1 and 765/400KV ICT (LV Side) @ TIRORA	IntraState	12/06/2024	16:00	12/06/2024	17:35	PO	CT OIL SAMPLE COLLECTION FOR DGA
TIE BAY 418 OF ICT-1 @ LONIKAND 2	IntraState	13/06/2024	06:18			PO	Diagnostic testing and Pre Monsoon Maintenance
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ PARLI	IntraState	11/06/2024	04:05			T	Tripped but no indication appears.
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	IntraState	12/06/2024	08:06	12/06/2024	16:49	PO	For the instalment of external cooling fans to enhance cooling in 400 kV, 125 MVAR, Bus Shunt Reactor.
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
220 KV KHAPARKHEDA (400KV) - AMBAZARI CKT	IntraState	12/06/2024	11:04	12/06/2024	16:42	PO	LINE ISOLATOR 29 D & AUXILLARY ISOLATOR 29 C OVERHAULING & ALIGNMENT WORK
DEEPNAGAR - THAPTI TANDA	IntraState	13/06/2024	06:22	13/06/2024	09:29	PO	Replacement of R- Phase suspension type string insulator at location No. 90 due to flash over observed due to lightning and AR successful operated at both end on 07.06.2024.
JEJURI - KARAD	IntraState	13/06/2024	08:49			PO	For diagnostic testing work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	11/06/2024	19:20	12/06/2024	17:45	T	REF Protection
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	11/06/2024	19:20	12/06/2024	17:45	T	TRIPPED ON REF PROTECTION OPERATED
MAIN BAY (419) OF 400/220/33kv 500MVA ICT-I @ LONIKAND 2	IntraState	13/06/2024	06:18			PO	Diagnostic testing and Pre Monsoon Maintenance
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	12/06/2024	10:10			PO	1) Relay replacement work of Reactor 2) Bay maint work 3) Replacement of 29C bus PG isolator
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
MAIN BUS @ KARKAMB	IntraState	12/06/2024	10:55	12/06/2024	14:42	PO	Outage is required for Quarterly Maintenance
220 KV LINE Outages/Trippings							
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
EKLAHARE (OCR) - PADGHE	IntraState	10/06/2024	08:42			HT	H/T for load management
JAMDE-DONDAICHA 2	IntraState	11/06/2024	18:25	12/06/2024	08:21	T	D/P,RPH,2.4KM R PH
JAMDE-DONDAICHA 2	IntraState	11/06/2024	18:25			T	Distance Protection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	11/06/2024	21:35	12/06/2024	01:08	PO	To re-connect jumpers of 220 kV AKP-Nashik line at TL No. 396 after erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333.
NTT - BAPGAON	IntraState	11/06/2024	21:35	12/06/2024	01:08	PO	To re-connect jumpers of 220 kV AKP-Nashik line at TL No. 396 after erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333.
LONAND-BOTHE	IntraState	12/06/2024	05:18	12/06/2024	06:04	T	Distance Protection
KANHAN-SURYALAKSHMI	IntraState	12/06/2024	07:59	12/06/2024	10:47	PO	1) FOR TIGHTENING NUT BOLT OF RPH (76.5) AND B PH (48.4) JUMPER AT LN 07 2) FOR TIGHTENING NUT BOLT OF B PH (64.1) JUMPER AT LN 24
HINGANGHAT - BHUGAON	IntraState	12/06/2024	08:38	12/06/2024	14:19	PO	DAIGONISTIC TESTING WORK AT BOTH END
KHAPARKHEDA - BUTIBORI 3	IntraState	12/06/2024	09:01	12/06/2024	16:45	PO	STRINGING WORK BETWEEN LOC NO 103-LOC NO 104 OF 220KV KORADI II TO BUTIBORI III DC ON MC TL
KHAPARKHEDA- BUTIBORI	IntraState	12/06/2024	09:06	12/06/2024	16:41	PO	STRINGING WORK BETWEEN LOC NO 103-LOC NO 104 OF 220KV KORADI II TO BUTIBORI III DC ON MC TL
220KV PANDHARKAWDA - WANI CKT I	IntraState	12/06/2024	09:20	12/06/2024	13:10	PO	DAIGONISTIC TESTING WORK

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
OSMANABAD - PARLY (PG)	IntraState	12/06/2024	12:05	12/06/2024	16:32	PO	FOR REPLACEMENT OF FLASHOVER R PHASE STRING INSULATOR AT LOC NO.259
GHATODI-NANDED	IntraState	12/06/2024	12:44	12/06/2024	16:17	PO	REPLACEMENT OF FLASHOVER STRING LOC. 13-RPH
220 KV DHULE(400 KV) - AMALNER	IntraState	12/06/2024	13:02	12/06/2024	14:27	EO	TO ATTENED RED HOT SPOT ON Y-PH CT(174 DEG) LINE SIDE
LOTEPARSHURAM- DASTURI LINE	IntraState	12/06/2024	14:11	12/06/2024	18:45	PO	Attending hot-spot on B ph CT palm towards CB of 220KV Dasturi line at 220KV Lote s/s. Also line isolator maintenance to be done.
220KV PANDHARKAWDA - WANI CKT li	IntraState	12/06/2024	14:12	12/06/2024	18:06	PO	DIAGNOSTIC TESTING (TAN DELTA, TIMING TEST ,CRM TEST
TIFIL - KALWA	IntraState	13/06/2024	08:55			PO	For making 220kV Pawane-TIFIL line LILO for M/s NXTRA Data Ltd for the proposed 220kV GIS S/stn.
GOREGAON - VERSOVA CKT - 1	IntraState	13/06/2024	09:32			PO	Pre-monsoon Maintenance work
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	12/06/2024	09:38	12/06/2024	12:23	PO	Pre-monsoon Maintenance Work
100 MVA 220/132 KV ICT - I @ JALKOT	IntraState	12/06/2024	09:40	12/06/2024	12:45	PO	PREMANSOON MAINTENANCE WORK
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	12/06/2024	09:42	12/06/2024	12:55	PO	125 MVA 220/100 Kv ICT No:01 Premansoon activites /Dignostic testing
200 MVA 220/132 KV ICT - III @ CHALISGAON	IntraState	12/06/2024	09:55	12/06/2024	13:48	PO	PREMANSOON MAINTENANCE WORK
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	12/06/2024	10:17	12/06/2024	14:35	PO	Pre-Monsoon work to be carried.
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	12/06/2024	10:20	12/06/2024	11:15	PO	LV Bay Maintenance & Attending Hot spot on LV CB
220/132 KV 200 MVA PTR NO 6 @ PARVATI	IntraState	12/06/2024	10:29	12/06/2024	13:32	PO	Half Yearly Maint Work
220/132 KV 100 MVA ICT 2 @ GHATODI	IntraState	12/06/2024	10:47	12/06/2024	17:39	PO	PREMANSOON MAINTENANCE WORK
220/132KV 200MVA ICT 3 @ PANDHARPUR	IntraState	12/06/2024	10:50			PO	Outage is required for Pre Monsoon maintenance
220/132 KV 200 MVA ICT 2	IntraState	12/06/2024	12:14	12/06/2024	13:48	PO	FOR PREMONSOON MAINTENANCE AND RM WORK OF BAY.
220/132 KV 100 MVA ICT 2 @ BELWANDI	IntraState	12/06/2024	12:32	12/06/2024	14:06	PO	Pre-monsoon Maintenance Work
220/132 KV 200MVA ICT NO 1 @ THEUR	IntraState	13/06/2024	06:15			PO	OLTC overhauling work
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
KANHAN-MANSAR	IntraState	12/06/2024	10:56	12/06/2024	13:20	PO	For routine maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 13/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KANHAN-MANSAR	IntraState	12/06/2024	10:56	12/06/2024	13:20		132KV Kanhan line Yph LA IR value to be taken due to high LA LCM value.Breaker timing,CRM and Routine Maintenance work
110 KV LINE Outages/Trippings							
AMBERNATH - KALYAN CKT - 2	IntraState	12/06/2024	06:32	12/06/2024	12:28	PO	INSULATOR REPLACEMENT
TATA AMBERNATH MSETCL NERAL	IntraState	13/06/2024	06:04	13/06/2024	07:50	PO	Bird nest removal at loc. 176,177,178,180,181,183,184,185,186
BHIVPURI - AMBERNATH CKT - 1	IntraState	13/06/2024	08:04	13/06/2024	09:20	PO	Bird nest removal at loc. 166,173,175,182

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage