

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Jul/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	130.591	1653.944	1) Gujrat	5.308	0.163
2) Hydro	10.183	80.867	2) Madhya Pradesh	8.754	65.309
3) Gas	0.000	0.000	3) Chattisgarh	1.750	28.530
Total MSPGCL	140.774	1734.811	4) Maharashtra	174.065	1955.983
B) 1) APMIL	66.761	733.407	5) Goa (Amona)	-1.053	-12.711
2) JSWEL	20.680	232.581	Total	188.824	2037.274
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.230	442.124
4) RPL(AMT)	18.747	281.871	b) Mumbai Drawl	42.125	484.681
5) SWPGPL	8.972	105.116	c) MSEDCL Bilateral *	90.851	1063.237
6) Other IPP	6.415	77.331	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.199	441.273
C) 1) TPCL Thermal	10.349	65.760	Include PX	0.000	0.000
2) TPCL Hydro	4.370	60.658	Standby	0.031	0.851
3) TPCL Gas	2.949	45.029	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.471	106.089	1) MSEDCL	442.434	5229.144
D) STATE			2) Mumbai Discoms	68.264	762.219
1) Thermal	270.986	3256.099	3) Other Discoms	9.954	117.992
(A1+C1+C4+(B1-B6))			TOTAL STATE	520.652	6109.355
2) Hydro (A2+C2)	14.553	141.525			
3) Gas (A3+B7+C3)	2.949	45.029			
4) Wind	35.241	500.795			
6) SOLAR	8.099	128.631			
TOTAL STATE	331.828	4072.079			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5529	5565	5567	5212
MSPGCL Hydro	198	157	1373	158
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5727	5722	6940	5370
Central Sector Receipt	8815	8612	7778	6680
WIND	1725	1533	1121	1308
CPP / IPP Thermal	5347	4994	5605	4816
CPP / IPP Gas	0	0	0	0
SOLAR	810	816	0	0
Exchange with Mumbai	-2105	-2288	-1457	-1232
MSEDCL DEMAND MET	19875	18937	19550	16618
Load Shedding	0	0	113	0
MSEDCL DEMAND	19875	18937	19663	16618
TPCL GENERATION	632	622	1128	601
AEML GENERATION	463	331	501	307
MUMBAI DEMAND	3200	3241	3086	2140
OTHER DISCOM DEMAND	444	452	437	324
STATE DEMAND MET	23519	22630	23073	19082
STATE DEMAND	23519	22630	23186	19082
Frequency (Hz)	50.05	50.06	49.88	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 18.02 Hrs	49.71 Hz at 19.58 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.66	45.44	170	115
Unit 8	13.10	146.32	581	494
Unit 9	12.70	142.60	562	500
Unit 10	0.00	111.14	0	0
Total	29.45	445.50		
Bhusawal				
Unit 3	3.04	33.55	135	115
Unit 4	8.90	116.04	440	290
Unit 5	9.40	120.70	455	295
Total	21.34	270.29		
Parli				
Unit 6	0.00	11.32	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	11.32		
Chandrapur				
Unit 3	3.14	40.05	150	100
Unit 4	3.22	39.12	145	122
Unit 5	0.00	0.00	0	0
Unit 6	7.48	95.27	359	265
Unit 7	7.36	95.20	326	288
Unit 8	9.73	118.06	427	365
Unit 9	10.63	122.76	466	410
Total	41.56	510.45		
Paras				
Unit 3	4.94	41.16	223	156
Unit 4	4.62	56.37	208	162
Total	9.56	97.53		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.43	30.59	112	83
Unit 3	3.74	46.31	176	135
Unit 4	4.00	39.21	189	135
Unit 5	10.23	119.77	450	397
Total	20.40	235.88		
Nasik				
Unit 3	4.22	29.60	182	150
Unit 4	4.06	41.05	178	143
Unit 5	0.00	12.33	0	0
Total	8.28	82.99		
Uran				
All Units	0.00	0.00	0	0
Total	0.00	0.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.08	0.08	23	0
Total	0.08	0.08		
Koyna				
Stage 1-2	2.84	24.92	460	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.91	2.81	487	0
Stage 3	1.17	10.20	240	0
Total	5.92	37.93		
Hydro				
KDPH	0.00	0.14	0	0
VTRNA	0.00	0.64	0	0
TILLARI	0.00	1.16	0	0
BHIRA T.R.	0.44	5.36	80	0
SMLHY_PTN	3.46	32.48	527	121
GHATGHAR	0.28	3.08	125	0
Total	4.18	42.86		
Wind				
Total	35.24	500.80	0	0
Total	35.24	500.80		
CPP				
APML(Mus)	66.76	733.41	0	0
JSWEL(Mus)	20.68	232.58	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.75	281.87	0	0
SWPGPL-Mus	8.97	105.12	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.17	61.08	270	175
Other(Mus)	1.24	16.25	0	0
Total	121.58	1430.31		
SOLAR				
Total	8.10	128.63	0	0
Total	8.10	128.63		
Tata				
Trombay 5	6.70	20.69	362	239
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.74	27.78	108	39
Trombay 7B	1.20	17.25	65	36
TATA Hydro	4.37	60.66	427	20
Trombay 8	3.65	45.07	213	131
Total	17.67	171.45		
AEML				
DTPS U-1&2	8.47	106.09	501	49
Total	8.47	106.09		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	130.59	1653.94	MSPGCL Total	140.77	1734.81
			MSPGCL Thml+Gas	130.59	1653.94	Koyna 1,2 & 4 Total	4.75	27.72
			MSPGCL Hydro	10.18	80.87	State Total	331.83	4072.08

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5397	225	0	5622	1446	5110	0	0	6917	6670	-1341	17146	0	0	17146	2559	361	20066	49.95
2	5333	160	0	5493	1173	5097	0	0	7048	6444	-1301	16567	0	0	16567	2359	339	19265	50.02
3	5272	158	0	5430	1337	4920	0	0	7026	6726	-1198	16879	0	0	16879	2248	336	19463	50.02
4	5212	158	0	5370	1308	4816	0	0	6868	6680	-1232	16618	0	0	16618	2140	324	19082	49.94
5	5265	163	0	5428	1645	4947	0	0	7219	6781	-1236	17220	0	0	17220	2135	345	19700	49.94
6	5231	168	0	5399	1792	5193	0	0	7790	7582	-1310	18286	0	0	18286	2227	370	20883	49.98
7	5279	158	0	5437	1796	5357	0	49	8667	8420	-1405	19269	0	0	19269	2370	385	22024	50.04
8	5417	245	0	5662	1714	5145	0	260	9082	8918	-1728	19548	0	0	19548	2574	423	22545	49.99
9	5491	553	0	6044	1592	4900	0	540	9119	9062	-2010	19691	0	0	19691	2885	437	23013	49.98
10	5529	198	0	5727	1725	5347	0	810	9220	8815	-2105	19875	0	0	19875	3200	444	23519	50.05
11	5267	198	0	5465	1860	4550	0	1092	9981	9399	-2473	19442	0	29	19442	3362	451	23255	50.04
12	5357	161	0	5518	1683	4072	0	1221	9796	9282	-2504	18824	0	0	18824	3412	448	22684	49.99
13	5446	367	0	5813	1605	3989	0	1125	9118	8843	-2466	18450	0	0	18450	3346	459	22255	49.97
14	5625	371	0	5996	1507	4329	0	910	8591	8540	-2269	18556	0	0	18556	3230	457	22243	50.04
15	5565	157	0	5722	1533	4994	0	816	8612	8612	-2288	18937	0	0	18937	3241	452	22630	50.06
16	5524	157	0	5681	1548	5270	0	627	8940	8527	-2361	18857	0	0	18857	3246	435	22538	50.04
17	5498	158	0	5656	1711	5249	0	410	9038	8496	-2287	18801	0	0	18801	3213	434	22448	49.99
18	5521	682	0	6203	1685	5054	0	208	8457	8316	-2128	18890	0	0	18890	3174	448	22512	49.98
19	5548	483	0	6031	1292	5470	0	31	8292	8477	-1806	19034	0	0	19034	3140	461	22635	50.04
20	5567	1373	0	6940	1121	5605	0	0	7790	7778	-1457	19550	113	0	19663	3086	437	23186	49.88
21	5613	1283	0	6896	1059	5565	0	0	7445	7112	-1397	18791	29	0	18820	2563	444	21827	49.89
22	5633	1134	0	6767	1010	5537	0	0	6880	6532	-1318	18088	0	0	18088	2918	440	21446	49.99
23	5567	899	0	6466	942	5524	0	0	6775	6621	-1271	17863	0	0	17863	2839	419	21121	49.97
24	5434	574	0	6008	1157	5535	0	0	6800	6191	-1234	17253	0	0	17253	2797	404	20454	50.03
MUs	130.59	10.18	0.00	140.77	35.24	121.58	0.00	8.10	195.47	188.82	-42.12	442.43	0.14	0.03	442.58	68.26	9.95	520.79	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) Due to overloading of 220kv nasik and BBLR line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jul/2023

Position as on 6.30 Hrs of 13/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	15/07/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhual.	
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	24/07/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57	13/07/2023	19:34	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Koyna STG-IV Unit-2	250	07/06/2023	15:30	12/07/2023	18:00	Due to water shortage.	
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	25/07/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/07/2023
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	29/06/2023	14:31	13/07/2023	17:27	On Zero Schedule	
IPP	SWPGPL U-1	135	02/07/2023	02:54		Continued.	PA Fan problem	14/07/2023
MSPGCL	Nasik Unit 5	210	04/07/2023	18:00		Continued.	Generator Swapping : nashik Unit-3 sync 16:35 Hrs and tolling agreement with IEPL	
MSPGCL	Parli Unit 6	250	07/07/2023	21:45	13/07/2023	16:38	ZERO SCHEDULE	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jul/2023

Position as on 6.30 Hrs of 13/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-5	270	10/07/2023	08:55		Continued.	Bottom Ash Problem.	14/07/2023
MSPGCL	Uran Unit 6	108	13/07/2023	22:16		Continued.	No Schedule	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT-2 @ EKTUNI	IntraState	12/07/2023	13:25	12/07/2023	18:46	EO	Emergency Outage for attending Visible hot-spot on ICT-II IV; 400KV Stub-Bus drop (TEED-Bus) connecting the IPS.
765/400kV 1500 MVA ICT-2 @ KORADI 3	IntraState	13/07/2023	12:19	13/07/2023	15:40	PO	DGA test of Metering Current Transformer
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synch CVT.
SPARE LINE-1 BAY (401) @ TAPTITANDA	IntraState	11/07/2023	09:42	13/07/2023	15:51	PO	Circuit Breaker Overhauling work by M/s CGL
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	13/07/2023	19:04		Continued.	T	Tripped on distance protection
NEW KOYNA-KARAD CKT - 1	IntraState	12/07/2023	01:11	12/07/2023	07:27	HT	H/T FOR O/V
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	12/07/2023	11:27	12/07/2023	18:51	PO	Replacement of faulty PID disc insulator. Said outage having sr. No 32 in state element outage list for the month of July-2023.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	13/07/2023	08:03			HT	H/T Due to load management.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	13/07/2023	11:13	13/07/2023	16:26	PO	(1) Main-1 distance relay testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work
DABHOL - NEW KOYNA CKT - 1	IntraState	13/07/2023	11:48	13/07/2023	19:09	PO	Rectification of line and bay isolator and earth switch operational issues.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	10/07/2023	10:45	12/07/2023	12:04	PO	Load Trials of Rapid restoration scheme
167 MVA SPARE ICT @ TALANDGE	IntraState	10/07/2023	11:17	12/07/2023	21:40	PO	For load trails on Rapid Restoration Scheme with 501 MVA ICT 3.
400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	IntraState	12/07/2023	09:24	12/07/2023	18:40	PO	Routine Testing and maintenance activities.
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	12/07/2023	12:22	12/07/2023	17:58	T	R ph LA burst :LV side
400/220/33 KV 315MVA ICT - 2 @ CHAKAN	IntraState	13/07/2023	10:37	13/07/2023	20:08	PO	Attending oil leakages Routine Maintenance and DT.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	13/07/2023	11:23			PO	Mechanism overhauling work of IV Bay Circuit Breaker
400 KV BUSBAR Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400KV MAIN BUS 2 @ 400KV DEEPNAGAR	IntraState	13/07/2023	10:46	13/07/2023	14:30	PO	For cable termination, wiring, testing & configuration of new Station TF (STN-6A) and Generating TF GT-6 bay in existing 400 kV Bus-II Busbar Panel in r/o 660 MW Unit.
220 KV MAINBAY Outages/Trippings							
TBC @ PARVATI	IntraState	12/07/2023	11:15	12/07/2023	13:40	PO	Half yearly maint.
220 KV BUS SECTION - 2	IntraState	13/07/2023	08:56	13/07/2023	17:21	PO	Diagnostic testing and Routine bay maintenance work.
220 KV LINE Outages/Trippings							
NARANGWADI - SOLAPUR PG CKT - 1	InterState	13/07/2023	08:47	13/07/2023	18:05	PO	Line terminal equipments AMP at 765kV Solapur Substation
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
DAHANU - VERSOVA	IntraState	10/07/2023	10:24			PO	Shifting of Lines on Newly constructed Towers for NHRCL Project Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
BOISAR - VERSOVA	IntraState	10/07/2023	10:27			PO	Shifting of Lines on Newly constructed Towers for NHRCL Project. Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
MALEGAON-SATANA	IntraState	12/07/2023	09:58	12/07/2023	16:07	PO	Outage proposal for replacement of faulty disc insulators strings found in PID testing at various locations.
MAIN BUS- A @ BAPGAON	IntraState	12/07/2023	10:48	12/07/2023	13:20	PO	For 220kV Bus Coupler CB B PH Top Palm Hotspot attending work.
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	12/07/2023	11:12	12/07/2023	18:48	PO	Outage is required for Quarterly Maintenance
KALYANI - BARAMATI AGRO	IntraState	12/07/2023	13:10	12/07/2023	15:15	EO	For R ph CT hot spot attending work
MAIN BUS - 1 @ SOUTH SOLAPUR	IntraState	12/07/2023	13:40	12/07/2023	17:05	PO	Outage is required for Quarterly Maintenance
PEDAMBE-KALAMBANI(TSS)	IntraState	12/07/2023	13:55	12/07/2023	18:18	EO	¿Y¿ and ¿B¿ Phase breaker to line side isolator jumper strand broken.
VITA - HIWARWADI	IntraState	13/07/2023	10:33	13/07/2023	17:34	PO	Cold washing of insulator strings
KARAD - VITA CKT- 1	IntraState	13/07/2023	10:33	13/07/2023	17:34	PO	Cold washing work of insulator strings
LONAND-PHALTAN MIDC	IntraState	13/07/2023	10:40	13/07/2023	14:45	PO	TBC Wiring & Testing Work
NAGOTHANE - SPCL	IntraState	13/07/2023	11:11	13/07/2023	13:11	PO	For relay testing work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 13/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BABLESHWAR- ALEPHATA CKT - 1	IntraState	13/07/2023	11:31	13/07/2023	21:09	PO	220 KvBabhaleshwarAlephataCktfor attending the damage conductor at various cut point locations found in monkey patrolling of the line. 83 Y phAlephataside, 82 B phAlephata side, 74 R Y B ph BBLR side, 98 R ph alephata side . 124 R ph BBLR side , 131 R Y B PH ALEphata side . 172 Y ph Alephata SIDE ,
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	13/07/2023	11:40	13/07/2023	15:00	EO	Y phase flashover string replacement work.
DONDAICHA- SHAHADA	IntraState	13/07/2023	15:00	13/07/2023	18:30	PO	Line 1, Commissioning and charging work.
KANDALGAON - KOYNA (POPHALI)	IntraState	13/07/2023	19:26		Continued.	T	Tripped on distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	12/07/2023	10:17	12/07/2023	14:17	EO	For emergency inspection of OLTC tap change problem
220/132KV 100MVA ICT 2 @ JEUR	IntraState	12/07/2023	10:25	12/07/2023	15:00	PO	Outage is required for Quarterly Maintenance
220 KV /132 KV 100 MVA ICT 1 @ CHITEGAON	IntraState	12/07/2023	10:30	12/07/2023	16:53	PO	CT Replacement work.
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	12/07/2023	11:35	12/07/2023	16:06	EO	Testing work of ICT.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
MANKAPUR - HINGNA-I	IntraState	12/07/2023	12:15	12/07/2023	12:32	T	132kv Mankapur Ss in dark, and ambazari Hingna1 under outage
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage