

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Jul/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	134.946	1660.754	1) Gujrat	1.820	16.978
2) Hydro	4.137	78.589	2) Madhya Pradesh	2.620	24.671
3) Gas	6.408	78.472	3) Chattisgarh	-0.540	11.450
Total MSPGCL	145.491	1817.815	4) Maharashtra	150.372	1802.836
B) 1) APLM	55.083	697.918	5) Goa (Amona)	-1.824	-22.249
2) JSWEL	19.130	234.470	Total	152.448	1833.686
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.771	447.350
4) RPL(AMT)	24.149	271.536	b) Mumbai Drawl	37.341	483.450
5) SWPGPL	11.995	143.360	c) MSEDCL Bilateral *	94.217	1104.852
6) Other IPP	12.765	147.653	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.771	447.350
C) 1) TPCL Thermal	10.334	141.568	Include PX	0.000	0.000
2) TPCL Hydro	5.124	57.642	Standby	0.000	0.000
3) TPCL Gas	4.128	45.697	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.956	117.221	1) MSEDCL	437.263	5257.979
D) STATE			2) Mumbai Discoms	65.883	845.576
1) Thermal	277.358	3414.480	3) Other Discoms	11.391	135.881
(A1+C1+C4+(B1-B6))			TOTAL STATE	514.537	6239.436
2) Hydro	9.261	136.231			
(A2+C2)					
3) Gas	10.536	124.169			
(A3+B7+C3)					
4) Wind	50.599	558.434			
6) SOLAR	14.335	172.438			
TOTAL STATE	362.089	4405.752			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5804	4824	5782	5896
MSPGCL Hydro	199	83	248	130
MSPGCL Gas	269	266	264	270
MSPGCL Total Generation	6272	5173	6294	6296
Central Sector Receipt	7454	7309	7242	4944
WIND	1840	2223	2411	1745
CPP / IPP Thermal	4969	4035	5669	5353
CPP / IPP Gas	0	0	0	0
SOLAR	1441	1914	0	0
Exchange with Mumbai	-1900	-2225	-1712	-868
MSEDCL DEMAND MET	19555	17951	19390	17086
Load Shedding	0	0	0	0
MSEDCL DEMAND	19555	17951	19390	17086
TPCL GENERATION	806	750	922	692
AEML GENERATION	348	338	402	449
MUMBAI DEMAND	3054	3313	3036	2009
OTHER DISCOM DEMAND	521	478	514	384
STATE DEMAND MET	23130	21742	22940	19479
STATE DEMAND	23130	21742	22940	19479
Frequency (Hz)	49.96	49.99	50.03	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 13.03 Hrs	49.73 Hz at 15.53 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Jul/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.11	47.97	184	137
Unit 8	11.32	137.98	548	378
Unit 9	12.01	140.88	575	370
Unit 10	11.48	92.99	525	400
Total	38.92	419.81		
Bhusawal				
Unit 3	3.12	39.50	170	115
Unit 4	0.00	0.00	0	0
Unit 5	9.09	117.78	455	285
Total	12.21	157.28		
Parli				
Unit 6	3.65	46.96	187	125
Unit 7	3.55	46.29	194	97
Unit 8	3.52	45.62	164	140
Total	10.72	138.87		
Chandrapur				
Unit 3	3.20	29.92	150	108
Unit 4	3.33	39.53	152	127
Unit 5	7.40	94.66	375	270
Unit 6	7.36	92.20	380	270
Unit 7	6.17	75.95	410	0
Unit 8	8.78	107.32	410	288
Unit 9	0.00	88.09	0	0
Total	36.25	527.66		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	4.70	58.62	236	145
Total	4.70	58.62		
Khaparkheda				
Unit 1	3.52	37.16	165	110
Unit 2	4.12	46.31	201	120
Unit 3	3.83	43.23	178	137
Unit 4	3.96	31.34	185	126
Unit 5	10.40	126.64	495	295
Total	25.83	284.68		
Nasik				
Unit 3	2.86	26.17	164	0
Unit 4	0.00	26.89	0	0
Unit 5	3.46	20.78	166	115
Total	6.31	73.83		
Uran				
All Units	6.41	78.47	271	261
Total	6.41	78.47		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	1.14	15.49	285	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	15.41	0	0
Stage 3	0.59	11.18	80	0
Total	1.73	42.07		
Hydro				
KDPH	0.00	0.05	0	0
VTRNA	0.00	1.01	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.40	4.12	80	0
SMLHY_PTN	2.01	28.68	96	79
GHATGHAR	0.00	2.66	0	0
Total	2.41	36.52		
Wind				
Total	50.60	558.43	0	0
Total	50.60	558.43		
CPP				
APML(Mus)	55.08	697.92	0	0
JSWEL(Mus)	19.13	234.47	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.15	271.54	0	0
SWPGPL-Mus	12.00	143.36	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.51	64.31	268	171
Other(Mus)	2.21	25.04	0	0
JPL	5.05	58.30	272	170
Total	123.12	1494.94		
SOLAR				
Total	14.34	172.44	0	0
Total	14.34	172.44		
Tata				
Trombay 5	6.77	92.12	373	249
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	28.22	108	108
Trombay 7B	1.54	17.48	64	64
TATA Hydro	5.12	57.64	361	120
Trombay 8	3.57	49.45	225	129
Total	19.59	244.91		
AEML				
DTPS U-1&2	8.96	117.22	491	282
Total	8.96	117.22		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	134.95	1660.75	MSPGCL Total	145.49	1817.82
			MSPGCL Thml+Gas	141.35	1739.23	Koyna 1,2 & 4 Total	1.14	30.90
			MSPGCL Hydro	4.14	78.59	State Total	362.09	4405.75

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Jul/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6167	146	269	6582	1584	5766	0	0	5384	5170	-864	17798	0	0	17798	2388	440	20626	50.03
2	6121	131	269	6521	1588	5536	0	0	5265	4813	-695	17349	0	0	17349	2218	414	19981	50.03
3	5982	130	270	6382	1631	5412	0	0	5485	5054	-825	17279	0	0	17279	2073	376	19727	50.01
4	5896	130	270	6296	1745	5353	0	0	5482	4944	-868	17086	0	0	17086	2009	384	19479	50.04
5	5893	131	271	6295	1815	5213	0	0	5564	5488	-900	17526	0	0	17526	1990	386	19901	50.00
6	6207	264	271	6742	1739	5512	0	0	5979	6095	-1076	18578	0	0	18578	2092	434	21104	50.03
7	6443	397	269	7109	1501	6063	0	127	6269	6355	-1097	19592	0	0	19592	2248	466	22306	50.01
8	6361	313	270	6944	1488	6066	0	494	6702	6581	-1313	19772	0	0	19772	2438	488	22698	50.01
9	6033	201	270	6504	1473	5440	0	948	7331	7210	-1619	19454	0	0	19454	2763	501	22719	50.04
10	5804	199	269	6272	1840	4969	0	1441	7642	7454	-1900	19555	0	0	19555	3054	521	23130	49.96
11	5623	147	269	6039	2137	4624	0	1723	7864	7287	-2177	19136	0	0	19136	3241	497	22874	50.06
12	5038	102	267	5407	2203	4432	0	1747	7961	7516	-2208	18604	0	0	18604	3311	494	22408	50.02
13	4824	83	266	5173	2223	4035	0	1914	7567	7309	-2225	17951	0	0	17951	3313	478	21742	49.99
14	4819	82	265	5166	2472	4052	0	1692	6646	6655	-2100	17465	0	0	17465	3214	472	21151	50.05
15	4774	81	263	5118	2489	4366	0	1642	6632	6433	-2067	17508	0	0	17508	3219	473	21200	49.98
16	4741	82	262	5085	2623	4562	0	1234	7327	6839	-2125	17723	0	0	17723	3223	496	21441	49.91
17	4698	81	261	5040	3075	4495	0	877	7334	6832	-2076	17744	0	0	17744	3133	499	21376	49.93
18	5023	107	262	5392	2970	4510	0	403	7023	6885	-2045	17591	0	0	17591	3103	524	21218	50.02
19	5600	343	264	6207	2716	4980	0	93	6902	6829	-1862	18422	0	0	18422	3101	540	22064	50.04
20	5782	248	264	6294	2411	5669	0	0	7493	7242	-1712	19390	0	0	19390	3036	514	22940	50.03
21	5757	242	266	6265	2225	5643	0	0	6782	6682	-1666	18635	0	0	18635	2920	514	22069	50.04
22	5844	248	265	6357	2165	5925	0	0	5876	5467	-1344	18064	0	0	18064	2735	506	21305	49.98
23	5835	132	269	6236	2217	5414	0	0	5840	5796	-1330	17840	0	0	17840	2587	493	20920	49.96
24	5681	117	267	6065	2269	5085	0	0	5776	5512	-1247	17203	0	0	17203	2474	480	20158	50.02
MUs	134.95	4.14	6.41	145.49	50.60	123.12	0.00	14.33	158.13	152.45	-37.34	437.26	0.00	0.00	437.26	65.88	11.39	514.54	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jul/2024

Position as on 6.30 Hrs of 13/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	14/07/2024
MSPGCL	Paras Unit 3	250	30/06/2024	22:35		Continued.	Annual Overhaul	14/08/2024
MSPGCL	Koyna Unit 5	80	02/07/2024	11:00		Continued.	PLC upgradation work	27/07/2024
MSPGCL	Koyna Unit 1	70	10/07/2024	08:00		Continued.	Governer replacement work.	07/08/2024
Total Capacity MSPGCL		900						
IPP								
IPP	RPL(AMT) U-1	270	01/07/2024	07:00		Continued.	Annual Overhaul	01/08/2024
Total Capacity IPP		270						
Total Capacity PLANNED OUTAGE		1170						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Chandrapur Unit 9	500	10/07/2024	17:44		Continued.	Boiler Tube Leakage	15/07/2024
MSPGCL	Nasik Unit 3	210	12/07/2024	14:10	12/07/2024	16:08	Malfunction of Vacuum Protection.	
MSPGCL	Chandrapur Unit 7	500	12/07/2024	16:52	12/07/2024	19:33	FIRE PROTECTION 2 MALFUNCTION	
MSPGCL	Chandrapur Unit 7	500	12/07/2024	19:37	12/07/2024	20:56	DRUM LEVEL VERY LOW	
MSPGCL	Khaparkheda Unit 3	210	13/07/2024	13:32		Continued.	Drum level low	14/07/2024
Total Capacity MSPGCL		2165						
IPP								
IPP	SWPGPL U-3	135	13/07/2024	23:54		Continued.	Boiler Tube Leakage	17/07/2024
Total Capacity IPP		135						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2620						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Jul/2024

Position as on 6.30 Hrs of 13/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	04/07/2024	23:59		Continued.	No Schedule by MSEDCL.	
MSPGCL	Uran Unit 5	108	10/07/2024	21:00	13/07/2024	19:12	Due to Zero schedule given by MSEDCL.	
MSPGCL	Uran Unit 5	108	13/07/2024	20:30		Continued.	No schedule	
Total Capacity MSPGCL		324						
IPP								
IPP	JSW (J) U2	300	01/07/2024	01:12		Continued.	Non availability of load schedule	
Total Capacity IPP		300						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		624						
UNIT OUT ON TOLLING *								
MSPGCL								
MSPGCL	Nasik Unit 4	210	11/07/2024	12:03		Continued.	Tolling under case IV from 23:52 hrs of dt.11.07.2024	
MSPGCL	Nasik Unit 3	210	13/07/2024	17:03		Continued.	Some internal problem (UNDER TOLLING FROM 07:04HRS, FROM DT.14.07.2024)	
Total Capacity MSPGCL		420						
Total Capacity UNIT OUT ON TOLLING *		420						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 13/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
SOLAPUR (PG) - PUNE (GIS)	InterState	11/07/2024	08:53	12/07/2024	06:56	PO	Due to Sant Tukaram Palkhi (Procession)-2024
400 KV TIEBAY Outages/Trippings							
TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	IntraState	12/07/2024	10:43	12/07/2024	13:38	PO	SF6 Gas Analysis Of CB.
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	11/07/2024	11:57			HT	For load management
KHADKA-AURANGABAD (WALUJ)	IntraState	12/07/2024	01:56	13/07/2024	06:40	HT	For controlled overvoltage
WARORA - IEPL	IntraState	12/07/2024	10:05	12/07/2024	19:23	PO	Line CT, CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work.
JAIGAD - KARAD CKT - 1	IntraState	13/07/2024	01:26	13/07/2024	06:47	HT	HIGH VOLTAGE
JAIGAD - KARAD CKT - 1	IntraState	13/07/2024	01:26	13/07/2024	06:47	HT	Over voltage.
DABHOL - NEW KOYNA CKT - 1	IntraState	13/07/2024	03:05	13/07/2024	04:38	T	Tripped from Dabhol end only and AR successful from New Koyana end.
DEEPNAGAR - THAPTI TANDA	IntraState	13/07/2024	06:52	13/07/2024	10:13	EO	replacement of 09 numbers of broken discs at location number 180
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/06/2024	00:07			HT	H/T LV side only.
400/11kv STN-4A @ DEEPNAGAR	IntraState	26/06/2024	11:13	12/07/2024	17:36	PO	For E/M for checking, cleaning and oil filtration work at MSPGCL End.
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	11/07/2024	20:12	12/07/2024	01:49	EO	400/220/33 kv 3*105 MVA ICT-1 Y ph unit oil top up work and Buchholz relay replacement work.
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	12/07/2024	10:33	12/07/2024	17:20	PO	Diagnostic Testing and routine maintenance work.
400/11kv STN-4B @ DEEPNAGAR	IntraState	13/07/2024	16:10			EO	For E/M for checking, cleaning and oil filtration work on STN-4B by M/s MSPGCL
220 KV TBC Outages/Trippings							
220 KV TBC	IntraState	12/07/2024	13:30	12/07/2024	14:20	EO	MEASUREMENT OF IR OF CT & ROUTINE MAINTENANCE WORK
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220KV PT-II	IntraState	12/07/2024	10:35	12/07/2024	14:50	PO	FOR REPLACEMENT OF BPH 220KV BUS PT II DUE TO HEAVY OIL LEAKAGE
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 13/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	17/06/2024	12:50			HT	For load management
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
ALEPHATA-PARGAON(KATHAPUR)	IntraState	02/07/2024	14:56			HT	For controlling loading of Kharghar - Talegaon PG.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/07/2024	09:55	12/07/2024	22:24	HT	For load managment on 220kv Nashik-Babhleshwar ckt 1&2
TROMBAY - MULUND	IntraState	11/07/2024	18:02	12/07/2024	21:18	T	Tripped on distance protection.
TROMBAY - MULUND	IntraState	12/07/2024	00:41	12/07/2024	21:18	EO	To attend CB issue of Mulund-Trombay line at Trimbay ss. CB ON at Mulund but tripped at Trimbay.
220 KV KAULEWADA-KORADI 2 CKT - I	IntraState	12/07/2024	07:03	12/07/2024	16:24	PO	LINE MAINT BIRD GAURD WORK
LONIKAND 2 - VSNL	IntraState	12/07/2024	09:17	12/07/2024	10:00	T	Tripped from VSNL end
BABHALESHWAR - DEOGAON RANGARI	IntraState	12/07/2024	10:23	12/07/2024	10:23	EO	TIGHTENING OF NUT BOLT JUM,PER AT CUT POINT LOCATIONS FOR ATTENDING THE HOT SPOT AT LOC NO 21 . R PH
BHAVEGHAR - ROMA	IntraState	12/07/2024	12:25	12/07/2024	16:45	PO	Insulator replacement Work identified in PID.
PADGHE - JAMBHUL 1	IntraState	12/07/2024	12:41	12/07/2024	17:08	PO	1) Attending of Hotspot on Rph Bus Isolator of 220kV Padghe-Jambhul Line. 2) New SCADA Testing & Commissioning Work
GHATGHAR - BAPGAON	IntraState	13/07/2024	06:23	13/07/2024	11:45	PO	For safety purpose during installation of supporting members on cross arms of newly erected monopoles in b/w TL No. 629-633.
220 KV KAULEWADA-KORADI 2 CKT - I	IntraState	13/07/2024	07:02	13/07/2024	16:31	PO	For fixing of Bird flight Divertor
TALANDGE - HAMIDWADA	IntraState	13/07/2024	07:11	13/07/2024	09:17	EO	replacement of flashover string loc. 87
MALEGAON-SATANA	IntraState	13/07/2024	08:43	13/07/2024	14:55	PO	outage propose for replacement of faulty disc insulator string found in PID testing at various location
PEDAMBE-KALAMBANI(TSS)	IntraState	13/07/2024	09:05	13/07/2024	15:33	PO	B phase CT to Gantry conductor unwound near CT clamp needs to be replaced.
URAN - APTA 4	IntraState	13/07/2024	10:59	13/07/2024	15:29	PO	Replacement of damaged Jumper at loc no 7, 25 & 60
MUMEWADI -HALKARNI 2 LINE	IntraState	13/07/2024	11:49	13/07/2024	17:17	PO	Attending hot spot and jump,and pId faulty string

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 13/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - GHATGHAR	IntraState	13/07/2024	13:15	13/07/2024	18:00	EO	R Phase CT leakage attending work.
EKLAHARE (OCR) - PADGHE	IntraState	13/07/2024	17:30			HT	For load management
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	21/06/2024	12:50			PO	Augmentation of 100 MVA ICT-02 with 200 MVA ICT
220/33 KV 50 MVA PTR 1 @ BABHLESHWAR	IntraState	12/07/2024	10:05	12/07/2024	17:17	PO	HV back-up relay replacement work.
220/33 KV 50 MVA PTR 2	IntraState	12/07/2024	11:05	12/07/2024	17:10	PO	1.Quarterly maintenance Work 2.Replacement Work of R,Y & B Ph CT Jump
220/22kV 50MVA TF-1 @ JAMBHUL	IntraState	12/07/2024	12:22	12/07/2024	18:19	PO	1) Attending of Hotspot on Rph Bus Isolator of 220kV Padghe-Jambhul Line. 2) New SCADA Testing & Commissioning Work
220/100 KV 100 MVA ICT 1 @ JAMBHUL	IntraState	12/07/2024	12:55	12/07/2024	15:56	PO	1) Attending of Hotspot on Rph Bus Isolator of 220kV Padghe-Jambhul Line. 2) New SCADA Testing & Commissioning Work
220/33 KV 25 MVA PTR @ RAYMOND	IntraState	12/07/2024	13:30	12/07/2024	15:10	T	Differential Protection
220/132 KV 100 MVA ICT 1	IntraState	12/07/2024	13:35			PO	Augmentation of 220/132kV 100MVA to 220/132kV 200MVA
200 MVA 220/132 KV ICT 1 @ GIRWALI	IntraState	12/07/2024	14:07	12/07/2024	15:41	EO	TO ATTEND HOTSPOT
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	12/07/2024	16:43	12/07/2024	17:32	T	Transformer fault
220 KV BUSBAR Outages/Trippings							
Main Bus Section-1 @ JAMBHUL-220 KV	IntraState	12/07/2024	12:57	12/07/2024	15:54	PO	1) Attending of Hotspot on Rph Bus Isolator of 220kV Padghe-Jambhul Line. 2) New SCADA Testing & Commissioning Work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage