

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Aug/2017 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	132.331	1550.334	1) Gujrat	4.190	62.207
2) Hydro	9.337	115.065	2) Madhya Pradesh	18.525	218.995
3) Gas	10.059	119.664	3) Chattisgarh	5.590	74.610
Total MSPGCL	151.727	1785.063	4) Maharashtra Net	114.047	1200.025
B) 1) APML	33.243	652.779	5) Goa (Amona)	-0.484	-5.786
2) JSWEL	14.996	176.684	Total	141.868	1550.051
3) VIPL	7.481	74.739	a) Mumbai Schedule	22.172	268.073
4) RPL(AMT)	15.524	40.346	b) Mumbai Drawl	25.835	310.883
5) WPCL	2.225	40.301	c) MSEDCL Bilateral *	30.405	271.445
6) PGPL	0.000	0.000	Include PX	12.039	70.549
7) Other IPP	3.491	40.084	d) Mumbai Bilateral *	22.172	268.073
C) 1) TPCL Thermal	15.014	185.625	Include PX	6.260	86.699
2) TPCL Hydro	3.747	59.448	Include Standby	0.000	0.000
3) TPCL Gas	4.348	49.078	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	10.518	128.304	1) MSEDCL	379.741	4410.293
D) STATE			2) Mumbai Discoms	59.459	733.334
1) Thermal	234.823	2889.196	TOTAL STATE	439.200	5143.627
(A1+C1+C4+(B1-B6))					
2) Hydro	13.084	174.513			
(A2+C2)					
3) Gas	14.407	168.742			
(A3+B6+C3)					
4) Wind	32.833	339.601			
6) SOLAR	2.188	21.528			
TOTAL STATE	297.335	3593.580			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5657	5733	5694	5376
MSPGCL Hydro	251	257	1240	210
MSPGCL Gas	412	401	421	431
MSPGCL Total Generation	6320	6391	7355	6017
Central Sector Receipt	7082	6864	4897	5061
WIND	1285	1311	1209	1404
CPP / IPP Thermal	3219	3267	3486	2952
CPP / IPP Gas	0	0	0	0
SOLAR	194	298	0	0
Exchange with Mumbai	-1564	-1283	-925	-752
MSEDCL DEMAND MET	16536	16848	16022	14682
Load Shedding	0	0	0	0
MSEDCL DEMAND	16536	16848	16022	14682
TPCL GENERATION	986	1165	1280	821
R-INFRA GENERATION	374	467	503	424
MUMBAI DEMAND	2924	2915	2708	1997
STATE DEMAND MET	19460	19763	18730	16679
STATE DEMAND	19460	19763	18730	16679
Frequency (Hz)	49.95	49.99	50.04	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 06.02 Hrs	49.84 Hz at 11.17 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 12/Aug/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.27	54.93	148	0
Unit 9	12.08	140.43	570	450
Unit 10	12.60	145.07	550	475
Total	24.95	340.43		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	3.83	3.83	190	8
Unit 4	11.81	135.08	505	390
Unit 5	0.00	0.00	0	0
Total	15.64	138.92		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.74	17.41	250	201
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	5.74	17.41		
Chandrapur				
Unit 3	4.76	55.43	204	175
Unit 4	4.40	52.39	188	171
Unit 5	9.87	91.03	430	384
Unit 6	9.67	105.80	420	377
Unit 7	9.63	120.01	423	357
Unit 8	0.00	120.18	0	0
Unit 9	10.78	127.49	484	360
Total	49.11	672.34		
Paras				
Unit 3	5.71	67.02	250	198
Unit 4	5.62	67.66	253	198
Total	11.33	134.68		
Khaparkheda				
Unit 1	3.70	22.28	165	130
Unit 2	4.18	18.47	185	150
Unit 3	3.41	16.76	160	138
Unit 4	0.00	0.00	0	0
Unit 5	9.80	133.80	500	0
Total	21.09	191.31		
Nasik				
Unit 3	0.00	38.47	0	0
Unit 4	4.47	15.32	207	162
Unit 5	0.00	1.46	0	0
Total	4.47	55.24		
Uran				
All Units	10.06	119.66	432	401
Total	10.06	119.66		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.03	0.60	23	0
Total	0.03	0.60		
Koyna				
Stage 1-2	3.08	37.54	385	40
Stage 4	3.08	35.83	647	0
Stage 3	2.04	19.78	240	0
Total	8.20	93.15		
Hydro				
KDPH	0.00	1.25	0	0
VTRNA	0.00	4.93	0	0
TILLARI	0.12	0.60	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.41	4.95	80	0
RNGR+BHTSA	0.00	2.14	0	0
BHANDARDRA	0.34	4.11	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.27	3.94	12	11
GHATGHAR	0.00	0.00	0	0
Total	1.14	21.91		
Wind				
Total	32.83	339.60	0	0
Total	32.83	339.60		
CPP				
APML(Mus)	33.24	652.78	0	0
JSWEL(Mus)	15.00	176.68	0	0
VIPL(Mus)	7.48	74.74	0	0
RPLAMT(Mus)	15.52	40.35	0	0
WPCL(Mus)	2.22	40.30	0	0
Other(Mus)	3.49	40.08	0	0
Total	76.96	1024.93		
SOLAR				
Total	2.19	21.53	0	0
Total	2.19	21.53		
Tata				
Trombay 5	9.65	119.88	488	307
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.75	30.56	116	110
Trombay 7B	1.60	18.52	67	66
Trombay 8	5.36	65.74	248	198
TATA Hydro	3.75	59.45	387	0
Total	23.11	294.15		
R-INFRA				
DTPS U-1&2	10.52	128.30	503	367
Total	10.52	128.30		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	132.33	1550.33	MSPGCL Total	151.73	1785.06
			MSPGCL Thml+Gas	142.39	1670.00	Koyna 1,2 & 4 Total	6.16	73.37
			MSPGCL Hydro	9.34	115.06	State Total	297.34	3593.58

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 12/Aug/2017

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5362	881	422	6665	1241	2965	0	0	4604	5241	-931	15181	0	15181	2370	17551	49.97
2	5373	373	419	6165	1370	2968	0	0	4498	5160	-725	14938	0	14938	2137	17075	50.01
3	5376	210	431	6017	1404	2952	0	0	4584	5061	-752	14682	0	14682	1997	16679	50.02
4	5441	152	420	6013	1496	2886	0	0	4437	5371	-852	14914	0	14914	1923	16837	50.02
5	5482	147	421	6050	1657	2980	0	0	4965	5307	-826	15168	0	15168	1898	17066	50.01
6	5490	172	420	6082	1598	3009	0	0	5514	6487	-879	16297	0	16297	1950	18247	50.00
7	5093	104	419	5616	1534	3015	0	6	7084	6961	-927	16205	0	16205	2007	18212	50.00
8	5167	341	430	5938	1349	3001	0	55	7174	6913	-1059	16197	0	16197	2137	18334	50.02
9	5597	87	417	6101	1258	2977	0	108	7233	6983	-1190	16237	0	16237	2329	18566	50.02
10	5627	173	414	6214	1571	2973	0	218	6599	5963	-1335	15604	0	15604	2600	18204	50.04
11	5629	215	413	6257	1562	3034	0	263	6470	6514	-1542	16088	0	16088	2863	18951	49.99
12	5657	251	412	6320	1285	3219	0	194	7090	7082	-1564	16536	0	16536	2924	19460	49.95
13	5733	257	401	6391	1311	3267	0	298	7015	6864	-1283	16848	0	16848	2915	19763	49.99
14	5720	77	420	6217	1417	3291	0	327	6776	6873	-1327	16798	0	16798	2796	19594	49.98
15	5775	70	408	6253	1452	3282	0	284	6718	6656	-1413	16514	0	16514	2788	19302	49.95
16	5307	472	410	6189	1421	3284	0	212	6739	6907	-1190	16823	0	16823	2801	19624	49.98
17	5280	806	412	6498	1522	3354	0	146	5832	5790	-1071	16239	0	16239	2775	19014	49.97
18	5297	701	414	6412	1359	3387	0	65	5376	5960	-1072	16111	0	16111	2728	18839	50.01
19	5452	217	428	6097	1192	3436	0	12	5363	5507	-1064	15180	0	15180	2679	17859	50.01
20	5491	1150	422	7063	1080	3471	0	0	4978	5022	-1054	15582	0	15582	2752	18334	50.01
21	5694	1240	421	7355	1209	3486	0	0	4275	4897	-925	16022	0	16022	2708	18730	50.04
22	5732	611	431	6774	1177	3570	0	0	4343	4760	-909	15372	0	15372	2541	17913	50.04
23	5756	310	422	6488	1173	3568	0	0	4522	4777	-972	15034	0	15034	2457	17491	50.02
24	5800	320	432	6552	1195	3585	0	0	4497	4812	-973	15171	0	15171	2387	17558	50.00
MUs	132.33	9.34	10.06	151.73	32.83	76.96	0.00	2.19	136.69	141.87	-25.83	379.74	0.00	379.74	59.46	439.20	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Aug/2017

Position as on 6.30 Hrs of 13/Aug/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
CENT.SECTOR	TARAPUR 4	540	23/04/2017	19:55		Continued.	Annual Maintenance	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
MSPGCL	Koradi Unit 7	210	21/06/2017	01.24		Continued.	COH.	
CENT.SECTOR	TARAPUR-3	540	11/07/2017	16.30		Continued.	Reactor Inspection Work	
MSPGCL	Khaparkhedda Unit 4	210	13/07/2017	03.36		Continued.	Drum level low. on Dated 14.07.2017 converted to zero schedule. Converted into COH from 00:00Hrs of 02.08.2017	
MSPGCL	Bhusawal Unit 5	500	15/07/2017	05.59		Continued.	Zero Schedule By MSEDCL (Converted to AOH from 00:00Hrs of 20.07.2017)	
MSPGCL	Koradi Unit-8	660	06/08/2017	00.05	12/08/2017	21.08	RAPH 8A and 8B work, Hot air ducts inspection and repair work.	
CPP	SWPGL U-3	135	13/08/2017	11.05	13/08/2017	12.40	Furnace Pressure High	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Shutdown	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	RPL(AMT) U-1	270	24/05/2017	03.27	12/08/2017	16.21	Flame Failure(converted to Zero Schedule from 00.00Hrs DT.13th Jun 17)	
IPP	JSW (J) U2	300	31/05/2017	23.58		Continued.	NO SCHEDULE.	
IPP	Dhariwal	300	01/06/2017	00.01		Continued.	NO SCHEDULE.	
IPP	RPL(AMT) U-4	270	09/06/2017	00.20		Continued.	Zero Schedule by MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Aug/2017

Position as on 6.30 Hrs of 13/Aug/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-5	270	09/06/2017	01.39	12/08/2017	10.10	Zero Schedule by MSEDCL	
MSPGCL	Parli Unit 7	250	13/06/2017	00.04		Continued.	Zero Schedule By MSEDCL, schedule issued on 00:00hrs of 09.08.2017 but synchronization delayed.	
MSPGCL	Bhusawal Unit 3	210	13/06/2017	06.01	12/08/2017	00.44	Zero Schedule By MSEDCL	
IPP	VIPL U-1	300	13/06/2017	08.30		Continued.	GT WORK	
MSPGCL	Parli Unit 8	250	17/06/2017	00.08		Continued.	Zero Schedule by MSEDCL, scheduled issued on 08.08.2017 but synchronization delayed.	
MSPGCL	Ghatghar Unit-2	125	28/07/2017	00.00		Continued.	due to common pressure shaft with unit 1.	
MSPGCL	Ghatghar Unit-1	125	28/07/2017	00.00		Continued.	rbtv leakage attending work.	
IPP	JSW (J) U4	300	05/08/2017	20.30		Continued.	Turbine shaft Vibration high.	
CPP	SWPGL U-3	135	06/08/2017	06.57		Continued.	Flame Failure	
IPP	Adani U-1	660	07/08/2017	00.29		Continued.	AIR PREHEATER PROBLEM.	
MSPGCL	Nasik Unit 5	210	09/08/2017	00.00		Continued.	ID Fan Problem converted to zero schedule from 19:00Hrs of 11.08.2017	
MSPGCL	Nasik Unit 3	210	10/08/2017	00.00		Continued.	Withdrawn for maintenance work.	
IPP	Adani U-2	660	11/08/2017	16.49		Continued.	Furnace Pressure High	
MSPGCL	Chandrapur Unit-8	500	11/08/2017	21.42		Continued.	Boiler Tube Leakage	
CPP	SWPGL U-3	135	11/08/2017	23.23	12/08/2017	03.43	Y ph ct of bhugoan ckt burst.	
CPP	SWPGL U-4	135	11/08/2017	23.23		Continued.	Y ph ct of bhugoan ckt burst.	
MSPGCL	Khaparkheda Unit 5	500	12/08/2017	15.05	12/08/2017	17.41	board supply fail.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Aug/2017

Statement-VII

Position as on 6.30 Hrs of 13/Aug/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar II	InterState	12/08/2017	19.12		Continued.	HT	Over Voltage
Parli (Pg) Wardha (Pg) li	InterState	13/08/2017	15.05	13/08/2017	18.08	PO	Work Of Power Grid
Ektuni-Bableshtar ckt I	IntraState	10/08/2017	06.43		Continued.	HT	Emergency outage on padghe bblsr ckt.
Karad - Jaigad - II	IntraState	10/08/2017	10.00	12/08/2017	12.06	EO	replacement of CVT
Khadka-Aurangabad (Waluj)	IntraState	11/08/2017	19.36	12/08/2017	08.47	HT	Over Voltage
Koradi-Bhusawal	IntraState	12/08/2017	08.55	12/08/2017	19.06	PO	diagnostic testing work.
Chandrapur II- Warora ckt II	IntraState	12/08/2017	11.48	12/08/2017	13.37	PO	replace and testing of display unit.
Warora-Adani(Tiroda)1	IntraState	12/08/2017	13.50	12/08/2017	14.26	PO	Line Maintenance work
karad -kolhapur-I	IntraState	12/08/2017	17.12		Continued.	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	12/08/2017	17.15		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	12/08/2017	19.15	13/08/2017	07.30	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	12/08/2017	19.15	13/08/2017	07.30	HT	Over Voltage
Main Bus I @ Kalwa	IntraState	13/08/2017	09.40	13/08/2017	18.33	PO	Placement Of Y Ph Damaged Jumper
Padghe - Kalwa-II	IntraState	13/08/2017	10.04	13/08/2017	20.08	PO	Faulty Insulator Replacement Work
Khadka-Aurangabad (Waluj)	IntraState	13/08/2017	18.49	13/08/2017	06.54	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv 315 Mva ICT I @Karad	IntraState	08/08/2017	06.15		Continued.	PO	REPLACEMENT OF Y PHASE UNIT(outage for 11 Days)
400/220KV 500MVA ICT1@koradi 2	IntraState	10/08/2017	11.39		Continued.	PO	Attend defects observed in OLTC of ICT 1.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	12/08/2017	10.52	12/08/2017	15.34	EO	Attending Hot Spot
400/220 KV 500MVA ICT II @ Nanded	IntraState	12/08/2017	14.28	12/08/2017	18.46	PO	normalising of rrs done on dt 10.8.17.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	NO SCHEDULE.
Borivali - Tarapur	InterState	12/08/2017	12.50		Continued.	PO	Dp,D-22%,R-Y TO E,Conductor Snapped At Loc No 198
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Vita - Mhaishal	IntraState	01/07/2017	14.19		Continued.	PO	Bunching Work
Vita - Miraj	IntraState	01/07/2017	14.53		Continued.	PO	bunching work.
Pedhambe - Oni	IntraState	10/08/2017	09.05	13/08/2017	16.34	PO	Breaker Overhauling Work
Kalwa - Mulund 1	IntraState	12/08/2017	04.56	12/08/2017	08.50	PO	Project work for 220kv.
Trombay - Kalwa	IntraState	12/08/2017	07.29	12/08/2017	15.17	T	Distance Protection
Dahanu Versova	IntraState	12/08/2017	09.31	12/08/2017	18.32	PO	isolator work.
New Koyana - Niwali	IntraState	12/08/2017	13.21	12/08/2017	17.21	T	niwali in dark due to outage on oni - pedhambe .
Bhosari 2 - Telco	IntraState	12/08/2017	14.46	12/08/2017	17.41	EO	cb maintenance work due to air leakage.
Bhosari 2 - Telco	IntraState	12/08/2017	23.57	13/08/2017	09.36	EO	cb maintenance work due to air leakage.
Mulund - GIS Bhandup	IntraState	13/08/2017	05.56	13/08/2017	10.18	PO	project work for 220kv bus coupler.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Aug/2017

Statement-VII

Position as on 6.30 Hrs of 13/Aug/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kalwa - Mulund 2	IntraState	13/08/2017	06.16	13/08/2017	11.36	PO	project work for 220kv bus coupler.
REL Borivali MSETCL Borivali Line-2	IntraState	13/08/2017	08.57	13/08/2017	11.48	PO	Annual Maintenance Work
Trombay - Mulund	IntraState	13/08/2017	11.43	13/08/2017	15.50	PO	Replacement Of Jumper At Location No198
REL Borivali MSETCL Borivali Line-1	IntraState	13/08/2017	11.55	13/08/2017	13.57	PO	Annual Maintenance Work
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 KV ICT-2 @Nagar	IntraState	12/08/2017	14.06	12/08/2017	17.50	PO	Routine Maintenance Work
132 KV LINE Outages/Trippings							
Waghala (Nanded2) - Tamsa	IntraState	13/08/2017	05.00	13/08/2017	05.13	T	Distance Protection
Solapur II(Bale)-Naldurg	IntraState	13/08/2017	12.59	13/08/2017	13.20	T	9Mw Solar Total 230 Me Load Affected