

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Aug/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	137.599	1537.563	1) Gujrat	12.563	137.404
2) Hydro	13.793	168.568	2) Madhya Pradesh	7.299	87.880
3) Gas	0.791	2.408	3) Chattisgarh	0.900	24.100
Total MSPGCL	152.183	1708.539	4) Maharashtra	168.482	1855.994
B) 1) APML	71.055	655.930	5) Goa (Amona)	-1.554	-19.024
2) JSWEL	11.178	155.517	Total	187.690	2086.354
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.355	397.820
4) RPL(AMT)	29.600	305.334	b) Mumbai Drawl	33.243	441.590
5) SWPGPL	11.083	97.650	c) MSEDCL Bilateral *	101.045	1096.402
6) Other IPP	7.194	76.153	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.355	397.820
C) 1) TPCL Thermal	12.079	132.323	Include PX	0.000	0.000
2) TPCL Hydro	5.267	62.029	Standby	0.000	0.000
3) TPCL Gas	3.482	33.548	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.113	110.412	1) MSEDCL	480.313	5250.788
D) STATE			2) Mumbai Discoms	64.184	779.902
1) Thermal	289.901	3070.882	3) Other Discoms	9.899	119.893
(A1+C1+C4+(B1-B6))			TOTAL STATE	554.396	6150.583
2) Hydro (A2+C2)	19.060	230.597			
3) Gas (A3+B7+C3)	4.273	35.956			
4) Wind	39.258	591.297			
6) SOLAR	14.214	135.497			
TOTAL STATE	366.706	4064.229			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5592	5523	5881	5755
MSPGCL Hydro	240	233	1512	378
MSPGCL Gas	0	0	103	7
MSPGCL Total Generation	5832	5756	7496	6140
Central Sector Receipt	9635	9090	7288	6548
WIND	1443	1910	1654	1615
CPP / IPP Thermal	5357	5567	5836	5465
CPP / IPP Gas	0	0	0	0
SOLAR	1743	1556	17	0
Exchange with Mumbai	-2202	-2030	-1230	-945
MSEDCL DEMAND MET	21355	21420	20608	18522
Load Shedding	0	0	369	0
MSEDCL DEMAND	21355	21420	20977	18522
TPCL GENERATION	532	544	1221	851
AEML GENERATION	409	389	438	308
MUMBAI DEMAND	3143	2963	2889	2104
OTHER DISCOM DEMAND	453	429	453	301
STATE DEMAND MET	24951	24812	23950	20927
STATE DEMAND	24951	24812	24319	20927
Frequency (Hz)	49.98	49.96	50.00	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 16.03 Hrs	49.83 Hz at 12.45 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.43	37.04	170	105
Unit 8	14.33	156.99	621	574
Unit 9	12.84	146.12	550	517
Unit 10	0.00	0.00	0	0
Total	30.59	340.16		
Bhusawal				
Unit 3	3.19	35.60	140	125
Unit 4	0.00	87.88	0	0
Unit 5	10.70	110.63	460	435
Total	13.88	234.11		
Parli				
Unit 6	4.41	19.01	249	128
Unit 7	5.02	18.79	241	151
Unit 8	4.73	21.21	226	146
Total	14.16	59.01		
Chandrapur				
Unit 3	3.14	33.66	145	121
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	8.20	92.10	390	285
Unit 7	7.17	87.06	344	265
Unit 8	10.21	121.55	453	365
Unit 9	9.67	122.29	430	339
Total	38.40	456.66		
Paras				
Unit 3	4.77	54.92	212	188
Unit 4	4.34	52.43	210	109
Total	9.11	107.35		
Khaparkheda				
Unit 1	2.43	23.94	115	85
Unit 2	2.68	30.96	126	90
Unit 3	3.95	44.77	176	151
Unit 4	4.26	44.91	186	167
Unit 5	10.20	112.50	450	340
Total	23.52	257.07		
Nasik				
Unit 3	3.90	43.70	169	153
Unit 4	4.03	26.43	180	147
Unit 5	0.00	13.08	0	0
Total	7.92	83.21		
Uran				
All Units	0.79	2.41	175	0
Total	0.79	2.41		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.86	11.67	50	0
Total	0.86	11.67		
Koyna				
Stage 1-2	3.08	32.91	410	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.38	35.42	560	0
Stage 3	1.59	18.58	240	0
Total	8.05	86.91		
Hydro				
KDPH	0.00	7.15	0	0
VTRNA	0.00	0.61	0	0
TILLARI	0.00	1.62	0	0
BHIRA T.R.	0.44	5.27	80	0
SMLHY_PTN	3.90	51.35	171	148
GHATGHAR	0.54	4.00	125	0
Total	4.88	69.99		
Wind				
Total	39.26	591.30	0	0
Total	39.26	591.30		
CPP				
APML(Mus)	71.06	655.93	0	0
JSWEL(Mus)	11.18	155.52	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	29.60	305.33	0	0
SWPGPL-Mus	11.08	97.65	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.18	63.90	270	227
Other(Mus)	1.01	12.26	0	0
Total	130.11	1290.58		
SOLAR				
Total	14.21	135.50	0	0
Total	14.21	135.50		
Tata				
Trombay 5	7.91	87.55	446	235
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.14	19.76	109	38
Trombay 7B	1.34	13.79	64	35
TATA Hydro	5.27	62.03	385	69
Trombay 8	4.17	44.77	233	126
Total	20.83	227.90		
AEML				
DTPS U-1&2	10.11	110.41	498	308
Total	10.11	110.41		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	137.60	1537.56	MSPGCL Total	152.18	1708.54
			MSPGCL Thml+Gas	138.39	1539.97	Koyna 1,2 & 4 Total	6.46	68.33
			MSPGCL Hydro	13.79	168.57	State Total	366.71	4064.23

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5762	438	0	6200	1585	5399	0	0	6712	6462	-916	18357	0	0	18357	2529	373	21259	50.01
2	5789	348	0	6137	1494	5430	0	0	6573	6470	-757	18434	0	0	18434	2351	340	21125	50.00
3	5790	449	0	6239	1481	5462	0	0	6669	6659	-859	18682	0	0	18682	2200	300	21182	49.99
4	5755	378	7	6140	1615	5465	0	0	6726	6548	-945	18522	0	0	18522	2104	301	20927	50.02
5	5746	399	83	6228	1540	5473	0	0	7035	6814	-883	18851	0	0	18851	2089	321	21261	50.04
6	5768	719	90	6577	1435	5498	0	0	7589	7232	-841	19544	0	0	19544	2172	357	22073	50.00
7	5824	1341	88	7253	1397	5494	0	64	7802	7756	-818	20748	182	0	20930	2258	398	23586	50.04
8	5834	863	10	6707	1308	5438	0	404	8366	8214	-1000	20651	0	0	20651	2365	420	23436	50.06
9	5607	434	0	6041	1557	5008	0	816	9372	8988	-1571	20413	0	0	20413	2575	426	23414	50.02
10	5733	422	0	6155	1603	4508	0	1296	9466	9644	-1823	20935	0	0	20935	2863	448	24246	50.02
11	5703	467	0	6170	1609	4807	0	1609	9653	9688	-2123	21315	0	0	21315	3087	445	24847	50.03
12	5592	240	0	5832	1443	5357	0	1743	9664	9635	-2202	21355	0	0	21355	3143	453	24951	49.98
13	5469	309	0	5778	1462	5197	0	1753	9516	9364	-2070	21050	0	0	21050	3111	434	24595	49.96
14	5450	267	0	5717	1484	5317	0	1711	8938	8991	-1933	20860	0	0	20860	2969	427	24256	49.98
15	5523	233	0	5756	1910	5567	0	1556	9229	9090	-2030	21420	0	0	21420	2963	429	24812	49.96
16	5596	228	0	5824	2100	5641	0	1417	9017	8696	-1993	21243	0	0	21243	2987	442	24672	50.03
17	5610	190	0	5800	2360	5479	0	1039	9067	8286	-1822	20677	0	0	20677	2962	465	24104	50.03
18	5543	288	2	5833	2012	5241	0	595	8576	8296	-1713	19800	0	0	19800	2900	464	23164	49.98
19	5804	576	59	6439	1653	5687	0	194	7802	7470	-1360	19620	0	0	19620	2871	463	22954	50.05
20	5881	1512	103	7496	1654	5836	0	17	7247	7288	-1230	20608	369	0	20977	2889	453	24319	50.00
21	5956	1257	175	7388	1602	5895	0	0	6826	6675	-1164	19953	37	0	19990	2838	443	23271	50.02
22	5964	906	165	7035	1673	5817	0	0	6628	6621	-1118	19579	0	0	19579	2731	449	22759	50.01
23	5949	780	9	6738	1622	5687	0	0	6516	6485	-1069	19031	0	0	19031	2643	432	22106	50.01
24	5951	749	0	6700	1659	5407	0	0	6453	6318	-1003	18666	0	0	18666	2584	415	21665	50.02
MUs	137.60	13.79	0.79	152.18	39.26	130.11	0.00	14.21	191.44	187.69	-33.24	480.31	0.59	0.00	480.90	64.18	9.90	554.98	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Aug/2023

Position as on 6.30 Hrs of 13/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	07/07/2023	09:06	12/08/2023	06:46	Annual Overhaul	13/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	25/08/2023
MSPGCL	Uran Unit 6	108	12/08/2023	07:16	12/08/2023	17:50	NO SCHEDULE	
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	COH	16/08/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	20/08/2023
MSPGCL	Uran Unit 7	108	20/07/2023	20:00	12/08/2023	19:05	Boiler Inspection work	
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	19/08/2023
MSPGCL	Nasik Unit 5	210	05/08/2023	00:00		Continued.	ID Fan Problem(On Tolling since 18:23Hrs DT. 05-08-2023)	
IPP	RPL(AMT) U-3	270	05/08/2023	19:07	12/08/2023	00:15	Due to TG shaft vibration high.	
IPP	JSW (J) U4	300	10/08/2023	05:55		Continued.	CW system leakage	14/08/2023
MSPGCL	Bhusawal Unit 4	500	10/08/2023	22:44		Continued.	Boiler Tube Leakage	14/08/2023
MSPGCL	Uran Unit 6	108	11/08/2023	22:16	12/08/2023	03:35	Zero Schedule	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Aug/2023

Position as on 6.30 Hrs of 13/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 7	108	12/08/2023	21:59		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 6	108	12/08/2023	22:15		Continued.	Zero Schedule.	
MSPGCL	Koyana Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	02/09/2023
MSPGCL	Nasik Unit 3	210	13/08/2023	16:00		Continued.	Boiler Tube Leakage	16/08/2023
MSPGCL	Koyana STG-IV Unit-2	250	13/08/2023	19:10		Continued.	Water Drain valve leakage.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 13/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV TBC Outages/Trippings							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	13/08/2023	21:05		Continued.	EO	Antiweeding of pole 2 Z1 & Z2 base filter As grass has grown very tall.
500 KV LR Outages/Trippings							
Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC	IntraState	12/08/2023	16:32	12/08/2023	18:20	EO	Attending Hotspot
Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC	IntraState	12/08/2023	16:32	13/08/2023	18:20	EO	For attending 1 no. of hotspot having temp.160 deg. cel
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KALWA - TALEGAON (PG)	InterState	13/08/2023	09:32	13/08/2023	19:47	PO	SSN to DSN replacement of insulator string Project & FWC mid span joint.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 2Y2 phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
PADGHE - KALWA CKT - 1	IntraState	11/08/2023	22:12	12/08/2023	04:28	EO	Fixing of repair sleeves at Loc.No. 1105
KORADI - KHADKA	IntraState	12/08/2023	10:30	12/08/2023	16:04	PO	For replacement of Y phase CT jump replacement work from PG Clamp to CT
KHADKA-AURANGABAD (WALUJ)	IntraState	12/08/2023	20:14	13/08/2023	08:41	HT	for load management
PADGHE - KALWA CKT - 2	IntraState	13/08/2023	00:50	13/08/2023	04:20	EO	For attending hot spot at Loc No.62 & 1135 .
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	12/08/2023	10:21			PO	1.Commissioning of High velocity water spray system for 315MVA ICT-1. 2. Routine maintenance of ICT 2. Maintenance and alignment of Isolators 3. Bay routine maintenance work
220 KV MAINBAY Outages/Trippings							
220 KV PT - I	IntraState	12/08/2023	12:25	12/08/2023	16:45	EO	Attending oil leakage of B ph PT-1
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21	13/08/2023	16:50	HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
MAIN BUS - 1 @ AAREY	IntraState	11/08/2023	23:48	12/08/2023	00:44	EO	For Shifting of 100 MVA Tr-4 form AIS Bay -8 to New GIS Bay no. 23 under MERC approved AIS to GIS conversion Project.
KOLSHET - ROMA	IntraState	12/08/2023	01:05	12/08/2023	05:52	EO	For launching of Pier cap at location No. P118 (Nr. Patlipada flyover) under 220Kv Kolshet Roma line of Mumbai Metro Rail Project of MMRDA package CA-12 ---for safety purpose

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 13/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA SALSETTE - 4	IntraState	12/08/2023	07:09	12/08/2023	08:43	PO	Bay Maintenance work
MALEGAON-SATANA	IntraState	12/08/2023	09:22	12/08/2023	15:20	PO	For jump replacement work.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	12/08/2023	09:30	12/08/2023	19:54	PO	1. Conversion of single jump into twin jump of tension tower at various locations. (As per current loading,frequent Red-Hot observed andalso with bypass jump done by Hot-Line. 2. Replacement of old disc insulator by new long-rod insulator at various location.
PEDHAMBE ONI LINE	IntraState	12/08/2023	09:45	12/08/2023	13:47	PO	For Bay R/M work
URAN - APTA 4	IntraState	12/08/2023	10:30	12/08/2023	19:45	PO	Replacement of damaged Jumper at loc no 7,26,25.
BOISAR - VERSOVA	IntraState	12/08/2023	10:50	13/08/2023	14:17	EO	To attend Air pressure low alarm on CB
220 KV DEEPNAGAR (400 KV) - CHALISGAON CKT	IntraState	12/08/2023	11:54	12/08/2023	15:38	PO	For Jump tightening and Maintenance work at tower LOC 309 & 398.
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	12/08/2023	12:20	12/08/2023	17:11	PO	Replacement of disc insulators LOC no.346 Y B ph and LOC no. 350 R ph.
BUS SECTION - 2 @ TROMBAY	IntraState	12/08/2023	13:18	13/08/2023	00:29	PO	For 1) Wave Trap replacement work of 220KV Sonkhar line 2) 220KV CC relocation/Shifting work & 3) Bus Section bay maintenance work.
DHARAVI - MAHALAXMI	IntraState	13/08/2023	00:11	13/08/2023	02:01	PO	R/M and Breaker testing at Dharav
KHARGHAR - SONKHAR	IntraState	13/08/2023	06:24	13/08/2023	17:23	EO	1) For replacing Damaged A bus Bph span in Sonkhar bay. 2) Replacement of Damaged Bph & Yph A-Bus conductor of Sonkhar bay.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	13/08/2023	07:15	13/08/2023	18:03	PO	for TOWER erection WORK of the additional 220kV D/C tower (NC + 6) between location No. 213- 214 to 220kV Babhaleshwar- Nasik 1 & 2 ckt under EHV O&M Division Babhaleshwar. BOTH CKT REQUIRED TO BE KEPT OFF FOR THE ABOVE SAID WORK.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	13/08/2023	17:15	13/08/2023	18:03	PO	1. Conversion of single jump into twin jump of tension tower at various locations. (As per current loading,frequent Red-Hot observed andalso with bypass jump done by Hot-Line. 2. Replacement of old disc insulator by new long-rod insulator at various location.
220 KV KEKATNIBHORA - KHADKA (400 KV) CKT	IntraState	13/08/2023	19:17	13/08/2023	19:45	HT	Heavy sparking observed in switch yard.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI	IntraState	11/08/2023	09:15	13/08/2023	11:25	PO	Oil filtration work to improve oil parameters.
200 MVA 220/132 KV ICT 1 @ GIRWALI	IntraState	12/08/2023	06:06	12/08/2023	12:36	HT	Sparking on R-ph HV Bushing Jumper
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	12/08/2023	11:40	12/08/2023	18:14	PO	Testing work of ICT.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 13/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 200 MVA PTR NO 6 @ PARVATI	IntraState	13/08/2023	17:45		Continued.	T	Tripped while changing tap. OSR winding relay And master trip operated.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage