

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Sep/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	106.268	1460.801	1) Gujrat	8.157	94.369
2) Hydro	12.853	162.734	2) Madhya Pradesh	-0.392	14.395
3) Gas	2.136	38.238	3) Chattisgarh	3.230	39.390
Total MSPGCL	121.257	1661.773	4) Maharashtra	154.438	1955.790
B) 1) APML	62.787	795.578	5) Goa (Amona)	-1.435	-11.097
2) JSWEL	16.734	228.983	Total	163.998	2092.847
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.895	401.488
4) RPL(AMT)	17.447	190.612	b) Mumbai Drawl	39.711	439.236
5) SWPGPL	5.122	63.758	c) MSEDCL Bilateral *	52.644	535.258
6) Other IPP	5.439	70.384	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.895	401.356
C) 1) TPCL Thermal	11.341	143.331	Include PX	0.000	0.000
2) TPCL Hydro	4.055	57.865	Standby	0.000	0.132
3) TPCL Gas	1.123	11.153	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.326	117.622	1) MSEDCL	378.933	4762.471
D) STATE			2) Mumbai Discoms	65.557	769.209
1) Thermal	234.464	3071.069	3) Other Discoms	9.196	108.722
(A1+C1+C4+(B1-B6))			TOTAL STATE	453.686	5640.402
2) Hydro (A2+C2)	16.908	220.599			
3) Gas (A3+B7+C3)	3.259	49.391			
4) Wind	29.759	102.001			
6) SOLAR	5.297	104.493			
TOTAL STATE	289.687	3547.553			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4426	4592	4688	4466
MSPGCL Hydro	533	712	942	302
MSPGCL Gas	89	88	89	90
MSPGCL Total Generation	5048	5392	5719	4858
Central Sector Receipt	8169	7282	7205	5462
WIND	931	1498	1517	953
CPP / IPP Thermal	4424	4470	5169	4238
CPP / IPP Gas	0	0	0	0
SOLAR	639	86	0	0
Exchange with Mumbai	-2099	-2125	-1687	-979
MSEDCL DEMAND MET	16675	16184	17499	14237
Load Shedding	0	0	0	0
MSEDCL DEMAND	16675	16184	17499	14237
TPCL GENERATION	704	607	849	652
AEML GENERATION	475	318	452	389
MUMBAI DEMAND	3278	3050	2988	2020
OTHER DISCOM DEMAND	437	419	424	295
STATE DEMAND MET	20390	19653	20911	16552
STATE DEMAND	20390	19653	20911	16552
Frequency (Hz)	50.02	49.99	50.00	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 08.31 Hrs	49.65 Hz at 14.12 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.31	35.79	135	0
Unit 7	0.00	0.00	0	0
Unit 8	10.01	127.25	460	372
Unit 9	0.00	0.00	0	0
Unit 10	10.17	125.04	485	372
Total	20.49	288.08		
Bhusawal				
Unit 3	2.19	32.32	130	0
Unit 4	8.64	109.64	405	300
Unit 5	0.00	0.21	0	0
Total	10.83	142.17		
Parli				
Unit 6	4.07	52.85	210	150
Unit 7	2.43	37.05	122	90
Unit 8	3.71	46.21	177	140
Total	10.21	136.11		
Chandrapur				
Unit 3	1.46	32.58	110	11
Unit 4	1.77	38.26	98	36
Unit 5	5.34	50.66	295	65
Unit 6	5.85	88.84	341	160
Unit 7	5.05	89.70	304	0
Unit 8	0.00	49.00	0	0
Unit 9	8.88	119.57	428	299
Total	28.35	468.62		
Paras				
Unit 3	4.46	54.14	228	148
Unit 4	4.50	54.35	222	155
Total	8.97	108.49		
Khaparkheda				
Unit 1	2.97	31.94	135	115
Unit 2	2.66	29.23	130	100
Unit 3	3.52	39.63	178	127
Unit 4	3.85	42.92	203	129
Unit 5	8.63	98.88	445	280
Total	21.62	242.60		
Nasik				
Unit 3	0.00	29.36	0	0
Unit 4	2.95	11.39	141	108
Unit 5	2.85	33.98	140	106
Total	5.80	74.73		
Uran				
All Units	2.14	38.24	91	86
Total	2.14	38.24		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	6.92	25	25
Total	0.60	6.92		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.50	30.24	475	35
Stage 4	0.84	28.86	313	0
Stage 3	1.08	13.72	160	0
Total	4.43	72.81		
Hydro				
KDPH	0.43	0.50	18	18
VTRNA	0.74	8.88	61	0
TILLARI	0.93	4.64	58	0
BHIRA T.R.	0.36	4.92	70	0
SMLHY_PTN	5.37	60.43	241	212
GHATGHAR	0.00	3.63	0	0
Total	7.83	83.00		
Wind				
Total	29.76	102.00	0	0
Total	29.76	102.00		
CPP				
APML(Mus)	62.79	795.58	0	0
JSWEL(Mus)	16.73	228.98	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	17.45	190.61	0	0
SWPGPL-Mus	5.12	63.76	0	0
Other(Mus)	5.44	70.38	0	0
Total	107.53	1349.32		
SOLAR				
Total	5.30	104.49	0	0
Total	5.30	104.49		
Tata				
Trombay 5	7.58	96.32	419	270
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.89	7.46	115	0
Trombay 7B	0.24	3.70	65	0
TATA Hydro	4.06	57.86	352	0
Trombay 8	3.76	47.01	232	129
Total	16.52	212.35		
AEML				
DTPS U-1&2	9.33	117.62	500	281
Total	9.33	117.62		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	106.27	1460.80	MSPGCL Total	121.26	1661.77
			MSPGCL Thml+Gas	108.40	1499.04	Koyna 1,2 & 4 Total	3.35	59.10
			MSPGCL Hydro	12.85	162.73	State Total	289.69	3547.55

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 12/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4896	300	90	5286	1059	4194	0	0	5787	5328	-955	14579	0	14579	2457	333	17369	50.01
2	4716	292	90	5098	1109	4002	0	0	5792	5281	-1029	14149	0	14149	2248	312	16709	49.95
3	4422	301	90	4813	1000	4075	0	0	5732	5611	-944	14251	0	14251	2104	304	16659	49.92
4	4466	302	90	4858	953	4238	0	0	5641	5462	-979	14237	0	14237	2020	295	16552	50.00
5	4318	306	91	4715	940	4260	0	0	6035	6200	-1020	14789	0	14789	2002	306	17097	50.02
6	4526	503	90	5119	804	4510	0	0	6210	6633	-1112	15624	0	15624	2099	330	18053	50.02
7	4623	967	90	5680	664	4788	0	10	7155	7234	-1251	16746	0	16746	2258	379	19383	49.96
8	4736	453	90	5279	551	5150	0	108	7882	7639	-1543	16790	0	16790	2441	394	19625	49.99
9	4656	471	90	5217	735	4863	0	290	8479	8369	-1885	17161	0	17161	2764	428	20353	50.05
10	4677	521	90	5288	749	4575	0	410	8332	8390	-2135	16850	0	16850	3087	427	20364	50.03
11	4426	533	89	5048	931	4424	0	639	8434	8169	-2099	16675	0	16675	3278	437	20390	50.02
12	4042	519	88	4649	939	4179	0	670	8611	7984	-2103	15887	0	15887	3339	431	19657	50.04
13	3804	447	87	4338	961	4047	0	786	8237	7857	-2241	15318	0	15318	3249	430	18997	49.98
14	3905	420	86	4411	1283	4229	0	807	7672	7262	-2264	15312	0	15312	3139	416	18867	49.99
15	3913	413	86	4412	1555	4101	0	692	7797	7197	-2311	15253	0	15253	3140	393	18786	49.88
16	3904	569	87	4560	1747	3889	0	510	7568	7343	-2322	15324	0	15324	3150	403	18877	49.87
17	4290	859	89	5238	1738	4009	0	287	7062	7251	-2266	15853	0	15853	3106	404	19363	49.90
18	4592	712	88	5392	1498	4470	0	86	6928	7282	-2125	16184	0	16184	3050	419	19653	49.99
19	4743	1088	89	5920	1470	4859	0	2	7310	7445	-1832	17437	0	17437	2999	427	20863	49.98
20	4688	942	89	5719	1517	5169	0	0	7343	7205	-1687	17499	0	17499	2988	424	20911	50.00
21	4596	638	89	5323	1772	5147	0	0	6693	6464	-1531	16770	0	16770	2854	405	20029	50.02
22	4486	536	89	5111	2058	5073	0	0	6144	5657	-1396	16120	0	16120	2713	383	19216	50.01
23	4422	391	89	4902	1829	4973	0	0	5649	5493	-1343	15492	0	15492	2580	362	18434	49.98
24	4421	374	90	4885	1897	4305	0	0	5749	5238	-1338	14633	0	14633	2491	354	17478	50.01
MUs	106.27	12.85	2.14	121.26	29.76	107.53	0.00	5.30	168.24	164.00	-39.71	378.93	0.00	378.93	65.56	9.20	453.68	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Sep/2022

Position as on 6.30 Hrs of 13/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
IPP	SWPGPL U-4	135	16/08/2022	00:45	12/09/2022	12:26	Coal Shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
IPP	RPL(AMT) U-4	270	31/08/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
TPC-G	Trombay 7B	60	09/09/2022	03:36	12/09/2022	19:39	Gas shortage	
TPC-G	Trombay 7A	120	09/09/2022	03:52	12/09/2022	15:01	Gas shortage	
MSPGCL	Nasik Unit 3	210	10/09/2022	11:46		Continued.	Turbine Vibration	18/09/2022
MSPGCL	Bhusawal Unit 5	500	11/09/2022	05:48	13/09/2022	23:08	Turbine Vibration	13/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
MSPGCL	Koradi Unit 6	210	12/09/2022	02:56	13/09/2022	02:56	AC Supply fail.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Sep/2022

Position as on 6.30 Hrs of 13/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 7	500	12/09/2022	10:33	12/09/2022	14:00	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	12/09/2022	21:13		Continued.	Zero schedule	
IPP	SWPGPL U-1	135	12/09/2022	23:28		Continued.	Turbine side drain valve steam leakage	13/09/2022
MSPGCL	Khaparkheda Unit 4	210	13/09/2022	13:33		Continued.	Poor Coal Quality	16/09/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 13/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	11/09/2022	20:58	12/09/2022	06:24	EO	Pole 2 B-phase Converter transformer for OLTC Diverter switch overhauling and Oil flow relay replacement.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 408 OF KOLHAPUR (TALANDGE) @ ALKUD	IntraState	13/09/2022	10:26	13/09/2022	20:03	PO	QM Work
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	13/09/2022	21:00		Continued.	T	Reason awaited
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (404) OF ICT - 2 @ JEJURI	IntraState	12/09/2022	16:27	12/09/2022	18:25	EO	To attend hotspot on 400kv 404 Bay R-ph CT
MAIN BAY (413) OF 500MVA ICT - 2 @ TAPTITANDA	IntraState	13/09/2022	10:01	13/09/2022	13:29	PO	CB diagnostic & CT diagnostic Testing
MAIN BAY - 407 OF KOLHAPUR (TALANDGE) @ ALKUD	IntraState	13/09/2022	10:25	13/09/2022	20:03	PO	QM Work
MAIN BUS - 1 @ ALKUD	IntraState	13/09/2022	10:59	13/09/2022	18:38	PO	QM Work
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38		Continued.	T	Y Phase Ground Fault
KARAD - LONIKAND I	IntraState	11/09/2022	11:26		Continued.	HT	For line loading control of 400 KV Karad Kolhapur
KHADKA-AURANGABAD (WALUJ)	IntraState	12/09/2022	00:13	12/09/2022	07:28	HT	H/T FOR O/V
KARAD - TALANDGE CKT - 1	IntraState	12/09/2022	06:03	12/09/2022	09:52	PO	Replacement of Y ph bottom side Jump & palm due to damages in outer side of Jump conductor.
PADGHE - NAGOTHANE CKT - 1	IntraState	12/09/2022	08:24	12/09/2022	18:25	PO	INSULATOR STRING REPLACEMENT WORK
KHADKA-AURANGABAD (WALUJ)	IntraState	12/09/2022	20:53	13/09/2022	08:56	HT	On Overvoltage
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	13/09/2022	09:23	13/09/2022	19:51	PO	As per the NOC received from BTPS DEEPNAGAR , the 400KV Waluj Deepnagar circuit is required to be hand tripped during outage on 400KV BUS - I , first and then open line isolator (89L) of 400KV Aurangabad Waluj Deepnagar circuit . Then close Main CB (408) of 400KV Aurangabad Waluj Deepnagar circuit and TIE CB (409) respectively for safety purpose of GT - 4 to avoid tripping of GT- 4 on line fault
KOLHAPUR (TALANDGE) - ALKUD	IntraState	13/09/2022	10:26	13/09/2022	20:04	PO	QM Work
KHADKA-AURANGABAD (WALUJ)	IntraState	13/09/2022	21:05		Continued.	HT	To control OV
400 KV ICT Outages/Trippings							
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	12/09/2022	09:43	12/09/2022	18:29	PO	Diagnostic testing & Relay testing work
400220kv 167MVA SPARE ICT @ DEEPNAGAR	IntraState	12/09/2022	09:58	12/09/2022	20:30	HT	HT for Main Bus-2 Outage
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	12/09/2022	10:39	12/09/2022	15:28	PO	1. Quarterly Maintenance Work 2. OLTC oil filtration work
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	12/09/2022	18:59	12/09/2022	20:29	EO	Attending hotspot (100 degree) observed on Y phase LV CT of ICT-1.
400 KV BUSBAR Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 13/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400KV MAIN BUS 2 @ 400KV DEEPNAGAR	IntraState	12/09/2022	09:58	12/09/2022	20:21	PO	For the work of Stringing between guide tower to 400 KV Main Bus 2 & removal of Bus-II Earth Switch.
400KV MAIN BUS 1 @ 400KV DEEPNAGAR	IntraState	13/09/2022	10:07	13/09/2022	19:05	PO	For the work of Stringing between guide tower to 400 KV Main Bus I & removal of Bus-I Earth Switch
220 KV LINE Outages/Trippings							
NAGOTHANE - POSCO	IntraState	11/09/2022	16:06	12/09/2022	01:18	T	Tripped on Dist Protection
EKLAHARE (OCR) - PADGHE	IntraState	12/09/2022	08:49		Continued.	HT	HT for Load Management
URAN - KHARGHAR 1	IntraState	12/09/2022	10:02	12/09/2022	17:37	PO	Replacement of flashover polymer insulator at Loc no. 48 and sparked jumper at Loc no. 44
ADLABS - PEDAMBE	IntraState	12/09/2022	18:08	13/09/2022	03:05	T	Tripped on distance protection
ALEPHATA-PARGAON(KATHAPUR)	IntraState	12/09/2022	18:48	12/09/2022	20:47	HT	For load management
WARDHA - WARDHA (PG)	IntraState	12/09/2022	19:03	12/09/2022	22:15	HT	Autoreclosed successfully at both end, current does not appear on Y ph.
BUS SECTION-6 @ TROMBAY	IntraState	12/09/2022	23:40	13/09/2022	05:18	EO	for Trombay Carnac -6 Isolator Maintenance and Trombay Carnac-6 29 A busbar removal.
KAMBA - VASAI	IntraState	13/09/2022	06:46	13/09/2022	09:11	EO	Attending hot spot at loc. No. 33 (Y Temp- 180°C)
URAN - APTA 2	IntraState	13/09/2022	09:18	13/09/2022	17:43	PO	1) For MAIN BUS 2 insulator and stub Bus insulator string replacement work.
URAN - ONGC URAN	IntraState	13/09/2022	09:52	13/09/2022	17:11	PO	1) For MAIN BUS 2 insulator and stub Bus insulator string replacement work.
WATHAR - MUDSHINGI 3 LINE	IntraState	13/09/2022	11:56	13/09/2022	17:40	PO	Quarterly Maint .work & Diagnostic testing work
TROMBAY (M) - CHEMBUR CKT-1	IntraState	13/09/2022	12:03	13/09/2022	18:54	PO	Routine testing of Distance/Differential Relay.
JEJURI-PHURSUNGI 1	IntraState	13/09/2022	12:18	13/09/2022	15:15	EO	Alignment of 29C and 29D isolator on urgent basis
220 KV ICT Outages/Trippings							
220 / 110 / 22KV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA ICT 1 @ KATHAPUR	IntraState	12/09/2022	10:38	12/09/2022	18:44	PO	Replacement of R & Y Phase LV Bushings due to High Tan Delta value.
220/33KV 50MVA PTR 2 @ MUMEWADI	IntraState	13/09/2022	11:56	13/09/2022	17:40	PO	For Diagnostic testing work of T/F & its HV/LV side equipments and Maintenance Work
220/132 KV 200 MVA PTR NO 3 @ PHURSUNGI	IntraState	13/09/2022	12:00	13/09/2022	17:04	PO	HV & LV CT Tan Delta & C testing work, HV & LV CB CRM Timing work, Bay HYM work & CTR make NIFPS servicing & replacement of FS cable.
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 13/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage