

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Oct/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	118.089	1434.743	1) Gujrat	11.105	124.059
2) Hydro	9.715	94.690	2) Madhya Pradesh	8.006	85.825
3) Gas	2.160	26.955	3) Chattisgarh	6.030	66.460
Total MSPGCL	129.964	1556.388	4) Maharashtra	157.246	1992.489
B) 1) APML	62.447	579.307	5) Goa (Amona)	-1.014	-15.400
2) JSWEL	14.378	199.253	Total	181.373	2253.433
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.909	393.369
4) RPL(AMT)	23.636	275.569	b) Mumbai Drawl	38.299	435.980
5) SWPGPL	7.534	84.781	c) MSEDCL Bilateral *	54.414	807.761
6) Other IPP	4.903	89.370	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.909	393.363
C) 1) TPCL Thermal	6.049	124.002	Include PX	0.000	0.000
2) TPCL Hydro	8.115	44.197	Standby	0.000	0.007
3) TPCL Gas	2.580	28.606	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.552	112.397	1) MSEDCL	386.047	4748.495
D) STATE			2) Mumbai Discoms	66.595	745.158
1) Thermal	248.588	2899.422	3) Other Discoms	9.348	110.260
(A1+C1+C4+(B1-B6))			TOTAL STATE	461.990	5603.913
2) Hydro	17.830	138.887			
3) Gas	4.740	55.561			
4) Wind	1.768	144.230			
6) SOLAR	7.691	112.404			
TOTAL STATE	280.617	3350.504			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5011	5253	5218	4475
MSPGCL Hydro	305	356	1688	192
MSPGCL Gas	92	89	91	93
MSPGCL Total Generation	5408	5698	6997	4760
Central Sector Receipt	8798	8209	8074	6151
WIND	43	47	51	33
CPP / IPP Thermal	4638	4760	5532	4384
CPP / IPP Gas	0	0	0	0
SOLAR	716	70	0	0
Exchange with Mumbai	-1954	-1931	-1808	-913
MSEDCL DEMAND MET	17224	16446	18411	14107
Load Shedding	0	0	0	0
MSEDCL DEMAND	17224	16446	18411	14107
TPCL GENERATION	669	669	736	899
AEML GENERATION	486	476	492	500
MUMBAI DEMAND	3109	3076	3036	2312
OTHER DISCOM DEMAND	425	407	435	308
STATE DEMAND MET	20758	19929	21882	16727
STATE DEMAND	20758	19929	21882	16727
Frequency (Hz)	50.01	49.95	50.02	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 13:02 Hrs	49.79 Hz at 18:17 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.56	9.94	185	2
Unit 7	0.00	0.00	0	0
Unit 8	7.50	123.66	460	0
Unit 9	0.00	37.66	0	0
Unit 10	9.56	118.97	420	381
Total	20.62	290.22		
Bhusawal				
Unit 3	2.58	25.21	120	80
Unit 4	4.53	96.76	355	0
Unit 5	8.50	97.07	430	280
Total	15.61	219.04		
Parli				
Unit 6	4.10	47.79	215	130
Unit 7	4.14	48.37	198	144
Unit 8	0.00	31.26	0	0
Total	8.24	127.42		
Chandrapur				
Unit 3	2.94	36.06	150	60
Unit 4	3.03	31.24	140	112
Unit 5	7.13	81.14	360	270
Unit 6	7.82	88.45	400	270
Unit 7	7.73	90.25	367	292
Unit 8	5.84	5.84	425	0
Unit 9	8.56	102.89	416	285
Total	43.05	435.88		
Paras				
Unit 3	4.19	45.61	195	136
Unit 4	0.00	0.00	0	0
Total	4.19	45.61		
Khaparkheda				
Unit 1	2.70	34.63	120	105
Unit 2	2.76	34.27	130	100
Unit 3	3.23	42.20	152	116
Unit 4	3.22	38.74	175	113
Unit 5	8.27	96.54	440	275
Total	20.18	246.37		
Nasik				
Unit 3	0.00	25.32	0	0
Unit 4	3.14	37.52	158	107
Unit 5	3.05	7.36	153	112
Total	6.19	70.20		
Uran				
All Units	2.16	26.96	93	84
Total	2.16	26.96		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.58	7.12	25	24
Total	0.58	7.12		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.61	24.66	470	35
Stage 4	2.00	20.82	918	0
Stage 3	1.13	11.35	240	0
Total	5.74	56.83		
Hydro				
KDPH	0.43	2.88	18	18
VTRNA	0.00	1.82	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.34	3.04	80	0
SMLHY_PTN	2.48	20.78	110	95
GHATGHAR	0.14	2.22	80	0
Total	3.39	30.74		
Wind				
Total	1.77	144.23	0	0
Total	1.77	144.23		
CPP				
APML(Mus)	62.45	579.31	0	0
JSWEL(Mus)	14.38	199.25	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	23.64	275.57	0	0
SWPGPL-Mus	7.53	84.78	0	0
Other(Mus)	4.90	89.37	0	0
Total	112.90	1228.28		
SOLAR				
Total	7.69	112.40	0	0
Total	7.69	112.40		
Tata				
Trombay 5	0.78	80.46	238	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.42	15.94	91	49
Trombay 7B	1.16	12.66	59	43
TATA Hydro	8.12	44.20	419	189
Trombay 8	5.26	43.54	235	180
Total	16.74	196.80		
AEML				
DTPS U-1&2	11.55	112.40	500	453
Total	11.55	112.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	118.09	1434.74	MSPGCL Total	129.96	1556.39
			MSPGCL Thml+Gas	120.25	1461.70	Koyna 1,2 & 4 Total	4.61	45.48
			MSPGCL Hydro	9.72	94.69	State Total	280.62	3350.50

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 12/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4542	192	92	4826	56	4367	0	0	6924	6730	-1108	14517	0	14517	2402	354	17273	50.03
2	4611	192	92	4895	41	4395	0	0	6409	6209	-949	14274	0	14274	2407	317	16998	50.00
3	4475	192	93	4760	33	4384	0	0	6015	6151	-913	14107	0	14107	2312	308	16727	50.02
4	4573	391	92	5056	27	4390	0	0	5874	6233	-1011	14392	0	14392	2099	303	16794	50.03
5	5144	362	92	5598	33	4491	0	0	6127	6230	-988	15043	0	15043	2062	321	17426	50.04
6	5390	201	92	5683	51	4756	0	1	6705	7144	-1022	16250	0	16250	2124	363	18737	50.02
7	5440	561	93	6094	70	5203	0	24	7141	7323	-1171	17171	0	17171	2268	372	19811	50.01
8	5179	681	93	5953	71	5311	0	179	8079	8105	-1377	17845	0	17845	2467	397	20709	50.06
9	5030	301	92	5423	50	5175	0	388	8528	8335	-1644	17306	0	17306	2782	421	20509	50.02
10	5011	305	92	5408	43	4638	0	716	8843	8798	-1954	17224	0	17224	3109	425	20758	50.01
11	4569	305	89	4963	75	4542	0	933	9223	8848	-2139	16793	0	16793	3302	429	20524	50.01
12	4441	218	88	4747	93	4243	0	1111	8899	8899	-2176	16490	0	16490	3337	427	20254	50.03
13	4443	185	86	4714	119	4113	0	1276	8369	8049	-2147	15704	0	15704	3310	420	19434	50.01
14	4384	176	86	4646	80	3742	0	1163	8038	8144	-2028	15331	0	15331	3168	416	18915	50.09
15	4606	172	85	4863	112	4044	0	911	7662	7964	-2020	15467	0	15467	3151	407	19025	49.97
16	4583	173	84	4840	127	4442	0	592	7996	7775	-2043	15336	0	15336	3184	397	18917	49.98
17	4829	179	86	5094	89	4657	0	327	8159	8079	-1994	15844	0	15844	3158	408	19410	49.99
18	5253	356	89	5698	47	4760	0	70	8046	8209	-1931	16446	0	16446	3076	407	19929	49.95
19	5474	1570	90	7134	32	5465	0	0	7304	7502	-1891	17819	0	17819	3071	423	21313	49.97
20	5218	1688	91	6997	51	5532	0	0	7547	8074	-1808	18411	0	18411	3036	435	21882	50.02
21	5329	501	90	5920	64	5384	0	0	8012	7691	-1672	16973	0	16973	2885	414	20272	50.01
22	5281	422	90	5793	70	5157	0	0	7538	7262	-1539	16320	0	16320	2735	423	19478	50.02
23	5246	210	91	5547	177	5016	0	0	7136	6882	-1417	15821	0	15821	2616	384	18821	50.01
24	5038	182	92	5312	157	4691	0	0	7032	6737	-1357	15164	0	15164	2534	376	18074	49.99
MUs	118.09	9.72	2.16	129.96	1.77	112.90	0.00	7.69	181.61	181.37	-38.30	386.05	0.00	386.05	66.60	9.35	461.99	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Oct/2022

Position as on 6.30 Hrs of 13/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	22/10/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52	12/10/2022	04:06	COH	11/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/10/2022
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	12/10/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	12/10/2022
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	18/10/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	18/10/2022
MSPGCL	Koradi Unit 9	660	10/10/2022	07:43		Continued.	Boiler Tube Leakage	13/10/2022
MSPGCL	Parli Unit 8	250	11/10/2022	00:01		Continued.	Boiler Tube Leakage	14/10/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	IEPL Unit 1	270	11/10/2022	22:09	13/10/2022	02:12	Generator Protection operated	
TPC-G	Trombay 5	500	12/10/2022	03:34		Continued.	Economizer Tube Leakage.	14/10/2022
MSPGCL	Koradi Unit 6	210	12/10/2022	18:24	12/10/2022	19:59	Flame Failure	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Oct/2022

Position as on 6.30 Hrs of 13/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 8	660	12/10/2022	18:53		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 13/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
Main Bay (706) OF EKTUNI-AKOLA II ckt-1 & LR @ EKTUNI	IntraState	12/10/2022	12:08	12/10/2022	15:35	PO	Diagnostic Testing of CT & Routine Maintenance
400 KV TIEBAY Outages/Trippings							
TIE BAY (429) OF ICT - 1 @ KORADI - 2	IntraState	12/10/2022	11:08	12/10/2022	17:43	PO	Diagnostic Testing of CT & CB and routine bay maintenance work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (409) of EKTUNI CKT-1 @ TAPTITANDA	IntraState	12/10/2022	11:49	12/10/2022	15:36	PO	CB Diagnostic Testing
400 KV LINE Outages/Trippings							
KARAD - LONIKAND I	IntraState	10/10/2022	09:28			PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	11/10/2022	08:52			HT	H/T FOR LOAD MANAGEMENT
PADGHE - KALWA CKT - 2	IntraState	12/10/2022	01:07	12/10/2022	02:40	EO	Attending Red Hot spot on Rph CB Bus side
JAIGAD - KARAD CKT - 2	IntraState	12/10/2022	04:09			HT	Overvoltage
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	12/10/2022	06:11	12/10/2022	17:43		Disc Insulator string Replacement by Long Rod Porcelain string
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	12/10/2022	06:11	12/10/2022	18:10	PO	Replacement of Disc Insulator Strings by Long Rod Porcelain strings
PARLI-SOLAPUR (LAMBOTI)	IntraState	12/10/2022	10:10	12/10/2022	17:22	PO	Hardware Tightening & Fitting Work
DHULE - DHULE(BDTCL) CKT - 2	IntraState	12/10/2022	11:00	12/10/2022	18:38	EO	Emergency outage For replacement of distance protection (Main2) Relay CT/PT card of 400kV Dhule-Songir (BDTCL) 2 line at 400kV Dhule end on 12.10.2022 from 09 Hrs to 14 Hrs.
PARLI-SOLAPUR (LAMBOTI)	IntraState	12/10/2022	21:07			T	TRIPPED ON DISTANCE PROTECTION
PADGHE - KALWA CKT - 1	IntraState	13/10/2022	00:19	13/10/2022	04:21	EO	For 1) Attending Hot spot on Y ph CT lineside Temp 113 deg 2) C bus Bph BPI clamp 158 deg 3) Rph CB B bus side 104deg 4) Rph B bus PG isolator jaw 134deg 5) C bud Yph PG isolator 89deg
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	13/10/2022	05:53				Disc Insulator string Replacement by Long Rod Porcelain string
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	13/10/2022	07:20			PO	Replacement of Disc Insulator Strings by Long Rod Porcelain strings
400 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 13/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ KORADI	IntraState	12/10/2022	16:18	12/10/2022	20:09	EO	Attending hot spot (284 Degree Celsius) on 220KV B Phase line isolator Clamp (Line side) ICT-2 bay on 220KV side at 400 / 220KV S/stn. Koradi-1 S/Stn on dt.- 12.10.2022. Photo is attached herewith.
400 KV BR Outages/Trippings							
125 MVAR BUS REACTOR @ 400KV KHAPARKHEDA S/S	InterState	12/10/2022	11:18	12/10/2022	16:30	PO	Fine tuning of CSD relay by siemens executive. for fine tuning activity requires the maximum 03-04 on/off operations of 125mvar bus reactor breaker and require gap between each operation 30 minutes .
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	06/10/2022	08:15			PO	Bunching of lines at location no.SS 82 to facilitate the following project work: NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223. DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	06/10/2022	08:22			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - PADGHE	IntraState	08/10/2022	22:52			HT	For load management
MAHALAXMI - AMONA	IntraState	12/10/2022	08:56	12/10/2022	17:45	PO	1) Annual maintenance work. 2) For cold washing of Bus & Bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments at Mahalaxmi end.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	12/10/2022	09:15	12/10/2022	22:08	HT	H/T FOR LOAD MANAGEMENT OF BBLR CKT
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	12/10/2022	09:53	12/10/2022	21:30	PO	Outage is required for Quarterly Maintenance
HALKARNI-MAHALAXMI LINE	IntraState	12/10/2022	09:54	12/10/2022	17:45	PO	For cold washing of Bus & Bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments.
CHINCHWAD-2 - TELCO	IntraState	12/10/2022	10:13	12/10/2022	17:13	PO	Stringing of conductors on newly erected Monopole tower no 16A to 17
ALKUD - VITA	IntraState	12/10/2022	10:43	12/10/2022	17:25	PO	Diagnostic Testing Work
LONAND-BARAMATI	IntraState	12/10/2022	11:07	12/10/2022	15:05	PO	Replacement of flashover string at Tower loc. No. 65 (B phase)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 12/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 13/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SADAWAGHAPUR KARAD CKT 1	IntraState	12/10/2022	11:34	12/10/2022	17:42	PO	As per instructions of Hon ED(Operation),Demo is arranged for various testing kits by M/s MKS ,Bangaluru on 12.10.2022 at EHV PC O&M Zone, Karad. Also replacement of R & Y ph jump between 29C&D Isolator due to damages of conductor strands of Jumps.
BOISAR II - TARAPUR	IntraState	12/10/2022	12:41	12/10/2022	18:40	PO	Replacement of Rusted Hardware work under scheme at Loc No.28 To 50
KHARGHAR - TOPWORTH	IntraState	12/10/2022	13:48	12/10/2022	17:53	EO	Replacement of decapped poliet disc insulator at Loc no. 651 (Bottom phase)
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	12/10/2022	09:00	12/10/2022	17:30	PO	Attending transformer oil leakage from top plate, inspection windows.
220/132KV 200MVA ICT 1 @ JEUR	IntraState	12/10/2022	10:37	12/10/2022	13:02	PO	Outage is required for Quarterly Maintenance
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	12/10/2022	12:13	12/10/2022	18:27	PO	For Annual relay testing work
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
KALYAN KALWA SALSETTE 1	IntraState	12/10/2022	05:57	12/10/2022	07:49	EO	Attending Hot spot at A2 structure of Salsette

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage