

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Oct/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	158.915	1888.214	1) Gujrat	9.990	116.366
2) Hydro	34.060	195.447	2) Madhya Pradesh	4.258	70.007
3) Gas	6.818	65.222	3) Chattisgarh	3.590	46.210
Total MSPGCL	199.793	2148.883	4) Maharashtra	193.048	2149.667
B) 1) APLM	76.277	693.727	5) Goa (Amona)	-1.435	-18.872
2) JSWEL	29.012	288.403	Total	209.451	2363.378
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.464	412.430
4) RPL(AMT)	27.100	319.248	b) Mumbai Drawl	38.588	464.439
5) SWPGPL	6.351	102.596	c) MSEDCL Bilateral *	76.574	924.400
6) Other IPP	9.553	44.544	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.203	412.078
C) 1) TPCL Thermal	15.229	163.221	Include PX	0.000	0.000
2) TPCL Hydro	6.915	56.727	Standby	0.261	0.352
3) TPCL Gas	1.871	30.021	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.281	112.542	1) MSEDCL	531.216	5684.462
D) STATE			2) Mumbai Discoms	73.884	826.950
1) Thermal	333.718	3612.495	3) Other Discoms	10.557	123.471
(A1+C1+C4+(B1-B6))			TOTAL STATE	615.657	6634.883
2) Hydro	40.975	252.174			
(A2+C2)					
3) Gas	8.689	95.243			
(A3+B7+C3)					
4) Wind	7.348	117.718			
6) SOLAR	15.476	193.875			
TOTAL STATE	406.206	4271.505			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6643	6533	6575	6648
MSPGCL Hydro	1336	1871	1911	1328
MSPGCL Gas	283	275	278	291
MSPGCL Total Generation	8262	8679	8764	8267
Central Sector Receipt	9779	9967	9247	7152
WIND	244	207	373	413
CPP / IPP Thermal	6105	6082	6076	6349
CPP / IPP Gas	0	0	0	0
SOLAR	2084	1115	1	0
Exchange with Mumbai	-2075	-2198	-1822	-933
MSEDCL DEMAND MET	23911	23376	22154	20914
Load Shedding	0	0	139	0
MSEDCL DEMAND	23911	23376	22293	20914
TPCL GENERATION	935	974	1153	909
AEML GENERATION	462	496	495	451
MUMBAI DEMAND	3472	3668	3470	2293
OTHER DISCOM DEMAND	488	476	485	334
STATE DEMAND MET	27871	27520	26109	23541
STATE DEMAND	27871	27520	26248	23541
Frequency (Hz)	50.02	50.00	49.94	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 13:01 Hrs	49.74 Hz at 16:53 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Oct/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.26	46.88	185	150
Unit 8	14.00	168.85	610	557
Unit 9	13.76	145.08	600	552
Unit 10	14.02	169.38	604	564
Total	46.04	530.19		
Bhusawal				
Unit 3	2.76	36.82	130	90
Unit 4	10.40	83.62	450	410
Unit 5	5.49	102.44	255	40
Total	18.64	222.88		
Parli				
Unit 6	5.25	53.66	238	162
Unit 7	5.22	54.17	238	137
Unit 8	4.11	47.58	211	130
Total	14.58	155.41		
Chandrapur				
Unit 3	2.75	29.55	130	98
Unit 4	3.46	28.65	154	128
Unit 5	0.00	34.06	0	0
Unit 6	7.54	77.92	335	290
Unit 7	6.59	77.40	307	240
Unit 8	11.36	121.57	489	456
Unit 9	10.99	123.36	475	424
Total	42.70	492.50		
Paras				
Unit 3	5.18	57.60	235	198
Unit 4	5.11	59.28	219	183
Total	10.29	116.88		
Khaparkheda				
Unit 1	3.38	43.12	165	105
Unit 2	1.70	25.79	111	45
Unit 3	3.84	34.02	177	144
Unit 4	0.97	38.54	151	0
Unit 5	9.86	125.60	440	385
Total	19.74	267.08		
Nasik				
Unit 3	0.00	31.99	0	0
Unit 4	3.56	35.36	156	129
Unit 5	3.35	35.93	152	115
Total	6.92	103.28		
Uran				
All Units	6.82	65.22	293	271
Total	6.82	65.22		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.94	11.75	51	0
Total	0.94	11.75		
Koyna				
Stage 1-2	6.35	43.54	530	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	18.50	73.03	1010	0
Stage 3	5.15	25.52	240	34
Total	30.00	142.09		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.65	0	0
TILLARI	0.18	1.38	60	0
BHIRA T.R.	0.42	3.74	80	0
SMLHY_PTN	2.52	31.99	116	100
GHATGHAR	0.00	3.85	0	0
Total	3.12	41.60		
Wind				
Total	7.35	117.72	0	0
Total	7.35	117.72		
CPP				
APML(Mus)	76.28	693.73	0	0
JSWEL(Mus)	29.01	288.40	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	27.10	319.25	0	0
SWPGPL-Mus	6.35	102.60	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.40	20.23	271	263
Other(Mus)	0.34	4.06	0	0
JPL	2.81	20.25	125	101
Total	148.29	1448.52		
SOLAR				
Total	15.48	193.88	0	0
Total	15.48	193.88		
Tata				
Trombay 5	10.96	108.59	467	407
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.98	17.20	69	34
Trombay 7B	0.89	12.83	52	33
TATA Hydro	6.92	56.73	436	131
Trombay 8	4.27	54.63	237	0
Total	24.02	249.97		
AEML				
DTPS U-1&2	11.28	112.54	499	431
Total	11.28	112.54		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	158.92	1888.21	MSPGCL Total	199.79	2148.88
			MSPGCL Thml+Gas	165.73	1953.44	Koyna 1,2 & 4 Total	24.85	116.57
			MSPGCL Hydro	34.06	195.45	State Total	406.21	4271.50

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Oct/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6655	1241	289	8185	229	6369	0	0	7834	7706	-1274	20825	0	0	20825	2783	390	23998	50.01
2	6718	1319	290	8327	287	6365	0	0	7551	7552	-1128	21026	0	0	21026	2568	377	23971	50.02
3	6673	1316	290	8279	344	6362	0	0	7327	7204	-995	20846	0	0	20846	2398	348	23592	50.03
4	6648	1328	291	8267	413	6349	0	0	7211	7152	-933	20914	0	0	20914	2293	334	23541	50.03
5	6734	1403	292	8429	396	6346	0	0	7651	7542	-918	21422	0	0	21422	2268	373	24063	49.96
6	6671	1441	292	8404	402	6353	0	0	8379	8320	-955	22132	0	0	22132	2326	392	24850	49.93
7	6672	1863	292	8827	337	6330	0	71	8730	8622	-1086	22681	0	20	22681	2452	420	25553	49.98
8	6585	1812	293	8690	366	6361	0	495	8277	8557	-1180	22845	0	4	22845	2611	444	25900	49.99
9	6660	1613	290	8563	317	6099	0	1134	8226	8175	-1470	22347	0	4	22347	2933	471	25751	50.02
10	6647	1143	286	8076	318	6103	0	1673	8999	9150	-1794	23049	0	4	23049	3248	477	26774	49.99
11	6643	1336	283	8262	244	6105	0	2084	9568	9779	-2075	23911	0	3	23911	3472	488	27871	50.02
12	6612	1098	279	7989	214	6096	0	2201	9778	9870	-2203	23689	0	20	23689	3562	478	27729	50.03
13	6594	556	278	7428	208	6060	0	2265	10151	9772	-2169	23117	0	42	23117	3542	447	27106	50.00
14	6578	332	271	7181	209	6038	0	2028	10463	10187	-2090	23091	0	3	23091	3497	462	27050	50.04
15	6572	1276	272	8120	192	6094	0	1647	9969	9905	-2183	23313	0	8	23313	3605	462	27380	50.01
16	6533	1871	275	8679	207	6082	0	1115	10111	9967	-2198	23376	0	7	23376	3668	476	27520	50.00
17	6606	1808	277	8691	203	6037	0	610	9782	9297	-2063	22296	0	4	22296	3618	479	26393	49.88
18	6582	1808	278	8668	260	6077	0	152	9209	9030	-1916	21793	0	3	21793	3498	478	25769	49.89
19	6575	1911	278	8764	373	6076	0	1	9311	9247	-1822	22154	139	0	22293	3470	485	26248	49.94
20	6540	1691	279	8510	423	6115	0	0	9413	8940	-1698	21814	129	0	21943	3394	476	25813	50.03
21	6540	1332	284	8156	397	6125	0	0	8756	8681	-1644	21242	0	0	21242	3246	473	24961	50.02
22	6567	1467	285	8319	383	6121	0	0	8266	8179	-1579	20966	0	0	20966	3164	457	24587	50.02
23	6609	1383	285	8277	333	6115	0	0	8320	8206	-1609	20886	0	0	20886	3140	436	24462	49.97
24	6701	1712	289	8702	293	6115	0	0	8358	8411	-1606	21480	0	0	21480	3128	435	25043	49.98
MUs	158.92	34.06	6.82	199.79	7.35	148.29	0.00	15.48	211.64	209.45	-38.59	531.22	0.27	0.12	531.48	73.88	10.56	615.93	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR carried due to 220KV BBLR-I & II line overload.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Oct/2023

Position as on 6.30 Hrs of 13/Oct/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	12/10/2023
MSPGCL	Koyana Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
IPP	SWPGPL U-4	135	29/09/2023	00:03		Continued.	Turbine Bearing no.4 temperature high	20/10/2023
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
MSPGCL	Nasik Unit 3	210	10/10/2023	23:55		Continued.	ESP Hoppers & restoration of ESP Filters	14/10/2023
IPP	SWPGPL U-3	135	10/10/2023	23:56		Continued.	Electrostatic precipitator problem	19/10/2023
MSPGCL	Chandrapur Unit 5	500	11/10/2023	08:12		Continued.	Turbine Vibration High.	27/10/2023
MSPGCL	Bhusawal Unit 5	500	11/10/2023	22:01	12/10/2023	00:42	PA FAN 5B UNLODED Resulted in Low furnace Pressure due to that Boiler Tripped	
MSPGCL	Khaparkheda Unit 4	210	12/10/2023	06:58	12/10/2023	22:44	Reheater Problem	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	19/10/2023
TPC-G	Bhira PSU	150	12/10/2023	10:29	12/10/2023	12:12	Due to Sprical valve closed	
TPC_G	Trombay 8	250	12/10/2023	12:03	12/10/2023	16:25	Low Vacuum	
MSPGCL	Khaparkheda Unit 4	210	12/10/2023	23:12	13/10/2023	01:08	HP Exhaust Temperature High Protection	
MSPGCL	Parli Unit 8	250	13/10/2023	00:10		Continued.	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 13/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (704) OF EKTUNI CKT - 1 @ AKOLA 2	IntraState	12/10/2023	12:14		Continued.	PO	Annual Bay Maintenance
400 KV TIEBAY Outages/Trippings							
Tie Bay (417) of Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	IntraState	12/10/2023	10:48	12/10/2023	17:19	PO	Diagnostic testing & allied bay maintenance work
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
MAIN BAY (407) OF BUS REACTOR @ LONIKAND 2	IntraState	12/10/2023	08:27	12/10/2023	12:50	PO	Diagnostic testing and Maintenance
Main bay (409) of Tirora - Warora ckt-2 @ TIRORA	IntraState	12/10/2023	09:00			PO	For line main bay breaker arcing contact inspection and testing work
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
AURANGABAD(MS) - AURANGABAD(PG) CKT -1	InterState	12/10/2023	11:11	12/10/2023	15:37	PO	Bay AMP Work
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ɛYɛ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/10/2023	08:04			HT	H/T for load management.
JEJURI - KARAD	IntraState	12/10/2023	13:15		Continued.	PO	PID Faulty disc insulator replacement work & cold line washing work
EKTUNI - BABLESHWAR CKT - 1	IntraState	12/10/2023	13:29		Continued.	PO	Line Maintenance work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	11/10/2023	07:30			EO	TRIP TRAILS OF 220KV BUS BAR/ICT HV & LV BY STU NOMINATED TEAM AS PER CE AC& I DIRECTIONS DATED 09.10.2023
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	11/10/2023	08:32			EO	TRIP TRAILS OF 220KV BUS BAR/ICT HV & LV BY STU NOMINATED TEAM AS PER CE AC& I DIRECTIONS DATED 09.10.2023
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	11/10/2023	08:40			EO	TRIP TRAILS OF 220KV BUS BAR/ICT HV & LV BY STU NOMINATED TEAM AS PER CE AC& I DIRECTIONS DATED 09.10.2023
220 KV LINE Outages/Trippings							
220 kV-Wardha(PG)-Yawatmal Ckt-1	InterState	12/10/2023	11:25	12/10/2023	19:10	PO	For Amp of Bay
220 kV-Wardha(PG)-Yawatmal Ckt-1	InterState	12/10/2023	11:25	12/10/2023	19:10	PO	AMP Work By PGCIL.
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 13/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AAREY - MSETCL BORIVALI CKT - 2	IntraState	05/10/2023	19:29	12/10/2023	18:06	T	Tripped on Differential protection.
EKLAHARE (OCR) - PADGHE	IntraState	06/10/2023	07:37			HT	Kept Handtripped from padghe end for load managemnet
PIRANGUT - HINJAWADI 2	IntraState	11/10/2023	08:36	12/10/2023	18:02	PO	C.B. operating mechanism overhauling
NEW KOYNA - POPHALI	IntraState	11/10/2023	09:16	13/10/2023	00:04	PO	CT Replacement work
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	12/10/2023	06:52	12/10/2023	08:55	T	Tripped on distance protection
HINJAWADI I- CHINCHWAD	IntraState	12/10/2023	07:25	12/10/2023	19:38	PO	Dismatelling of old tower no.160, 161,162.
MALINAGAR - TEMBHURNI	IntraState	12/10/2023	09:10	12/10/2023	17:24	PO	Cold line washing of strings LILO Loc 118 to 149.
NAGOTHANE - ACCIL	IntraState	12/10/2023	09:33	12/10/2023	18:00	PO	Twin jumpering work at all cut point locations.
220 KV KHADKA(400 KV) - KEKATNIBHORA CKR	IntraState	12/10/2023	10:14	12/10/2023	16:10	PO	Diagnostic Testing Work.
WARDHA - WARDHA RLY TSS 1	IntraState	12/10/2023	10:29	12/10/2023	14:58	PO	Tan delta cb dcrm line maintenance work.
MUDSHINGI- BELEWADI LINE	IntraState	12/10/2023	10:38	12/10/2023	17:26	PO	Quarterly Maintenance Work
BUS SECTION - 1 @ KHAREPATAN	IntraState	12/10/2023	10:41	12/10/2023	18:37	PO	For Replacement of 220kV Rph Bus PT, 220kV Rph PT Replacement to be done as High Tan Delta values observed. Quarterly Maintenance of Bay Equipment in Bus Section I.
ANANDNAGAR - PALAVA	IntraState	12/10/2023	11:07	12/10/2023	16:13	PO	Repl. Of damaged Jumper(CB to line ISO B ph)
GHATGHAR - JINDAL	IntraState	12/10/2023	13:00	12/10/2023	13:27	T	Tripped on distance protection
MHAISAL - ALKUD	IntraState	12/10/2023	16:47	12/10/2023	19:05	PO	Aux Bus Isolator Maintenance & isolator alignment work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 50MVA PTR NO 1 @ BARAMATI	IntraState	12/10/2023	10:00	12/10/2023	12:25	PO	Diagnostic testing work
220/132KV 100MVA ICT 1@ PETH	IntraState	12/10/2023	10:00	12/10/2023	13:50	PO	Diagnostic Testing Work
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	12/10/2023	10:04	12/10/2023	19:26	PO	For Replacement of 220kV Rph Bus PT, 220kV Rph PT Replacement to be done as High Tan Delta values observed. Quarterly Maintenance of Bay Equipment in Bus Section I.
220/100 KV 200 MVA ICT 1 @ BORIVALI	IntraState	12/10/2023	10:19			PO	For replacement of various EHV equipments under LE Scheme. The old EHV equipments are to be replaced under LE Scheme whose details are as given below - 1. 220 kV Circuit Breaker - 1 No. 2. 220 kV Lightning Arrestors - 3 Nos. 3. 100 kV Potential Transformers - 6 Nos. 4. 100 kV Isolators - 9 Nos. Also the Anti Corrosive Painting of ICT-1 will be carried out in this outage.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 13/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	IntraState	12/10/2023	12:00	12/10/2023	15:54	PO	REPLACEMENT OF Y PH HV CT DUE TO HIGH TAN DELTA On Dt 12/10/2023. By TESTING UNIT SOLAPUR.
220/33 KV 25MVA PTR 3 @ BARAMATI	IntraState	12/10/2023	12:30	12/10/2023	15:40	PO	Diagnostic testing work.
220/33KV 50MVA PTR 2 @ BARAMATI	IntraState	12/10/2023	15:44	12/10/2023	18:55	PO	Diagnostic testing work
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
MAIN BUS @ BARAMATI AGRO	IntraState	12/10/2023	13:25	12/10/2023	17:45	PO	for connecting Jumper from main bus to MAIN BUS isolator of 30MW New Metering bay.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage