

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Nov/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.456	1733.413	1) Gujrat	-8.359	-107.227
2) Hydro	5.516	92.512	2) Madhya Pradesh	-1.975	-25.533
3) Gas	2.174	20.469	3) Chattisgarh	6.320	71.300
Total MSPGCL	151.146	1846.394	4) Maharashtra	171.258	1978.328
B) 1) APLM	60.355	753.182	5) Goa (Amona)	-1.581	-17.513
2) JSWEL	13.538	154.974	Total	165.663	1899.355
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.234	384.297
4) RPL(AMT)	25.515	306.356	b) Mumbai Drawl	35.497	428.650
5) SWPGPL	8.330	78.281	c) MSEDCL Bilateral *	84.533	832.487
6) Other IPP	35.866	356.612	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.234	384.297
C) 1) TPCL Thermal	10.797	130.016	Include PX	0.000	0.000
2) TPCL Hydro	3.408	47.310	Standby	0.000	0.000
3) TPCL Gas	0.000	6.990	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.051	105.478	1) MSEDCL	453.360	5189.648
D) STATE			2) Mumbai Discoms	58.753	718.444
1) Thermal	306.908	3618.312	3) Other Discoms	9.426	111.980
(A1+C1+C4+(B1-B6))			TOTAL STATE	521.539	6020.072
2) Hydro (A2+C2)	8.924	139.822			
3) Gas (A3+B7+C3)	2.174	27.459			
4) Wind	26.891	190.564			
6) SOLAR	10.979	144.560			
TOTAL STATE	355.876	4120.717			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	5773	6304	6334	5257
MSPGCL Hydro	280	156	842	141
MSPGCL Gas	89	85	89	91
MSPGCL Total Generation	6142	6545	7265	5489
Central Sector Receipt	7798	7730	7733	6057
WIND	1536	769	667	1579
CPP / IPP Thermal	6353	6312	6039	5287
CPP / IPP Gas	0	0	0	0
SOLAR	1520	1131	0	0
Exchange with Mumbai	-1689	-1568	-1490	-1465
MSEDCL DEMAND MET	21251	20516	19783	16586
Load Shedding	0	0	0	0
MSEDCL DEMAND	21251	20516	19783	16586
TPCL GENERATION	635	693	821	488
AEML GENERATION	496	484	469	303
MUMBAI DEMAND	2820	2745	2780	2256
OTHER DISCOM DEMAND	410	403	430	361
STATE DEMAND MET	24480	23664	22994	19203
STATE DEMAND	24480	23664	22994	19203
Frequency (Hz)	50.02	50.00	50.02	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 06:02 Hrs	49.75 Hz at 17:44 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.56	55.02	215	110
Unit 7	0.00	0.00	0	0
Unit 8	13.40	148.28	585	507
Unit 9	13.16	148.59	579	505
Unit 10	0.00	91.74	0	0
Total	31.11	443.63		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.00	107.64	435	275
Unit 5	9.72	109.82	465	270
Total	18.72	217.46		
Parli				
Unit 6	4.10	45.27	222	144
Unit 7	4.04	44.08	238	144
Unit 8	3.87	36.20	199	142
Total	12.01	125.55		
Chandrapur				
Unit 3	2.86	38.34	130	90
Unit 4	2.80	34.76	140	103
Unit 5	5.91	77.61	295	105
Unit 6	7.65	79.97	380	272
Unit 7	7.28	86.69	348	280
Unit 8	10.04	116.13	471	278
Unit 9	9.80	110.83	443	313
Total	46.33	544.33		
Paras				
Unit 3	4.95	58.46	222	183
Unit 4	4.96	12.63	223	185
Total	9.91	71.09		
Khaparkheda				
Unit 1	2.68	32.01	130	85
Unit 2	2.60	31.66	130	85
Unit 3	3.46	41.06	178	121
Unit 4	3.32	39.92	155	126
Unit 5	10.22	120.21	490	280
Total	22.28	264.86		
Nasik				
Unit 3	0.00	1.31	0	0
Unit 4	0.00	28.41	0	0
Unit 5	3.10	36.77	153	109
Total	3.10	66.48		
Uran				
All Units	2.17	20.47	100	85
Total	2.17	20.47		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	10.40	46	0
Total	0.14	10.40		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.84	27.26	415	40
Stage 4	0.58	16.69	383	0
Stage 3	0.44	9.68	80	0
Total	2.86	53.63		
Hydro				
KDPH	0.58	2.38	36	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.58	0	0
BHIRA T.R.	0.28	2.34	80	0
SMLHY_PTN	1.51	19.63	65	60
GHATGHAR	0.14	3.56	115	0
Total	2.51	28.49		
Wind				
Total	26.89	190.56	0	0
Total	26.89	190.56		
CPP				
APML(Mus)	60.36	753.18	0	0
JSWEL(Mus)	13.54	154.97	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.52	306.36	0	0
SWPGPL-Mus	8.33	78.28	0	0
Other(Mus)	35.87	356.61	0	0
Total	143.60	1649.40		
SOLAR				
Total	10.98	144.56	0	0
Total	10.98	144.56		
Tata				
Trombay 5	7.29	88.14	391	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	3.41	47.31	419	9
Trombay 8	3.51	41.87	175	131
Total	14.20	184.32		
AEML				
DTPS U-1&2	9.05	105.48	499	281
Total	9.05	105.48		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.46	1733.41	MSPGCL Total	151.15	1846.39
			MSPGCL Thml+Gas	145.63	1753.88	Koyna 1,2 & 4 Total	2.43	43.95
			MSPGCL Hydro	5.52	92.51	State Total	355.88	4120.72

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 12/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5257	141	91	5489	1579	5287	0	0	5632	6057	-1465	16586	0	16586	2256	361	19203	50.01
2	5387	140	91	5618	1507	5442	0	0	5653	5925	-1358	16796	0	16796	2099	338	19233	50.00
3	5379	141	91	5611	1414	5778	0	0	5780	5836	-1287	17042	0	17042	1986	310	19338	49.99
4	5670	140	91	5901	1326	5865	0	0	5705	5662	-1202	17245	0	17245	1898	306	19450	50.00
5	5975	143	91	6209	1319	6068	0	0	5766	5769	-1184	17843	0	17843	1875	337	20056	50.02
6	6128	137	92	6357	1294	6563	0	0	6032	6392	-1267	18985	0	18985	1956	354	21295	50.02
7	6200	137	90	6427	1346	6563	0	31	6841	6722	-1303	19421	0	19421	2023	366	21809	50.04
8	6235	141	91	6467	1271	6637	0	303	6771	6941	-1342	19895	0	19895	2120	382	22397	50.05
9	5989	139	90	6218	1187	6521	0	774	6826	6969	-1489	19774	0	19774	2335	406	22515	50.03
10	5727	359	90	6176	1419	6195	0	1208	6998	7426	-1520	20495	0	20495	2617	409	23521	50.00
11	5773	280	89	6142	1536	6353	0	1520	7341	7798	-1689	21251	0	21251	2820	410	24480	50.02
12	5694	230	87	6011	1487	5905	0	1670	7461	7926	-1733	20855	0	20855	2866	411	24132	50.01
13	5978	199	100	6277	1115	5827	0	1655	7423	7662	-1707	20408	0	20408	2834	421	23663	49.97
14	6082	137	91	6310	893	5949	0	1508	7293	7565	-1611	20200	0	20200	2733	414	23347	50.01
15	6304	156	85	6545	769	6312	0	1131	7379	7730	-1568	20516	0	20516	2745	403	23664	50.00
16	6398	553	87	7038	591	5953	0	768	7626	7899	-1539	20302	0	20302	2764	408	23474	50.02
17	6382	213	89	6684	508	6014	0	364	8116	7872	-1428	19580	0	19580	2756	435	22770	49.98
18	6431	337	89	6857	519	6021	0	47	7751	7620	-1487	19148	0	19148	2719	428	22296	49.96
19	6334	842	89	7265	667	6039	0	0	7632	7733	-1490	19783	0	19783	2780	430	22994	50.02
20	6265	360	92	6717	822	6057	0	0	7353	7384	-1530	19009	0	19009	2705	441	22155	50.04
21	5967	171	91	6229	979	5915	0	0	6611	6589	-1605	17674	0	17674	2609	433	20716	50.00
22	5937	153	92	6182	1026	5686	0	0	6078	6295	-1612	17162	0	17162	2497	415	20074	50.01
23	5972	146	92	6210	1119	5345	0	0	5898	6094	-1544	16818	0	16818	2397	406	19621	49.94
24	5992	121	93	6206	1198	5309	0	0	5905	5797	-1537	16572	0	16572	2363	401	19336	49.99
MUs	143.46	5.52	2.17	151.15	26.89	143.60	0.00	10.98	161.87	165.66	-35.50	453.36	0.00	453.36	58.75	9.43	521.54	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Nov/2022

Position as on 6.30 Hrs of 13/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00	13/11/2022	18:25	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	14/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	14/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	
IPP	JSW (J) U3	300	09/11/2022	08:08		Continued.	Generator Elect. Fault	12/11/2022
MSPGCL	Nasik Unit 4	210	09/11/2022	22:00	13/11/2022	06:33	Boiler validity work	12/11/2022
MSPGCL	Uran Unit 6	108	10/11/2022	10:44		Continued.	Gas shortage	
MSPGCL	Koradi Unit-10	660	10/11/2022	22:13		Continued.	Boiler Tube Leakage	13/11/2022
MSPGCL	Nasik Unit 3	210	11/11/2022	03:16		Continued.	Boiler Tube Leakage	13/11/2022
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.	13/11/2022
IPP	Adani U-3	660	12/11/2022	15:00		Continued.	Hot PA Bellow Leakage.	15/11/2022
MSPGCL	Chandrapur Unit 5	500	13/11/2022	06:33		Continued.	Drum level low	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 13/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21	12/11/2022	20:42	PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21	12/11/2022	20:42	PO	Annual Maintenance work AC & DC yard Equipment, Valve Hall,Diagnostic testing, Line Maintenance, etc.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KALWA - TALEGAON (PG)	InterState	13/11/2022	11:09	13/11/2022	14:48	EO	To apply repaire sleeve on broken conductor strength near vibration damper at, 178, 179, 159,162 & also to attend the Hot spot at fire wedge connector location at loc. no. 171, 172
PADGHE - PADGHE HVDC CKT- 2	IntraState	05/11/2022	12:21	12/11/2022	20:42	PO	1. Bay maint. work 2. Diagnostic testing work 3. Bhel CB Pole Overhauling work 4. A bus PG Isolator Replacement work under LES 5. If pole Overhauling work not completed due to any reason line will be charge on TBC. 6. Hot line work for Replacement of Hanger assembly of A bus PG Isolator 7. Outage Should be Reschedule with annual outage of HVDC Pole if any date change .
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
BUS - 1 @ NEW KOYNA	IntraState	09/11/2022	13:07			PO	1) 09/11/2022 to 10/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 11/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 and damage conductor replacement work 3) 12/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 13/11/2022 Bus Insulator replacement work at section Koyana -I & II 5) 14/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 15/11/2022 to 16/11/2022 Bus Insulator replacement work at section Jaigad - I & II
KARAD - TALANDGE CKT - 2	IntraState	10/11/2022	12:39			PO	Overhauling of A bus, B Bus PG isolators.
KHADKA-AURANGABAD (WALUJ)	IntraState	11/11/2022	20:52	12/11/2022	05:43	HT	H/T DUE TO O/V
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	12/11/2022	06:02	12/11/2022	18:05	PO	Replacement of faulty Disc Insulator strings by LRP strings

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 13/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GT-10 @ KORADI-2	IntraState	12/11/2022	11:44				1) Routine maintenance of isolator. 2) Health check up of CB 402-Q52 by M/S Siemens(OEM) 3) Routine Bay maintenance work. 4) Erection, testing and commissioning of dedicated metering CT and IVT for the metering arrangement for GT-10 bay at 400 kV Koradi II S/s.
KHADKA-AURANGABAD (WALUJ)	IntraState	12/11/2022	21:03	13/11/2022	06:08	HT	H/T DUE TO O/V
JEJURI- KOYNA STAGE-IV	IntraState	13/11/2022	08:23	13/11/2022	18:22	PO	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
AKOLA - KHADKA (BHUSAWAL)	IntraState	13/11/2022	11:23	13/11/2022	15:58	PO	String replacement work on Loc. No. 95 which is DCDC type single suspension location tower. PID testing work was carried out by Hot Line Unit, Akola & detected that 5 discs punctured in R & Y phase strings each and 6 discs punctured in B phase string of same location.
KHADKA-AURANGABAD (WALUJ)	IntraState	13/11/2022	22:45		Continued.	HT	H/T DUE TO O/V
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	07/11/2022	10:17			PO	Overhauling of 400kV Circuit Breaker (CGL Make) of 400/220kV, 315 MVA ICT-2 @ Girwali. 400/220kV, 315 MVA ICT-2 @ Girwali will remain charged through TBC
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	09/11/2022	09:12	12/11/2022	16:17	PO	For HV CB Mechanism overhauling work
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	12/11/2022	12:05	12/11/2022	22:02	PO	For Overhauling of Bus C 89C Rph, Yph and Bph PG Isolators and Routine Testing and Maintenance Work.
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	13/11/2022	16:34	13/11/2022	21:05	PO	For the work of erection of Loc. No. 138 (NDX+6) for shifting of existing of 220KV PGCIL-Nalasopara Line between Loc no. 139-140 for NHRCL
EKLAHARE (OCR) - PADGHE	IntraState	07/11/2022	07:42	13/11/2022	22:34	HT	For Overloading of 220kV Nashik-BBLR Line
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/11/2022	08:24			HT	For Load Management
LAMBOTI - PANDHARPUR	IntraState	09/11/2022	06:34	12/11/2022	21:14	PO	Outage is required for Replacement of old Tower of Loc no. 506 by B+9 mtr due to low ground clearance alongwith allied work.
LAMBOTI - KARKAMB	IntraState	09/11/2022	06:47	12/11/2022	21:28	PO	Replacement of old Tower of Loc no. 506 by B+9 mtr due to low ground clearance alongwith allied work.
BUS SECTION - 3 @ TROMBAY	IntraState	11/11/2022	22:06	12/11/2022	07:15	PO	(1) 220 kV BUS PT Diagnostic Testing work. (2) 220KV Mulund line Bus-Isolator spring replacement. (3) TATA Tie-1 line Bus-Isolator clamp replacement by TATA at MSETCL end. (4) BUS SEC -3 TATA CVT (1-Phase) disconnection work by TATA.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 13/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KHADKI- CENTURY ENKA	IntraState	12/11/2022	00:38	12/11/2022	01:23	T	EHV metering check CT R Ph burst at Century Enka end
KALWA - SIEMENS	IntraState	12/11/2022	01:19	12/11/2022	04:45	T	Distance Protection
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	12/11/2022	08:15	12/11/2022	23:22	HT	For load management
INFOSYS - HINJAWADI 1	IntraState	12/11/2022	08:18	12/11/2022	21:03	PO	Dtd:10.11.2022 1.Cable termination work at MCTT tower- ckt 2 2.Structure erection of LA / BPI at 220kV Infosys S/s ckt 1 Dtd:11.11.2022 1.Cable termination work at MCTT tower- ckt 1 2.Structure erection of LA / BPI at 220kV Infosys S/s ckt 1 3. Stringing from MCTT to Tower no 1 Dtd:12.11.2022 1.Temp Stringing from MDN to GT 2.Removal of conductor from 158 A to 15B 3.Stringing of MCTT to 158 4.Jumper work at MCTT & tower loc no 1
BIDRI - SAWANTWADI	IntraState	12/11/2022	09:01	12/11/2022	12:24	PO	C & Tan-delta testing of Bay HVCT & CRM of CB along with Quarterly maintenance of Bay equipment at Sawantwadi end.
AAREY - AEML BORIVALI	IntraState	12/11/2022	10:19	12/11/2022	16:10	PO	Annul maintenance of CB
TALANDGE - SAWANTWADI	IntraState	12/11/2022	12:30	12/11/2022	14:47	PO	C & Tan-delta testing of Bay HVCT & CRM of CB along with Quarterly maintenance of Bay equipment at Sawantwadi end.
DASTURI-KANDALGAON LINE	IntraState	12/11/2022	12:45	12/11/2022	19:25	PO	Diagnostic testing, Bay maintenance works at 220 kV Kandalgaon SS & Outage tree cutting and other line maintenance work.
PADGHE - NALASOPARA - VASAI (T)	IntraState	13/11/2022	02:02	13/11/2022	06:54	PO	To carry out modification work of AEML existing 220kV Double Circuit, Tower location SS-225 & SS-228 in connection with DFC project of Government of India. Work will be carried out by DFCCIL under Ministry of Railway.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 13/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KAMBA - VASAI	IntraState	13/11/2022	02:06	13/11/2022	06:36	PO	To carry out modification work of AEML existing 220kV Double Circuit, Tower location SS-225 & SS-228 in connection with DFC project of Government of India. Work will be carried out by DFCCIL under Ministry of Railway.
TILLARI - AMONA LINE	IntraState	13/11/2022	12:25	13/11/2022	19:46	T	Tripped on distance protection
INFOSYS - HINJAWADI 1	IntraState	13/11/2022	15:43	13/11/2022	19:37	PO	Bunching at tower no 1 Jumper removal at tower no 4
PIRANGUT - HINJAWADI 2	IntraState	13/11/2022	17:06	13/11/2022	19:29	PO	1.Bunching at Tower no 1 2.Jumper removal of tower no 4
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
NERAL - AMBERNATH	IntraState	12/11/2022	11:05	12/11/2022	18:15	PO	To Replace Line Circuit Breaker . (Breaker Required to be replaced on Urgent Basis , As SF 6 Gas of own CB Found contaminated.
TATA BORIVLI MSETCL BORIVLI 2	IntraState	13/11/2022	10:32	13/11/2022	15:05	PO	Distance protection and CVT testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage